

Ken Landgon  
Vice President-Nine Mile Point

P.O. Box 63  
Lycoming, New York 13093  
315.349.5200  
315.349.1321 Fax

**CENG**<sup>SM</sup>

a joint venture of



Constellation  
Energy



NINE MILE POINT  
NUCLEAR STATION

June 4, 2012

U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

**ATTENTION:** Document Control Desk

**SUBJECT:** Nine Mile Point Nuclear Station  
Unit No. 2, Docket No. 50-410

Withdrawal of Emergency License Amendment Request to Revise the Main Steam  
Isolation Valve Allowable Leakage Rate Limit

**REFERENCE:** (a) Letter from K. Langdon (NMPNS) to Document Control Desk (NRC), dated June 1, 2012, Emergency License Amendment Request Pursuant to 10 CFR 50.90: Revision of the Main Steam Isolation Valve Allowable Leakage Rate Limit

By letter dated June 1, 2012 (Reference a), Nine Mile Point Nuclear Station, LLC (NMPNS) requested an amendment to Nine Mile Point Unit 2 (NMP2) Renewed Facility Operating License NPF-69. The proposed amendment would have modified Technical Specification (TS) Section 3.6.1.3, "Primary Containment Isolation Valves (PCIVs)," by revising Surveillance Requirement (SR) 3.6.1.3.12 for the leakage rate through the main steam isolation valves (MSIV).

NMPNS hereby withdraws the Emergency License Amendment Request submitted in Reference (a) because MSIV repairs have resulted in a satisfactory leakage rate in accordance with current Technical Specifications.


Should you have any questions regarding the information in this submittal, please contact John J. Dosa, Director Licensing, at (315) 349-5219.

Very truly yours,

AODI  
MRK

**STATE OF NEW YORK**       :  
  :  
  :  
**COUNTY OF OSWEGO**       :

I, Ken Langdon, being duly sworn, state that I am Vice President-Nine Mile Point, and that I am duly authorized to execute and file this submittal on behalf of Nine Mile Point Nuclear Station, LLC. To the best of my knowledge and belief, the statements contained in this document are true and correct. To the extent that these statements are not based on my personal knowledge, they are based upon information provided by other Nine Mile Point employees and/or consultants. Such information has been reviewed in accordance with company practice and I believe it to be reliable.

  
\_\_\_\_\_

Subscribed and sworn before me, a Notary Public in and for the State of New York and County of Onondaga, this 4<sup>th</sup> day of June, 2012.

WITNESS my Hand and Notarial Seal:

  
\_\_\_\_\_  
Notary Public

My Commission Expires:  
3/17/2016  
Date

DENNIS E. VANDEPUTTE  
Notary Public, State of New York  
No. 01VA6183401  
Qualified in Onondaga County  
Certificate Filed in Oswego County  
Commission Expires 3/17/2016

KL/KJK

cc:     Regional Administrator, Region I, NRC  
          Project Manager, NRC  
          Resident Inspector, NRC  
          A. L. Peterson, NYSERDA