

**SUMMARY OF MAJOR FINDINGS
FROM NORTH ANNA IPE**

supported by a comprehensive set of analysis files, which detail the assumptions and information sources used at each stage of model development.

A formal Quality Assurance Plan was developed for the project to ensure the appropriate level of review and documentation. The work products were reviewed at each stage, by project team members. North Anna station personnel reviewed key documents. In addition, an independent review was performed to ensure consistency within the overall methodology. All comments received have been addressed and retained within the appropriate analysis files.

1.4 SUMMARY OF MAJOR FINDINGS

1.4.1 Results of Core Damage Frequency for Internal Events

Core damage is defined as failure of decay heat removal such that the maximum fuel temperature will exceed the licensing basis temperature of 2200°F or the core exit thermocouples will reach 1200°F and long-term cooling cannot be established. Although these criteria are slightly conservative, the increase in the time to the onset of significant core damage following failure of decay heat removal compared with the time to 2200°F is not significant in terms of system recovery or actions by the operators. In a number of sequences, the time it takes to achieve this temperature limit is based on actions taken by the operators when the core exit thermocouples indicate 1200°F. Each event tree was extended to include the containment systems and where appropriate the recovery of cooling injection after core damage or vessel failure in order to accurately define the plant damage states which were the basis for the containment accident progression and source term analysis.

The internal events portion of the PRA identified 61 core damage sequences with an annual frequency of greater than 1.0E-7, which contributed 96% of the overall core damage frequency. An additional 161 sequences with a point estimate frequency of greater than 1.0E-9/year contributed the remaining 4% of the overall core damage frequency. The accident grouping by initiating event class is shown in Table 1-1 and Figure 1-1.

The internal events core damage model gave a point estimate frequency of 6.8E-5 per reactor-year. The combined frequency of the 161 sequences below the 1.0E-7 cutoff is less than 2.9E-6. An uncertainty analysis was performed to evaluate the uncertainty on core damage frequency resulting from the uncertainties on the parameter values of the core damage model. The cumulative distribution function for the core damage frequency is shown in Figure 1-2.

Some significant parameters of the core damage frequency distribution function are as follows:

Mean	1.66E-4
Standard Deviation	1.03E-3
95th Percentile	3.41E-4
Median	7.41E-5
5th Percentile	2.74E-5

The difference between the mean value, obtained from the uncertainty analysis, and the point estimate, results from the correlation of the samples of those basic event probabilities that are based on the same parameter value distribution. This is the so-called state of knowledge correlation (Apostolakis and Kaplan, 1981). Several of the cut sets that are affected have point estimate frequencies in the $1.0E-8$ range. The parameter values that contribute to these cut sets are generally based on generic estimates. The reason they contribute significantly to the difference is that the representation of the uncertainty on the parameters results in a large variance on the parameter value. This is in many respects somewhat arbitrary; for example, the choice of the lognormal distribution was based on accepted industry practice; the use of large error factors is a way of increasing the mean value with respect to a given median value [e.g., air-operated valves (AOVs)], but it also increases the variance. Thus, the difference between the point estimate and mean value is potentially exaggerated by the way in which the uncertainty characterization of parameter estimates was established.

On review of the cut sets, it did not appear that the overall characterization of the safety of the plant, in terms of the contributors and their relative importance, would be significantly altered by using the uncertainty analysis for the estimation of core damage frequency. Therefore, the point estimate results were used in the remainder of the analysis. In further support of this approach, it should be noted that the point estimate values chosen for the parameters were either realistic (when sufficient data were available) or conservative.

An event importance analysis was performed on the overall core damage model. In this analysis the relative importance of each basic event was calculated with respect to three different measures: Fussell-Vesely, risk reduction worth, and risk achievement worth. The results are shown in Table 1-2.

The Fussell-Vesely importance is a measure of the contribution of the given component to the overall core damage frequency by comparing the sum of cut sets in which that basic event occurs with the total sum of all cut sets. The risk reduction worth shows the reduction in the core damage frequency that would be achieved if the component were perfect or its failure probability were zero.

Three of the top four highest ranking events for risk reduction are the Loss of Offsite Power initiating event (IE-T1), the small LOCA initiating event (IE-S2), and the steam generator tube rupture event (IE-T7). (Note the complement events indicated by "C-xxx" and the 1EE-BAT-i-2HR Battery failure in 2 hours after SBO are not true events and should not be considered in the interpretation of results.) This is consistent with the core damage profile where T1 accounts for 29.2% of CDF (this includes the station blackout contribution), S2 accounts for 14.8% of CDF, and T7 accounts for 10.3% of CDF. In Table 1-2, the Fussell-Vesely importance values for these initiators are precisely these percentages. Having an initiating event group as the top risk reduction item indicates the risk from these initiators is spread over many components and involves several aspects of accident mitigation. Alternatively, it can be said that there are no single component improvements or changes that would have a dominant impact on accident mitigation for all these initiating events. The frequencies for the T1, S2, and T7 initiators are generic industry values as opposed to plant specific data. The S1 LOCA and T8 loss of Emergency Switchgear Room cooling initiating events are the fifth and sixth most important risk reduction events having F-V values of .098 and .097, respectively.

The most important component for risk reduction is the 1H Emergency Diesel Generator. This component is the most important single component. The seventh, eighth and eleventh events (or numbers 9, 13 and 17 in the listing) represent different fault modes of EDG 1H. As such, they can be combined to yield one F-V measure of unavailability for EDG 1H which is .23 (the sum of the three F-V values). This is due to 1) the relatively high fault probabilities for the EDG 1H compared to other components and 2) the higher Loss of Offsite Power (T1, T1A and T1Tr) and partial loss of switchyard feeder power (T9A and T9ATr) contribution to the total CDF (35% for all 5 events, T1, T1A, T1Tr, T9A and T9ATr).

The second most important component for risk reduction is the turbine driven Auxiliary Feedwater pump. The ninth, 16th, 24th and 46th events (or numbers 15, 23, 32 and 57 in the listing) represent different fault modes of the turbine driven Auxiliary Feedwater pump. As such they can be combined to yield one F-V measure for unavailability of the turbine driven pump. If the four values are added, the resultant F-V for the turbine driven AFW pump is .18. This is due to 1) the relatively high fault probabilities for the turbine driven pump compared to other components (high fault probabilities for turbine driven pump is typical) and 2) the increased reliance on the turbine driven Auxiliary Feedwater pump for initiators such as T9A, T9B, T5A, T5B, and T7, where one motor driven pump is unavailable due to the initiator, or in the case of T7, is aligned to the affected generator. Having the turbine driven pump as a significant component for risk reduction indicates the risk profile is dominated by loss of steam generator heat removal following the initiating event.

The third most important event and the most important operator action (number five in the listing) is failure of operator action to initiate High Head Safety Injection. This human action appears in T1 and T1A sequences involving loss of AFW and in several Hv transfer sequences (e.g., event trees T1Tr, T2Tr, T2ATr, etc.) involving restoration of Emergency Power before core damage, but where HHSI is required to prevent a RC Pump Seal LOCA. Although the human action to manually initiate HHSI is important, the split between Loss of Offsite Power and other transient initiators indicates that two human action models would be more appropriate, yielding the same combined importance but with an apportionment between the two transient types.

The next most important operator action is the 10th event (number 16 in the listing), recovery actions for loss of Unit 1 ESGR cooling using Unit 2 ESGR chilled air. Initiating events for transients with MFW available and large LOCA are listed next. The 20th listed event is failure of operator action to rapidly depressurize the Steam Generators during a medium break LOCA.

The event listed 22 represents unavailability of Emergency Diesel Generator 1J. It can be combined with events 25 and 41, which represent other failure modes of EDG 1J. Adding these three events together yields an overall F-V importance value of .13 for EDG 1J. This places it fifth in true ranking, behind the S2 initiator. The asymmetrical dependence between the 1J and 1H diesel is due to the greater dependence of ESGR cooling components upon the 1H bus (2 chillers) than on the 1J bus (1 chiller).

The events ranked in order of risk achievement worth are shown in Table 1-3. Risk achievement worth must be viewed with an understanding of how it is calculated. The risk achievement worth for an event represents the increase in core damage frequency if that event's probability is 1.0. This can be interpreted as guaranteeing that the failure will occur. The two top events for risk achievement are modeled to lead straight to core damage. These are Reactor Vessel rupture and Interfacing System LOCA initiating events. Also, they have very low probabilities in the base case CDF profile. Thus, if their probabilities are increased to 1.0, the resultant increase in CDF is very high.

The third most important event in risk achievement worth is mechanical binding of the control rods. This has a high risk achievement worth because, it leads directly to core damage when combined with any initiator and it has a very low probability in the base case.

The next event (#4) involves common cause failure of the Service Water Reservoir screens, which fails both Unit 1 ESGR cooling, and its recovery, Unit 2 ESGR cooling. It has a high risk achievement worth because it affects all of the Hv Transfer event trees. The next two events, 1QSMV--PG-1Q38, and 1SICKV-CC-838689, cause common

mode failure of the HHSI and LHSI systems. The QS term is plugging of the manual isolation valve on the discharge of the RWST and the SI term is common cause failure of check valves 83, 86, and 89 which are located in the SI injection lines into the cold legs.

The next several events involve faults of a 4160 V or 480 V bus. Both 4160 V buses, the 480 V buses, and several MCC's are represented. These events appear in virtually all the sequences at lower frequencies. Note that the 1H buses characteristically have a higher risk achievement worth than comparable 1J buses, again due to the greater dependence of ESGR cooling components upon the 1H buses.

1.4.2 Core Damage Frequency from Internal Flooding

The core damage frequency from internal flooding is $3.6E-6$ /year which is approximately 5% of the overall core damage frequency. The dominant contribution is from service water floods in the Auxiliary Building.

It can be seen that the base case results show that core damage from internal flooding is not a vulnerability at North Anna. This is the result of identifying a number of minor modifications during the course of the study, as potential flooding vulnerabilities were identified. The required plant modifications included in the IPE model are as follows:

1. Back flow prevention devices are fitted in the charging pump cubicles' floor drains in order to prevent floods in the Auxiliary Building and Quench Spray Pump House spreading to the charging cubicles.
2. A flood barrier is erected in the pipe tunnel between the Quench Spray Pump House and the Auxiliary Building to prevent the spreading of floods from one to the other.
3. The Chiller Room doors are modified to prevent flooding of the Instrument Rack Room and Emergency Switchgear Room following a flood in the Chiller Room.

1.4.3 Containment Building Performance

The North Anna Containment Building structures and systems are robust with respect to the challenges presented by severe accidents. Because of the high assessed strength of the Containment structure, both early as well as late over-pressure failure of the Containment is very unlikely. The North Anna Containment Building is operated in a subatmospheric mode; consequently, the probability of loss of isolation is extremely remote since any significant preexisting leakage would be easily

detected. The major threat of early, large radionuclide leakage at North Anna results from core damage Containment bypass sequences, particularly SGTRs. Figure 1-3 shows a breakdown of the predicted North Anna Containment Building performance for severe accidents. Table 1-4 compares the North Anna IPE, the Surry IPE and NUREG-1150 results. In general, the results from the three studies are quite similar. The differences that exist stem mostly from the difference in contributions from the different initiators. Section 7.2 discusses this in more detail.

1.4.4 Comparison of Results

The major purpose of this study, was to ensure that the PRA model was developed and understood by the Virginia Power staff and represented the as-built-and-as-operated condition of North Anna Units 1 and 2 at the time of the performance of the PRA. The guidance for performing the IPE indicated that heavy reliance could be placed on the results of the previous studies performed for similar plants. Therefore, the work performed for the Surry IPE was used as the starting point for the North Anna Analysis.

All the systems at North Anna were analyzed and new fault trees developed for each one. There are differences in the support system (electric power, cooling water) design which resulted in the identification of different initiating events. The results from the North Anna IPE are compared with the Surry IPE and the NRC PRA of Surry reported in NUREG/CR-4550.

1.4.4.1 Comparison of Core Damage Frequencies

The comparison of core damage frequencies is shown in Table 1-5. It can be seen that the results for Surry (Virginia Power, 1991a) and North Anna IPEs are very similar and somewhat higher than those from the NRC study of Surry. However, investigations of the design requirement for room cooling, the capability of removing heat from the Containment Building, and the requirements for RHR following an SGTR resulted in the introduction of new sequences associated with loss of Emergency Switchgear Room cooling, consequential loss of ESGR cooling after other initiators, loss of Containment heat removal (Surry only), and a revised frequency for core damage sequences following an SGTR.

Whereas in the NUREG/CR-4550 study the LOOP leading to station blackout was the dominant contributor to core damage, it can now be seen from Figure 1-2 that, although loss of offsite power is still a high contributor, LOCA, SGTR, and transients are all significant contributors. It should be noted that the increase in the loss of feedwater initiating event contribution to core damage frequency is entirely due to the dependency on Emergency Switchgear Room cooling and not on poor performance of the front-line decay heat removal systems.

The relative reduction in the station blackout core damage frequency from NUREG/CR-4550 is the result of three changes. First, the IPEs credited successful Turbine-Driven Auxiliary Feedwater Pump (AFWP) operation after battery depletion. Thus, although the battery depletion time was similar to that in NUREG/CR-4550, AFW was potentially available until Emergency Condensate Storage Tank (ECST) depletion. An extension of the time to core uncovering is probable for the case in which the AFW pumps are running at the time of battery depletion. (Operators have indicated that they are not instructed by procedure to trip the pumps at that time and, thus, that they would not do so.) Second, the RC Pump seal LOCA model used for the IPE predicted an average core uncovering time due to seal failure of about 9 hours, rather than the 3.5 hours used in NUREG/CR-4550. The IPE seal LOCA model is based on Westinghouse seal performance analysis. Third, the common-cause failure probabilities for diesel generators was lower than that used in the NUREG. A rigorous analysis of industry data was performed to generate as realistic a value as possible for the potential for common-cause failures of the diesel generators.

Finally, the ATWS sequence frequencies are somewhat lower as the result of more accurate analysis of the pressure relief requirements at the various stages of core burnup. Although the results for North Anna and Surry are approximately the same there are differences in the design which individually would have been expected to give different results for the two stations. The joint Westinghouse Owners Group/Westinghouse program for the ATWS rule administration described in WCAP-11992 (Westinghouse, 1988) identified a more rigorous method for determining the probabilities of core damage based on evaluating the pressure relief requirement during core burnup, following an anticipated trip without scram. It also discussed the impact of fitting the AMSAC modification. The AMSAC modification has been installed at North Anna but was not installed at Surry at the time of the IPE. The calculated unfavorable exposure time (UET) for North Anna, Unit 1 was 27.7% compared with zero for Surry. The most likely reason for the higher UET is a combination of the higher nominal inlet temperatures at hot full power at North Anna and larger power defects from the higher power North Anna cores. Thus the reduction in core damage frequency from the fitting of the AMSAC modifications is offset by an increase due to the unfavorable exposure time, when the pressure relief is inadequate.

1.4.4.2 Fission Product Release

There are several factors that would tend to produce small releases at North Anna: the Containment Building is strong; there is a high degree of redundancy in the sprays; as the plant is subatmospheric, there is a very low probability of its being in a non-isolated state; and the piping arrangement in the Safeguards Building is such that most interfacing LOCAs (V) will vent releases under

water. The cavity is not connected to the sump directly at floor level but rather through a somewhat elevated vent path. This means that it is difficult to get water into the cavity other than by operation of the Quench/Recirculation Sprays or in vessel injection (following reactor vessel failure). This has advantages and disadvantages; a wet cavity means debris cooling, but it also can impose a large heat load on the Containment.

The sprays play several roles, all of which are important with regard to source terms: they can "wash out" airborne radionuclides in the Containment, they provide the major pathway for the introduction of water into the cavity and onto the debris, and they are the vehicle for Containment heat removal.

The MAAP-derived release fractions (calculated for 11 of the 24 source term categories) confirm what is already known from other work (NUREG-1150, for example) the Containment Building bypass sequences (interfacing LOCA [V] and SGTR) have the greatest release potential. This is because of the relative scarcity of mitigating features in the release pathways. Following a SGTR, the Steam Generator with the broken tube is likely to be dry when core damage and fission product release occurs. The SGTR sequence is also significant on a frequency basis (see Section 4.7.4).

The calculated release fractions generally agree in magnitude with values reported for NUREG-0956 and NUREG-1150. A comparison of the IPE values and those reported in NUREG-1150 is shown in Figures 1-4 and 1-5. Sensitivity studies demonstrated that the sprays are important in minimizing releases and that different modeling assumptions regarding tellurium release from the fuel can affect its release fraction significantly. While no direct analyses of uncertainty were performed, the extensive NUREG-1150 work has indicated that in most cases two orders of magnitude is not unreasonable uncertainty for many of the release fractions for any given source term category (STC).

1.5 REFERENCES

Apostolakis, G., and S. Kaplan. "Pitfalls in Risk Calculations," Reliability Engineering, Volume 2, pages 135-145, 1981.

Bertucio, R. C., and J. A. Julius, Analysis of Core Damage Frequency, Surry Unit 1: Internal Events, NUREG/CR-4550, Volume 3, Revision 1, Part 1, Sandia National Laboratories, Albuquerque, New Mexico, April 1990.

Bohn, M. P., et al., Analysis of Core Damage Frequency, Surry Power Station, Unit 1: External Events, NUREG/CR-4550, Volume 3, Revision 1, Part 3, Sandia National Laboratories, Albuquerque, New Mexico, December 1990.

Breeding, R. J., et al., Evaluation of Severe Accident Risks: Surry Unit 1, NUREG/CR-4551, Volume 3, Revision 1, Part 1 (Main Report), and Part 2 (Appendixes), Sandia National Laboratories, Albuquerque, New Mexico, October 1990.

HNUS, NUPRA Users Manual, NUS-5218, Halliburton NUS Environmental Corporation, Gaithersburg, Maryland, May 1992.

Fulford, P. J., and R. R. Sherry, NUCAP+ User's Manual, NUS-5282, HNUS Corporation, Gaithersburg, Maryland, April 1991.

Gorham-Bergeron, E. D., Evaluation of Severe Accident Risks: Methodology for the Containment, Source Term, Consequence and Risk Integration Analyses, NUREG/CR-4451 (Draft A), Volumes 1 and 2, Sandia National Laboratories, Albuquerque, New Mexico, 1988.

NRC (U.S. Nuclear Regulatory Commission), Individual Plant Examination for Severe Accident Vulnerabilities, 10CFR50.54(f) (Generic Letter 88-20), Washington, D.C., 1988.

NRC (U.S. Nuclear Regulatory Commission), Individual Plant Examination: Submittal Guidance, NUREG-1335, Washington, D.C., August 1989a.

NRC (U.S. Nuclear Regulatory Commission), Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants. NUREG-1150, Volume 1, Washington, D.C., 1989b.

Virginia Power (Virginia Electric and Power Company), Probabilistic Risk Assessment Surry Nuclear Power Plant - Units 1 and 2 For the Individual Plant Examination: Final Report, Richmond, Virginia, August 1991a.

Virginia Power (Virginia Electric and Power Company), Internal Flooding Analysis Supplemental Report: Surry Nuclear Power Plant Units 1 and 2 for Individual Plant Examination, Richmond, Virginia, November 1991b.

Westinghouse, Joint Westinghouse Owners Group/Westinghouse Program: ATWS Rule Administration Process. WCAP-11992, Pittsburgh, Pennsylvania, 1988.

**TABLE 1-1
ACCIDENT GROUPING BY INITIATING EVENT CLASS**

<u>Initiating Event Type</u>	<u>Point Estimate Frequency (per year)</u>	<u>Percentage of Total</u>
Internal Events:		
LOCA (A, S1, S2, RX)	2.1E-5	31
Loss of Offsite Power (T1, T1A, T1TR)	2.0E-5	29
Transient (T2, T2A, T3, T4, T5A T5B, T6, T8, T9A, T9B, T2TR, T2ATR, T3TR, T9ATR, T9BTR)	1.8E-5	27
Steam Generator Tube Rupture (T7)	7.0E-6	10
Interfacing System LOCA (VX)	1.6E-6	2
ATWS (TH, TL)	<u>4.2E-7</u>	<u>1</u>
Total Internal Events	6.8E-5	100
Internal Flooding:		
Auxiliary Building	2.6E-6	72
Air Conditioning Chiller Room	9.7E-7	27
Turbine Building	<u>0</u>	<u>0</u>
Total Internal Flooding	3.6E-6	100
Combined CDF:		
Total Internal Events	6.8E-5	95
Total Internal Flooding	<u>3.6E-6</u>	<u>5</u>
	7.1E-5	100

TABLE 1-5
OVERALL COMPARISON OF RESULTS OF THE NORTH ANNA IPE
WITH THE SURRY IPE AND NUREG/CR-4550 (SURRY) RESULTS

<u>Initiating Event</u> ⁽²⁾	Core Damage Frequency		
	<u>North Anna</u> <u>IPE</u>	<u>Surry</u> <u>IPE</u>	<u>Surry</u> ⁽¹⁾ <u>NUREG/CR</u> <u>-4550</u>
Loss of Coolant Accident			
Small LOCA	1.0E-5	1.1E-5	1.1E-6
Medium LOCA	6.6E-6	5.3E-6	3.1E-6
Large LOCA	4.1E-6	4.6E-6	2.0E-6
Interfacing System LOCA	1.6E-6	1.6E-6	1.2E-6
Loss of Offsite Power			
Loss of Offsite Power	1.2E-5	7.1E-6	<1.5E-7
Station Blackout	8.0E-6	8.1E-6	2.1E-5
Transients			
Loss of ESGR Cooling	6.6E-6	1.8E-5	N/A
Other Transients	6.1E-6	4.8E-6	N/A
Loss of 4160 V Bus 1H	3.7E-6	-	N/A
Loss of Feedwater	1.0E-6	4.7E-7	1.7E-6
Loss of 4160 V Bus 1J	6.5E-7	-	N/A
Loss of DC Bus 1-I	1.1E-7	6.8E-7	1.4E-7
Loss of DC Bus 1-III	1.1E-7	6.8E-7	1.4E-7
Steam Generator Tube Rupture	7.0E-6	1.0E-5	1.9E-6
ATWS	4.2E-7	3.2E-7	1.4E-6
Total of Internal Events	----- 6.8E-5	----- 7.4E-5	----- 3.4E-5
Internal Flooding	3.6E-6	5.1E-5	-

NOTE 1: From NUREG/CR-4550 Vol. 3 Rev. 1 Table 4.10-5.

NOTE 2: For North Anna, Hv transfer event tree (namely, consequential loss and coincidental loss of ESGR cooling) contributions to core damage frequency have been summed with those of the parent tree for comparison to Surry.




Figure 1-1
Contribution of Initiators to Core Damage Frequency