

LimerickNPEm Resource

From: Christopher.Wilson2@exeloncorp.com
Sent: Wednesday, January 25, 2012 8:35 AM
To: Kuntz, Robert
Subject: RE: REVISED DRAFT Request for Information RE: Limerick License Renewal Application

Hi Rob

We reviewed the revised draft package.

We would like to discuss again DRAI B.2.30-2. This is the one that stated panels had a variation in thickness of more than 30 percent due to general corrosion.

Now it is revised to state that panels had a variation in thickness of up to 50 mils(20 percent) due to general corrosion. We do not understand this RAI

Minor Typo's to DRAI B.2.1.40-2

- o Background, 7th line, "front half of quotations needs to be added for Electrical Penetrations
- o Request, at end of paragraph, prior to period, close parentheses started on 3rd line of paragraph following "component types."

Thanks Chris

Chris Wilson
Exelon Nuclear
KSQ License Renewal
610-765-5667 (office) 609-709-3249 (cell)
200 Exelon Way, KSA/2-E

From: Kuntz, Robert [<mailto:Robert.Kuntz@nrc.gov>]
Sent: Tuesday, January 24, 2012 11:35 AM
To: Wilson, Christopher D:(GenCo-Nuc)
Subject: REVISED DRAFT Request for Information RE: Limerick License Renewal Application

Chris,

Attached is a DRAFT request for information that was revised to clarify the request based on a teleconference held 1/19/12 between the NRC staff and Exelon. If you would like clarification on the attached, let me know and I will set up a teleconference. The following DRAIs were revised based on the teleconference:

B.2.1.30-2
B.2.1.32-3
B.2.1.40-3
B.2.1.40-4
B.2.1.41-2

Robert Kuntz
Sr. Project Manager
NRR/ADRO/DLR/RPB1
(301) 415-3733
robert.kuntz@nrc.gov

***** This e-mail and any of its attachments may contain Exelon Corporation proprietary information, which is privileged, confidential, or subject to copyright belonging to the Exelon Corporation family of Companies. This e-mail is intended solely for the use of the individual or entity to which it is addressed. If you are not the intended recipient of this e-mail, you are hereby notified that any dissemination, distribution, copying, or action taken in relation to the contents of and attachments to this e-mail is strictly prohibited and may be unlawful. If you have received this e-mail in error, please notify the sender immediately and permanently delete the original and any copy of this e-mail and any printout. Thank You. *****

Hearing Identifier: Limerick_LR_NonPublic
Email Number: 423

Mail Envelope Properties (9A15F707EB47A04D882D9FEB352EDDF803994298)

Subject: RE: REVISED DRAFT Request for Information RE: Limerick License Renewal
Application
Sent Date: 1/25/2012 8:35:28 AM
Received Date: 1/25/2012 8:35:35 AM
From: Christopher.Wilson2@exeloncorp.com

Created By: Christopher.Wilson2@exeloncorp.com

Recipients:
"Kuntz, Robert" <Robert.Kuntz@nrc.gov>
Tracking Status: None

Post Office: cccmsxch12.energy.power.corp

Files	Size	Date & Time
MESSAGE	2437	1/25/2012 8:35:35 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: