



Monticello Nuclear Generating Plant
2807 W County Road 75
Monticello, MN 55362

June 11, 2012

L-MT-12-058
10 CFR 50.54(f)

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Monticello Nuclear Generating Plant
Docket No. 50-263
Renewed Facility Operating License No. DPR-22

MNGP 90-Day Response to NRC Request for Information Pursuant to 10 CFR 50.54(f)
Regarding the Flooding Aspects of Recommendations 2.1 and 2.3 of the Near-Term Task
Force Review of Insights from the Fukushima Dai-ichi Accident

References:

1. NRC Letter, "Request for Information Pursuant to Title 10 of the *Code of Federal Regulations* 50.54(f) Regarding Recommendations 2.1, 2.3, and 9.3, of the Near-Term Task Force Review of Insights from the Fukushima Dai-ichi Accident" dated March 12, 2012, ADAMs Accession No. ML12056A046.
2. NRC Letter, "Prioritization of Response Due Dates for Request for Information Pursuant to Title 10 of the *Code of Federal Regulations* 50.54(f) Regarding Flooding Hazard Reevaluations for Recommendation 2.1 of the Near-Term Task Force Review of Insights from the Fukushima Dai-ichi Accident," dated May 11, 2012, ADAMs Accession No. ML12097A510.
3. NRC Letter, "Endorsement of Nuclear Energy Institute (NEI) 12-07, 'Guidelines for Performing Verification Walkdowns of Plant Flood Protection Features,'" dated May 31, 2012, ADAMs Accession No. ML12144A142.

On March 12, 2012, the NRC Staff issued Reference 1 to all NRC power reactor licensees and holders of construction permits in active or deferred status. Enclosures 2 and 4 of the March 12, 2012 letter contain specific Requested Actions, Requested Information, and Required Responses associated with Recommendations 2.1 and 2.3, Flooding Evaluations and Walkdowns. Addressees were requested in Enclosure 4 to confirm if they intend to use the NRC-endorsed flooding walkdown procedures within 90 days of the date of Reference 1, in accordance with 10 CFR 50.54(f). Addressees were also requested in Enclosure 2 to provide a response within 90 days of the date of the Reference 1 if an addressee cannot meet the requested response date. This letter provides the required 90-day response

for the Northern States Power Company, a Minnesota corporation, d/b/a Xcel Energy (NSPM), on behalf of the Monticello Nuclear Generating Plant (MNGP).

Recommendation 2.1 - Flooding

In Reference 2, the MNGP was identified as a Category 2 site with a required response date for the MNGP's flood hazard reevaluation as March 12, 2014, which corresponds to two years from the date of issuance of Reference 1. NSPM plans to comply with the requested response date delineated in Reference 2.

NSPM also plans to meet the requested response dates for the other Required Responses in Enclosure 2 of Reference 1. Specifically, an approach for developing an Integrated Assessment Report for the MNGP will be submitted within 60 days of the date of the NRC's issuance of guidance on implementation details of the Integrated Assessment Report. In addition, if the MNGP is requested to complete an Integrated Assessment Report, NSPM will submit written responses within two years following the submittal of the Hazard Reevaluation Report to the NRC.

Recommendation 2.3 - Flooding

Enclosure 4 of Reference 1 requires each licensee to confirm that it intends to use the NRC-endorsed flooding walkdown procedures or provide the NRC a description of the process that will be used to conduct the flooding walkdowns. NSPM confirms that it will use the flooding walkdown procedure NEI 12-07, "Guidelines for Performing Verification Walkdowns of Plant Flood Protection Features," endorsed by the NRC in Reference 3, as the basis for the flooding walkdowns at the MNGP.


If there are any questions or if additional information is needed, please contact Ms. Jennie Eckholt, Licensing Engineer, at 612-330-5788.

Summary of Commitments

This letter makes no new commitments and no revisions to existing commitments.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on June 11, 2012



Timothy J. O'Connor
Site Vice President, Monticello Nuclear Generating Plant
Northern States Power Company - Minnesota

cc: Administrator, Region III, USNRC
Director of Nuclear Reactor Regulation (NRR), USNRC
NRR Project Manager, MNGP, USNRC
Senior Resident Inspector, MNGP, USNRC