



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 22, 2012

APPLICANT: NextEra Energy Seabrook, LLC

FACILITY: Seabrook Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 29, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE DRAFT REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (NextEra or the applicant), held a telephone conference call on May 29, 2012, to discuss the draft request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the draft RAI that was discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink that reads "Arthur Cunanan".

Arthur Cunanan, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:
As stated

cc w/encls: Listserv

**TELEPHONE CONFERENCE CALL
SEABROOK STATION LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS
May 29, 2012**

PARTICIPANTS

Arthur Cunanan

Bo Pham

Aloysius Obodoako

Ken Karwoski

Rick Cliche

Ed Carley

Bob McCormack

AFFILIATIONS

U.S. Nuclear Regulatory Commission (NRC)

NRC

NRC

NRC

NextEra Energy Seabrook, LLC. (NextEra)

NextEra

NextEra

**TELEPHONE CONFERENCE CALL
SEABROOK STATION
LICENSE RENEWAL APPLICATION**

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (the applicant), held telephone conference calls on May 29, 2012, to discuss the draft request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Draft RAI B.2.1.10-3: Related to the Steam Generator Tube Integrity Program

The staff discussed its concerns with the Steam Generator Tube Integrity Program related to tube-to-tubesheet welds and the steam generator divider plate.

The applicant understands the staff's concern and discussed submitting LRA supplement to resolve the concern.

The staff will not send the RAI if the response is timely. This item is tracked as Open Item OI 3.0.3.2.2-1 in the safety evaluation report with open items.

Memorandum to NextEra Energy Seabrook, LLC from A. Cunanan dated June 22, 2012

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 29, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE DRAFT REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDir Resource

RidsNrrDirRpb1 Resource

RidsNrrDirRpb2 Resource

RidsNrrDirRarb Resource

RidsNrrDirRapb Resource

RidsNrrDirRasb Resource

RidsNrrDirRerb Resource

RidsNrrDirRpob Resource

MWentzel

ACunanan

DMorey

JLamb

DMcIntyre, OPA

EDacus, OCA

MSpencer, OGC

WRaymond, RI

DTift, RI

NMcNamara, RI

NSheehan, RI

DScrenci, RI

JJohnson, RI

ABurritt, RI

APPLICANT: NextEra Energy Seabrook, LLC

FACILITY: Seabrook Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON MAY 29, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE DRAFT REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (NextEra or the applicant), held a telephone conference call on May 29, 2012, to discuss the draft request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the draft RAI that was discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

/RAI

Arthur Cunanan, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:
As stated

cc w/encls: Listserv

DISTRIBUTION:

See next page

ADAMS Accession No.: ML12164A756

OFFICE	LA:RPB1:DLR	PM:RPB1:DLR	BC:RPB1:DLR	PM:RPB1:DLR
NAME	IKing	ACunanan	DMorey	ACunanan
DATE	06/ 21 /12	06/ 21 /12	06/ 22 /12	06/ 22 /12

OFFICIAL RECORD COPY