



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

July 03, 2012

APPLICANT: NextEra Energy Seabrook, LLC

FACILITY: Seabrook Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 19, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (NextEra or the applicant), held a telephone conference call on April 19, 2012, to discuss the response to a request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs that were discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

A handwritten signature in black ink that reads "Arthur Cunanan".

Arthur Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:  
As stated

cc w/encls: Distribution via Listserv

**TELEPHONE CONFERENCE CALL  
SEABROOK STATION  
LICENSE RENEWAL APPLICATION**

**LIST OF PARTICIPANTS**  
April 19, 2012

**PARTICIPANTS**

Arthur Cunanan  
Michael Marshall  
Abdul Sheikh  
Alice Erickson  
Richard Cliche  
Paul Willoughby  
Ken Chew  
Ed Carley

**AFFILIATIONS**

U.S. Nuclear Regulatory Commission (NRC)  
NRC  
NRC  
NRC  
NextEra Energy Seabrook, LLC (NextEra)  
NextEra  
NextEra  
NextEra

**TELEPHONE CONFERENCE CALL  
SEABROOK STATION  
LICENSE RENEWAL APPLICATION**

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (the applicant), held a telephone conference call on April 19, 2012, to discuss the response to the request for additional information (RAIs) concerning the Seabrook Station license renewal application (LRA).

**RAI B.2.1.28-3 and RAI B.2.1.31-1: Related to the ASME Section XI, Subsection IWL and Structures Monitoring Programs**

The staff discussed its concerns with the ASME Section XI, Subsection IWL and Structures Monitoring Programs.

The applicant understands the staff's concern and discussed submitting a plant-specific aging management program related to alkali-silica reaction (ASR) as well as submitting the engineering evaluation on the docket.

The staff will review the applicant's submittal. The staff will not send an RAI. This item is tracked as Open Item OI 3.0.3.2.18-1 in the safety evaluation report with open items.

Memorandum to NextEra Energy Seabrook, LLC from A. Cunanan dated July 03, 2012

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 19, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

DISTRIBUTION:

**HARD COPY:**

DLR RF

**E-MAIL:**

PUBLIC

RidsNrrDir Resource  
RidsNrrDirRpb1 Resource  
RidsNrrDirRpb2 Resource  
RidsNrrDirRarb Resource  
RidsNrrDirRapb Resource  
RidsNrrDirRasb Resource  
RidsNrrDirRerb Resource  
RidsNrrDirRpob Resource

-----  
MWentzel  
ACunanan  
DMorey  
JLamb  
DMcIntyre, OPA  
EDacus, OCA  
MSpencer, OGC  
WRaymond, RI  
DTiftt, RI  
NMcNamara, RI  
NSheehan, RI  
DScrenci, RI  
JJohnson, RI  
ABurritt, RI

APPLICANT: NextEra Energy Seabrook, LLC

FACILITY: Seabrook Station

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL HELD ON APRIL 19, 2012, BETWEEN THE U.S. NUCLEAR REGULATORY COMMISSION AND NEXTERA ENERGY SEABROOK, LLC, CONCERNING THE RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION PERTAINING TO THE SEABROOK STATION LICENSE RENEWAL APPLICATION (TAC NO. ME4028)

The U.S. Nuclear Regulatory Commission (NRC or the staff) and representatives of NextEra Energy Seabrook, LLC (NextEra or the applicant), held a telephone conference call on April 19, 2012, to discuss the response to a request for additional information (RAI) concerning the Seabrook Station license renewal application (LRA).

Enclosure 1 provides a listing of the participants and Enclosure 2 contains a listing of the RAIs that were discussed with the applicant, including a brief description on the status of the item.

The applicant had an opportunity to comment on this summary.

***/RA/***

Arthur Cunanan, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-443

Enclosures:  
As stated

cc w/encls: Distribution via Listserv

DISTRIBUTION:  
See next page

ADAMS Accession No. ML12164A759

OFFICE	LA:DLR	PM:RPB1:DLR	BC:RPB1:DLR	PM:RPB1:DLR
NAME	YEdmonds	ACunanan	DMorey	ACunanan
DATE	06/ 25 /12	06/ 25 /12	07/ 02 /12	07/ 03 /12

OFFICIAL RECORD COPY