

BellBendCOLPEm Resource

From: Canova, Michael
Sent: Thursday, June 14, 2012 9:15 AM
To: 'Sgarro, Rocco R'; Kirkwood, Jon K
Cc: Devlin, Stephanie; Karas, Rebecca; BellBendCOL Resource
Subject: Call Summary -Clarifying Call on RAI 118 Question 2.5.2-1

Attendees:

NRC

Rebecca Karas
Stephanie Devlin
Mike Canova

Applicant:

Rocky Sgarro – PPL Director of Licensing
Vincent Kelly – PPL Engineering
William Kline – UNE Engineering
Jon Kirkwood – UNE Bell Bend Licensing Supervisor
Richard Quittmeyer – Paul C. Rizzo Associates
John Paul Guinta – Paul C. Rizzo Associates – Bell Bend Project Manager.

Call Summary

Applicant had no specific issues for clarification at this time, having attended the call on the RCOL on this subject.

Staff shared some basic information to aid the applicant in determining the level of information the staff would be looking for in the response:

Staff advised that when the applicant responds, the use accompanying native digital files would substantially shorten the staff's effort in verifying the data as opposed attempting to extrapolate plot information.

Staff also commented that a sensitivity approach to the [CEUS-SSC](#) vs. existing response spectra should include 10^{-4} and 10^{-5} comparisons.

Staff advised that the applicant should identify whether they would be revising their GMRS or using a sensitivity approach when addressing this RAI scheduler information in order that the staff could reasonably determine the required review resource effort necessary for the review.

The Rizzo attendee identified that the GMRS would be revised to address the [CEUS-SSC](#) model and the TABLES in the FSAR would be revised at some point.

The PPL Project manager confirmed that a public meeting would be scheduled to provide details of the approach and schedule for deliverables commensurate with other related activities in this area.

Mike Canova

Project Manager - Bell Bend
Licensing Branch 1
Division of New Reactor Licensing
Office of New Reactors
301-415-0737

Hearing Identifier: BellBend_COL_Public
Email Number: 542

Mail Envelope Properties (77BCCD26C6050B42A72FE3939CF492EDCA1E85E1A6)

Subject: Call Summary -Clarifying Call on RAI 118 Question 2.5.2-1
Sent Date: 6/14/2012 9:14:31 AM
Received Date: 6/14/2012 9:14:33 AM
From: Canova, Michael

Created By: Michael.Canova@nrc.gov

Recipients:

"Devlin, Stephanie" <Stephanie.Devlin@nrc.gov>
Tracking Status: None
"Karas, Rebecca" <Rebecca.Karas@nrc.gov>
Tracking Status: None
"BellBendCOL Resource" <BellBendCOL.Resource@nrc.gov>
Tracking Status: None
"Sgarro, Rocco R" <rrsgarro@pplweb.com>
Tracking Status: None
"Kirkwood, Jon K" <jon.kirkwood@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	1874	6/14/2012 9:14:33 AM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: