



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 3, 2012

Mr. Michael J. Pacilio
President and Chief Nuclear Officer
Exelon Nuclear
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION—CORRECTION TO
RELIEF FROM THE REQUIREMENTS OF THE ASME CODE, RELIEF
REQUEST NO. PR-01 FOR FIFTH INSERVICE TESTING INTERVAL
(TAC NO. ME7616)

Dear Mr. Pacilio:

By letter dated November 17, 2011 (Agencywide Documents and Access Management System (ADAMS) Accession No. ML113250626), Exelon Nuclear submitted Relief Request (RR) PR-01 for Oyster Creek Nuclear Generating Station (OCNGS) during the fifth Inservice Testing (IST) interval, requesting the use of an alternative to certain requirements of the American Society of Mechanical Engineers (ASME) *Code for Operation and Maintenance of Nuclear Power Plants* (OM Code).

By letter dated June 21, 2012 (ADAMS Accession No. ML120050329), the U.S. Nuclear Regulatory Commission (NRC) staff authorized the alternative described in RR PR-01 for the fifth IST interval at OCNGS, which will begin on October 14, 2012, and ends on October 13, 2022.

Subsequently, it was discovered that the NRC staff made a typographical error in the third sentence of the second paragraph on page 5 of the safety evaluation (SE). The sentence currently reads:

However, the NRC staff has reviewed OMN-18, and currently has no concerns with its usage, providing that the high values of the Group A test "Required Action Range" for flow (Q) and differential pressure (ΔP) are greater than 106% of the respective reference values.

The sentence should be corrected in the SE to read the following:


However, the NRC staff has reviewed OMN-18, and currently has no concerns with its usage, providing that the high values of the Group A test "Required Action Range" for flow (Q) and differential pressure (ΔP) are less than 106% of the respective reference values.

M. Pacilio

- 2 -

If you have any questions regarding this matter, please contact me at (301) 415-3100 or by e-mail at John.Lamb@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "John G. Lamb". The signature is fluid and cursive, with the first name "John" being the most prominent.

John G. Lamb, Senior Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-219

cc: Distribution via Listserv

If you have any questions regarding this matter, please contact me at (301) 415-3100 or by e-mail at John.Lamb@nrc.gov.

Sincerely,

/ra/

John G. Lamb, Senior Project Manager
Plant Licensing Branch I-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-219

cc: Distribution via Listserv

DISTRIBUTIONPUBLIC
RidsNrrDoriLp1-2
RidsNrrPMOysterCreek
RidsNrrLAABaxter
RidsNrrDeEptb
RidsRgn1MailCenter
RidsOgcRp
RidsAcrcAcnw_MailCTR
JHuang, NRR
LChang OEDO
LPL1-2 R/F

ADAMS Accession No.: ML12181A009

OFFICE	LPL1-2/PM	LPL1-2/LA	LPL1-2/BC
NAME	JLamb	ABaxter	MKhanna
DATE	07/02 /12	07/02 /12	07/03/12

OFFICIAL RECORD COPY