

SeabrookNPEM Resource

From: Wentzel, Michael
Sent: Friday, June 29, 2012 11:02 AM
To: Cliche, Richard; Carley, Edward
Cc: Green, Kimberly
Subject: RE: Phone Call to Discuss Draft SAMA RAIs
Attachments: Revised Seabrook Supplement SAMA RAIs.docx

Rick,

Attached is a revised copy of the draft SAMA RAIs. There are three additional questions under #4. If you have any questions, please let me know.

Thanks,
Mike

-----Original Message-----

From: Cliche, Richard [<mailto:Richard.Cliche@fpl.com>]
Sent: Thursday, June 28, 2012 4:06 PM
To: Wentzel, Michael; Carley, Edward
Subject: RE: Phone Call to Discuss Draft SAMA RAIs

Mike,

Tuesday 7/3 at 3PM works for us. FYI, Paul Freeman has been replaced by Kevin Walsh as VP. The letter should be addressed to Kevin.
.....Rick

From: Wentzel, Michael [Michael.Wentzel@nrc.gov]
Sent: Thursday, June 28, 2012 4:00 PM
To: Carley, Edward; Cliche, Richard
Subject: Phone Call to Discuss Draft SAMA RAIs

Rick, Ed,

We would like to have a call at 3:00pm on Tuesday, July 3 to discuss the attached draft SAMA RAIs. I will forward on the dial-in info, once I've set-up the line. If you have any questions, please let me know.

Thanks,
Mike

Michael Wentzel
Project Manager
NRR/DLR/RPB2
(301) 415-6459
michael.wentzel@nrc.gov<<mailto:michael.wentzel@nrc.gov>>

Hearing Identifier: Seabrook_License_Renewal_NonPublic
Email Number: 3189

Mail Envelope Properties (C0A338EE37A11447B136119705BF9A3F013799D8DA6B)

Subject: RE: Phone Call to Discuss Draft SAMA RAIs
Sent Date: 6/29/2012 11:02:05 AM
Received Date: 6/29/2012 11:02:14 AM
From: Wentzel, Michael

Created By: Michael.Wentzel@nrc.gov

Recipients:

"Green, Kimberly" <Kimberly.Green@nrc.gov>
Tracking Status: None
"Cliche, Richard" <Richard.Cliche@fpl.com>
Tracking Status: None
"Carley, Edward" <Edward.Carley@fpl.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	1126	6/29/2012 11:02:14 AM
Revised Seabrook Supplement SAMA RAIs.docx		39570

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Mr. Kevin Walsh
Site Vice President
c/o Mr. Michael O'Keefe
NextEra Energy Seabrook, LLC
P.O. Box 300
Seabrook, NH 03874

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION FOR THE REVIEW OF THE
SEABROOK STATION LICENSE RENEWAL APPLICATION ENVIRONMENTAL
REVIEW – SAMA REVIEW (TAC NO. ME3959)

Dear Walsh:

By letter dated May 25, 2010, NextEra Energy Seabrook, LLC (NextEra) submitted an application and associated environmental report pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 51 and 10 CFR Part 54, to renew Operating License NPF-86 for Seabrook Station Unit 1 (Seabrook). In August 2011, the U.S. Nuclear Regulatory Commission (NRC or the staff) issued its draft plant-specific Supplement 46 to NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (SEIS), regarding the environmental impacts of renewing the Seabrook operating license for an additional 20 years.

Subsequent to the issuance of the draft SEIS, by letter dated March 19, 2012, NextEra submitted a supplement to their environmental report that identified changes that were made to the severe accident mitigation alternatives analysis (SAMA) related to the Seabrook license renewal application. The staff is reviewing the information contained in the supplement, and has identified, in the enclosure, areas where additional information is needed to complete the SAMA review. Further requests for additional information may be issued in the future.

Items in the enclosure were discussed with Mr. Rick Cliche of your staff and a mutually agreeable date for the response is within 60 days from the date of this letter. If you have any questions, please contact me at 301-415-6459 or by e-mail at michael.wentzel@nrc.gov.

Sincerely,

Michael Wentzel, Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-443
Enclosure: As stated
cc w/encl: Distribution via Listserv

Mr. Kevin Walsh
Site Vice President
c/o Mr. Michael O'Keefe
NextEra Energy Seabrook, LLC
P.O. Box 300
Seabrook, NH 03874

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION FOR THE REVIEW OF THE
SEABROOK STATION LICENSE RENEWAL APPLICATION ENVIRONMENTAL
REVIEW – SAMA REVIEW (TAC NO. ME3959)

Dear Mr. Walsh:

By letter dated May 25, 2010, NextEra Energy Seabrook, LLC (NextEra) submitted an application and associated environmental report pursuant to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 51 and 10 CFR Part 54, to renew Operating License NPF-86 for Seabrook Station Unit 1 (Seabrook). In August 2011, the U.S. Nuclear Regulatory Commission (NRC or the staff) issued its draft plant-specific Supplement 46 to NUREG-1437, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants" (SEIS), regarding the environmental impacts of renewing the Seabrook operating license for an additional 20 years.

Subsequent to the issuance of the draft SEIS, by letter dated March 19, 2012, NextEra submitted a supplement to their environmental report that identified changes that were made to the severe accident mitigation alternatives analysis (SAMA) related to the Seabrook license renewal application. The staff is reviewing the information contained in the supplement, and has identified, in the enclosure, areas where additional information is needed to complete the SAMA review. Further requests for additional information may be issued in the future.

Items in the enclosure were discussed with Mr. Rick Cliche of your staff and a mutually agreeable date for the response is within 60 days from the date of this letter. If you have any questions, please contact me at 301-415-6459 or by e-mail at michael.wentzel@nrc.gov.

Sincerely,

Michael Wentzel, Project Manager
Projects Branch 2
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-443
Enclosure: As stated
cc w/encl: Distribution via Listserv
DISTRIBUTION: See next page
ADAMS Accession No. ML

OFFICE	LA:RPB2:DLR	PM:RPB2:DLR	OGC	BC:DLR:RPB2	D:DLR:RPB2
NAME		MWentzel	MSpencer	DWrona	MWentzel
DATE					

OFFICIAL RECORD COPY

Letter to K. Walsh from M. Wentzel dated July XX, 2012

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION FOR THE REVIEW OF THE
SEABROOK STATION LICENSE RENEWAL APPLICATION ENVIRONMENTAL
REVIEW – SAMA REVIEW (TAC NO. ME3959)

DISTRIBUTION:

HARD COPY:

DLR RF

E-MAIL:

PUBLIC

RidsNrrDir Resource

RidsNrrDirRpb1 Resource

RidsNrrDirRpb2 Resource

RidsNrrDirRarb Resource

RidsNrrDirRapb Resource

RidsNrrDirRasb Resource

RidsNrrDirRerb Resource

RidsNrrDirRpob Resource

RidsNrrDraApla Resource

SeabrookPEm Resource

ACunнан

MWentzel

DWrona

DMorey

JLamb

RGallucci

JParillo

TTate

DMcIntyre, OPA

EDacus, OCA

MSpencer, OGC

WRaymond, RI

JDeBoer, RI

DTifft, RI

NMcNamara, RI

NSheehan, RI

DScrenci, RI

ABurritt, RI

Request for Additional Information
Regarding the Analysis of Severe Accident Mitigation Alternatives
For the Seabrook Station License Renewal Review

- 1) Please provide the following information regarding the Level 1 Probabilistic Safety Assessment (PSA) used for the Severe Accident Mitigation Alternatives (SAMA) analysis:
 - a. The Initiating Event Contribution to core damage frequency (CDF) Table in Section 3.1.1 of the Supplement present initiating event contributors down to 2.5% of the total combined (i.e., internal and external) CDF. Please provide initiating event contributors down to 1.0% of the total CDF.
 - b. Section 3.1 states on page 4 that an installation of a flow orifice in fire protection piping in control building is credited in the SB2011 probabilistic risk assessment (PRA) model update and is undergoing final acceptance testing. Please clarify when this design change will be implemented and whether it has passed final acceptance testing. In addition please verify that the as-built design change supports the PRA SAMA assumptions.
 - c. The CDF for Station Blackout (SBO) and Anticipated Transient Without Scram (ATWS) is not presented, and it is not clear whether these values have changed from the original 2009 submittal. Please provide CDF values for SBO and ATWS.
- 2) Please provide the following information relative to the Level 2 analysis:
 - a. The discussion for source term group SELL identifies that SELL uses the source term from release category LL5a and frequency from release category SELL5a. The Table on page 6 identifies that LL5a is a contributor to source term group LL5. The discussion for LL5 identifies that MAAP Case #106f was used to provide a representative source term while the discussion for SELL identifies that MAAP Case #106g was used for this source group. Please clarify this apparent discrepancy.
 - b. The dose risk and Off-site Economic Cost Risk (OECR) results are different for the SB2006 and SB2011 PRA model results. The reason for these differences is not clear in every case. Using Table F.3.2.1-1 and requests for additional information (RAIs) 2g and 4a associated with the SB2006 environmental report (ER), and release category results from the SB2011 submittal, please explain the model changes that caused the following differences:
 - i. LE1 – The CDF for this release category decreased from 1.1E-7/yr to 5.2E-8/yr, and the SB2011 release fractions for the noble gases, iodine (I) and cesium (Cs), are significantly delayed compared to their timing in the SB2006 model.
 - ii. LE2 – The CDF for this release category increased from 4.0E-9/yr to 1.8E-8/yr. The SB2011 noble gas release fraction is similar to the SB2006 model, but the I and Cs release fractions are reduced by half.

- iii. SE3 – The dose risk and OECR for this release category decreased by a factor of about three. The new Small/Early Containment Penetration Failure to Isolate and Large/Late Containment Basemat Failure (SELL) source term group appears to be a sub-part of the original small early containment isolation failure source term group (i.e., SE3).
 - c. The dose risk and OECR results for release category LL5 changed significantly between SB2006 and SB2011 (greater than a factor of 100). The text on page 33 indicates that the increase in SAMA case “MAB” is due to higher release category source terms (apparently referring to LL5). The CDF for LL5 increased from 3.2E-7/yr to 3.1E-6/yr, the SB2011 noble gas release fraction is similar to the SB2006 model, but the I and Cs release fractions are larger, and the release timing is significantly earlier. Please explain the model changes that caused these changes. Please include as part of this explanation a discussion of the relative impacts on increased I and Cs release fraction, the earlier release timing, and the event frequency change.
 - d. Please provide a general explanation of the differences in the release start times and durations from MAAP presented in the Table on page 12 from the release start times and durations presented in the Tables on pages 20-26 for MACCS. For example, for LE1, on page 12 the first puff release starts at 3.2 hr (~11,520 s) and the second puff starts at 39.3 hr (~141,800 s). However, on page 20 the first plume starts at 9328 s (~2.6 hr) and the fourth plume starts at 172,800 s (48 hr).
- 3) Please provide the following with regard to the SAMA identification and screening process:
- a. Two Tables in Section 3.1.1, Top 15 Basic Events Contributing to CDF and Top 15 Basic Events Contributing to large early release frequency (LERF), provide the Risk Reduction Worth (RRW) for CDF and LERF down to a value of 1.02. IN Section 4.1 the Top 15 Basic Events Contributing to CDF, LERF, and release category (RC) contributing to 90% of the Public Risk provides the top 15 basic events for each of the following: CDF, LERF (which includes LE1, LE2, LE3, and LE4), and RCs LL-5, SE-5, and SELL. The RRW values for basic events importance to LL-5, SE-5, and SELL are not provided. In an RAI response dated January 13, 2011, the top 15 basic events were provided along with their corresponding RRW values for the risk dominant (i.e., contributing to 90% of the population dose) release categories (i.e., SE3, LL3, LE1, SE1, and LL4). From RAI response it could be determined that the maximum benefit that might be calculated from eliminating the 15th most important basic event resulted in benefits less than a simple hardware implementation cost of (i.e., \$100K). Given the changes in release frequencies, such as the 10 fold increase in LL5, it is not clear whether all important basic events are identified as part of the 45 basic events presented in the Section 4.1 table. Please provide the RRWs for basic events contributing to LL-5, SE-5, and SELL where the benefit exceeds the cost of a simple hardware or administrative change (~\$100K). If further basic events are identified, please include their evaluation in Table 2 of Section 4.3.
- 4) Please provide the following with regard to the Phase II cost-benefit evaluations:
- a. Section 4.2 provides the new Maximum Averted Benefit (i.e., \$819K) using the SSPSS-2011 PRA model. Also please provide the Averted Public Exposure (APE) costs,

Averted Off-site Property Damage Costs (AOC), Averted Occupational Exposure (AOE) costs, and Averted Onsite Costs (AOC).

- b. In Table 1 of Section 4.3, neither the risk reduction values nor PRA modeling assumptions for SAMA case MAB are provided. The cost benefit with uncertainty and the seismic multiplier for SAMA 77 (evaluated by this SAMA case) is >\$15M, making the cost benefit the same as the expected cost for this SAMA. The evaluation for SAMA 77 incorrectly states that “Cost to engineer and implement installation of large passive air cooling system is far in excess of the attainable benefit”. The original SAMA evaluation submittal estimated the cost of implementing this SAMA to be >\$3M. Please provide the risk reduction values and PRA modeling assumptions for SAMA case MAB. Also, please provide justification of the cost of SAMA 77 and explain why it was necessary to increase this cost estimate.

Table 1 of Section 4.3 presents revised SAMA case CONTX1 which is defined to eliminate alternating current (AC) and direct current (DC) power and Primary Component Cooling Water (PCCW) support system failures for one division of Containment Building Spray (CBS). The evaluation for this SAMA case explains that this case more realistically represents the potential risk reduction benefit than the case it replaced (i.e., CONT01 - Installation of an independent division of containment spray). It is not clear that the PRA assumption for this case (CONTX1), which consists of eliminating support system failures, bounds the SAMAs represented by this case (i.e., #91, #94, #99, #102, and #107). In light of the potentially high cost benefit (the current cost benefit with uncertainty and the seismic multiplier is >\$5.7M), please provide justification for why this case is representative of each SAMA grouped under it and clarify whether a less restrictive or different case may be more appropriate. If a less restrictive or different case may be more appropriate please provide the corresponding evaluations.

- c. In Table 1 of Section 4.3, the expected cost of SAMA 162 (Increase the capacity margin of the condensate storage tank (CST)) is >\$2.5M. In the original submittal the expected cost of this SAMA was presented as >\$100K. The evaluation of this SAMA in the supplement states that the “Cost of expanding capacity of the CST is based on project scope of installing a new (larger) safety grade CST, which is judged necessary to achieve full benefit.” In light of the fact that the new cost benefit with uncertainty and the seismic multiplier is 238K, please explain the basis for the earlier cost estimate and why it was necessary to increase this cost estimate by a factor of 25.
- d. In Table 1 of Section 4.3, the expected cost of SAMA 189 (Modify or analyze supplemental emergency power supply (SEPS) capability; 1 of 2 SEPS for loss of off-site power (LOSP) non-safety injection (SI) loads, 2 of 2 LOSP SI loads) is >\$2M. In the original submittal the expected cost of this SAMA was presented as >\$300K. The SAMA appears that it could primarily be an analytical task. In light of this and the fact that the new cost benefit with uncertainty and the seismic multiplier is 311K, please explain why it was necessary to increase this cost estimate by a factor of 7.
- e. In Table 2 of Section 4.3, the cost benefit for SAMA case OHSB0 (for BE #5) is presented as >1M in the “Expected SAMA cost” column, yet the discussion in the “Evaluation” column states that the cost was estimated to be \$1.5M. Please clarify this discrepancy.

- f. In Table 2 of Section 4.3, the evaluation for BE #34 states that the PRA case “conservatively assumes that elimination of Bus E5 and E6 random failures that could cause an initiating event.... and/or fail the associated power division during mission time”. Please clarify whether the PRA assumptions for this modeling case (i.e., SWGE561) include elimination of initiators, basic events or both.
- g. In Table 2 of Section 4.3, the event description for BE #38 refers to operator actions after loss of coolant accident (LOCA) and steam generator tube rupture (SGTR), but the evaluation refers to actions after a small LOCA (SLOCA) and interfacing system LOCA (ISLOCA). Please clarify this discrepancy.
- h. In Table 2 of Section 4.3, the cost benefit analyses provided for IE #16 is a hardware installation to improve Component Cooling Water (CCW) reliability. In the evaluation for IE #16 on page 93 the associated SAMA case (i.e., CCTE1) is not identified as a cost beneficial SAMA. Yet, CCTE1 is identified as cost beneficial in Table 1 on page 65. Please clarify this apparent discrepancy.
- i. In Table 2 of Section 4.3, cost benefit analyses are provided for IE #23, #24, #25, #26, and #27, which are seismic initiators of different levels, (0.7g, 1.0g, 1.4g, 1.8g, and 2.5g) that lead to ATWS events (SAMA case NOATWS). No descriptions of the associated SAMA is provided nor is the basis for the presented cost estimate (i.e., >500K). Table 2 shows that IE #28, which is an ATWS event with loss of Main Feedwater, is also grouped into this SAMA case. It is not clear why this initiating event (i.e., IE#28) can be grouped as part of a seismic upgrade related SAMA case. Please provide the SAMA description and basis for the cost estimate for these six initiator cases.
- j. In Table 2 of Section 4.3, the entries for IE #8 and #9 appear to be duplicates. Please clarify.
- k. In Table 2 of Section 4.3, the cost benefit analyses provided for IE #16 is a hardware installation to improve Component Cooling Water (CCW) reliability. In the evaluation for IE #16 on page 93 the associated SAMA case (i.e., CCTE1) is not identified as a cost beneficial SAMA. Yet, CCTE1 is identified as cost beneficial in Table 1 on page 65. Please clarify this apparent discrepancy.
- l. In Table 2 of Section 4.3, cost benefit analyses are provided for IE #23, #24, #25, #26, and #27, which are seismic initiators of different levels, (0.7g, 1.0g, 1.4g, 1.8g, and 2.5g) that lead to ATWS events (SAMA case NOATWS). No description of the associated SAMA is provided nor is the basis for the presented cost estimate (i.e., >500K). Table 2 shows that IE #28, which is an ATWS event with loss of Main Feedwater, is also grouped into this SAMA case. It is not clear why this initiating event (i.e., IE#28) can be grouped as part of a seismic upgrade related SAMA case. Please provide the SAMA description and basis for the cost estimate for these six initiator cases.