

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-6	B-6-(015)	15	10/20/2011	12:01	1.53E+00	8.34E+00	1.10E+01	Co-60
I-2	I-2-(004)	4	12/8/2011	14:15	-2.12E+00	8.46E+00	1.04E+01	Co-60
LAF-002	LAF-002-(016)	16	12/13/2011	10:31	5.21E+00	8.73E+00	1.29E+01	Co-60
MH-5	MH-5-(027)	27	10/17/2011	10:07	-2.77E+00	7.92E+00	9.24E+00	Co-60
MH-5	MH-5-(028)	28	10/31/2011	14:20	3.37E-01	1.09E+01	1.53E+01	Co-60
MW-111	MW-111-(036)	36	11/11/2011	11:30	2.76E+00	8.97E+00	1.21E+01	Co-60
MW-30-69	MW-30-69-(042)	42	11/30/2011	11:20	2.82E+00	7.41E+00	1.11E+01	Co-60
MW-30-84	MW-30-84-(033)	33	11/30/2011	11:37	-1.64E+00	1.05E+01	1.26E+01	Co-60
MW-31-49	MW-31-49-(034)	34	11/21/2011	10:32	-3.55E+00	9.54E+00	1.08E+01	Co-60
MW-31-63	MW-31-63-(034)	34	11/21/2011	11:14	2.93E+00	8.19E+00	1.20E+01	Co-60
MW-31-85	MW-31-85-(034)	34	11/21/2011	11:25	-6.05E-01	9.57E+00	1.22E+01	Co-60
MW-32-149	MW-32-149-(028)	28	11/17/2011	12:05	2.57E+00	8.07E+00	1.12E+01	Co-60
MW-32-173	MW-32-173-(026)	26	11/17/2011	12:01	-1.50E-01	9.93E+00	1.26E+01	Co-60
MW-32-190	MW-32-190-(030)	30	11/17/2011	12:03	-4.42E-01	6.24E+00	7.93E+00	Co-60
MW-32-59	MW-32-59-(028)	28	11/17/2011	14:15	-1.58E+00	9.84E+00	1.21E+01	Co-60
MW-32-85	MW-32-85-(031)	31	11/17/2011	15:08	-1.88E+00	9.06E+00	1.09E+01	Co-60
MW-36-24	MW-36-24-(024)	24	12/7/2011	11:04	-1.38E+00	6.00E+00	7.29E+00	Co-60
MW-36-41	MW-36-41-(018)	18	12/7/2011	13:09	-5.23E-01	7.86E+00	1.01E+01	Co-60
MW-36-52	MW-36-52-(023)	23	12/7/2011	11:36	5.68E+00	9.03E+00	1.31E+01	Co-60
MW-37-22	MW-37-22-(024)	24	11/23/2011	11:33	-1.41E+00	7.35E+00	9.09E+00	Co-60
MW-37-32	MW-37-32-(024)	24	11/23/2011	11:19	-6.59E+00	8.76E+00	8.06E+00	Co-60
MW-37-40	MW-37-40-(024)	24	11/23/2011	11:46	9.11E-01	7.29E+00	1.00E+01	Co-60
MW-37-57	MW-37-57-(024)	24	11/23/2011	11:22	3.00E+00	9.12E+00	1.27E+01	Co-60
MW-39-102	MW-39-102-(014)	14	12/1/2011	14:10	-2.95E+00	6.99E+00	7.97E+00	Co-60
MW-39-124	MW-39-124-(014)	14	12/1/2011	11:42	2.71E+00	7.89E+00	9.85E+00	Co-60
MW-39-183	MW-39-183-(014)	14	12/1/2011	11:26	4.19E+00	8.16E+00	1.46E+01	Co-60
MW-39-195	MW-39-195-(014)	14	12/1/2011	11:28	5.51E-01	9.48E+00	1.22E+01	Co-60
MW-39-67	MW-39-67-(014)	14	12/1/2011	14:04	-3.39E+00	8.07E+00	9.37E+00	Co-60
MW-39-84	MW-39-84-(014)	14	12/1/2011	14:17	-1.71E+00	8.82E+00	1.05E+01	Co-60
MW-40-100	MW-40-100-(020)	20	12/9/2011	10:28	8.66E-01	7.77E+00	1.01E+01	Co-60
MW-40-127	MW-40-127-(020)	20	12/9/2011	10:40	-3.35E+00	9.18E+00	1.04E+01	Co-60
MW-40-162	MW-40-162-(018)	18	12/9/2011	11:02	-4.71E+00	1.17E+01	1.30E+01	Co-60
MW-40-27	MW-40-27-(017)	17	12/9/2011	11:50	3.19E+00	7.14E+00	1.03E+01	Co-60
MW-40-46	MW-40-46-(018)	18	12/9/2011	12:03	-9.20E-01	6.39E+00	8.16E+00	Co-60
MW-40-81	MW-40-81-(018)	18	12/9/2011	10:23	1.07E+00	1.07E+01	1.39E+01	Co-60
MW-41-40	MW-41-40-(023)	23	11/28/2011	14:25	-4.82E+00	9.81E+00	1.11E+01	Co-60
MW-41-63	MW-41-63-(022)	22	11/28/2011	14:08	-9.03E-01	7.41E+00	9.17E+00	Co-60
MW-42-49	MW-42-49-(028)	28	11/3/2011	11:13	-1.75E+00	7.56E+00	9.18E+00	Co-60
MW-42-78	MW-42-78-(023)	23	11/3/2011	11:31	1.37E-01	7.74E+00	9.98E+00	Co-60
MW-43-28	MW-43-28-(021)	21	11/22/2011	11:23	-3.96E+00	8.07E+00	8.55E+00	Co-60
MW-43-62	MW-43-62-(022)	22	11/22/2011	12:22	1.94E+00	1.06E+01	1.41E+01	Co-60
MW-44-102	MW-44-102-(024)	24	12/1/2011	12:18	-5.88E-01	9.33E+00	1.15E+01	Co-60
MW-44-66	MW-44-66-(023)	23	12/8/2011	12:00	2.32E+00	7.56E+00	1.04E+01	Co-60
MW-45-42	MW-45-42-(027)	27	11/28/2011	15:03	-2.64E+00	6.96E+00	7.84E+00	Co-60
MW-45-61	MW-45-61-(027)	27	11/28/2011	11:44	-6.01E-01	9.42E+00	1.19E+01	Co-60
MW-46	MW-46-(027)	27	10/20/2011	13:35	-1.03E+00	8.07E+00	1.01E+01	Co-60
MW-47-56	MW-47-56-(008)	8	10/28/2011	11:36	2.06E-01	1.01E+01	1.29E+01	Co-60
MW-47-80	MW-47-80-(007)	7	10/28/2011	13:24	1.21E+00	6.45E+00	8.88E+00	Co-60
MW-49-26	MW-49-26-(026)	26	11/4/2011	11:50	5.17E+00	8.04E+00	1.17E+01	Co-60
MW-49-42	MW-49-42-(026)	26	11/4/2011	11:43	-3.91E+00	1.04E+01	1.20E+01	Co-60
MW-49-65	MW-49-65-(026)	26	11/4/2011	11:47	-6.56E-01	9.45E+00	1.15E+01	Co-60
MW-50-42	MW-50-42-(028)	28	10/27/2011	10:48	-2.60E+00	8.01E+00	9.51E+00	Co-60
MW-50-66	MW-50-66-(033)	33	10/27/2011	10:53	1.01E+01	1.01E+01	1.49E+01	Co-60
MW-51-104	MW-51-104-(019)	19	12/12/2011	12:12	9.25E+00	9.80E+00	1.43E+01	Co-60
MW-51-135	MW-51-135-(019)	19	12/12/2011	12:50	-3.73E+00	8.40E+00	9.41E+00	Co-60
MW-51-163	MW-51-163-(019)	19	12/12/2011	12:26	-8.50E-01	8.52E+00	1.08E+01	Co-60
MW-51-189	MW-51-189-(019)	19	12/12/2011	12:23	1.93E+00	8.34E+00	1.13E+01	Co-60
MW-51-40	MW-51-40-(021)	21	12/12/2011	10:43	4.82E+00	7.89E+00	1.18E+01	Co-60
MW-51-79	MW-51-79-(021)	21	12/12/2011	11:09	-3.01E-01	7.62E+00	9.88E+00	Co-60
MW-53-120	MW-53-120-(026)	26	11/2/2011	11:56	-1.89E-01	7.89E+00	1.03E+01	Co-60
MW-53-82	MW-53-82-(022)	22	11/2/2011	11:26	-6.95E-01	8.73E+00	1.07E+01	Co-60
MW-54-123	MW-54-123-(020)	20	12/6/2011	10:37	1.04E+00	5.01E+00	6.08E+00	Co-60
MW-54-144	MW-54-144-(020)	20	12/6/2011	13:25	3.97E-01	5.58E+00	6.68E+00	Co-60
MW-54-173	MW-54-173-(020)	20	12/6/2011	13:26	9.05E-01	5.19E+00	6.34E+00	Co-60

IPEC00257769

MW-54-190	MW-54-190-(020)	20	12/6/2011	13:38	1.47E+00	4.11E+00	5.26E+00	Co-60
MW-54-37	MW-54-37-(020)	20	12/6/2011	10:37	4.84E-01	8.94E+00	1.14E+01	Co-60
MW-54-58	MW-54-58-(020)	20	12/6/2011	10:23	1.72E+00	4.56E+00	5.85E+00	Co-60
MW-55-24	MW-55-24-(019)	19	11/14/2011	11:26	3.58E+00	1.08E+01	1.50E+01	Co-60
MW-55-35	MW-55-35-(018)	18	11/14/2011	11:23	8.98E-01	8.22E+00	1.06E+01	Co-60
MW-55-54	MW-55-54-(019)	19	11/14/2011	11:07	3.60E+00	6.69E+00	1.03E+01	Co-60
MW-56-53	MW-56-53-(013)	13	10/31/2011	12:13	4.41E+00	8.22E+00	1.26E+01	Co-60
MW-56-83	MW-56-83-(015)	15	10/31/2011	12:00	2.43E+00	8.94E+00	1.22E+01	Co-60
MW-58-26	MW-58-26-(015)	15	11/15/2011	14:22	2.18E+00	9.42E+00	1.24E+01	Co-60
MW-58-65	MW-58-65-(015)	15	11/15/2011	14:05	-7.70E-01	7.23E+00	8.96E+00	Co-60
MW-60-135	MW-60-135-(019)	19	12/2/2011	10:10	2.05E+00	8.28E+00	1.13E+01	Co-60
MW-60-154	MW-60-154-(019)	19	12/2/2011	10:18	-3.69E+00	1.00E+01	1.13E+01	Co-60
MW-60-176	MW-60-176-(019)	19	12/2/2011	10:27	1.35E+00	1.01E+01	1.36E+01	Co-60
MW-60-35	MW-60-35-(019)	19	12/2/2011	11:21	2.63E+00	7.86E+00	1.12E+01	Co-60
MW-60-53	MW-60-53-(019)	19	12/2/2011	11:46	-9.95E-01	4.83E+00	5.65E+00	Co-60
MW-60-72	MW-60-72-(019)	19	12/2/2011	10:01	-1.72E+00	8.28E+00	1.01E+01	Co-60
MW-62-138	MW-62-138-(020)	20	10/21/2011	11:29	2.45E-01	1.03E+01	1.33E+01	Co-60
MW-62-18	MW-62-18-(020)	20	10/21/2011	10:14	-8.37E-01	8.82E+00	1.11E+01	Co-60
MW-62-182	MW-62-182-(020)	20	10/21/2011	11:37	-1.67E+00	1.06E+01	1.27E+01	Co-60
MW-62-37	MW-62-37-(020)	20	10/21/2011	10:02	-1.66E+00	8.07E+00	9.72E+00	Co-60
MW-62-53	MW-62-53-(019)	19	10/21/2011	10:17	2.49E+00	7.05E+00	1.01E+01	Co-60
MW-62-71	MW-62-71-(020)	20	10/21/2011	9:44	2.06E+00	9.84E+00	1.32E+01	Co-60
MW-62-92	MW-62-92-(020)	20	10/21/2011	9:42	1.88E-01	9.18E+00	1.22E+01	Co-60
MW-63-112	MW-63-112-(020)	20	10/18/2011	14:20	1.78E+00	7.02E+00	9.82E+00	Co-60
MW-63-121	MW-63-121-(020)	20	10/18/2011	11:27	2.81E+00	9.33E+00	1.31E+01	Co-60
MW-63-163	MW-63-163-(020)	20	10/18/2011	11:37	-1.98E+00	6.54E+00	7.63E+00	Co-60
MW-63-174	MW-63-174-(020)	20	10/18/2011	11:42	-4.33E+00	8.13E+00	9.02E+00	Co-60
MW-63-18	MW-63-18-(020)	20	10/18/2011	11:34	1.72E+00	1.09E+01	1.44E+01	Co-60
MW-63-34	MW-63-34-(020)	20	10/18/2011	11:39	2.21E+00	7.62E+00	1.11E+01	Co-60
MW-63-50	MW-63-50-(020)	20	10/18/2011	13:55	-2.69E+00	1.09E+01	1.34E+01	Co-60
MW-63-93	MW-63-93-(021)	21	10/18/2011	14:14	3.55E+00	6.87E+00	1.02E+01	Co-60
MW-66-21	MW-66-21-(019)	19	11/29/2011	11:08	1.73E+00	7.50E+00	1.01E+01	Co-60
MW-66-36	MW-66-36-(018)	18	11/29/2011	11:01	1.63E+00	8.64E+00	1.21E+01	Co-60
MW-67-105	MW-67-105-(018)	18	11/29/2011	14:10	-1.41E+00	8.73E+00	1.04E+01	Co-60
MW-67-173	MW-67-173-(019)	19	11/29/2011	14:23	-1.48E+00	1.08E+01	1.30E+01	Co-60
MW-67-219	MW-67-219-(018)	18	11/29/2011	10:41	1.99E+00	7.65E+00	1.12E+01	Co-60
MW-67-276	MW-67-276-(018)	18	11/29/2011	10:57	-7.14E-01	8.82E+00	1.11E+01	Co-60
MW-67-323	MW-67-323-(018)	18	11/29/2011	10:57	1.58E+00	5.43E+00	8.36E+00	Co-60
MW-67-340	MW-67-340-(018)	18	11/29/2011	10:46	1.23E+00	8.85E+00	1.14E+01	Co-60
MW-67-39	MW-67-39-(019)	19	11/29/2011	13:59	-1.78E+00	9.48E+00	1.17E+01	Co-60
U1-CSS	U1-CSS-(018)	18	10/27/2011	13:02	1.05E+00	7.08E+00	9.69E+00	Co-60
U1-NCD	U1-NCD-(012)	12	10/3/2011	13:20	1.93E+00	7.20E+00	9.97E+00	Co-60
U1-NCD	U1-NCD-(013)	13	12/26/2011	12:45	-1.01E+00	9.48E+00	1.17E+01	Co-60
U1-SFDS	U1-SFDS-(014)	14	10/5/2011	9:00	-6.39E+00	8.94E+00	9.49E+00	Co-60
U1-SFDS	U1-SFDS-(015)	15	12/28/2011	8:19	3.75E-01	1.02E+01	1.33E+01	Co-60
U3-4D	U3-4D-(031)	31	11/16/2011	12:56	-9.21E-01	9.27E+00	1.17E+01	Co-60
U3-4S	U3-4S-(006)	6	11/16/2011	11:28	1.63E+00	7.80E+00	1.08E+01	Co-60
U3-T1	U3-T1-(034)	34	10/19/2011	11:39	2.12E-01	9.12E+00	1.17E+01	Co-60
U3-T2	U3-T2-(040)	40	10/19/2011	10:20	-5.13E+00	1.12E+01	1.23E+01	Co-60

IPEC00257770

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-6	B-6-(015)	15	10/20/2011	12:01	-3.07E+00	7.65E+00	8.33E+00	Cs-137
I-2	I-2-(004)	4	12/8/2011	14:15	-2.35E+00	8.76E+00	1.00E+01	Cs-137
LAF-002	LAF-002-(016)	16	12/13/2011	10:31	-3.83E+00	9.48E+00	1.11E+01	Cs-137
MH-5	MH-5-(027)	27	10/17/2011	10:07	1.51E+00	7.68E+00	9.98E+00	Cs-137
MH-5	MH-5-(028)	28	10/31/2011	14:20	5.56E+00	1.15E+01	1.61E+01	Cs-137
MW-111	MW-111-(036)	36	11/11/2011	11:30	-2.01E-01	7.11E+00	8.62E+00	Cs-137
MW-30-69	MW-30-69-(042)	42	11/30/2011	11:20	1.95E+00	7.71E+00	9.97E+00	Cs-137
MW-30-84	MW-30-84-(033)	33	11/30/2011	11:37	-1.63E+00	9.48E+00	1.09E+01	Cs-137
MW-31-49	MW-31-49-(034)	34	11/21/2011	10:32	0.00E+00	1.14E+01	9.96E+00	Cs-137
MW-31-63	MW-31-63-(034)	34	11/21/2011	11:14	-2.72E+00	9.45E+00	1.09E+01	Cs-137
MW-31-85	MW-31-85-(034)	34	11/21/2011	11:25	-3.23E+00	9.21E+00	1.04E+01	Cs-137
MW-32-149	MW-32-149-(028)	28	11/17/2011	12:05	-5.25E+00	7.74E+00	7.86E+00	Cs-137
MW-32-173	MW-32-173-(026)	26	11/17/2011	12:01	2.87E+00	9.12E+00	1.13E+01	Cs-137
MW-32-190	MW-32-190-(030)	30	11/17/2011	12:03	1.30E+00	6.57E+00	8.59E+00	Cs-137
MW-32-59	MW-32-59-(028)	28	11/17/2011	14:15	-3.91E+00	1.01E+01	1.18E+01	Cs-137
MW-32-85	MW-32-85-(031)	31	11/17/2011	15:08	-1.20E+00	7.38E+00	8.80E+00	Cs-137
MW-36-24	MW-36-24-(024)	24	12/7/2011	11:04	1.75E+00	7.26E+00	9.17E+00	Cs-137
MW-36-41	MW-36-41-(018)	18	12/7/2011	13:09	1.19E-02	7.17E+00	9.00E+00	Cs-137
MW-36-52	MW-36-52-(023)	23	12/7/2011	11:36	2.89E+00	7.74E+00	1.01E+01	Cs-137
MW-37-22	MW-37-22-(024)	24	11/23/2011	11:33	2.26E+00	9.12E+00	1.19E+01	Cs-137
MW-37-32	MW-37-32-(024)	24	11/23/2011	11:19	7.81E+00	9.00E+00	1.28E+01	Cs-137
MW-37-40	MW-37-40-(024)	24	11/23/2011	11:46	1.06E+00	1.43E+01	7.71E+00	Cs-137
MW-37-57	MW-37-57-(024)	24	11/23/2011	11:22	-6.08E-01	8.28E+00	1.01E+01	Cs-137
MW-39-102	MW-39-102-(014)	14	12/1/2011	14:10	1.42E+00	7.68E+00	9.90E+00	Cs-137
MW-39-124	MW-39-124-(014)	14	12/1/2011	11:42	5.73E-01	7.95E+00	9.19E+00	Cs-137
MW-39-183	MW-39-183-(014)	14	12/1/2011	11:26	-2.81E+00	1.34E+01	1.59E+01	Cs-137
MW-39-195	MW-39-195-(014)	14	12/1/2011	11:28	2.12E+00	7.98E+00	1.03E+01	Cs-137
MW-39-67	MW-39-67-(014)	14	12/1/2011	14:04	-3.99E+00	9.24E+00	1.02E+01	Cs-137
MW-39-84	MW-39-84-(014)	14	12/1/2011	14:17	-1.59E+00	6.48E+00	7.42E+00	Cs-137
MW-40-100	MW-40-100-(020)	20	12/9/2011	10:28	1.85E+00	7.98E+00	9.93E+00	Cs-137
MW-40-127	MW-40-127-(020)	20	12/9/2011	10:40	-1.26E+00	8.91E+00	1.04E+01	Cs-137
MW-40-162	MW-40-162-(018)	18	12/9/2011	11:02	1.06E+00	8.43E+00	1.07E+01	Cs-137
MW-40-27	MW-40-27-(017)	17	12/9/2011	11:50	7.86E-01	7.02E+00	8.97E+00	Cs-137
MW-40-46	MW-40-46-(018)	18	12/9/2011	12:03	1.26E+00	7.41E+00	9.46E+00	Cs-137
MW-40-81	MW-40-81-(018)	18	12/9/2011	10:23	4.60E-01	2.64E+01	1.18E+01	Cs-137
MW-41-40	MW-41-40-(023)	23	11/28/2011	14:25	6.21E+00	8.16E+00	1.13E+01	Cs-137
MW-41-63	MW-41-63-(022)	22	11/28/2011	14:08	-7.79E-01	7.20E+00	8.56E+00	Cs-137
MW-42-49	MW-42-49-(028)	28	11/3/2011	11:13	3.03E+03	3.90E+02	1.29E+01	Cs-137
MW-42-78	MW-42-78-(023)	23	11/3/2011	11:31	-2.93E+00	7.32E+00	8.03E+00	Cs-137
MW-43-28	MW-43-28-(021)	21	11/22/2011	11:23	-9.87E-02	5.58E+00	7.14E+00	Cs-137
MW-43-62	MW-43-62-(022)	22	11/22/2011	12:22	-1.43E+01	1.42E+01	1.67E+01	Cs-137
MW-44-102	MW-44-102-(024)	24	12/1/2011	12:18	-7.91E-02	8.73E+00	1.04E+01	Cs-137
MW-44-66	MW-44-66-(023)	23	12/8/2011	12:00	1.99E+00	7.35E+00	9.30E+00	Cs-137
MW-45-42	MW-45-42-(027)	27	11/28/2011	15:03	1.21E+00	5.94E+00	7.69E+00	Cs-137
MW-45-61	MW-45-61-(027)	27	11/28/2011	11:44	3.28E-01	7.41E+00	9.39E+00	Cs-137
MW-46	MW-46-(027)	27	10/20/2011	13:35	-4.36E+00	8.19E+00	8.94E+00	Cs-137
MW-47-56	MW-47-56-(008)	8	10/28/2011	11:36	1.34E+00	8.85E+00	1.07E+01	Cs-137
MW-47-80	MW-47-80-(007)	7	10/28/2011	13:24	-1.35E+00	6.54E+00	7.91E+00	Cs-137
MW-49-26	MW-49-26-(026)	26	11/4/2011	11:50	2.60E+00	1.11E+01	7.92E+00	Cs-137
MW-49-42	MW-49-42-(026)	26	11/4/2011	11:43	5.99E-01	1.87E+01	1.10E+01	Cs-137
MW-49-65	MW-49-65-(026)	26	11/4/2011	11:47	-4.27E+00	8.88E+00	9.11E+00	Cs-137
MW-50-42	MW-50-42-(028)	28	10/27/2011	10:48	1.76E+00	7.11E+00	9.22E+00	Cs-137
MW-50-66	MW-50-66-(033)	33	10/27/2011	10:53	-6.49E-01	8.64E+00	1.02E+01	Cs-137
MW-51-104	MW-51-104-(019)	19	12/12/2011	12:12	-3.81E+00	9.12E+00	1.01E+01	Cs-137
MW-51-135	MW-51-135-(019)	19	12/12/2011	12:50	6.83E+00	9.42E+00	1.28E+01	Cs-137
MW-51-163	MW-51-163-(019)	19	12/12/2011	12:26	2.25E+00	8.94E+00	1.16E+01	Cs-137
MW-51-189	MW-51-189-(019)	19	12/12/2011	12:23	-4.49E+00	8.10E+00	8.53E+00	Cs-137
MW-51-40	MW-51-40-(021)	21	12/12/2011	10:43	-5.53E+00	8.49E+00	9.48E+00	Cs-137
MW-51-79	MW-51-79-(021)	21	12/12/2011	11:09	-3.25E+00	7.98E+00	8.95E+00	Cs-137
MW-53-120	MW-53-120-(026)	26	11/2/2011	11:56	4.60E+00	8.52E+00	1.15E+01	Cs-137
MW-53-82	MW-53-82-(022)	22	11/2/2011	11:26	-1.19E+00	6.78E+00	7.87E+00	Cs-137
MW-54-123	MW-54-123-(020)	20	12/6/2011	10:37	-1.21E+00	4.38E+00	4.89E+00	Cs-137
MW-54-144	MW-54-144-(020)	20	12/6/2011	13:25	8.64E-01	5.58E+00	6.45E+00	Cs-137
MW-54-173	MW-54-173-(020)	20	12/6/2011	13:26	-8.33E-01	4.83E+00	5.47E+00	Cs-137

IPEC00257771

MW-54-190	MW-54-190-(020)	20	12/6/2011	13:38	5.15E-01	3.87E+00	4.56E+00	Cs-137
MW-54-37	MW-54-37-(020)	20	12/6/2011	10:37	-6.26E+00	9.72E+00	1.03E+01	Cs-137
MW-54-58	MW-54-58-(020)	20	12/6/2011	10:23	9.45E-01	4.23E+00	5.14E+00	Cs-137
MW-55-24	MW-55-24-(019)	19	11/14/2011	11:26	0.00E+00	8.49E+00	1.07E+01	Cs-137
MW-55-35	MW-55-35-(018)	18	11/14/2011	11:23	2.04E-01	7.08E+00	8.67E+00	Cs-137
MW-55-54	MW-55-54-(019)	19	11/14/2011	11:07	-2.66E+00	8.67E+00	1.04E+01	Cs-137
MW-56-53	MW-56-53-(013)	13	10/31/2011	12:13	4.08E+00	9.36E+00	1.24E+01	Cs-137
MW-56-83	MW-56-83-(015)	15	10/31/2011	12:00	2.19E+00	7.29E+00	9.56E+00	Cs-137
MW-58-26	MW-58-26-(015)	15	11/15/2011	14:22	1.04E+00	1.99E+01	8.90E+00	Cs-137
MW-58-65	MW-58-65-(015)	15	11/15/2011	14:05	-1.89E+00	8.82E+00	9.54E+00	Cs-137
MW-60-135	MW-60-135-(019)	19	12/2/2011	10:10	-1.37E-02	7.68E+00	9.43E+00	Cs-137
MW-60-154	MW-60-154-(019)	19	12/2/2011	10:18	1.25E+00	9.33E+00	1.17E+01	Cs-137
MW-60-176	MW-60-176-(019)	19	12/2/2011	10:27	7.24E-01	9.60E+00	1.20E+01	Cs-137
MW-60-35	MW-60-35-(019)	19	12/2/2011	11:21	-8.20E-01	9.33E+00	1.15E+01	Cs-137
MW-60-53	MW-60-53-(019)	19	12/2/2011	11:46	4.62E-01	4.68E+00	5.62E+00	Cs-137
MW-60-72	MW-60-72-(019)	19	12/2/2011	10:01	-2.19E+00	6.99E+00	8.20E+00	Cs-137
MW-62-138	MW-62-138-(020)	20	10/21/2011	11:29	-5.88E+00	1.01E+01	1.10E+01	Cs-137
MW-62-18	MW-62-18-(020)	20	10/21/2011	10:14	-1.19E+00	6.87E+00	8.28E+00	Cs-137
MW-62-182	MW-62-182-(020)	20	10/21/2011	11:37	-4.81E+00	1.22E+01	1.34E+01	Cs-137
MW-62-37	MW-62-37-(020)	20	10/21/2011	10:02	5.93E-01	8.19E+00	9.98E+00	Cs-137
MW-62-53	MW-62-53-(019)	19	10/21/2011	10:17	1.64E+00	6.66E+00	8.55E+00	Cs-137
MW-62-71	MW-62-71-(020)	20	10/21/2011	9:44	8.75E-01	9.06E+00	1.13E+01	Cs-137
MW-62-92	MW-62-92-(020)	20	10/21/2011	9:42	3.18E-01	9.39E+00	1.17E+01	Cs-137
MW-63-112	MW-63-112-(020)	20	10/18/2011	14:20	-1.39E+00	7.53E+00	8.79E+00	Cs-137
MW-63-121	MW-63-121-(020)	20	10/18/2011	11:27	-6.42E+00	1.26E+01	1.62E+01	Cs-137
MW-63-163	MW-63-163-(020)	20	10/18/2011	11:37	-4.58E+00	9.51E+00	9.82E+00	Cs-137
MW-63-174	MW-63-174-(020)	20	10/18/2011	11:42	-6.37E-02	8.43E+00	1.03E+01	Cs-137
MW-63-18	MW-63-18-(020)	20	10/18/2011	11:34	1.31E+00	8.28E+00	1.07E+01	Cs-137
MW-63-34	MW-63-34-(020)	20	10/18/2011	11:39	-3.77E+00	8.31E+00	9.14E+00	Cs-137
MW-63-50	MW-63-50-(020)	20	10/18/2011	13:55	-9.09E-01	1.09E+01	1.29E+01	Cs-137
MW-63-93	MW-63-93-(021)	21	10/18/2011	14:14	7.43E-01	6.45E+00	8.33E+00	Cs-137
MW-66-21	MW-66-21-(019)	19	11/29/2011	11:08	7.86E-01	6.60E+00	8.51E+00	Cs-137
MW-66-36	MW-66-36-(018)	18	11/29/2011	11:01	5.21E+00	9.78E+00	1.32E+01	Cs-137
MW-67-105	MW-67-105-(018)	18	11/29/2011	14:10	-1.36E+00	8.73E+00	1.01E+01	Cs-137
MW-67-173	MW-67-173-(019)	19	11/29/2011	14:23	-1.48E+00	9.87E+00	1.14E+01	Cs-137
MW-67-219	MW-67-219-(018)	18	11/29/2011	10:41	-1.12E+01	1.14E+01	1.19E+01	Cs-137
MW-67-276	MW-67-276-(018)	18	11/29/2011	10:57	-2.95E+00	1.01E+01	1.19E+01	Cs-137
MW-67-323	MW-67-323-(018)	18	11/29/2011	10:57	-3.91E+00	9.81E+00	1.15E+01	Cs-137
MW-67-340	MW-67-340-(018)	18	11/29/2011	10:46	-7.65E+00	7.53E+00	7.09E+00	Cs-137
MW-67-39	MW-67-39-(019)	19	11/29/2011	13:59	-1.60E+01	1.39E+01	1.60E+01	Cs-137
U1-CSS	U1-CSS-(018)	18	10/27/2011	13:02	-2.80E+00	8.07E+00	8.99E+00	Cs-137
U1-NCD	U1-NCD-(012)	12	10/3/2011	13:20	5.92E+03	8.04E+02	1.43E+01	Cs-137
U1-NCD	U1-NCD-(013)	13	12/26/2011	12:45	7.73E+03	9.75E+02	1.84E+01	Cs-137
U1-SFDS	U1-SFDS-(014)	14	10/5/2011	9:00	4.27E+00	9.96E+00	1.25E+01	Cs-137
U1-SFDS	U1-SFDS-(015)	15	12/28/2011	8:19	-3.38E+00	9.87E+00	1.13E+01	Cs-137
U3-4D	U3-4D-(031)	31	11/16/2011	12:56	-9.88E-01	8.82E+00	1.07E+01	Cs-137
U3-4S	U3-4S-(006)	6	11/16/2011	11:28	-2.06E+00	9.27E+00	1.12E+01	Cs-137
U3-T1	U3-T1-(034)	34	10/19/2011	11:39	-3.93E-01	9.51E+00	1.17E+01	Cs-137
U3-T2	U3-T2-(040)	40	10/19/2011	10:20	-4.88E+00	1.02E+01	1.09E+01	Cs-137

IPEC00257772

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-6	B-6-(015)	15	10/20/2011	12:01	1.70E+02	3.48E+02	3.87E+02	H-3
I-2	I-2-(004)	4	12/8/2011	14:15	-3.49E+01	3.45E+02	4.09E+02	H-3
LAF-002	LAF-002-(016)	16	12/13/2011	10:31	6.96E+01	4.14E+02	4.79E+02	H-3
MH-5	MH-5-(027)	27	10/17/2011	10:07	1.48E+04	1.09E+03	3.86E+02	H-3
MH-5	MH-5-(028)	28	10/31/2011	14:20	2.40E+04	1.37E+03	3.89E+02	H-3
MW-111	MW-111-(036)	36	11/11/2011	11:30	1.11E+04	1.42E+03	3.31E+02	H-3
MW-30-69	MW-30-69-(042)	42	11/30/2011	11:20	9.12E+04	3.06E+03	4.87E+02	H-3
MW-30-84	MW-30-84-(033)	33	11/30/2011	11:37	7.24E+03	9.39E+02	4.80E+02	H-3
MW-31-49	MW-31-49-(034)	34	11/21/2011	10:32	1.54E+04	9.78E+02	3.42E+02	H-3
MW-31-63	MW-31-63-(034)	34	11/21/2011	11:14	7.23E+03	9.00E+02	2.36E+02	H-3
MW-31-85	MW-31-85-(034)	34	11/21/2011	11:25	5.49E+03	6.33E+02	3.45E+02	H-3
MW-32-149	MW-32-149-(028)	28	11/17/2011	12:05	5.91E+02	3.45E+02	3.41E+02	H-3
MW-32-173	MW-32-173-(026)	26	11/17/2011	12:01	5.06E+02	3.33E+02	3.34E+02	H-3
MW-32-190	MW-32-190-(030)	30	11/17/2011	12:03	1.46E+03	4.05E+02	3.36E+02	H-3
MW-32-59	MW-32-59-(028)	28	11/17/2011	14:15	2.91E+04	1.74E+03	2.26E+02	H-3
MW-32-85	MW-32-85-(031)	31	11/17/2011	15:08	8.88E+03	7.65E+02	3.42E+02	H-3
MW-36-24	MW-36-24-(024)	24	12/7/2011	11:04	0.00E+00	4.20E+02	4.96E+02	H-3
MW-36-41	MW-36-41-(018)	18	12/7/2011	13:09	2.63E+03	6.51E+02	4.78E+02	H-3
MW-36-52	MW-36-52-(023)	23	12/7/2011	11:36	4.76E+03	8.10E+02	4.91E+02	H-3
MW-37-22	MW-37-22-(024)	24	11/23/2011	11:33	4.97E+03	8.28E+02	4.96E+02	H-3
MW-37-32	MW-37-32-(024)	24	11/23/2011	11:19	4.33E+03	7.80E+02	4.91E+02	H-3
MW-37-40	MW-37-40-(024)	24	11/23/2011	11:46	5.22E+03	8.28E+02	4.83E+02	H-3
MW-37-57	MW-37-57-(024)	24	11/23/2011	11:22	4.87E+03	8.16E+02	4.91E+02	H-3
MW-39-102	MW-39-102-(014)	14	12/1/2011	14:10	1.12E+03	5.25E+02	4.77E+02	H-3
MW-39-124	MW-39-124-(014)	14	12/1/2011	11:42	1.73E+02	4.35E+02	4.89E+02	H-3
MW-39-183	MW-39-183-(014)	14	12/1/2011	11:26	-8.23E+01	4.11E+02	4.97E+02	H-3
MW-39-195	MW-39-195-(014)	14	12/1/2011	11:28	5.13E+03	8.28E+02	4.87E+02	H-3
MW-39-67	MW-39-67-(014)	14	12/1/2011	14:04	1.03E+03	5.13E+02	4.75E+02	H-3
MW-39-84	MW-39-84-(014)	14	12/1/2011	14:17	1.39E+02	4.32E+02	4.88E+02	H-3
MW-40-100	MW-40-100-(020)	20	12/9/2011	10:28	4.85E+01	4.29E+02	5.00E+02	H-3
MW-40-127	MW-40-127-(020)	20	12/9/2011	10:40	5.65E+01	4.08E+02	4.71E+02	H-3
MW-40-162	MW-40-162-(018)	18	12/9/2011	11:02	-2.60E+01	3.42E+02	4.06E+02	H-3
MW-40-27	MW-40-27-(017)	17	12/9/2011	11:50	2.24E+01	4.20E+02	4.90E+02	H-3
MW-40-46	MW-40-46-(018)	18	12/9/2011	12:03	9.00E+01	4.17E+02	4.77E+02	H-3
MW-40-81	MW-40-81-(018)	18	12/9/2011	10:23	-8.05E+01	4.02E+02	4.86E+02	H-3
MW-41-40	MW-41-40-(023)	23	11/28/2011	14:25	6.16E+02	5.13E+02	5.14E+02	H-3
MW-41-63	MW-41-63-(022)	22	11/28/2011	14:08	6.41E+02	5.22E+02	5.22E+02	H-3
MW-42-49	MW-42-49-(028)	28	11/3/2011	11:13	1.40E+03	5.70E+02	5.00E+02	H-3
MW-42-78	MW-42-78-(023)	23	11/3/2011	11:31	3.23E+02	4.65E+02	5.02E+02	H-3
MW-43-28	MW-43-28-(021)	21	11/22/2011	11:23	1.21E+02	3.60E+02	4.05E+02	H-3
MW-43-62	MW-43-62-(022)	22	11/22/2011	12:22	2.01E+02	3.72E+02	4.10E+02	H-3
MW-44-102	MW-44-102-(024)	24	12/1/2011	12:18	1.05E+03	4.50E+02	4.07E+02	H-3
MW-44-66	MW-44-66-(023)	23	12/8/2011	12:00	3.70E+02	3.84E+02	4.04E+02	H-3
MW-45-42	MW-45-42-(027)	27	11/28/2011	15:03	1.65E+03	6.27E+02	5.10E+02	H-3
MW-45-61	MW-45-61-(027)	27	11/28/2011	11:44	2.06E+03	6.72E+02	5.16E+02	H-3
MW-46	MW-46-(027)	27	10/20/2011	13:35	2.28E+03	4.68E+02	3.46E+02	H-3
MW-47-56	MW-47-56-(008)	8	10/28/2011	11:36	5.31E+03	8.52E+02	4.99E+02	H-3
MW-47-80	MW-47-80-(007)	7	10/28/2011	13:24	9.68E+04	3.21E+03	5.07E+02	H-3
MW-49-26	MW-49-26-(026)	26	11/4/2011	11:50	4.92E+03	8.37E+02	5.06E+02	H-3
MW-49-42	MW-49-42-(026)	26	11/4/2011	11:43	4.91E+03	8.19E+02	4.90E+02	H-3
MW-49-65	MW-49-65-(026)	26	11/4/2011	11:47	4.24E+03	7.23E+02	4.64E+02	H-3
MW-50-42	MW-50-42-(028)	28	10/27/2011	10:48	9.99E+02	5.25E+02	4.92E+02	H-3
MW-50-66	MW-50-66-(033)	33	10/27/2011	10:53	7.83E+03	9.87E+02	4.94E+02	H-3
MW-51-104	MW-51-104-(019)	19	12/12/2011	12:12	1.48E+02	2.91E+02	3.24E+02	H-3
MW-51-135	MW-51-135-(019)	19	12/12/2011	12:50	1.32E+02	2.93E+02	3.33E+02	H-3
MW-51-163	MW-51-163-(019)	19	12/12/2011	12:26	1.71E+02	3.03E+02	3.32E+02	H-3
MW-51-189	MW-51-189-(019)	19	12/12/2011	12:23	-5.57E+01	2.30E+02	3.29E+02	H-3
MW-51-40	MW-51-40-(021)	21	12/12/2011	10:43	1.86E+02	3.06E+02	3.28E+02	H-3
MW-51-79	MW-51-79-(021)	21	12/12/2011	11:09	1.50E+02	2.95E+02	3.29E+02	H-3
MW-53-120	MW-53-120-(026)	26	11/2/2011	11:56	8.02E+03	9.27E+02	4.67E+02	H-3
MW-53-82	MW-53-82-(022)	22	11/2/2011	11:26	2.27E+02	4.50E+02	5.00E+02	H-3
MW-54-123	MW-54-123-(020)	20	12/6/2011	10:37	3.92E+03	6.00E+02	3.71E+02	H-3
MW-54-144	MW-54-144-(020)	20	12/6/2011	13:25	6.85E+03	7.44E+02	3.71E+02	H-3
MW-54-173	MW-54-173-(020)	20	12/6/2011	13:26	2.32E+03	6.66E+02	3.26E+02	H-3

IPEC00257773

MW-54-190	MW-54-190-(020)	20	12/6/2011	13:38	8.77E+03	8.22E+02	3.68E+02	H-3
MW-54-37	MW-54-37-(020)	20	12/6/2011	10:37	1.40E+04	1.02E+03	3.73E+02	H-3
MW-54-58	MW-54-58-(020)	20	12/6/2011	10:23	4.83E+03	6.48E+02	3.70E+02	H-3
MW-55-24	MW-55-24-(019)	19	11/14/2011	11:26	2.57E+03	6.66E+02	4.98E+02	H-3
MW-55-35	MW-55-35-(018)	18	11/14/2011	11:23	2.79E+03	6.84E+02	5.00E+02	H-3
MW-55-54	MW-55-54-(019)	19	11/14/2011	11:07	5.97E+03	8.25E+02	4.67E+02	H-3
MW-56-53	MW-56-53-(013)	13	10/31/2011	12:13	6.15E+01	4.41E+02	5.09E+02	H-3
MW-56-83	MW-56-83-(015)	15	10/31/2011	12:00	7.25E+04	2.80E+03	5.11E+02	H-3
MW-58-26	MW-58-26-(015)	15	11/15/2011	14:22	4.77E+03	7.29E+02	2.31E+02	H-3
MW-58-65	MW-58-65-(015)	15	11/15/2011	14:05	1.75E+03	4.32E+02	3.42E+02	H-3
MW-60-135	MW-60-135-(019)	19	12/2/2011	10:10	3.05E+02	3.81E+02	4.08E+02	H-3
MW-60-154	MW-60-154-(019)	19	12/2/2011	10:18	6.27E+02	5.22E+02	5.23E+02	H-3
MW-60-176	MW-60-176-(019)	19	12/2/2011	10:27	1.30E+03	5.97E+02	5.19E+02	H-3
MW-60-35	MW-60-35-(019)	19	12/2/2011	11:21	1.74E+02	3.66E+02	4.07E+02	H-3
MW-60-53	MW-60-53-(019)	19	12/2/2011	11:46	2.65E+02	3.30E+02	3.33E+02	H-3
MW-60-72	MW-60-72-(019)	19	12/2/2011	10:01	3.08E+02	3.75E+02	4.01E+02	H-3
MW-62-138	MW-62-138-(020)	20	10/21/2011	11:29	3.01E+03	5.97E+02	2.36E+02	H-3
MW-62-18	MW-62-18-(020)	20	10/21/2011	10:14	6.50E+02	3.54E+02	3.45E+02	H-3
MW-62-182	MW-62-182-(020)	20	10/21/2011	11:37	6.88E+02	3.42E+02	3.27E+02	H-3
MW-62-37	MW-62-37-(020)	20	10/21/2011	10:02	3.74E+02	3.33E+02	3.47E+02	H-3
MW-62-53	MW-62-53-(019)	19	10/21/2011	10:17	4.82E+02	3.39E+02	3.42E+02	H-3
MW-62-71	MW-62-71-(020)	20	10/21/2011	9:44	4.68E+02	3.36E+02	3.42E+02	H-3
MW-62-92	MW-62-92-(020)	20	10/21/2011	9:42	5.51E+02	3.45E+02	3.42E+02	H-3
MW-63-112	MW-63-112-(020)	20	10/18/2011	14:20	1.34E+03	5.43E+02	3.29E+02	H-3
MW-63-121	MW-63-121-(020)	20	10/18/2011	11:27	3.63E+03	8.40E+02	3.33E+02	H-3
MW-63-163	MW-63-163-(020)	20	10/18/2011	11:37	4.85E+02	3.75E+02	3.80E+02	H-3
MW-63-174	MW-63-174-(020)	20	10/18/2011	11:42	4.53E+02	3.72E+02	3.80E+02	H-3
MW-63-18	MW-63-18-(020)	20	10/18/2011	11:34	2.59E+02	2.34E+02	2.20E+02	H-3
MW-63-34	MW-63-34-(020)	20	10/18/2011	11:39	4.30E+02	3.36E+02	3.46E+02	H-3
MW-63-50	MW-63-50-(020)	20	10/18/2011	13:55	3.14E+02	3.63E+02	3.85E+02	H-3
MW-63-93	MW-63-93-(021)	21	10/18/2011	14:14	5.04E+02	3.78E+02	3.83E+02	H-3
MW-66-21	MW-66-21-(019)	19	11/29/2011	11:08	2.64E+02	3.27E+02	3.32E+02	H-3
MW-66-36	MW-66-36-(018)	18	11/29/2011	11:01	3.34E+03	6.78E+02	4.85E+02	H-3
MW-67-105	MW-67-105-(018)	18	11/29/2011	14:10	1.89E+03	5.94E+02	4.78E+02	H-3
MW-67-173	MW-67-173-(019)	19	11/29/2011	14:23	5.88E+02	4.74E+02	4.78E+02	H-3
MW-67-219	MW-67-219-(018)	18	11/29/2011	10:41	1.20E+03	4.92E+02	4.45E+02	H-3
MW-67-276	MW-67-276-(018)	18	11/29/2011	10:57	1.06E+03	5.25E+02	4.84E+02	H-3
MW-67-323	MW-67-323-(018)	18	11/29/2011	10:57	3.62E+02	4.56E+02	4.86E+02	H-3
MW-67-340	MW-67-340-(018)	18	11/29/2011	10:46	5.62E+02	4.68E+02	4.76E+02	H-3
MW-67-39	MW-67-39-(019)	19	11/29/2011	13:59	3.51E+03	8.07E+02	3.31E+02	H-3
U1-CSS	U1-CSS-(018)	18	10/27/2011	13:02	1.70E+03	5.64E+02	4.77E+02	H-3
U1-NCD	U1-NCD-(012)	12	10/3/2011	13:20	1.13E+04	1.03E+03	3.35E+02	H-3
U1-NCD	U1-NCD-(013)	13	12/26/2011	12:45	2.32E+03	5.13E+02	3.74E+02	H-3
U1-SFDS	U1-SFDS-(014)	14	10/5/2011	9:00	2.02E+03	5.01E+02	3.35E+02	H-3
U1-SFDS	U1-SFDS-(015)	15	12/28/2011	8:19	1.10E+02	3.21E+02	3.61E+02	H-3
U3-4D	U3-4D-(031)	31	11/16/2011	12:56	3.50E+02	3.63E+02	3.81E+02	H-3
U3-4S	U3-4S-(006)	6	11/16/2011	11:28	7.52E+02	4.41E+02	3.32E+02	H-3
U3-T1	U3-T1-(034)	34	10/19/2011	11:39	7.69E+02	4.05E+02	3.84E+02	H-3
U3-T2	U3-T2-(040)	40	10/19/2011	10:20	2.98E+03	7.62E+02	3.28E+02	H-3

IPEC00257774

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
LAF-002	LAF-002-(016)	16	12/13/2011	10:31	6.36E+00	1.11E+01	1.22E+01	Ni-63
MW-42-49	MW-42-49-(028)	28	11/3/2011	11:13	5.77E+01	1.57E+01	1.45E+01	Ni-63
MW-42-78	MW-42-78-(023)	23	11/3/2011	11:31	-2.26E+00	1.18E+01	1.35E+01	Ni-63
MW-47-56	MW-47-56-(008)	8	10/28/2011	11:36	-6.21E+00	1.24E+01	1.44E+01	Ni-63
MW-47-80	MW-47-80-(007)	7	10/28/2011	13:24	3.54E+00	1.31E+01	1.46E+01	Ni-63
MW-49-26	MW-49-26-(026)	26	11/4/2011	11:50	-2.73E+00	1.26E+01	1.44E+01	Ni-63
MW-49-42	MW-49-42-(026)	26	11/4/2011	11:43	4.27E+00	1.30E+01	1.45E+01	Ni-63
MW-49-65	MW-49-65-(026)	26	11/4/2011	11:47	7.03E-01	1.21E+01	1.36E+01	Ni-63
MW-50-42	MW-50-42-(028)	28	10/27/2011	10:48	-5.76E+00	1.21E+01	1.41E+01	Ni-63
MW-50-66	MW-50-66-(033)	33	10/27/2011	10:53	-4.90E+00	1.66E+01	1.92E+01	Ni-63
MW-51-104	MW-51-104-(019)	19	12/12/2011	12:12	-3.91E+00	1.33E+01	1.51E+01	Ni-63
MW-51-135	MW-51-135-(019)	19	12/12/2011	12:50	-6.68E+00	1.18E+01	1.35E+01	Ni-63
MW-51-163	MW-51-163-(019)	19	12/12/2011	12:26	-3.59E+00	1.22E+01	1.38E+01	Ni-63
MW-51-189	MW-51-189-(019)	19	12/12/2011	12:23	-9.34E+00	1.94E+01	2.22E+01	Ni-63
MW-51-40	MW-51-40-(021)	21	12/12/2011	10:43	-3.48E+00	1.39E+01	1.58E+01	Ni-63
MW-51-79	MW-51-79-(021)	21	12/12/2011	11:09	-1.12E+00	1.13E+01	1.27E+01	Ni-63
MW-53-120	MW-53-120-(026)	26	11/2/2011	11:56	2.58E+00	1.93E+01	2.17E+01	Ni-63
MW-53-82	MW-53-82-(022)	22	11/2/2011	11:26	-4.95E-01	1.24E+01	1.41E+01	Ni-63
MW-54-123	MW-54-123-(020)	20	12/6/2011	10:37	5.81E+00	1.28E+01	1.41E+01	Ni-63
MW-54-144	MW-54-144-(020)	20	12/6/2011	13:25	-2.77E+00	1.22E+01	1.38E+01	Ni-63
MW-54-173	MW-54-173-(020)	20	12/6/2011	13:26	-2.75E+00	1.24E+01	1.41E+01	Ni-63
MW-54-190	MW-54-190-(020)	20	12/6/2011	13:38	3.28E+00	1.21E+01	1.34E+01	Ni-63
MW-54-37	MW-54-37-(020)	20	12/6/2011	10:37	-5.68E+00	1.25E+01	1.43E+01	Ni-63
MW-54-58	MW-54-58-(020)	20	12/6/2011	10:23	2.66E+00	1.25E+01	1.40E+01	Ni-63
MW-55-24	MW-55-24-(019)	19	11/14/2011	11:26	-7.45E+00	1.87E+01	2.17E+01	Ni-63
MW-55-35	MW-55-35-(018)	18	11/14/2011	11:23	4.79E+00	1.87E+01	2.09E+01	Ni-63
MW-55-54	MW-55-54-(019)	19	11/14/2011	11:07	1.62E+00	1.92E+01	2.17E+01	Ni-63
MW-56-53	MW-56-53-(013)	13	10/31/2011	12:13	4.96E+00	1.94E+01	2.17E+01	Ni-63
MW-56-83	MW-56-83-(015)	15	10/31/2011	12:00	-3.01E+00	2.14E+01	2.44E+01	Ni-63
MW-60-53	MW-60-53-(019)	19	12/2/2011	11:46	-3.05E+00	1.22E+01	1.39E+01	Ni-63
MW-66-21	MW-66-21-(019)	19	11/29/2011	11:08	-3.27E+00	1.37E+01	1.56E+01	Ni-63
MW-66-36	MW-66-36-(018)	18	11/29/2011	11:01	0.00E+00	1.94E+01	2.18E+01	Ni-63
MW-67-105	MW-67-105-(018)	18	11/29/2011	14:10	3.65E+00	1.97E+01	2.20E+01	Ni-63
MW-67-173	MW-67-173-(019)	19	11/29/2011	14:23	7.39E+00	1.18E+01	1.29E+01	Ni-63
MW-67-219	MW-67-219-(018)	18	11/29/2011	10:41	1.02E+01	1.13E+01	1.23E+01	Ni-63
MW-67-276	MW-67-276-(018)	18	11/29/2011	10:57	6.48E+00	1.19E+01	1.31E+01	Ni-63
MW-67-323	MW-67-323-(018)	18	11/29/2011	10:57	1.66E+01	2.34E+01	2.56E+01	Ni-63
MW-67-340	MW-67-340-(018)	18	11/29/2011	10:46	1.70E+00	1.06E+01	1.17E+01	Ni-63
MW-67-39	MW-67-39-(019)	19	11/29/2011	13:59	2.69E+00	1.24E+01	1.38E+01	Ni-63
U1-CSS	U1-CSS-(018)	18	10/27/2011	13:02	-8.01E+00	1.78E+01	2.07E+01	Ni-63
U1-NCD	U1-NCD-(012)	12	10/3/2011	13:20	1.36E+02	2.21E+01	1.86E+01	Ni-63
U1-NCD	U1-NCD-(013)	13	12/26/2011	12:45	1.96E+02	2.79E+01	1.88E+01	Ni-63
U1-SFDS	U1-SFDS-(014)	14	10/5/2011	9:00	2.06E+01	1.87E+01	2.00E+01	Ni-63
U1-SFDS	U1-SFDS-(015)	15	12/28/2011	8:19	-4.44E+00	1.47E+01	1.73E+01	Ni-63

IPEC00257775

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-6	B-6-(015)	15	10/20/2011	12:01	-1.65E-01	1.57E+00	1.98E+00	Sr-90
I-2	I-2-(004)	4	12/8/2011	14:15	-2.39E-01	1.56E+00	1.92E+00	Sr-90
LAF-002	LAF-002-(016)	16	12/13/2011	10:31	1.65E+00	1.67E+00	1.75E+00	Sr-90
MH-5	MH-5-(027)	27	10/17/2011	10:07	-5.57E-01	1.17E+00	1.65E+00	Sr-90
MH-5	MH-5-(028)	28	10/31/2011	14:20	1.06E+00	1.72E+00	1.87E+00	Sr-90
MW-111	MW-111-(036)	36	11/11/2011	11:30	1.09E+00	1.53E+00	1.62E+00	Sr-90
MW-30-69	MW-30-69-(042)	42	11/30/2011	11:20	-4.56E-01	1.51E+00	1.96E+00	Sr-90
MW-30-84	MW-30-84-(033)	33	11/30/2011	11:37	5.31E-02	1.45E+00	1.81E+00	Sr-90
MW-31-49	MW-31-49-(034)	34	11/21/2011	10:32	-3.16E-01	1.08E+00	1.45E+00	Sr-90
MW-31-63	MW-31-63-(034)	34	11/21/2011	11:14	1.36E+00	1.42E+00	1.40E+00	Sr-90
MW-31-85	MW-31-85-(034)	34	11/21/2011	11:25	9.56E-01	1.41E+00	1.50E+00	Sr-90
MW-32-149	MW-32-149-(028)	28	11/17/2011	12:05	3.84E-01	1.46E+00	1.72E+00	Sr-90
MW-32-173	MW-32-173-(026)	26	11/17/2011	12:01	7.83E-02	9.63E-01	1.24E+00	Sr-90
MW-32-190	MW-32-190-(030)	30	11/17/2011	12:03	-7.57E-01	8.37E-01	1.41E+00	Sr-90
MW-32-59	MW-32-59-(028)	28	11/17/2011	14:15	-1.28E+00	1.58E+00	2.33E+00	Sr-90
MW-32-85	MW-32-85-(031)	31	11/17/2011	15:08	4.57E-01	1.56E+00	1.82E+00	Sr-90
MW-36-24	MW-36-24-(024)	24	12/7/2011	11:04	-3.36E-01	1.29E+00	1.70E+00	Sr-90
MW-36-41	MW-36-41-(018)	18	12/7/2011	13:09	9.00E-01	1.71E+00	1.89E+00	Sr-90
MW-36-52	MW-36-52-(023)	23	12/7/2011	11:36	5.23E+00	1.96E+00	1.24E+00	Sr-90
MW-37-22	MW-37-22-(024)	24	11/23/2011	11:33	8.02E+00	2.57E+00	1.38E+00	Sr-90
MW-37-32	MW-37-32-(024)	24	11/23/2011	11:19	1.26E+01	3.21E+00	1.52E+00	Sr-90
MW-37-40	MW-37-40-(024)	24	11/23/2011	11:46	1.50E+01	3.45E+00	1.47E+00	Sr-90
MW-37-57	MW-37-57-(024)	24	11/23/2011	11:22	1.88E+01	3.90E+00	1.81E+00	Sr-90
MW-39-102	MW-39-102-(014)	14	12/1/2011	14:10	2.77E+00	2.06E+00	1.95E+00	Sr-90
MW-39-124	MW-39-124-(014)	14	12/1/2011	11:42	-2.58E-01	1.41E+00	1.82E+00	Sr-90
MW-39-183	MW-39-183-(014)	14	12/1/2011	11:26	1.34E-01	1.45E+00	1.80E+00	Sr-90
MW-39-195	MW-39-195-(014)	14	12/1/2011	11:28	3.00E-01	1.46E+00	1.75E+00	Sr-90
MW-39-67	MW-39-67-(014)	14	12/1/2011	14:04	2.37E+00	1.90E+00	1.76E+00	Sr-90
MW-39-84	MW-39-84-(014)	14	12/1/2011	14:17	3.12E+00	2.08E+00	1.81E+00	Sr-90
MW-40-100	MW-40-100-(020)	20	12/9/2011	10:28	1.04E+00	1.37E+00	1.41E+00	Sr-90
MW-40-127	MW-40-127-(020)	20	12/9/2011	10:40	1.27E+00	1.50E+00	1.51E+00	Sr-90
MW-40-162	MW-40-162-(018)	18	12/9/2011	11:02	6.89E-01	1.75E+00	1.95E+00	Sr-90
MW-40-27	MW-40-27-(017)	17	12/9/2011	11:50	1.74E-01	1.46E+00	1.77E+00	Sr-90
MW-40-46	MW-40-46-(018)	18	12/9/2011	12:03	2.87E-01	1.62E+00	1.92E+00	Sr-90
MW-40-81	MW-40-81-(018)	18	12/9/2011	10:23	3.77E-01	1.51E+00	1.79E+00	Sr-90
MW-41-40	MW-41-40-(023)	23	11/28/2011	14:25	6.83E-01	1.73E+00	1.95E+00	Sr-90
MW-41-63	MW-41-63-(022)	22	11/28/2011	14:08	6.76E-01	1.73E+00	1.95E+00	Sr-90
MW-42-49	MW-42-49-(028)	28	11/3/2011	11:13	8.98E-01	1.51E+00	1.65E+00	Sr-90
MW-42-78	MW-42-78-(023)	23	11/3/2011	11:31	-5.46E-02	1.15E+00	1.49E+00	Sr-90
MW-43-28	MW-43-28-(021)	21	11/22/2011	11:23	1.40E+00	1.81E+00	1.95E+00	Sr-90
MW-43-62	MW-43-62-(022)	22	11/22/2011	12:22	9.55E-01	1.78E+00	1.96E+00	Sr-90
MW-44-102	MW-44-102-(024)	24	12/1/2011	12:18	-2.13E-01	1.52E+00	1.93E+00	Sr-90
MW-44-66	MW-44-66-(023)	23	12/8/2011	12:00	-8.25E-01	1.44E+00	1.94E+00	Sr-90
MW-45-42	MW-45-42-(027)	27	11/28/2011	15:03	8.10E-01	1.75E+00	1.95E+00	Sr-90
MW-45-61	MW-45-61-(027)	27	11/28/2011	11:44	4.76E-01	1.70E+00	1.97E+00	Sr-90
MW-46	MW-46-(027)	27	10/20/2011	13:35	3.95E-01	1.30E+00	1.52E+00	Sr-90
MW-47-56	MW-47-56-(008)	8	10/28/2011	11:36	-6.21E-01	8.79E-01	1.40E+00	Sr-90
MW-47-80	MW-47-80-(007)	7	10/28/2011	13:24	2.13E+00	1.58E+00	1.38E+00	Sr-90
MW-49-26	MW-49-26-(026)	26	11/4/2011	11:50	1.27E+01	2.95E+00	1.25E+00	Sr-90
MW-49-42	MW-49-42-(026)	26	11/4/2011	11:43	2.11E+01	3.90E+00	1.51E+00	Sr-90
MW-49-65	MW-49-65-(026)	26	11/4/2011	11:47	2.02E+01	3.60E+00	1.47E+00	Sr-90
MW-50-42	MW-50-42-(028)	28	10/27/2011	10:48	3.02E+01	4.44E+00	1.54E+00	Sr-90
MW-50-66	MW-50-66-(033)	33	10/27/2011	10:53	2.68E+01	4.35E+00	1.59E+00	Sr-90
MW-51-104	MW-51-104-(019)	19	12/12/2011	12:12	1.23E+00	1.76E+00	1.85E+00	Sr-90
MW-51-135	MW-51-135-(019)	19	12/12/2011	12:50	2.67E-01	1.64E+00	1.94E+00	Sr-90
MW-51-163	MW-51-163-(019)	19	12/12/2011	12:26	1.58E+00	1.81E+00	1.94E+00	Sr-90
MW-51-189	MW-51-189-(019)	19	12/12/2011	12:23	-3.94E-01	1.43E+00	1.91E+00	Sr-90
MW-51-40	MW-51-40-(021)	21	12/12/2011	10:43	-7.34E-01	1.58E+00	1.94E+00	Sr-90
MW-51-79	MW-51-79-(021)	21	12/12/2011	11:09	-1.38E-01	1.52E+00	1.90E+00	Sr-90
MW-53-120	MW-53-120-(026)	26	11/2/2011	11:56	4.05E+01	5.16E+00	1.52E+00	Sr-90
MW-53-82	MW-53-82-(022)	22	11/2/2011	11:26	-2.42E-01	1.09E+00	1.49E+00	Sr-90
MW-54-123	MW-54-123-(020)	20	12/6/2011	10:37	1.55E+00	1.86E+00	1.95E+00	Sr-90
MW-54-144	MW-54-144-(020)	20	12/6/2011	13:25	9.05E+00	2.99E+00	1.96E+00	Sr-90
MW-54-173	MW-54-173-(020)	20	12/6/2011	13:26	4.72E+00	2.32E+00	1.97E+00	Sr-90

IPEC00257776

MW-54-190	MW-54-190-(020)	20	12/6/2011	13:38	1.81E+01	3.72E+00	1.90E+00	Sr-90
MW-54-37	MW-54-37-(020)	20	12/6/2011	10:37	4.48E+00	2.07E+00	1.92E+00	Sr-90
MW-54-58	MW-54-58-(020)	20	12/6/2011	10:23	1.60E+00	1.80E+00	1.91E+00	Sr-90
MW-55-24	MW-55-24-(019)	19	11/14/2011	11:26	2.33E+01	4.08E+00	1.56E+00	Sr-90
MW-55-35	MW-55-35-(018)	18	11/14/2011	11:23	2.35E+01	3.99E+00	1.60E+00	Sr-90
MW-55-54	MW-55-54-(019)	19	11/14/2011	11:07	1.75E+01	3.57E+00	1.46E+00	Sr-90
MW-56-53	MW-56-53-(013)	13	10/31/2011	12:13	5.82E-02	1.09E+00	1.39E+00	Sr-90
MW-56-83	MW-56-83-(015)	15	10/31/2011	12:00	9.41E-01	1.49E+00	1.61E+00	Sr-90
MW-58-26	MW-58-26-(015)	15	11/15/2011	14:22	-4.32E-01	8.28E-01	1.25E+00	Sr-90
MW-58-65	MW-58-65-(015)	15	11/15/2011	14:05	3.02E-01	1.71E+00	2.03E+00	Sr-90
MW-60-135	MW-60-135-(019)	19	12/2/2011	10:10	-1.48E-01	1.62E+00	1.97E+00	Sr-90
MW-60-154	MW-60-154-(019)	19	12/2/2011	10:18	-1.97E-01	1.54E+00	1.96E+00	Sr-90
MW-60-176	MW-60-176-(019)	19	12/2/2011	10:27	-1.37E+00	1.41E+00	1.95E+00	Sr-90
MW-60-35	MW-60-35-(019)	19	12/2/2011	11:21	3.94E-01	1.72E+00	1.98E+00	Sr-90
MW-60-53	MW-60-53-(019)	19	12/2/2011	11:46	9.60E-02	1.69E+00	1.97E+00	Sr-90
MW-60-72	MW-60-72-(019)	19	12/2/2011	10:01	8.41E-01	1.73E+00	1.93E+00	Sr-90
MW-62-138	MW-62-138-(020)	20	10/21/2011	11:29	1.24E+00	1.48E+00	1.50E+00	Sr-90
MW-62-18	MW-62-18-(020)	20	10/21/2011	10:14	-1.09E+00	1.66E+00	2.27E+00	Sr-90
MW-62-182	MW-62-182-(020)	20	10/21/2011	11:37	-2.48E-01	1.45E+00	1.90E+00	Sr-90
MW-62-37	MW-62-37-(020)	20	10/21/2011	10:02	-3.24E-01	1.60E+00	2.05E+00	Sr-90
MW-62-53	MW-62-53-(019)	19	10/21/2011	10:17	-1.78E-02	1.24E+00	1.61E+00	Sr-90
MW-62-71	MW-62-71-(020)	20	10/21/2011	9:44	-1.43E-01	1.29E+00	1.69E+00	Sr-90
MW-62-92	MW-62-92-(020)	20	10/21/2011	9:42	4.45E-01	1.27E+00	1.48E+00	Sr-90
MW-63-112	MW-63-112-(020)	20	10/18/2011	14:20	-5.35E-01	1.39E+00	1.87E+00	Sr-90
MW-63-121	MW-63-121-(020)	20	10/18/2011	11:27	1.49E+00	1.71E+00	1.75E+00	Sr-90
MW-63-163	MW-63-163-(020)	20	10/18/2011	11:37	9.47E-01	1.35E+00	1.43E+00	Sr-90
MW-63-174	MW-63-174-(020)	20	10/18/2011	11:42	1.02E+00	1.71E+00	1.86E+00	Sr-90
MW-63-18	MW-63-18-(020)	20	10/18/2011	11:34	1.26E+00	1.74E+00	1.83E+00	Sr-90
MW-63-34	MW-63-34-(020)	20	10/18/2011	11:39	-4.71E-01	1.27E+00	1.78E+00	Sr-90
MW-63-50	MW-63-50-(020)	20	10/18/2011	13:55	4.62E-01	1.68E+00	1.94E+00	Sr-90
MW-63-93	MW-63-93-(021)	21	10/18/2011	14:14	5.60E-01	1.37E+00	1.56E+00	Sr-90
MW-66-21	MW-66-21-(019)	19	11/29/2011	11:08	3.54E-01	1.33E+00	1.49E+00	Sr-90
MW-66-36	MW-66-36-(018)	18	11/29/2011	11:01	1.02E+01	1.77E+00	1.38E+00	Sr-90
MW-67-105	MW-67-105-(018)	18	11/29/2011	14:10	1.13E+00	1.74E+00	1.90E+00	Sr-90
MW-67-173	MW-67-173-(019)	19	11/29/2011	14:23	1.13E+00	1.62E+00	1.76E+00	Sr-90
MW-67-219	MW-67-219-(018)	18	11/29/2011	10:41	3.14E-01	1.42E+00	1.63E+00	Sr-90
MW-67-276	MW-67-276-(018)	18	11/29/2011	10:57	1.99E-01	1.70E+00	1.95E+00	Sr-90
MW-67-323	MW-67-323-(018)	18	11/29/2011	10:57	7.61E-01	1.71E+00	1.91E+00	Sr-90
MW-67-340	MW-67-340-(018)	18	11/29/2011	10:46	-5.80E-01	1.53E+00	1.87E+00	Sr-90
MW-67-39	MW-67-39-(019)	19	11/29/2011	13:59	1.30E+01	2.39E+00	1.94E+00	Sr-90
U1-CSS	U1-CSS-(018)	18	10/27/2011	13:02	7.82E-01	1.28E+00	1.39E+00	Sr-90
U1-NCD	U1-NCD-(012)	12	10/3/2011	13:20	1.58E+01	3.72E+00	1.74E+00	Sr-90
U1-NCD	U1-NCD-(013)	13	12/26/2011	12:45	1.49E+01	5.52E+00	3.33E+00	Sr-90
U1-SFDS	U1-SFDS-(014)	14	10/5/2011	9:00	5.54E+00	2.53E+00	1.97E+00	Sr-90
U1-SFDS	U1-SFDS-(015)	15	12/28/2011	8:19	2.66E+00	2.22E+00	2.08E+00	Sr-90
U3-4D	U3-4D-(031)	31	11/16/2011	12:56	3.17E-01	1.38E+00	1.64E+00	Sr-90
U3-4S	U3-4S-(006)	6	11/16/2011	11:28	9.35E-01	1.38E+00	1.47E+00	Sr-90
U3-T1	U3-T1-(034)	34	10/19/2011	11:39	1.59E-01	1.19E+00	1.45E+00	Sr-90
U3-T2	U3-T2-(040)	40	10/19/2011	10:20	-8.79E-02	1.15E+00	1.47E+00	Sr-90

IPEC00257777