

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-1	B-1-(012)	12	4/25/2011	10:50	3.18E+00	9.06E+00	1.11E+01	Co-60
B-6	B-6-(012)	12	4/25/2011	9:48	4.73E+00	1.06E+01	1.35E+01	Co-60
LAF-002	LAF-002-(015)	15	5/2/2011	12:50	-6.46E-01	7.24E+00	7.65E+00	Co-60
MH-5	MH-5-(015)	15	4/22/2011	13:37	-1.60E+00	9.06E+00	9.51E+00	Co-60
MW-107	MW-107-(010)	10	5/2/2011	9:25	2.39E+00	6.84E+00	8.63E+00	Co-60
MW-30-69	MW-30-69-(039)	39	5/5/2011	12:08	2.21E+00	9.58E+00	1.16E+01	Co-60
MW-30-84	MW-30-84-(030)	30	5/5/2011	12:58	4.65E-02	7.14E+00	7.76E+00	Co-60
MW-31-49	MW-31-49-(031)	31	4/18/2011	12:53	6.17E+00	8.70E+00	1.13E+01	Co-60
MW-31-63	MW-31-63-(031)	31	4/18/2011	13:21	1.76E+00	8.74E+00	1.03E+01	Co-60
MW-31-85	MW-31-85-(031)	31	4/18/2011	13:18	3.84E+00	1.01E+01	1.22E+01	Co-60
MW-32-149	MW-32-149-(025)	25	4/27/2011	11:12	9.88E-01	7.76E+00	8.83E+00	Co-60
MW-32-173	MW-32-173-(023)	23	4/27/2011	11:27	2.47E-01	9.58E+00	1.07E+01	Co-60
MW-32-190	MW-32-190-(027)	27	4/27/2011	11:17	-6.60E+00	8.98E+00	6.37E+00	Co-60
MW-32-59	MW-32-59-(025)	25	4/27/2011	12:26	-3.37E+00	9.58E+00	9.50E+00	Co-60
MW-32-85	MW-32-85-(028)	28	4/27/2011	13:04	5.30E-01	1.02E+01	1.15E+01	Co-60
MW-36-24	MW-36-24-(022)	22	4/28/2011	14:34	2.82E+00	7.48E+00	9.35E+00	Co-60
MW-36-41	MW-36-41-(016)	16	4/28/2011	15:39	-2.96E-01	1.04E+01	1.12E+01	Co-60
MW-36-52	MW-36-52-(021)	21	4/28/2011	14:38	-2.61E+00	8.50E+00	8.36E+00	Co-60
MW-37-22	MW-37-22-(022)	22	4/28/2011	12:05	5.14E-01	7.86E+00	8.62E+00	Co-60
MW-37-32	MW-37-32-(022)	22	4/28/2011	12:21	-1.92E+00	1.09E+01	1.09E+01	Co-60
MW-37-40	MW-37-40-(022)	22	4/28/2011	11:31	6.47E-01	8.94E+00	1.02E+01	Co-60
MW-37-57	MW-37-57-(022)	22	4/28/2011	12:17	-1.42E+00	8.36E+00	8.80E+00	Co-60
MW-39-102	MW-39-102-(011)	11	4/26/2011	14:33	6.03E+00	7.96E+00	1.07E+01	Co-60
MW-39-124	MW-39-124-(011)	11	4/26/2011	13:01	3.07E+00	7.52E+00	9.27E+00	Co-60
MW-39-183	MW-39-183-(011)	11	4/26/2011	11:35	-1.52E+00	8.68E+00	8.94E+00	Co-60
MW-39-195	MW-39-195-(011)	11	4/26/2011	12:38	4.62E+00	8.70E+00	1.13E+01	Co-60
MW-39-67	MW-39-67-(011)	11	4/26/2011	14:52	-4.05E+00	9.42E+00	9.00E+00	Co-60
MW-39-84	MW-39-84-(011)	11	4/26/2011	14:25	-4.02E-01	6.92E+00	7.41E+00	Co-60
MW-40-100	MW-40-100-(018)	18	4/29/2011	11:27	2.99E+00	7.96E+00	9.80E+00	Co-60
MW-40-127	MW-40-127-(018)	18	4/29/2011	11:26	-1.62E+00	9.68E+00	9.87E+00	Co-60
MW-40-162	MW-40-162-(016)	16	4/29/2011	12:26	4.43E-01	9.50E+00	1.08E+01	Co-60
MW-40-27	MW-40-27-(015)	15	4/29/2011	13:29	-9.20E-01	9.86E+00	1.15E+01	Co-60
MW-40-46	MW-40-46-(016)	16	4/29/2011	13:31	-3.98E+00	9.84E+00	9.04E+00	Co-60
MW-40-81	MW-40-81-(016)	16	4/29/2011	11:08	-2.66E-01	8.04E+00	8.83E+00	Co-60
MW-41-40	MW-41-40-(020)	20	4/20/2011	13:51	3.02E+00	1.06E+01	1.25E+01	Co-60
MW-41-63	MW-41-63-(019)	19	4/20/2011	13:13	4.02E+00	8.74E+00	1.09E+01	Co-60
MW-42-49	MW-42-49-(025)	25	4/21/2011	14:04	3.41E+00	9.16E+00	1.09E+01	Co-60
MW-42-78	MW-42-78-(020)	20	4/21/2011	13:45	3.58E+00	8.56E+00	1.11E+01	Co-60
MW-43-28	MW-43-28-(019)	19	4/21/2011	11:15	4.50E+00	8.60E+00	1.09E+01	Co-60
MW-43-62	MW-43-62-(019)	19	4/21/2011	11:00	-2.34E+00	8.70E+00	8.43E+00	Co-60
MW-44-102	MW-44-102-(021)	21	4/26/2011	12:18	-2.06E+00	7.86E+00	7.82E+00	Co-60
MW-44-66	MW-44-66-(020)	20	4/26/2011	13:17	3.29E+00	1.07E+01	1.31E+01	Co-60
MW-45-42	MW-45-42-(024)	24	4/20/2011	14:09	7.13E+00	1.07E+01	1.29E+01	Co-60
MW-45-61	MW-45-61-(024)	24	4/20/2011	10:07	-8.47E-01	7.56E+00	7.91E+00	Co-60
MW-46	MW-46-(024)	24	4/25/2011	11:19	-4.44E+00	7.44E+00	6.77E+00	Co-60
MW-49-26	MW-49-26-(024)	24	4/15/2011	11:58	4.03E+00	1.20E+01	1.47E+01	Co-60
MW-49-42	MW-49-42-(024)	24	4/15/2011	11:55	1.15E-01	7.72E+00	8.33E+00	Co-60
MW-49-65	MW-49-65-(024)	24	4/15/2011	11:50	4.62E-02	1.01E+01	1.10E+01	Co-60
MW-50-42	MW-50-42-(025)	25	5/3/2011	12:05	5.79E-01	1.02E+01	1.16E+01	Co-60
MW-50-66	MW-50-66-(030)	30	5/3/2011	12:07	-2.32E+00	9.06E+00	9.12E+00	Co-60
MW-51-104	MW-51-104-(017)	17	4/29/2011	12:35	-6.79E-01	1.10E+01	1.20E+01	Co-60
MW-51-135	MW-51-135-(017)	17	4/29/2011	13:16	-5.69E-01	9.00E+00	9.56E+00	Co-60
MW-51-163	MW-51-163-(017)	17	4/29/2011	13:19	9.25E-01	7.72E+00	8.87E+00	Co-60
MW-51-189	MW-51-189-(017)	17	4/29/2011	12:52	-5.07E+00	9.48E+00	8.89E+00	Co-60
MW-51-40	MW-51-40-(019)	19	4/29/2011	10:41	6.20E+00	1.11E+01	1.40E+01	Co-60
MW-51-79	MW-51-79-(019)	19	4/29/2011	10:57	-8.38E-01	8.08E+00	8.53E+00	Co-60
MW-52-11	MW-52-11-(006)	6	4/22/2011	12:10	5.08E+00	9.92E+00	1.24E+01	Co-60
MW-52-122	MW-52-122-(006)	6	4/22/2011	10:45	-1.96E+00	7.96E+00	7.90E+00	Co-60
MW-52-162	MW-52-162-(006)	6	4/22/2011	10:18	1.95E-02	1.00E+01	1.10E+01	Co-60
MW-52-18	MW-52-18-(006)	6	4/22/2011	12:16	-1.49E+00	9.44E+00	9.90E+00	Co-60
MW-52-181	MW-52-181-(006)	6	4/22/2011	10:22	-1.09E+00	1.22E+01	1.30E+01	Co-60
MW-52-48	MW-52-48-(006)	6	4/22/2011	12:18	1.35E+00	7.80E+00	9.17E+00	Co-60
MW-52-64	MW-52-64-(006)	6	4/22/2011	15:23	-8.05E+00	8.28E+00	6.18E+00	Co-60
MW-53-120	MW-53-120-(023)	23	4/18/2011	11:52	4.87E-01	9.24E+00	1.02E+01	Co-60

IPEC00233539

MW-53-82	MW-53-82-(019)	19	4/18/2011	12:45	3.12E+00	8.78E+00	1.07E+01	Co-60
MW-54-123	MW-54-123-(017)	17	4/12/2011	12:22	1.86E+00	8.04E+00	9.55E+00	Co-60
MW-54-144	MW-54-144-(017)	17	4/12/2011	9:50	-4.68E+00	9.58E+00	8.86E+00	Co-60
MW-54-173	MW-54-173-(017)	17	4/12/2011	9:56	5.93E+00	9.66E+00	1.25E+01	Co-60
MW-54-190	MW-54-190-(017)	17	4/12/2011	10:01	8.70E-01	9.00E+00	1.00E+01	Co-60
MW-54-37	MW-54-37-(017)	17	4/12/2011	12:02	2.50E+00	8.26E+00	9.96E+00	Co-60
MW-54-58	MW-54-58-(017)	17	4/12/2011	12:04	1.14E+00	8.74E+00	9.95E+00	Co-60
MW-56-53	MW-56-53-(010)	10	4/27/2011	12:08	-1.64E+00	8.42E+00	8.44E+00	Co-60
MW-56-83	MW-56-83-(012)	12	4/27/2011	13:46	-1.27E+00	9.50E+00	1.01E+01	Co-60
MW-57-11	MW-57-11-(007)	7	5/4/2011	10:28	2.05E+00	8.40E+00	9.72E+00	Co-60
MW-57-20	MW-57-20-(007)	7	5/4/2011	10:37	-7.32E-01	9.22E+00	1.02E+01	Co-60
MW-57-45	MW-57-45-(008)	8	5/4/2011	11:03	-1.84E+00	9.48E+00	9.59E+00	Co-60
MW-58-26	MW-58-26-(012)	12	5/3/2011	9:58	-6.42E+00	9.02E+00	8.00E+00	Co-60
MW-58-65	MW-58-65-(012)	12	5/3/2011	10:11	-7.81E-01	7.04E+00	7.26E+00	Co-60
MW-60-135	MW-60-135-(017)	17	4/15/2011	13:25	-2.48E+00	9.86E+00	1.01E+01	Co-60
MW-60-154	MW-60-154-(017)	17	4/15/2011	13:19	-7.25E-01	6.50E+00	6.79E+00	Co-60
MW-60-176	MW-60-176-(017)	17	4/15/2011	13:49	-2.35E+00	1.02E+01	1.03E+01	Co-60
MW-60-35	MW-60-35-(017)	17	4/15/2011	11:36	-8.48E-01	9.58E+00	1.03E+01	Co-60
MW-60-53	MW-60-53-(017)	17	4/15/2011	11:37	-1.11E+00	8.68E+00	8.95E+00	Co-60
MW-60-72	MW-60-72-(017)	17	4/15/2011	13:12	-3.30E+00	1.14E+01	1.14E+01	Co-60
MW-62-138	MW-62-138-(017)	17	4/13/2011	14:39	1.71E+00	8.82E+00	1.02E+01	Co-60
MW-62-18	MW-62-18-(017)	17	4/13/2011	11:58	-4.07E-01	1.06E+01	1.16E+01	Co-60
MW-62-182	MW-62-182-(017)	17	4/13/2011	14:44	-9.44E-01	1.08E+01	1.15E+01	Co-60
MW-62-37	MW-62-37-(017)	17	4/13/2011	12:10	-1.68E+00	9.02E+00	9.05E+00	Co-60
MW-62-53	MW-62-53-(016)	16	4/13/2011	11:32	-3.00E-01	6.24E+00	6.58E+00	Co-60
MW-62-71	MW-62-71-(017)	17	4/13/2011	11:15	-2.38E+00	8.50E+00	8.56E+00	Co-60
MW-62-92	MW-62-92-(017)	17	4/13/2011	11:03	-2.10E+00	8.94E+00	8.88E+00	Co-60
MW-63-112	MW-63-112-(017)	17	4/19/2011	11:25	1.64E+00	1.17E+01	1.36E+01	Co-60
MW-63-121	MW-63-121-(017)	17	4/19/2011	9:54	-1.09E+01	9.86E+00	5.99E+00	Co-60
MW-63-163	MW-63-163-(017)	17	4/19/2011	9:49	4.78E+00	1.02E+01	1.26E+01	Co-60
MW-63-174	MW-63-174-(017)	17	4/19/2011	9:52	-9.85E-01	8.58E+00	9.20E+00	Co-60
MW-63-18	MW-63-18-(017)	17	4/19/2011	10:35	-3.22E+00	8.16E+00	7.75E+00	Co-60
MW-63-34	MW-63-34-(017)	17	4/19/2011	10:25	3.72E+00	8.28E+00	1.02E+01	Co-60
MW-63-50	MW-63-50-(017)	17	4/19/2011	11:25	3.72E+00	8.18E+00	1.03E+01	Co-60
MW-63-93	MW-63-93-(018)	18	4/19/2011	11:27	-4.35E-01	6.80E+00	7.25E+00	Co-60
MW-66-21	MW-66-21-(017)	17	4/14/2011	13:43	6.94E+00	9.82E+00	1.25E+01	Co-60
MW-66-36	MW-66-36-(016)	16	4/14/2011	12:53	5.40E-01	7.92E+00	9.01E+00	Co-60
MW-67-105	MW-67-105-(016)	16	4/14/2011	13:43	-1.91E-01	7.24E+00	7.88E+00	Co-60
MW-67-173	MW-67-173-(017)	17	4/14/2011	14:09	-9.27E+00	1.03E+01	6.85E+00	Co-60
MW-67-219	MW-67-219-(016)	16	4/14/2011	10:49	4.16E+00	9.78E+00	1.20E+01	Co-60
MW-67-276	MW-67-276-(016)	16	4/14/2011	10:53	1.62E+00	1.02E+01	1.15E+01	Co-60
MW-67-323	MW-67-323-(016)	16	4/14/2011	11:33	-1.12E+00	7.80E+00	8.21E+00	Co-60
MW-67-340	MW-67-340-(016)	16	4/14/2011	11:17	4.57E+00	9.02E+00	1.15E+01	Co-60
MW-67-39	MW-67-39-(017)	17	4/14/2011	13:25	3.71E+00	9.54E+00	1.14E+01	Co-60
U1-CSS	U1-CSS-(016)	16	5/4/2011	13:24	7.12E+00	9.42E+00	1.24E+01	Co-60
U3-4D	U3-4D-(028)	28	4/25/2011	14:50	4.81E-01	7.14E+00	8.11E+00	Co-60
U3-4S	U3-4S-(003)	3	4/25/2011	14:13	1.75E+00	8.92E+00	1.03E+01	Co-60
U3-T1	U3-T1-(032)	32	5/6/2011	10:23	8.49E-01	1.09E+01	1.21E+01	Co-60
U3-T2	U3-T2-(037)	37	5/6/2011	11:41	5.77E-01	9.68E+00	1.08E+01	Co-60

IPEC00233540

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-1	B-1-(012)	12	4/25/2011	10:50	2.05E+01	1.33E+01	1.03E+01	Cs-137
B-6	B-6-(012)	12	4/25/2011	9:48	-1.31E-01	8.56E+00	9.08E+00	Cs-137
LAF-002	LAF-002-(015)	15	5/2/2011	12:50	-5.80E-01	7.86E+00	8.57E+00	Cs-137
MH-5	MH-5-(015)	15	4/22/2011	13:37	-3.21E+00	8.36E+00	8.43E+00	Cs-137
MW-107	MW-107-(010)	10	5/2/2011	9:25	-3.56E+00	1.30E+01	1.65E+01	Cs-137
MW-30-69	MW-30-69-(039)	39	5/5/2011	12:08	2.46E+00	8.92E+00	1.03E+01	Cs-137
MW-30-84	MW-30-84-(030)	30	5/5/2011	12:58	3.00E+00	8.04E+00	9.35E+00	Cs-137
MW-31-49	MW-31-49-(031)	31	4/18/2011	12:53	-1.82E+00	8.82E+00	9.22E+00	Cs-137
MW-31-63	MW-31-63-(031)	31	4/18/2011	13:21	-3.10E-01	7.62E+00	8.46E+00	Cs-137
MW-31-85	MW-31-85-(031)	31	4/18/2011	13:18	-4.50E+00	9.34E+00	9.19E+00	Cs-137
MW-32-149	MW-32-149-(025)	25	4/27/2011	11:12	2.12E+00	7.44E+00	8.59E+00	Cs-137
MW-32-173	MW-32-173-(023)	23	4/27/2011	11:27	0.00E+00	2.00E+01	9.23E+00	Cs-137
MW-32-190	MW-32-190-(027)	27	4/27/2011	11:17	8.61E-01	8.68E+00	9.74E+00	Cs-137
MW-32-59	MW-32-59-(025)	25	4/27/2011	12:26	4.77E+00	8.64E+00	1.04E+01	Cs-137
MW-32-85	MW-32-85-(028)	28	4/27/2011	13:04	-1.23E+00	6.80E+00	7.31E+00	Cs-137
MW-36-24	MW-36-24-(022)	22	4/28/2011	14:34	-6.43E-01	7.68E+00	8.47E+00	Cs-137
MW-36-41	MW-36-41-(016)	16	4/28/2011	15:39	2.18E+00	9.26E+00	1.07E+01	Cs-137
MW-36-52	MW-36-52-(021)	21	4/28/2011	14:38	4.29E+00	8.42E+00	1.03E+01	Cs-137
MW-37-22	MW-37-22-(022)	22	4/28/2011	12:05	7.12E-01	6.96E+00	7.67E+00	Cs-137
MW-37-32	MW-37-32-(022)	22	4/28/2011	12:21	3.56E+00	1.20E+01	1.42E+01	Cs-137
MW-37-40	MW-37-40-(022)	22	4/28/2011	11:31	4.10E+00	9.02E+00	1.09E+01	Cs-137
MW-37-57	MW-37-57-(022)	22	4/28/2011	12:17	5.18E+00	1.72E+01	8.67E+00	Cs-137
MW-39-102	MW-39-102-(011)	11	4/26/2011	14:33	4.48E+00	2.08E+01	9.86E+00	Cs-137
MW-39-124	MW-39-124-(011)	11	4/26/2011	13:01	9.13E+00	8.56E+00	8.57E+00	Cs-137
MW-39-183	MW-39-183-(011)	11	4/26/2011	11:35	6.46E+00	8.88E+00	1.09E+01	Cs-137
MW-39-195	MW-39-195-(011)	11	4/26/2011	12:38	-2.03E+00	1.11E+01	1.28E+01	Cs-137
MW-39-67	MW-39-67-(011)	11	4/26/2011	14:52	-8.12E-01	8.22E+00	8.78E+00	Cs-137
MW-39-84	MW-39-84-(011)	11	4/26/2011	14:25	-9.39E-01	7.42E+00	7.84E+00	Cs-137
MW-40-100	MW-40-100-(018)	18	4/29/2011	11:27	5.53E+00	7.14E+00	9.23E+00	Cs-137
MW-40-127	MW-40-127-(018)	18	4/29/2011	11:26	-2.13E-01	8.26E+00	8.83E+00	Cs-137
MW-40-162	MW-40-162-(016)	16	4/29/2011	12:26	4.54E+00	1.23E+01	1.42E+01	Cs-137
MW-40-27	MW-40-27-(015)	15	4/29/2011	13:29	1.91E+00	8.40E+00	9.77E+00	Cs-137
MW-40-46	MW-40-46-(016)	16	4/29/2011	13:31	-9.96E-01	8.46E+00	9.00E+00	Cs-137
MW-40-81	MW-40-81-(016)	16	4/29/2011	11:08	3.05E+00	6.90E+00	8.51E+00	Cs-137
MW-41-40	MW-41-40-(020)	20	4/20/2011	13:51	2.20E+00	9.22E+00	1.06E+01	Cs-137
MW-41-63	MW-41-63-(019)	19	4/20/2011	13:13	3.53E+00	8.52E+00	1.01E+01	Cs-137
MW-42-49	MW-42-49-(025)	25	4/21/2011	14:04	2.15E+04	2.88E+03	2.08E+01	Cs-137
MW-42-78	MW-42-78-(020)	20	4/21/2011	13:45	-9.71E-01	9.16E+00	9.83E+00	Cs-137
MW-43-28	MW-43-28-(019)	19	4/21/2011	11:15	-9.31E-01	8.74E+00	9.22E+00	Cs-137
MW-43-62	MW-43-62-(019)	19	4/21/2011	11:00	-1.90E+00	9.08E+00	9.35E+00	Cs-137
MW-44-102	MW-44-102-(021)	21	4/26/2011	12:18	3.59E-01	7.42E+00	8.15E+00	Cs-137
MW-44-66	MW-44-66-(020)	20	4/26/2011	13:17	-1.14E-01	9.36E+00	1.03E+01	Cs-137
MW-45-42	MW-45-42-(024)	24	4/20/2011	14:09	7.04E-01	6.50E+00	7.46E+00	Cs-137
MW-45-61	MW-45-61-(024)	24	4/20/2011	10:07	-4.02E+00	7.76E+00	7.55E+00	Cs-137
MW-46	MW-46-(024)	24	4/25/2011	11:19	-2.48E+00	7.24E+00	7.06E+00	Cs-137
MW-49-26	MW-49-26-(024)	24	4/15/2011	11:58	4.75E+00	1.07E+01	1.27E+01	Cs-137
MW-49-42	MW-49-42-(024)	24	4/15/2011	11:55	-6.72E+00	7.62E+00	6.17E+00	Cs-137
MW-49-65	MW-49-65-(024)	24	4/15/2011	11:50	2.59E+00	9.66E+00	1.12E+01	Cs-137
MW-50-42	MW-50-42-(025)	25	5/3/2011	12:05	1.92E+00	9.44E+00	1.07E+01	Cs-137
MW-50-66	MW-50-66-(030)	30	5/3/2011	12:07	0.00E+00	1.77E+01	9.05E+00	Cs-137
MW-51-104	MW-51-104-(017)	17	4/29/2011	12:35	-1.90E+00	1.08E+01	1.25E+01	Cs-137
MW-51-135	MW-51-135-(017)	17	4/29/2011	13:16	2.52E+00	1.01E+01	1.17E+01	Cs-137
MW-51-163	MW-51-163-(017)	17	4/29/2011	13:19	2.26E+00	8.40E+00	9.72E+00	Cs-137
MW-51-189	MW-51-189-(017)	17	4/29/2011	12:52	-8.07E-01	5.82E+00	6.25E+00	Cs-137
MW-51-40	MW-51-40-(019)	19	4/29/2011	10:41	-3.40E+00	9.48E+00	9.62E+00	Cs-137
MW-51-79	MW-51-79-(019)	19	4/29/2011	10:57	-4.93E-01	7.56E+00	8.23E+00	Cs-137
MW-52-11	MW-52-11-(006)	6	4/22/2011	12:10	2.27E+00	1.02E+01	1.17E+01	Cs-137
MW-52-122	MW-52-122-(006)	6	4/22/2011	10:45	3.48E+01	2.08E+01	9.71E+00	Cs-137
MW-52-162	MW-52-162-(006)	6	4/22/2011	10:18	1.47E+00	8.40E+00	9.68E+00	Cs-137
MW-52-18	MW-52-18-(006)	6	4/22/2011	12:16	8.81E+00	1.29E+01	9.01E+00	Cs-137
MW-52-181	MW-52-181-(006)	6	4/22/2011	10:22	6.46E+01	2.68E+01	1.22E+01	Cs-137
MW-52-48	MW-52-48-(006)	6	4/22/2011	12:18	-4.59E+00	7.58E+00	7.31E+00	Cs-137
MW-52-64	MW-52-64-(006)	6	4/22/2011	15:23	1.87E+00	6.72E+00	7.70E+00	Cs-137
MW-53-120	MW-53-120-(023)	23	4/18/2011	11:52	1.38E+00	8.82E+00	9.99E+00	Cs-137

IPEC00233541

MW-53-82	MW-53-82-(019)	19	4/18/2011	12:45	-4.57E+00	9.82E+00	9.80E+00	Cs-137
MW-54-123	MW-54-123-(017)	17	4/12/2011	12:22	-5.24E+00	8.14E+00	7.60E+00	Cs-137
MW-54-144	MW-54-144-(017)	17	4/12/2011	9:50	6.43E+00	7.44E+00	9.59E+00	Cs-137
MW-54-173	MW-54-173-(017)	17	4/12/2011	9:56	-1.29E+01	1.38E+01	1.53E+01	Cs-137
MW-54-190	MW-54-190-(017)	17	4/12/2011	10:01	3.33E+00	7.86E+00	9.23E+00	Cs-137
MW-54-37	MW-54-37-(017)	17	4/12/2011	12:02	2.95E+00	8.26E+00	9.69E+00	Cs-137
MW-54-58	MW-54-58-(017)	17	4/12/2011	12:04	1.70E+00	8.58E+00	9.66E+00	Cs-137
MW-56-53	MW-56-53-(010)	10	4/27/2011	12:08	3.04E+00	8.50E+00	1.01E+01	Cs-137
MW-56-83	MW-56-83-(012)	12	4/27/2011	13:46	-1.05E+00	1.14E+01	1.33E+01	Cs-137
MW-57-11	MW-57-11-(007)	7	5/4/2011	10:28	3.74E+00	8.32E+00	9.74E+00	Cs-137
MW-57-20	MW-57-20-(007)	7	5/4/2011	10:37	1.48E+00	7.52E+00	8.43E+00	Cs-137
MW-57-45	MW-57-45-(008)	8	5/4/2011	11:03	7.40E+00	9.54E+00	1.21E+01	Cs-137
MW-58-26	MW-58-26-(012)	12	5/3/2011	9:58	2.29E+00	5.80E+00	6.89E+00	Cs-137
MW-58-65	MW-58-65-(012)	12	5/3/2011	10:11	1.93E+00	5.92E+00	7.00E+00	Cs-137
MW-60-135	MW-60-135-(017)	17	4/15/2011	13:25	-6.83E+00	1.39E+01	1.63E+01	Cs-137
MW-60-154	MW-60-154-(017)	17	4/15/2011	13:19	-2.09E+00	7.62E+00	7.82E+00	Cs-137
MW-60-176	MW-60-176-(017)	17	4/15/2011	13:49	-7.83E-02	9.90E+00	1.10E+01	Cs-137
MW-60-35	MW-60-35-(017)	17	4/15/2011	11:36	2.46E+00	1.14E+01	8.95E+00	Cs-137
MW-60-53	MW-60-53-(017)	17	4/15/2011	11:37	2.17E+00	9.90E+00	1.14E+01	Cs-137
MW-60-72	MW-60-72-(017)	17	4/15/2011	13:12	-5.14E+00	6.54E+00	5.80E+00	Cs-137
MW-62-138	MW-62-138-(017)	17	4/13/2011	14:39	1.29E+00	9.08E+00	1.04E+01	Cs-137
MW-62-18	MW-62-18-(017)	17	4/13/2011	11:58	-4.38E+00	1.00E+01	1.09E+01	Cs-137
MW-62-182	MW-62-182-(017)	17	4/13/2011	14:44	5.54E+00	8.70E+00	1.09E+01	Cs-137
MW-62-37	MW-62-37-(017)	17	4/13/2011	12:10	-4.48E+00	8.32E+00	7.76E+00	Cs-137
MW-62-53	MW-62-53-(016)	16	4/13/2011	11:32	5.42E-01	6.78E+00	7.51E+00	Cs-137
MW-62-71	MW-62-71-(017)	17	4/13/2011	11:15	2.33E+00	7.96E+00	9.27E+00	Cs-137
MW-62-92	MW-62-92-(017)	17	4/13/2011	11:03	-2.87E+00	7.18E+00	7.31E+00	Cs-137
MW-63-112	MW-63-112-(017)	17	4/19/2011	11:25	4.96E+00	1.05E+01	1.25E+01	Cs-137
MW-63-121	MW-63-121-(017)	17	4/19/2011	9:54	-1.03E+00	6.92E+00	7.17E+00	Cs-137
MW-63-163	MW-63-163-(017)	17	4/19/2011	9:49	4.43E-01	8.94E+00	9.98E+00	Cs-137
MW-63-174	MW-63-174-(017)	17	4/19/2011	9:52	-6.41E+00	8.32E+00	7.72E+00	Cs-137
MW-63-18	MW-63-18-(017)	17	4/19/2011	10:35	8.69E-01	8.04E+00	8.92E+00	Cs-137
MW-63-34	MW-63-34-(017)	17	4/19/2011	10:25	4.36E+00	8.34E+00	9.94E+00	Cs-137
MW-63-50	MW-63-50-(017)	17	4/19/2011	11:25	-6.46E+00	9.76E+00	9.29E+00	Cs-137
MW-63-93	MW-63-93-(018)	18	4/19/2011	11:27	3.31E+00	8.92E+00	1.03E+01	Cs-137
MW-66-21	MW-66-21-(017)	17	4/14/2011	13:43	-4.70E+00	8.74E+00	8.45E+00	Cs-137
MW-66-36	MW-66-36-(016)	16	4/14/2011	12:53	1.50E-01	7.24E+00	8.14E+00	Cs-137
MW-67-105	MW-67-105-(016)	16	4/14/2011	13:43	-3.96E-01	9.66E+00	1.05E+01	Cs-137
MW-67-173	MW-67-173-(017)	17	4/14/2011	14:09	5.04E+00	9.64E+00	1.17E+01	Cs-137
MW-67-219	MW-67-219-(016)	16	4/14/2011	10:49	-2.70E+00	6.62E+00	6.47E+00	Cs-137
MW-67-276	MW-67-276-(016)	16	4/14/2011	10:53	-5.30E+00	6.78E+00	6.12E+00	Cs-137
MW-67-323	MW-67-323-(016)	16	4/14/2011	11:33	2.02E+00	8.36E+00	9.62E+00	Cs-137
MW-67-340	MW-67-340-(016)	16	4/14/2011	11:17	5.89E+00	9.02E+00	1.12E+01	Cs-137
MW-67-39	MW-67-39-(017)	17	4/14/2011	13:25	4.53E+00	8.78E+00	1.04E+01	Cs-137
U1-CSS	U1-CSS-(016)	16	5/4/2011	13:24	3.29E+00	8.36E+00	9.79E+00	Cs-137
U3-4D	U3-4D-(028)	28	4/25/2011	14:50	-3.17E+00	7.58E+00	7.50E+00	Cs-137
U3-4S	U3-4S-(003)	3	4/25/2011	14:13	5.35E+00	8.82E+00	1.07E+01	Cs-137
U3-T1	U3-T1-(032)	32	5/6/2011	10:23	-3.24E+00	9.12E+00	9.22E+00	Cs-137
U3-T2	U3-T2-(037)	37	5/6/2011	11:41	2.82E+00	7.26E+00	8.74E+00	Cs-137

IPEC00233542

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-1	B-1-(012)	12	4/25/2011	10:50	8.10E+03	9.22E+02	4.53E+02	H-3
B-6	B-6-(012)	12	4/25/2011	9:48	2.68E+03	6.18E+02	4.53E+02	H-3
LAF-002	LAF-002-(015)	15	5/2/2011	12:50	6.69E+01	3.04E+02	3.43E+02	H-3
MH-5	MH-5-(015)	15	4/22/2011	13:37	1.25E+04	1.10E+03	4.46E+02	H-3
MW-107	MW-107-(010)	10	5/2/2011	9:25	3.15E+02	3.76E+02	3.95E+02	H-3
MW-30-69	MW-30-69-(039)	39	5/5/2011	12:08	1.13E+05	3.48E+03	3.99E+02	H-3
MW-30-84	MW-30-84-(030)	30	5/5/2011	12:58	7.57E+03	9.46E+02	3.92E+02	H-3
MW-31-49	MW-31-49-(031)	31	4/18/2011	12:53	1.08E+03	5.20E+02	4.66E+02	H-3
MW-31-63	MW-31-63-(031)	31	4/18/2011	13:21	1.81E+04	1.45E+03	4.67E+02	H-3
MW-31-85	MW-31-85-(031)	31	4/18/2011	13:18	3.08E+03	6.96E+02	4.66E+02	H-3
MW-32-149	MW-32-149-(025)	25	4/27/2011	11:12	8.69E+02	4.44E+02	4.11E+02	H-3
MW-32-173	MW-32-173-(023)	23	4/27/2011	11:27	5.82E+02	4.98E+02	5.08E+02	H-3
MW-32-190	MW-32-190-(027)	27	4/27/2011	11:17	1.21E+03	5.64E+02	5.10E+02	H-3
MW-32-59	MW-32-59-(025)	25	4/27/2011	12:26	3.31E+03	6.36E+02	4.08E+02	H-3
MW-32-85	MW-32-85-(028)	28	4/27/2011	13:04	1.14E+04	1.19E+03	5.10E+02	H-3
MW-36-24	MW-36-24-(022)	22	4/28/2011	14:34	3.07E+03	7.26E+02	5.19E+02	H-3
MW-36-41	MW-36-41-(016)	16	4/28/2011	15:39	8.17E+03	1.04E+03	5.14E+02	H-3
MW-36-52	MW-36-52-(021)	21	4/28/2011	14:38	5.84E+03	9.06E+02	5.15E+02	H-3
MW-37-22	MW-37-22-(022)	22	4/28/2011	12:05	6.87E+03	9.66E+02	5.14E+02	H-3
MW-37-32	MW-37-32-(022)	22	4/28/2011	12:21	4.11E+03	7.98E+02	5.15E+02	H-3
MW-37-40	MW-37-40-(022)	22	4/28/2011	11:31	3.92E+03	8.02E+02	5.33E+02	H-3
MW-37-57	MW-37-57-(022)	22	4/28/2011	12:17	5.81E+03	8.98E+02	5.07E+02	H-3
MW-39-102	MW-39-102-(011)	11	4/26/2011	14:33	1.43E+04	1.09E+03	4.19E+02	H-3
MW-39-124	MW-39-124-(011)	11	4/26/2011	13:01	1.51E+02	3.70E+02	4.15E+02	H-3
MW-39-183	MW-39-183-(011)	11	4/26/2011	11:35	1.15E+02	3.54E+02	4.02E+02	H-3
MW-39-195	MW-39-195-(011)	11	4/26/2011	12:38	7.04E+03	8.04E+02	4.20E+02	H-3
MW-39-67	MW-39-67-(011)	11	4/26/2011	14:52	1.09E+04	9.64E+02	4.18E+02	H-3
MW-39-84	MW-39-84-(011)	11	4/26/2011	14:25	4.40E+02	4.02E+02	4.13E+02	H-3
MW-40-100	MW-40-100-(018)	18	4/29/2011	11:27	2.70E+02	4.06E+02	4.38E+02	H-3
MW-40-127	MW-40-127-(018)	18	4/29/2011	11:26	-2.27E+01	3.60E+02	4.32E+02	H-3
MW-40-162	MW-40-162-(016)	16	4/29/2011	12:26	1.05E+02	3.78E+02	4.33E+02	H-3
MW-40-27	MW-40-27-(015)	15	4/29/2011	13:29	1.77E+02	3.66E+02	4.07E+02	H-3
MW-40-46	MW-40-46-(016)	16	4/29/2011	13:31	7.82E+01	3.54E+02	4.05E+02	H-3
MW-40-81	MW-40-81-(016)	16	4/29/2011	11:08	3.39E+02	4.12E+02	4.36E+02	H-3
MW-41-40	MW-41-40-(020)	20	4/20/2011	13:51	4.51E+03	7.36E+02	4.55E+02	H-3
MW-41-63	MW-41-63-(019)	19	4/20/2011	13:13	7.58E+02	4.90E+02	4.72E+02	H-3
MW-42-49	MW-42-49-(025)	25	4/21/2011	14:04	1.71E+03	5.88E+02	4.80E+02	H-3
MW-42-78	MW-42-78-(020)	20	4/21/2011	13:45	6.26E+02	4.78E+02	4.77E+02	H-3
MW-43-28	MW-43-28-(019)	19	4/21/2011	11:15	2.34E+02	4.30E+02	4.72E+02	H-3
MW-43-62	MW-43-62-(019)	19	4/21/2011	11:00	1.05E+02	4.12E+02	4.72E+02	H-3
MW-44-102	MW-44-102-(021)	21	4/26/2011	12:18	6.70E+02	4.14E+02	3.99E+02	H-3
MW-44-66	MW-44-66-(020)	20	4/26/2011	13:17	6.87E+02	4.20E+02	4.03E+02	H-3
MW-45-42	MW-45-42-(024)	24	4/20/2011	14:09	8.56E+03	1.03E+03	4.65E+02	H-3
MW-45-61	MW-45-61-(024)	24	4/20/2011	10:07	2.03E+03	6.12E+02	4.74E+02	H-3
MW-46	MW-46-(024)	24	4/25/2011	11:19	5.25E+03	7.54E+02	3.95E+02	H-3
MW-49-26	MW-49-26-(024)	24	4/15/2011	11:58	3.29E+03	7.18E+02	4.80E+02	H-3
MW-49-42	MW-49-42-(024)	24	4/15/2011	11:55	1.90E+03	6.04E+02	4.78E+02	H-3
MW-49-65	MW-49-65-(024)	24	4/15/2011	11:50	2.38E+03	6.48E+02	4.81E+02	H-3
MW-50-42	MW-50-42-(025)	25	5/3/2011	12:05	3.77E+03	5.58E+02	3.41E+02	H-3
MW-50-66	MW-50-66-(030)	30	5/3/2011	12:07	4.73E+03	6.12E+02	3.45E+02	H-3
MW-51-104	MW-51-104-(017)	17	4/29/2011	12:35	1.97E+02	3.90E+02	4.32E+02	H-3
MW-51-135	MW-51-135-(017)	17	4/29/2011	13:16	0.00E+00	3.66E+02	4.35E+02	H-3
MW-51-163	MW-51-163-(017)	17	4/29/2011	13:19	4.68E+01	3.66E+02	4.30E+02	H-3
MW-51-189	MW-51-189-(017)	17	4/29/2011	12:52	2.32E+02	3.96E+02	4.33E+02	H-3
MW-51-40	MW-51-40-(019)	19	4/29/2011	10:41	3.63E+02	4.14E+02	4.35E+02	H-3
MW-51-79	MW-51-79-(019)	19	4/29/2011	10:57	1.17E+02	3.82E+02	4.33E+02	H-3
MW-52-11	MW-52-11-(006)	6	4/22/2011	12:10	3.04E+02	4.08E+02	4.35E+02	H-3
MW-52-122	MW-52-122-(006)	6	4/22/2011	10:45	-2.27E+01	3.60E+02	4.33E+02	H-3
MW-52-162	MW-52-162-(006)	6	4/22/2011	10:18	1.85E+02	3.84E+02	4.29E+02	H-3
MW-52-18	MW-52-18-(006)	6	4/22/2011	12:16	7.01E+01	3.76E+02	4.35E+02	H-3
MW-52-181	MW-52-181-(006)	6	4/22/2011	10:22	2.45E+02	3.96E+02	4.33E+02	H-3
MW-52-48	MW-52-48-(006)	6	4/22/2011	12:18	1.06E+02	3.82E+02	4.36E+02	H-3
MW-52-64	MW-52-64-(006)	6	4/22/2011	15:23	-2.26E+01	3.58E+02	4.32E+02	H-3
MW-53-120	MW-53-120-(023)	23	4/18/2011	11:52	4.11E+03	7.72E+02	4.75E+02	H-3

IPEC00233543

MW-53-82	MW-53-82-(019)	19	4/18/2011	12:45	6.24E+02	4.56E+02	4.50E+02	H-3
MW-54-123	MW-54-123-(017)	17	4/12/2011	12:22	8.24E+02	4.98E+02	4.77E+02	H-3
MW-54-144	MW-54-144-(017)	17	4/12/2011	9:50	1.48E+03	5.68E+02	4.79E+02	H-3
MW-54-173	MW-54-173-(017)	17	4/12/2011	9:56	1.26E+03	5.46E+02	4.78E+02	H-3
MW-54-190	MW-54-190-(017)	17	4/12/2011	10:01	2.07E+03	6.18E+02	4.78E+02	H-3
MW-54-37	MW-54-37-(017)	17	4/12/2011	12:02	5.16E+03	8.40E+02	4.76E+02	H-3
MW-54-58	MW-54-58-(017)	17	4/12/2011	12:04	9.94E+02	5.20E+02	4.79E+02	H-3
MW-56-53	MW-56-53-(010)	10	4/27/2011	12:08	1.18E+02	3.48E+02	3.97E+02	H-3
MW-56-83	MW-56-83-(012)	12	4/27/2011	13:46	7.64E+04	2.40E+03	4.19E+02	H-3
MW-57-11	MW-57-11-(007)	7	5/4/2011	10:28	6.40E+03	6.84E+02	3.41E+02	H-3
MW-57-20	MW-57-20-(007)	7	5/4/2011	10:37	2.03E+04	1.15E+03	3.44E+02	H-3
MW-57-45	MW-57-45-(008)	8	5/4/2011	11:03	1.35E+04	9.48E+02	3.43E+02	H-3
MW-58-26	MW-58-26-(012)	12	5/3/2011	9:58	7.22E+02	4.30E+02	4.21E+02	H-3
MW-58-65	MW-58-65-(012)	12	5/3/2011	10:11	3.29E+02	3.78E+02	3.97E+02	H-3
MW-60-135	MW-60-135-(017)	17	4/15/2011	13:25	4.14E+02	4.02E+02	4.12E+02	H-3
MW-60-154	MW-60-154-(017)	17	4/15/2011	13:19	3.06E+02	3.96E+02	4.21E+02	H-3
MW-60-176	MW-60-176-(017)	17	4/15/2011	13:49	8.99E+02	4.66E+02	4.18E+02	H-3
MW-60-35	MW-60-35-(017)	17	4/15/2011	11:36	2.03E+02	4.32E+02	4.80E+02	H-3
MW-60-53	MW-60-53-(017)	17	4/15/2011	11:37	-5.87E+01	3.96E+02	4.80E+02	H-3
MW-60-72	MW-60-72-(017)	17	4/15/2011	13:12	2.19E+02	3.78E+02	4.13E+02	H-3
MW-62-138	MW-62-138-(017)	17	4/13/2011	14:39	6.31E+02	5.04E+02	5.09E+02	H-3
MW-62-18	MW-62-18-(017)	17	4/13/2011	11:58	3.25E+02	4.56E+02	4.92E+02	H-3
MW-62-182	MW-62-182-(017)	17	4/13/2011	14:44	1.92E+02	4.50E+02	5.03E+02	H-3
MW-62-37	MW-62-37-(017)	17	4/13/2011	12:10	1.56E+02	4.36E+02	4.91E+02	H-3
MW-62-53	MW-62-53-(016)	16	4/13/2011	11:32	1.57E+02	4.36E+02	4.92E+02	H-3
MW-62-71	MW-62-71-(017)	17	4/13/2011	11:15	3.39E+02	4.72E+02	5.08E+02	H-3
MW-62-92	MW-62-92-(017)	17	4/13/2011	11:03	5.06E+02	4.78E+02	4.92E+02	H-3
MW-63-112	MW-63-112-(017)	17	4/19/2011	11:25	4.22E+02	4.68E+02	4.92E+02	H-3
MW-63-121	MW-63-121-(017)	17	4/19/2011	9:54	5.77E+02	4.84E+02	4.91E+02	H-3
MW-63-163	MW-63-163-(017)	17	4/19/2011	9:49	4.92E+02	4.84E+02	5.03E+02	H-3
MW-63-174	MW-63-174-(017)	17	4/19/2011	9:52	1.56E+02	4.48E+02	5.04E+02	H-3
MW-63-18	MW-63-18-(017)	17	4/19/2011	10:35	7.23E+01	4.38E+02	5.05E+02	H-3
MW-63-34	MW-63-34-(017)	17	4/19/2011	10:25	3.94E+02	4.60E+02	4.87E+02	H-3
MW-63-50	MW-63-50-(017)	17	4/19/2011	11:25	1.68E+02	4.36E+02	4.89E+02	H-3
MW-63-93	MW-63-93-(018)	18	4/19/2011	11:27	9.64E+01	4.42E+02	5.05E+02	H-3
MW-66-21	MW-66-21-(017)	17	4/14/2011	13:43	9.30E+01	3.88E+02	4.46E+02	H-3
MW-66-36	MW-66-36-(016)	16	4/14/2011	12:53	3.52E+03	7.36E+02	4.79E+02	H-3
MW-67-105	MW-67-105-(016)	16	4/14/2011	13:43	1.10E+03	4.84E+02	4.12E+02	H-3
MW-67-173	MW-67-173-(017)	17	4/14/2011	14:09	5.72E+02	4.20E+02	4.10E+02	H-3
MW-67-219	MW-67-219-(016)	16	4/14/2011	10:49	1.07E+03	4.78E+02	4.12E+02	H-3
MW-67-276	MW-67-276-(016)	16	4/14/2011	10:53	1.06E+03	4.84E+02	4.19E+02	H-3
MW-67-323	MW-67-323-(016)	16	4/14/2011	11:33	4.26E+02	4.06E+02	4.13E+02	H-3
MW-67-340	MW-67-340-(016)	16	4/14/2011	11:17	6.56E+02	4.32E+02	4.13E+02	H-3
MW-67-39	MW-67-39-(017)	17	4/14/2011	13:25	3.73E+03	7.14E+02	4.17E+02	H-3
U1-CSS	U1-CSS-(016)	16	5/4/2011	13:24	6.38E+03	6.84E+02	3.40E+02	H-3
U3-4D	U3-4D-(028)	28	4/25/2011	14:50	7.41E+02	4.36E+02	3.98E+02	H-3
U3-4S	U3-4S-(003)	3	4/25/2011	14:13	1.48E+02	3.78E+02	4.22E+02	H-3
U3-T1	U3-T1-(032)	32	5/6/2011	10:23	7.82E+02	5.16E+02	5.03E+02	H-3
U3-T2	U3-T2-(037)	37	5/6/2011	11:41	3.83E+03	6.42E+02	4.19E+02	H-3

IPEC00233544

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
LAF-002	LAF-002-(015)	15	5/2/2011	12:50	-3.48E-01	1.60E+01	1.83E+01	Ni-63
MW-42-49	MW-42-49-(025)	25	4/21/2011	14:04	1.90E+02	2.72E+01	1.73E+01	Ni-63
MW-42-78	MW-42-78-(020)	20	4/21/2011	13:45	5.89E-01	1.49E+01	1.72E+01	Ni-63
MW-49-26	MW-49-26-(024)	24	4/15/2011	11:58	1.81E+00	1.50E+01	1.72E+01	Ni-63
MW-49-42	MW-49-42-(024)	24	4/15/2011	11:55	6.68E+00	1.55E+01	1.73E+01	Ni-63
MW-49-65	MW-49-65-(024)	24	4/15/2011	11:50	4.11E+00	1.49E+01	1.68E+01	Ni-63
MW-50-42	MW-50-42-(025)	25	5/3/2011	12:05	5.86E-01	1.69E+01	1.92E+01	Ni-63
MW-50-66	MW-50-66-(030)	30	5/3/2011	12:07	8.43E+00	1.70E+01	1.88E+01	Ni-63
MW-53-120	MW-53-120-(023)	23	4/18/2011	11:52	1.76E+01	1.77E+01	1.87E+01	Ni-63
MW-53-82	MW-53-82-(019)	19	4/18/2011	12:45	-5.86E-01	1.48E+01	1.72E+01	Ni-63
MW-54-123	MW-54-123-(017)	17	4/12/2011	12:22	-3.35E+00	1.48E+01	1.75E+01	Ni-63
MW-54-144	MW-54-144-(017)	17	4/12/2011	9:50	-2.75E+00	1.48E+01	1.74E+01	Ni-63
MW-54-173	MW-54-173-(017)	17	4/12/2011	9:56	-2.17E+00	1.50E+01	1.76E+01	Ni-63
MW-54-190	MW-54-190-(017)	17	4/12/2011	10:01	3.35E-01	1.58E+01	1.82E+01	Ni-63
MW-54-37	MW-54-37-(017)	17	4/12/2011	12:02	3.16E+00	1.45E+01	1.65E+01	Ni-63
MW-54-58	MW-54-58-(017)	17	4/12/2011	12:04	5.01E+00	1.58E+01	1.78E+01	Ni-63
MW-57-11	MW-57-11-(007)	7	5/4/2011	10:28	6.20E+00	1.66E+01	1.85E+01	Ni-63
MW-57-20	MW-57-20-(007)	7	5/4/2011	10:37	-5.44E+00	1.64E+01	1.91E+01	Ni-63
MW-57-45	MW-57-45-(008)	8	5/4/2011	11:03	6.39E+00	1.78E+01	1.98E+01	Ni-63
MW-60-135	MW-60-135-(017)	17	4/15/2011	13:25	4.64E+00	1.47E+01	1.65E+01	Ni-63
MW-60-154	MW-60-154-(017)	17	4/15/2011	13:19	1.62E+00	1.44E+01	1.64E+01	Ni-63
MW-60-176	MW-60-176-(017)	17	4/15/2011	13:49	-2.40E-01	1.40E+01	1.62E+01	Ni-63
MW-60-35	MW-60-35-(017)	17	4/15/2011	11:36	2.65E+00	1.42E+01	1.61E+01	Ni-63
MW-60-53	MW-60-53-(017)	17	4/15/2011	11:37	-1.06E+00	1.43E+01	1.66E+01	Ni-63
MW-60-72	MW-60-72-(017)	17	4/15/2011	13:12	-2.93E+00	1.39E+01	1.63E+01	Ni-63
MW-66-21	MW-66-21-(017)	17	4/14/2011	13:43	1.81E+00	1.51E+01	1.72E+01	Ni-63
MW-66-36	MW-66-36-(016)	16	4/14/2011	12:53	6.10E-01	1.55E+01	1.79E+01	Ni-63
MW-67-105	MW-67-105-(016)	16	4/14/2011	13:43	5.71E+00	1.55E+01	1.73E+01	Ni-63
MW-67-173	MW-67-173-(017)	17	4/14/2011	14:09	7.50E+00	1.23E+01	1.34E+01	Ni-63
MW-67-219	MW-67-219-(016)	16	4/14/2011	10:49	2.95E+00	1.43E+01	1.62E+01	Ni-63
MW-67-276	MW-67-276-(016)	16	4/14/2011	10:53	5.62E-01	1.42E+01	1.63E+01	Ni-63
MW-67-323	MW-67-323-(016)	16	4/14/2011	11:33	-2.21E-01	1.30E+01	1.50E+01	Ni-63
MW-67-340	MW-67-340-(016)	16	4/14/2011	11:17	7.58E+00	1.54E+01	1.71E+01	Ni-63
MW-67-39	MW-67-39-(017)	17	4/14/2011	13:25	6.99E+00	1.47E+01	1.63E+01	Ni-63
U1-CSS	U1-CSS-(016)	16	5/4/2011	13:24	-1.05E+01	1.55E+01	1.84E+01	Ni-63

IPEC00233545

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-1	B-1-(012)	12	4/25/2011	10:50	-6.21E-03	1.74E+00	2.09E+00	Sr-90
B-6	B-6-(012)	12	4/25/2011	9:48	-6.69E-01	1.58E+00	2.09E+00	Sr-90
LAF-002	LAF-002-(015)	15	5/2/2011	12:50	1.16E+00	1.55E+00	1.66E+00	Sr-90
MH-5	MH-5-(015)	15	4/22/2011	13:37	8.17E-01	1.85E+00	2.08E+00	Sr-90
MW-107	MW-107-(010)	10	5/2/2011	9:25	8.29E-01	1.29E+00	1.40E+00	Sr-90
MW-30-69	MW-30-69-(039)	39	5/5/2011	12:08	2.40E+00	1.37E+00	1.23E+00	Sr-90
MW-30-84	MW-30-84-(030)	30	5/5/2011	12:58	1.64E-01	1.15E+00	1.40E+00	Sr-90
MW-31-49	MW-31-49-(031)	31	4/18/2011	12:53	4.98E-01	1.81E+00	2.09E+00	Sr-90
MW-31-63	MW-31-63-(031)	31	4/18/2011	13:21	7.26E-01	1.84E+00	2.08E+00	Sr-90
MW-31-85	MW-31-85-(031)	31	4/18/2011	13:18	-1.09E+00	1.46E+00	2.09E+00	Sr-90
MW-32-149	MW-32-149-(025)	25	4/27/2011	11:12	3.00E-01	1.43E+00	1.67E+00	Sr-90
MW-32-173	MW-32-173-(023)	23	4/27/2011	11:27	6.37E-01	1.54E+00	1.74E+00	Sr-90
MW-32-190	MW-32-190-(027)	27	4/27/2011	11:17	7.54E-01	1.13E+00	1.20E+00	Sr-90
MW-32-59	MW-32-59-(025)	25	4/27/2011	12:26	4.03E-01	1.50E+00	1.74E+00	Sr-90
MW-32-85	MW-32-85-(028)	28	4/27/2011	13:04	1.58E+00	1.69E+00	1.75E+00	Sr-90
MW-36-24	MW-36-24-(022)	22	4/28/2011	14:34	1.38E+00	1.53E+00	1.59E+00	Sr-90
MW-36-41	MW-36-41-(016)	16	4/28/2011	15:39	3.31E+00	1.75E+00	1.36E+00	Sr-90
MW-36-52	MW-36-52-(021)	21	4/28/2011	14:38	3.41E+00	1.56E+00	1.11E+00	Sr-90
MW-37-22	MW-37-22-(022)	22	4/28/2011	12:05	8.72E+00	2.90E+00	2.05E+00	Sr-90
MW-37-32	MW-37-32-(022)	22	4/28/2011	12:21	2.62E+01	3.76E+00	1.68E+00	Sr-90
MW-37-40	MW-37-40-(022)	22	4/28/2011	11:31	2.30E+01	3.66E+00	1.68E+00	Sr-90
MW-37-57	MW-37-57-(022)	22	4/28/2011	12:17	1.58E+01	3.54E+00	2.00E+00	Sr-90
MW-39-102	MW-39-102-(011)	11	4/26/2011	14:33	1.08E+00	1.85E+00	2.03E+00	Sr-90
MW-39-124	MW-39-124-(011)	11	4/26/2011	13:01	5.20E-01	1.37E+00	1.55E+00	Sr-90
MW-39-183	MW-39-183-(011)	11	4/26/2011	11:35	1.12E+00	1.56E+00	1.67E+00	Sr-90
MW-39-195	MW-39-195-(011)	11	4/26/2011	12:38	1.88E+00	1.75E+00	1.79E+00	Sr-90
MW-39-67	MW-39-67-(011)	11	4/26/2011	14:52	1.74E+00	1.49E+00	1.50E+00	Sr-90
MW-39-84	MW-39-84-(011)	11	4/26/2011	14:25	-2.03E-01	1.15E+00	1.50E+00	Sr-90
MW-40-100	MW-40-100-(018)	18	4/29/2011	11:27	2.46E-01	1.42E+00	1.67E+00	Sr-90
MW-40-127	MW-40-127-(018)	18	4/29/2011	11:26	5.72E-01	1.78E+00	2.05E+00	Sr-90
MW-40-162	MW-40-162-(016)	16	4/29/2011	12:26	8.71E-01	1.34E+00	1.46E+00	Sr-90
MW-40-27	MW-40-27-(015)	15	4/29/2011	13:29	1.18E+00	1.74E+00	1.87E+00	Sr-90
MW-40-46	MW-40-46-(016)	16	4/29/2011	13:31	2.83E+00	1.88E+00	1.77E+00	Sr-90
MW-40-81	MW-40-81-(016)	16	4/29/2011	11:08	1.07E+00	1.58E+00	1.70E+00	Sr-90
MW-41-40	MW-41-40-(020)	20	4/20/2011	13:51	2.32E+00	1.57E+00	1.44E+00	Sr-90
MW-41-63	MW-41-63-(019)	19	4/20/2011	13:13	-7.72E-01	1.51E+00	2.03E+00	Sr-90
MW-42-49	MW-42-49-(025)	25	4/21/2011	14:04	5.45E+00	2.18E+00	1.45E+00	Sr-90
MW-42-78	MW-42-78-(020)	20	4/21/2011	13:45	4.25E-01	1.13E+00	1.32E+00	Sr-90
MW-43-28	MW-43-28-(019)	19	4/21/2011	11:15	1.46E+00	1.96E+00	2.04E+00	Sr-90
MW-43-62	MW-43-62-(019)	19	4/21/2011	11:00	-4.65E-01	1.67E+00	2.18E+00	Sr-90
MW-44-102	MW-44-102-(021)	21	4/26/2011	12:18	1.09E+00	1.41E+00	1.49E+00	Sr-90
MW-44-66	MW-44-66-(020)	20	4/26/2011	13:17	7.05E-01	1.52E+00	1.70E+00	Sr-90
MW-45-42	MW-45-42-(024)	24	4/20/2011	14:09	1.45E+00	1.56E+00	1.61E+00	Sr-90
MW-45-61	MW-45-61-(024)	24	4/20/2011	10:07	7.22E-01	1.36E+00	1.51E+00	Sr-90
MW-46	MW-46-(024)	24	4/25/2011	11:19	1.48E+00	1.72E+00	1.80E+00	Sr-90
MW-49-26	MW-49-26-(024)	24	4/15/2011	11:58	1.26E+01	3.06E+00	1.91E+00	Sr-90
MW-49-42	MW-49-42-(024)	24	4/15/2011	11:55	1.57E+01	3.34E+00	2.07E+00	Sr-90
MW-49-65	MW-49-65-(024)	24	4/15/2011	11:50	1.62E+01	3.12E+00	1.60E+00	Sr-90
MW-50-42	MW-50-42-(025)	25	5/3/2011	12:05	9.53E+00	2.20E+00	1.04E+00	Sr-90
MW-50-66	MW-50-66-(030)	30	5/3/2011	12:07	2.63E+01	3.30E+00	1.08E+00	Sr-90
MW-51-104	MW-51-104-(017)	17	4/29/2011	12:35	1.41E+00	1.45E+00	1.48E+00	Sr-90
MW-51-135	MW-51-135-(017)	17	4/29/2011	13:16	1.14E+00	1.52E+00	1.63E+00	Sr-90
MW-51-163	MW-51-163-(017)	17	4/29/2011	13:19	5.27E-01	1.45E+00	1.65E+00	Sr-90
MW-51-189	MW-51-189-(017)	17	4/29/2011	12:52	1.28E+00	1.50E+00	1.57E+00	Sr-90
MW-51-40	MW-51-40-(019)	19	4/29/2011	10:41	2.26E-01	1.37E+00	1.59E+00	Sr-90
MW-51-79	MW-51-79-(019)	19	4/29/2011	10:57	1.03E+00	1.67E+00	1.82E+00	Sr-90
MW-52-11	MW-52-11-(006)	6	4/22/2011	12:10	1.29E-01	1.35E+00	1.60E+00	Sr-90
MW-52-122	MW-52-122-(006)	6	4/22/2011	10:45	1.14E+00	1.17E+00	1.17E+00	Sr-90
MW-52-162	MW-52-162-(006)	6	4/22/2011	10:18	-7.50E-01	9.50E-01	1.42E+00	Sr-90
MW-52-18	MW-52-18-(006)	6	4/22/2011	12:16	1.37E+00	1.39E+00	1.42E+00	Sr-90
MW-52-181	MW-52-181-(006)	6	4/22/2011	10:22	1.18E+00	1.42E+00	1.48E+00	Sr-90
MW-52-48	MW-52-48-(006)	6	4/22/2011	12:18	1.69E-01	1.37E+00	1.62E+00	Sr-90
MW-52-64	MW-52-64-(006)	6	4/22/2011	15:23	5.12E-01	1.13E+00	1.27E+00	Sr-90
MW-53-120	MW-53-120-(023)	23	4/18/2011	11:52	3.55E+01	4.56E+00	1.67E+00	Sr-90

IPEC00233546



MW-53-82	MW-53-82-(019)	19	4/18/2011	12:45	4.40E-01	1.45E+00	1.67E+00	Sr-90
MW-54-123	MW-54-123-(017)	17	4/12/2011	12:22	3.44E+00	1.96E+00	1.72E+00	Sr-90
MW-54-144	MW-54-144-(017)	17	4/12/2011	9:50	1.20E+01	2.92E+00	1.81E+00	Sr-90
MW-54-173	MW-54-173-(017)	17	4/12/2011	9:56	3.91E+00	1.92E+00	1.58E+00	Sr-90
MW-54-190	MW-54-190-(017)	17	4/12/2011	10:01	1.90E+01	3.38E+00	1.77E+00	Sr-90
MW-54-37	MW-54-37-(017)	17	4/12/2011	12:02	4.91E+00	2.08E+00	1.69E+00	Sr-90
MW-54-58	MW-54-58-(017)	17	4/12/2011	12:04	1.15E+00	1.84E+00	2.01E+00	Sr-90
MW-56-53	MW-56-53-(010)	10	4/27/2011	12:08	-3.07E-02	1.23E+00	1.60E+00	Sr-90
MW-56-83	MW-56-83-(012)	12	4/27/2011	13:46	3.87E+00	1.60E+00	1.28E+00	Sr-90
MW-57-11	MW-57-11-(007)	7	5/4/2011	10:28	3.11E+01	3.62E+00	1.04E+00	Sr-90
MW-57-20	MW-57-20-(007)	7	5/4/2011	10:37	1.74E+00	1.11E+00	9.49E-01	Sr-90
MW-57-45	MW-57-45-(008)	8	5/4/2011	11:03	9.06E-01	9.74E-01	9.60E-01	Sr-90
MW-58-26	MW-58-26-(012)	12	5/3/2011	9:58	3.15E-01	1.13E+00	1.32E+00	Sr-90
MW-58-65	MW-58-65-(012)	12	5/3/2011	10:11	-4.47E-01	1.03E+00	1.44E+00	Sr-90
MW-60-135	MW-60-135-(017)	17	4/15/2011	13:25	6.52E-01	1.90E+00	2.16E+00	Sr-90
MW-60-154	MW-60-154-(017)	17	4/15/2011	13:19	-4.20E-01	1.53E+00	2.02E+00	Sr-90
MW-60-176	MW-60-176-(017)	17	4/15/2011	13:49	-8.29E-01	1.41E+00	2.10E+00	Sr-90
MW-60-35	MW-60-35-(017)	17	4/15/2011	11:36	3.77E-01	1.66E+00	2.00E+00	Sr-90
MW-60-53	MW-60-53-(017)	17	4/15/2011	11:37	-1.18E-02	1.60E+00	2.04E+00	Sr-90
MW-60-72	MW-60-72-(017)	17	4/15/2011	13:12	7.12E-01	1.72E+00	1.97E+00	Sr-90
MW-62-138	MW-62-138-(017)	17	4/13/2011	14:39	1.22E+00	1.29E+00	1.32E+00	Sr-90
MW-62-18	MW-62-18-(017)	17	4/13/2011	11:58	7.82E-01	1.54E+00	1.71E+00	Sr-90
MW-62-182	MW-62-182-(017)	17	4/13/2011	14:44	-5.04E-01	1.05E+00	1.45E+00	Sr-90
MW-62-37	MW-62-37-(017)	17	4/13/2011	12:10	-1.97E-01	1.08E+00	1.37E+00	Sr-90
MW-62-53	MW-62-53-(016)	16	4/13/2011	11:32	1.72E+00	1.79E+00	1.84E+00	Sr-90
MW-62-71	MW-62-71-(017)	17	4/13/2011	11:15	9.04E-01	1.45E+00	1.58E+00	Sr-90
MW-62-92	MW-62-92-(017)	17	4/13/2011	11:03	2.87E-01	1.11E+00	1.30E+00	Sr-90
MW-63-112	MW-63-112-(017)	17	4/19/2011	11:25	-7.96E-01	1.00E+00	1.47E+00	Sr-90
MW-63-121	MW-63-121-(017)	17	4/19/2011	9:54	4.12E-01	1.18E+00	1.37E+00	Sr-90
MW-63-163	MW-63-163-(017)	17	4/19/2011	9:49	1.11E+00	1.82E+00	2.00E+00	Sr-90
MW-63-174	MW-63-174-(017)	17	4/19/2011	9:52	-7.87E-01	9.72E-01	1.48E+00	Sr-90
MW-63-18	MW-63-18-(017)	17	4/19/2011	10:35	-3.13E-01	1.13E+00	1.49E+00	Sr-90
MW-63-34	MW-63-34-(017)	17	4/19/2011	10:25	-1.13E+00	1.22E+00	1.83E+00	Sr-90
MW-63-50	MW-63-50-(017)	17	4/19/2011	11:25	7.72E-01	1.39E+00	1.53E+00	Sr-90
MW-63-93	MW-63-93-(018)	18	4/19/2011	11:27	-4.30E-02	1.14E+00	1.44E+00	Sr-90
MW-66-21	MW-66-21-(017)	17	4/14/2011	13:43	6.73E-01	1.64E+00	1.85E+00	Sr-90
MW-66-36	MW-66-36-(016)	16	4/14/2011	12:53	1.06E+01	2.88E+00	1.95E+00	Sr-90
MW-67-105	MW-67-105-(016)	16	4/14/2011	13:43	2.70E-01	1.72E+00	2.11E+00	Sr-90
MW-67-173	MW-67-173-(017)	17	4/14/2011	14:09	-2.56E-01	1.69E+00	1.99E+00	Sr-90
MW-67-219	MW-67-219-(016)	16	4/14/2011	10:49	-7.57E-01	9.50E-01	1.53E+00	Sr-90
MW-67-276	MW-67-276-(016)	16	4/14/2011	10:53	3.46E-01	1.22E+00	1.45E+00	Sr-90
MW-67-323	MW-67-323-(016)	16	4/14/2011	11:33	1.05E+00	1.52E+00	1.62E+00	Sr-90
MW-67-340	MW-67-340-(016)	16	4/14/2011	11:17	2.62E-01	1.16E+00	1.40E+00	Sr-90
MW-67-39	MW-67-39-(017)	17	4/14/2011	13:25	1.25E+01	3.76E+00	2.10E+00	Sr-90
U1-CSS	U1-CSS-(016)	16	5/4/2011	13:24	1.61E+01	2.70E+00	1.01E+00	Sr-90
U3-4D	U3-4D-(028)	28	4/25/2011	14:50	1.18E+00	1.38E+00	1.46E+00	Sr-90
U3-4S	U3-4S-(003)	3	4/25/2011	14:13	6.69E-01	1.27E+00	1.41E+00	Sr-90
U3-T1	U3-T1-(032)	32	5/6/2011	10:23	-6.43E-02	9.94E-01	1.30E+00	Sr-90
U3-T2	U3-T2-(037)	37	5/6/2011	11:41	3.27E-01	1.32E+00	1.58E+00	Sr-90

IPEC00233547