

18

**Hernandez, Pete**

---

**From:** Hernandez, Pete *JMH*  
**Sent:** Tuesday, November 15, 2011 12:25 PM  
**To:** Zimmerman, Jacob  
**Subject:** Draft email

Good afternoon,

A follow-up internal call was held this morning at 11am with staff from Region 3 and NRR regarding the Davis Besse Shield building. We are waiting on the following 4 items from the licensee:

- Literature and documented studies about bonding between concrete and rebar (on the Sunday, 11/13 call licensee promised us these)
- Availability of Professor Darwin to discuss his peer review (licensee indicated he would not be available until Thursday, 11/17)
- Splice evaluation for NRC review (this evaluation is underway)
- Summary document detailing their assumptions and engineering basis of how they still meet the design basis specifications (licensee has stated that this will be provided this afternoon or evening).

The licensee requested a delay of the public meeting to give them more time to finish the splice evaluation. The NRC accepted so that we would have time to review the documents before the meeting.

Thanks,

Pete

*B/18*