



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

July 26, 2012

Mr. Barry S. Allen, Vice President  
Davis-Besse Nuclear Power Station  
FirstEnergy Nuclear Operating Company  
5501 North State Route 2  
Oak Harbor, OH 43449

SUBJECT: SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION FOR THE  
REVIEW OF THE DAVIS-BESSE NUCLEAR POWER STATION LICENSE  
RENEWAL APPLICATION RELATED TO PRESSURE-TEMPERATURE LIMITS  
(TAC NO. ME4640)

Dear Mr. Allen:

By letter dated August 27, 2010, FirstEnergy Nuclear Operating Company submitted an application pursuant to Title 10 of the *Code of Federal Regulations*, Part 54 for renewal of Operating License NPF-3 for the Davis-Besse Nuclear Power Station. The staff of the U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing this application in accordance with the guidance in NUREG-1800, "Standard Review Plan for Review of License Renewal Applications for Nuclear Power Plants." During its review, the staff has identified areas where additional information is needed to complete the review. The staff's requests for additional information are included in the enclosure. Further requests for additional information may be issued in the future.

Items in the enclosure were discussed with Steven Dort, of your staff, and a mutually agreeable date for the response is within 30 days from the date of this letter. If you have any questions, please contact me by telephone at 301-415-2277 or by e-mail at [brian.harris2@nrc.gov](mailto:brian.harris2@nrc.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "B. Harris", written over a horizontal line.

Brian K. Harris, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure:  
As stated

cc w/encl: Listserv

DAVIS-BESSE NUCLEAR POWER STATION  
LICENSE RENEWAL APPLICATION  
SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION  
RELATED TO PRESSURE-TEMPERATURE LIMITS

**RAI 4.2.2-4 – Pressure-Temperature (P-T) Limits**

Background:

The Davis-Besse License Renewal Application (LRA), Section 4.2.4 describes the time-limited aging analysis for the pressure-temperature (P-T) limit curves at Davis-Besse. As stated in LRA Section 4.2.4, the Davis-Besse P-T limit curves are established in a P-T Limits Report (PTLR), the contents of which are controlled in accordance with Technical Specification (TS) 5.6.4 requirements. The current Davis-Besse PTLR contains P-T limit curves that are valid through 32 effective full power years of facility operation. LRA Section 4.2.4 states that the P-T limit curves, as established in the PTLR, will be updated as necessary in accordance with TS 5.6.4 requirements and managed for the period of extended operation, as part of the Reactor Vessel Surveillance Program (LRA Appendix B, Section B.2.35), in accordance with the requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) 54.21(c)(1)(iii).

10 CFR Part 50, Appendix G, Paragraph IV.A states that, "*the pressure-retaining components of the reactor coolant pressure boundary [RCPB] that are made of ferritic materials must meet the requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code [ASME Code, Section III], supplemented by the additional requirements set forth in [paragraph IV.A.2, "Pressure-Temperature (P-T) Limits and Minimum Temperature Requirements"]...*" Therefore, 10 CFR Part 50, Appendix G requires that P-T limits be developed for the ferritic materials in the reactor vessel (RV) beltline (neutron fluence  $\geq 1 \times 10^{17}$  n/cm<sup>2</sup>, E > 1 MeV), as well as ferritic materials not in the RV beltline (neutron fluence <  $1 \times 10^{17}$  n/cm<sup>2</sup>, E > 1 MeV). Further, 10 CFR Part 50, Appendix G requires that all RCPB components must meet the American Society of Mechanical Engineers (ASME) Code, Section III requirements. The relevant ASME Code, Section III requirement that will affect the P-T limits is the lowest service temperature requirement for all RCPB components specified in Section III, NB-2332(b).

Issue:

P-T limit calculations for ferritic RCPB components that are not RV beltline shell materials may define P-T curves that are more limiting than those calculated for the RV beltline shell materials. This may be due to the following factors:

1. RV nozzles, penetrations, and other discontinuities have complex geometries that may exhibit significantly higher stresses than those for the RV beltline shell region. These higher stresses can potentially result in more restrictive P-T limits, even if the reference temperature (RT<sub>NDT</sub>) for these components is not as high as that of RV beltline shell materials that have simpler geometries.
2. Ferritic RCPB components that are not part of the RV may have initial RT<sub>NDT</sub> values, which may define a more restrictive lowest operating temperature in the P-T limits than those for the RV beltline shell materials.

ENCLOSURE

Request:

Describe how the P-T limit curves to be developed for use in the period of extended operation, and the methodology used to develop these curves, consider all RV materials (beltline and non-beltline) and the lowest service temperature of all ferritic RCPB materials, consistent with the requirements of 10 CFR Part 50, Appendix G.

Letter to Barry S. Allen from Brian K. Harris dated July 26, 2012

SUBJECT: SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION FOR THE  
REVIEW OF THE DAVIS-BESSE NUCLEAR POWER STATION LICENSE  
RENEWAL APPLICATION RELATED TO PRESSURE-TEMPERATURE LIMITS  
(TAC NO. ME4640)

DISTRIBUTION:

**HARD COPY:**

DLR R/F

**E-MAIL:**

PUBLIC

RidsNrrDirResource  
RidsNrrDirRpb1 Resource  
RidsNrrDirRpb2 Resource  
RidsNrrDirRer1 Resource  
RidsNrrDirRer2 Resource  
RidsNrrDirRerb Resource  
RidsNrrDirRpob Resource  
RidsNrrDciCvib Resource  
RidsNrrDciCpnb Resource  
RidsNrrDciCsgb Resource  
RidsNrrDraAfpb Resource  
RidsNrrDraApla Resource  
RidsNrrDeEmcb Resource  
RidsNrrDeEeeb Resource  
RidsNrrDssSrxb Resource  
RidsNrrDssSbpb Resource  
RidsNrrDssScvb Resource  
RidsOgcMailCenter Resource

-----  
P. Cooper  
B. Harris (OGC)  
M. Mahoney

Mr. Barry S. Allen, Vice President  
Davis-Besse Nuclear Power Station  
FirstEnergy Nuclear Operating Company  
5501 North State Route 2  
Oak Harbor, OH 43449

SUBJECT: SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION FOR THE  
REVIEW OF THE DAVIS-BESSE NUCLEAR POWER STATION LICENSE  
RENEWAL APPLICATION RELATED TO PRESSURE-TEMPERATURE LIMITS  
(TAC NO. ME4640)

Dear Mr. Allen:

By letter dated August 27, 2010, FirstEnergy Nuclear Operating Company submitted an application pursuant to Title 10 of the *Code of Federal Regulations* Part 54 for renewal of Operating License NPF-3 for the Davis-Besse Nuclear Power Station. The staff of the U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing this application in accordance with the guidance in NUREG-1800, "Standard Review Plan for Review of License Renewal Applications for Nuclear Power Plants." During its review, the staff has identified areas where additional information is needed to complete the review. The staff's requests for additional information are included in the enclosure. Further requests for additional information may be issued in the future.

Items in the enclosure were discussed with Steven Dort, of your staff, and a mutually agreeable date for the response is within 30 days from the date of this letter. If you have any questions, please contact me by telephone at 301-415-2277 or by e-mail at [brian.harris2@nrc.gov](mailto:brian.harris2@nrc.gov).

Sincerely,

*/RA/*

Brian K. Harris, Project Manager  
Projects Branch 1  
Division of License Renewal  
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure:  
As stated

cc w/encl: Listserv

DISTRIBUTION:  
See next page

**ADAMS Accession No.:**ML12201B519

<b>OFFICE</b>	LA:DLR/RPB1	PM:DLR/RPB1	BC:DLR/RPB1	PM:DLR/RPB1
<b>NAME</b>	YEdmonds	BHarris	DMorey	BHarris
<b>DATE</b>	07 / 26 /12	07 / 26 /12	07 / 25 /12	07 / 26 /12

**OFFICIAL RECORD COPY**