

Pacific Gas and Electric Company®

James R. Becker Site Vice President Diablo Canyon Power Plant Mail Code 104/6 P. O. Box 56 Avila Beach, CA 93424

805.545.3462 Internal: 691.3462 Fax: 805.545.6445

July 19, 2012

PG&E Letter DCL-12-070

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80 Docket No. 50-323, OL-DPR-82 Diablo Canyon Units 1 and 2 <u>10 CFR 50.46 Annual Report of Emergency Core Cooling System Evaluation</u> Model Changes for Peak Cladding Temperature for 2011

Dear Commissioners and Staff:

Pursuant to 10 CFR 50.46, the enclosure to this letter provides an annual report of changes in the Westinghouse emergency core cooling system evaluation models that affect peak cladding temperature (PCT) calculations for Pacific Gas and Electric Company (PG&E) Diablo Canyon Power Plant, Units 1 and 2.

There have been no changes in the small-break loss-of-coolant accident (SBLOCA) PCT results or the large-break, best-estimate loss-of-coolant accident (BELOCA) PCT results for either Unit 1 or Unit 2 since the last annual update. The last update was provided in PG&E Letter DCL-11-082, "10 CFR 50.46 Annual Report of Emergency Core Cooling System Evaluation Model Changes for 2010," dated July 19, 2011.

A summary of the PCT margin allocations and their bases are provided in the enclosed attachments. The Unit 1 SBLOCA and BELOCA PCT Margin Utilization sheets are provided in Attachment A. The Unit 2 SBLOCA and BELOCA PCT Margin Utilization Sheets are provided in Attachment B.

The PCT values remain within the 2200 degree Fahrenheit (F) limit specified in 10 CFR 50.46. However, because the Unit 1 BELOCA has a total PCT margin allocation that is currently greater than 50 degrees F, and in order to coordinate with the 24-month fuel cycle project schedule, PG&E expects to complete the Unit 1 BELOCA reanalysis and provide the updated PCT results to the NRC by December 2016, as stated in PG&E Letter DCL-11-082, "10 CFR 50.46 Annual Report of Emergency Core Cooling System Evaluation Model Changes for 2010," dated July 19, 2011.

10 CFR 50.46

PG&E Letter DCL-12-070



PG&E makes no new or revised regulatory commitments (as defined by NEI 99-04) in this report.

If you have questions regarding this submittal please contact Mr. Steve Baker at 805-545-6742.

Sincerely,

m rwebb for

James R. Becker Site Vice President

wrl8/6980/64059110 Enclosure cc/enc: Elmo E. Collins, NRC Region IV Michael S. Peck, NRC Senior Resident Inspector Joseph M. Sebrosky, NRR Senior Project Manager Diablo Distribution

ANNUAL REPORT OF EMERGENCY CORE COOLING SYSTEM EVALUATION MODEL CHANGES FOR PEAK CLADDING TEMPERATURE

Pursuant to 10 CFR 50.46, this enclosure provides an annual report of changes in the Westinghouse emergency core cooling system (ECCS) evaluation models that affect peak cladding temperature (PCT) calculations for Pacific Gas and Electric Company (PG&E) Diablo Canyon Power Plant (DCPP), Units 1 and 2. This report is based on changes described in the following Westinghouse 10 CFR 50.46 notification letter:

Westinghouse Letter LTR-LIS-12-116, "Diablo Canyon Units 1 and 2 10 CFR 50.46 Annual Notification and Reporting for 2011," dated February 20, 2012

Attachment A to this enclosure provides DCPP, Unit 1 small-break loss-of-coolant accident (SBLOCA) and best-estimate, large-break loss-ofcoolant accident (BELOCA) PCT Margin Utilization sheets. Attachment B to this enclosure provides DCPP Unit 2 SBLOCA and BELOCA PCT Margin Utilization sheets. There have been no changes in the SBLOCA PCT results or the BELOCA PCT results for either Unit 1 or Unit 2 since the last annual update. The last update was provided in PG&E Letter DCL-11-082, "10 CFR 50.46 Annual Report of Emergency Core Cooling System Evaluation Model Changes for 2010," dated July 19, 2011.

A summary of the PCT margin allocations and their bases are provided in the attachments.

The final net PCT values are listed below for each unit. It should be noted that two PCT values are reported for the Unit 1 BELOCA results. The two BELOCA PCT values are labeled Reflood 1 and Reflood 2, as they represent the two distinctive PCT peaks that occur during the reflood phase for the Unit 1 BELOCA Code Qualification Document methodology. The Unit 2 BELOCA reports only one PCT value consistent with the BELOCA ASTRUM methodology.

Small-Break LOCA		<u>Large-Break, Best-Estimate LOCA</u>		
		Reflood 1	Reflood 2	
Unit 1:	1391°F (no change)	1990°F (no change)	1975°F (no change)	
Unit 2:	1288°F (no change)	1888°F (no change)		

The PCT values remain within the 2200 degree Fahrenheit (F) limit specified in 10 CFR 50.46. However, because the Unit 1 BELOCA has a total PCT margin allocation that is currently greater than 50 degrees F, and in order to coordinate with the 24-month fuel cycle project schedule, PG&E expects to complete the

Unit 1 BELOCA reanalysis and provide the updated PCT results to the NRC by December 2016, as stated in PG&E Letter DCL-11-082, "10 CFR 50.46 Annual Report of Emergency Core Cooling System Evaluation Model Changes for 2010," dated July 19, 2011.

DCPP UNIT 1 PEAK CLADDING TEMPERATURE MARGIN UTILIZATION

	SMALL-BREAK LOCA			PG&E Letter ¹
A.	ANALYSIS OF RECORD	PCT =	1391°F	DCL-09-057
B.	PRIOR 10 CFR 50.46 ECCS MODEL ASSESSMENTS ² 1. None	∆PCT =	0°F	
C.	10 CFR 50.46 ECCS MODEL ASSESSMENTS THIS YEAR 1. None	∆PCT =	0°F	
D.	 SUM OF 10 CFR 50.46 CHANGES 1. Net Sum of 10 CFR 50.46 PCT Changes 2. Absolute Sum of 	∆PCT =	0°F	
E.	10 CFR 50.46 PCT Changes Analysis of Record PCT - Line A + Line D.1 Net Sum of 10 CFR 50.46 PCT Changes	∆PCT =	0°F 1391°F	-

The sum of the PCT from the most recent analysis of record using an acceptable evaluation model and the estimates of the net PCT effect for changes and errors identified since this analysis remains less than 2200°F.

¹ For those issues that have been previously reported under 10 CFR 50.46, a PG&E letter number is listed.

² Only permanent assessments of PCT margin are included. Temporary PCT allocations that address current LOCA model issues are not considered with respect to 10 CFR 50.46 reporting requirements.

DCPP UNIT 1 PEAK CLADDING TEMPERATURE MARGIN UTILIZATION

ļ	BEST-ESTIMATE, LARGE-BREAK LOCA			PG&E Letter ¹
		Reflood 1	Reflood 2	
A.	ANALYSIS OF RECORD	1900°F	1860°F	DCL-05-146
B.	PRIOR 10 CFR 50.46 ECCS	<u>APCT</u>	<u>∆PCT</u>	
	 Revised blowdown heatup uncertainty distribution. 	5°F	5°F	DCL-05-086
	2. HOTSPOT Fuel Relocation Error.	10°F	0°F	DCL-07-071
	3. Replacement Steam Generators	75°F	71°F	DCL-09-057
C.	 10 CFR 50.46 ECCS MODEL ASSESSMENTS THIS YEAR 1. 230kV Degraded Voltage Event Evaluation 	0°F	39°F	DCL-11-082
D.	SUM OF 10 CFR 50.46 CHANGES 1. Net Sum of 10 CFR 50.46 PCT Changes	90°F	115°F	
	2. Absolute Sum of 10 CFR 50.46 PCT Changes	90°F	1156°F	
E.	Analysis of Record PCT - Line A + Line D.1 Net Sum of 10 CFR 50.46 PCT Changes	1990°F	1975°F	-

The sum of the PCT from the most recent analysis of record using an acceptable evaluation model and the estimates of the net PCT effect for changes and errors identified since this analysis remains less than 2200°F.

¹ For those issues that have been previously reported under 10 CFR 50.46, a PG&E letter number is listed.

² Only permanent assessments of PCT margin are included. Temporary PCT allocations that address current LOCA model issues are not considered with respect to 10 CFR 50.46 reporting requirements.

DCPP UNIT 2 PEAK CLADDING TEMPERATURE MARGIN UTILIZATION

<u>SM</u>	ALL-BREAK LOCA			PG&E Letter ¹
A.	ANALYSIS OF RECORD	PCT =	1288°F	DCL-08-061
В.	PRIOR 10 CFR 50.46 ECCS MODEL ASSESSMENTS ²			
	1. None	∆PCT =	0°F	
C.	10 CFR 50.46 ECCS MODEL ASSESSMENTS THIS YEAR			
	2. None	∆PCT =	0°F	
D.	SUM OF 10 CFR 50.46 CHANGES			
	3. Net Sum of 10 CFR 50.46 PCT Changes	∆PCT =	0°F	
	 Absolute Sum of 10 CFR 50.46 PCT Changes 	∆PCT =	0°F	
E.	Analysis of Record PCT - Line A + Line D.1 Net Sum of 10 CFR 50.46 PCT Changes		1288°F	_

The sum of the PCT from the most recent analysis of record using an acceptable evaluation model and the estimates of the net PCT effect for changes and errors identified since this analysis remains less than 2200°F.

¹ For those issues that have been previously reported under 10 CFR 50.46, a PG&E Letter number is listed.

² Only permanent assessments of PCT margin are included. Temporary PCT allocations that address current LOCA model issues are not considered with respect to 10 CFR 50.46 reporting requirements.

DCPP UNIT 2 PEAK CLADDING TEMPERATURE MARGIN UTILIZATION

BE	<u>ST-ESTIMATE, LARGE-BREAK LOC</u>	A		PG&E Letter ¹
Α.	ANALYSIS OF RECORD	PCT=	1872°F	DCL-07-071
В.	PRIOR 10 CFR 50.46 ECCS MODEL ASSESSMENTS ²			
	1. HOTSPOT Fuel Relocation Error.	∆PCT=	0°F	DCL-07-071
C.	10 CFR 50.46 ECCS MODEL ASSESSMENTS THIS YEAR			
	 230kV Degraded Voltage Event Evaluation 	∆PCT=	16°F	DCL-11-082
D.	SUM OF 10 CFR 50.46 CHANGES			
	1. Net Sum of 10 CFR 50.46 PCT Changes	∆PCT=	16°F	
	 Absolute Sum of 10 CFR 50.46 PCT Changes 	∆PCT=	16°F	
E.	Analysis of Record PCT - Line A + Line D.1 Net Sum of 10 CFR 50.46 PCT Changes		1888°F	

The sum of the PCT from the most recent analysis of record using an acceptable evaluation model and the estimates of the net PCT effect for changes and errors identified since this analysis remains less than 2200°F.

¹ For those issues that have been previously reported under 10 CFR 50.46, a PG&E letter number is listed.

² Only permanent assessments of PCT margin are included. Temporary PCT allocations that address current LOCA model issues are not considered with respect to 10 CFR 50.46 reporting requirements.