

CHAPTER 1  
INTRODUCTION AND GENERAL DESCRIPTION OF THE PLANT

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.1	INTRODUCTION.....	1.1-1
1.1.1	PLANT LOCATION .....	1.1-1
1.1.5	SCHEDULE.....	1.1-2
1.1.6.1	Regulatory Guide 1.70.....	1.1-2
1.1.6.3	Text, Tables and Figures .....	1.1-2
1.1.6.5	Proprietary Information .....	1.1-3
1.1.6.6	Acronyms.....	1.1-3
1.1.7	COMBINED LICENSE INFORMATION.....	1.1-4
1.2	GENERAL PLANT DESCRIPTION.....	1.2-1
1.2.2	SITE DESCRIPTION.....	1.2-1
1.3	COMPARISONS WITH SIMILAR FACILITY DESIGNS .....	1.3-1
1.4	IDENTIFICATION OF AGENTS AND CONTRACTORS.....	1.4-1
1.4.1	APPLICANT – PROGRAM MANAGER .....	1.4-1
1.4.2.8	Other Contractors .....	1.4-2
1.4.2.8.1	CH2M Hill, Inc. ....	1.4-2
1.4.2.8.2	Sargent & Lundy, LLC.....	1.4-2
1.4.2.8.3	WorleyParsons Resources and Energy.....	1.4-2
1.5	REQUIREMENTS FOR FURTHER TECHNICAL INFORMATION .....	1.5-1
1.6	MATERIAL REFERENCED .....	1.6-1
1.7	DRAWINGS AND OTHER DETAILED INFORMATION.....	1.7-1
1.7.2	PIPING AND INSTRUMENTATION DIAGRAMS.....	1.7-1
1.8	INTERFACES FOR STANDARD DESIGN .....	1.8-1
1.9	COMPLIANCE WITH REGULATORY CRITERIA.....	1.9-1
1.9.1	REGULATORY GUIDES.....	1.9-1
1.9.1.1	Division 1 Regulatory Guides - Power Reactors.....	1.9-1
1.9.1.2	Division 4 Regulatory Guides - Environmental and Siting .....	1.9-2

Levy Nuclear Plant Units 1 and 2  
COL Application  
Part 2, Final Safety Analysis Report

TABLE CONTENTS (Continued)

<u>Section</u>	<u>Title</u>	<u>Page</u>
1.9.1.3	Division 5 Regulatory Guides - Materials and Plant Protection .....	1.9-2
1.9.1.4	Division 8 Regulatory Guides - Occupational Health .....	1.9-3
1.9.1.5	Combined License Information .....	1.9-3
1.9.2	COMPLIANCE WITH STANDARD REVIEW PLAN (NUREG-0800).....	1.9-3
1.9.4.1	Review of NRC List of Unresolved Safety Issues and Generic Safety Issues.....	1.9-4
1.9.4.2.3	New Generic Issues .....	1.9-4
1.9.5.1.5	Station Blackout .....	1.9-6
1.9.5.2.15	Severe Accident Mitigation Design Alternatives.....	1.9-6
1.9.5.5	Operational Experience .....	1.9-7
1.9.6	REFERENCES.....	1.9-7
1.10	NUCLEAR POWER PLANTS TO BE OPERATED ON MULTI-UNIT SITES.....	1.10-1
1.10.1	POTENTIAL CONSTRUCTION ACTIVITY HAZARDS .....	1.10-1
1.10.2	POTENTIALLY IMPACTED SSCs AND LIMITING CONDITIONS FOR OPERATION .....	1.10-2
1.10.3	MANAGERIAL AND ADMINISTRATIVE CONTROLS .....	1.10-2
APP. 1A	CONFORMANCE WITH REGULATORY GUIDES.....	1A-1
APP. 1B	SEVERE ACCIDENT MITIGATION DESIGN ALTERNATIVES .....	1B-1
APP. 1AA	CONFORMANCE WITH REGULATORY GUIDES.....	1AA-1

LIST OF TABLES

<u>Number</u>	<u>Title</u>
1.1-201	Acronyms and Abbreviations Used in the FSAR
1.1-202	Left Margin Annotations
1.1-203	Schedule for Construction and Operation of LNP 1 and LNP 2
1.6-201	Additional Material Referenced
1.7-201	AP1000 System Designators and System Diagrams
1.8-201	Summary of FSAR Departures from the DCD
1.8-202	COL Item Tabulation
1.8-203	Summary of FSAR Discussions of AP1000 Plant Interfaces
1.9-201	Regulatory Guide/FSAR Section Cross-References
1.9-202	Conformance with SRP Acceptance Criteria
1.9-203	Listing of Unresolved Safety Issues and Generic Safety Issues
1.9-204	Generic Communications Assessment
1.10-201	Potential Hazards from Construction Activities
1.10-202	Hazards During Construction Activities
1.10-203	Managerial and Administrative Construction Controls

LIST OF FIGURES

<u>Number</u>	<u>Title</u>
1.1-201	Site Layout

DRAFT

---

CHAPTER 1

**INTRODUCTION AND GENERAL DESCRIPTION OF THE PLANT**

1.1 INTRODUCTION

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

Add the following paragraphs to the end of DCD **Section 1.1**

STD SUP 1.1-1

This Final Safety Analysis Report (FSAR) incorporates the Design Control Document (DCD) (as identified in **Table 1.6-201**) for a simplified passive advanced light water reactor plant provided by Westinghouse Electric Company, the entity originally sponsoring and obtaining the AP1000 design certification documented in 10 CFR Part 52, Appendix D. Throughout this FSAR, the “referenced DCD” is the AP1000 DCD submitted by Westinghouse as Revision 19 including any supplemental material as identified in **Table 1.6-201**. Unless otherwise specified, reference to the DCD refers to Tier 2 information, including references to the sensitive unclassified non-safeguards information (including proprietary information) and safeguards information, contained in the AP1000 DCD. Such DCD information is included in this combined license application in the same manner as it is included in the AP1000 DCD, i.e., references in the DCD are included as references in the FSAR, and material incorporated by reference into the DCD is incorporated by reference into the FSAR. Appropriate agreements are in place to provide for the licensee's rights to possession (including constructive possession) and use of the withheld sensitive unclassified non-safeguards information (including proprietary information) and safeguards information referenced in the AP1000 DCD for the life of the project.

Appendix D to 10 CFR Part 52 is hereby incorporated by reference into the COL application.

---

LNP SUP 1.1-2

This FSAR is hereby submitted under Section 103 of the Atomic Energy Act by Florida Power Corporation, doing business as Progress Energy Florida, Inc. (PEF) to the Nuclear Regulatory Commission (NRC) as part of the application for two Class 103 combined licenses (COLs) to construct and operate two nuclear power plants under the provisions of 10 CFR 52 Subpart C.

---

1.1.1 PLANT LOCATION

---

Add the following text at the beginning of DCD **Subsection 1.1.1**:

LNP COL 2.1-1

The Levy Nuclear Plant Units 1 and 2 (LNP) site is located in Levy County, Florida (**Figure 2.1.1-201**). This is a large, primarily rural area located southwest of Gainesville and west of Ocala and approximately 15.5 kilometers (km) (9.6

---

miles [mi.]) northeast of the Crystal River Energy Complex, an energy facility also owned by PEF (Figure 2.1.1-201). The nearest towns from the site are Inglis and Yankeetown, which are located 6.6 km (4.1 mi.) southwest and 12.9 km (8.0 mi.) southwest from the site, respectively. The Gulf of Mexico is located approximately 12.8 km (7.9 mi.) west of the proposed LNP site and Lake Rousseau lies about 4.8 km (3.0 mi.) to the south (Figure 2.1.1-202).

Figure 2.1.1-201 identifies the site location. Figure 1.1-201 identifies the plant arrangement within the site.

---

#### 1.1.5 SCHEDULE

---

Add the following text to the end of DCD Subsection 1.1.5:

LNP COL 1.1-1

Table 1.1-203 displays the anticipated schedule for construction and operation of two AP1000 units at the LNP site. A site-specific construction plan and startup schedule will be provided to the NRC after issuance of the COL.

---

#### 1.1.6.1 Regulatory Guide 1.70

---

Add the following text to the end of DCD Subsection 1.1.6.1.

STD SUP 1.1-6

This FSAR generally follows the AP1000 DCD organization and numbering. Some organization and numbering differences are adopted where necessary to include additional material, such as additional content identified in Regulatory Guide 1.206. Any exceptions are identified with the appropriate left margin annotation as discussed in Subsection 1.1.6.3 and Table 1.1-202.

---

#### 1.1.6.3 Text, Tables and Figures

---

Add the following text to the end of DCD Subsection 1.1.6.3.

STD SUP 1.1-3

Table 1.1-202 describes the left margin annotations used in this document to identify departures, supplementary information, COL items, and conceptual design information.

FSAR tables, figures, and references are numbered in the same manner as the DCD, but the first new FSAR item is numbered as 201, the second 202, the third 203, and consecutively thereafter. When a table, figure, or reference in the DCD is changed, the change is appropriately left margin annotated as identified above. New appendices are included in the FSAR with double letter designations following the pertinent chapter (e.g., 12AA).

---

When it provides greater contextual clarity, an existing DCD table or figure is revised by adding new information to the table or figure and replacing the DCD table or figure with a new one in the FSAR. In this instance, the revised table or figure clearly identifies the information being added, and retains the same numbering as in the DCD, but the table or figure number is revised to end with the designation "R" to indicate that the table or figure has been revised and replaced. For example, revised "Table 4.2-1" would become "Table 4.2-1R." New and revised tables and figures are labeled in the left margin as described in [Table 1.1-202](#).

---

1.1.6.5 Proprietary Information

---

Insert the following text to the end of DCD [Subsection 1.1.6.5](#).

STD SUP 1.1-4

Some portions of this FSAR may be considered as proprietary, personal, or sensitive and withheld from public disclosure pursuant to 10 CFR 2.390 and Regulatory Issue Summary (RIS) 2005-026. Such material is clearly marked and the withheld material is separately provided for NRC review.

---

1.1.6.6 Acronyms

---

Add the following text to the end of DCD [Subsection 1.1.6.6](#).

LNP SUP 1.1-5

[Table 1.1-201](#) provides a list of acronyms and abbreviations used in the LNP 1 and 2 FSAR in addition to the acronyms identified in DCD [Table 1.1-1](#) and system designation identified in [Table 1.7-201](#) and DCD [Table 1.7-2](#).

---

1.1.7 COMBINED LICENSE INFORMATION

---

Add the following text to the end of DCD [Subsection 1.1.7](#).

LNP COL 1.1-1

This COL Item is addressed in [Subsection 1.1.5](#).

---

DRAFT

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 1 of 33)**  
**Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
°C	degrees Celsius
°F	degrees Fahrenheit
$\chi/Q$	Chi/Q (atmospheric dilution factor)
$\phi'$	effective friction angle
$\phi_{cv}$	critical void ratio friction angle
$\nu$	Poisson's ratio
$\mu\text{m}$	Micrometer
$\mu\text{Ci}/\text{cm}^3$ or $\mu\text{Ci}/\text{cc}$	microcuries per cubic centimeter
$\mu\text{Ci}/\text{ml}$	microcuries per milliliter
2-D	two dimensional
3-D	three-dimensional
$a_{\text{max}}$	peak acceleration
AADT	Average Annual Daily Traffic
AASHTO	American Association of State Highway and Transportation Officials
ac.	Acres
ac.-ft.	acre-feet
ACI	American Concrete Institute
ADAMS	Agencywide Documents Access and Management System
AE	Architect Engineer
AFW	Auxiliary Feedwater System
AMS	American Meteorological Society

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 2 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
amsl	above mean sea level
ANSS	Advanced National Seismic System
AOV	air-operated valve
AP1000	Westinghouse's AP1000 Reactor
$^{40}\text{Ar}/^{39}\text{Ar}$	Argon isotope ratio
ASCE/SEI	American Society of Civil Engineers/Structural Engineering Institute
ASD	Allowable Strength Design
ASOS	Automated Surface Observing System
AST	above ground storage tank
ASTM	American Society for Testing and Materials
BAT	Barten Aerial Technologies
BE	best estimate
BEBR	Bureau of Economic and Business Research
BES	Bulk Electric System
BF – ITAAC	Backfill ITAAC
bgs	below ground surface
BMT	Becker Hammer Test
bpf	blow per foot
B&PVC	Boiler and Pressure Vessel Code
BTOC	below top of casing
Btu/hr	British Thermal Units per hour

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 3 of 33)**  
**Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
BWR	boiling water reactor
$c'$	effective cohesion
$C_{\epsilon\alpha}$	coefficient of secondary compression
$C_c$	compression index
$C_r$	unloading-reloading index
C-I	seismic Category I
C-II	seismic Category II
CAM	Continuous Air Monitors
CAV	cumulative absolute velocity
CCDP	conditional core damage probability
CCTV	Closed Circuit Television
CD	Compact disk
CDDIS	Crustal Dynamics Data Information System
CDE	Committed Dose Equivalent
CDF	core damage frequency
CDI	Conceptual Design Information
CDL	clandestine drug lab
CEDE	Committed Effective Dose Equivalent
CEO	Chief Executive Officer
CEUS	central and eastern United States
CFBC	Cross Florida Barge Canal
cfs	cubic feet per second

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 4 of 33)**  
**Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
CH	fat clay
Chi/Q	atmospheric dilution factor
CL	lean clay
CLSM	controlled low strength material
cm	centimeter
cm <sup>3</sup> /cm <sup>3</sup>	cubic centimeter per cubic centimeter
cm/5 min	centimeter per 5 minutes
cm/hr	centimeter per hour
cm/sec	centimeters per second
cm <sup>2</sup> /sec	square centimeters per second
cm <sup>3</sup> /sec	cubic centimeters per second
CMT	centroid-moment-tensor
cm/y	centimeters per year
CNO	Chief Nuclear Officer
CO	carbon monoxide
Co-58	cobalt isotope 58
Co-60	cobalt isotope 60
COC	cycles of concentration
COCORP	Consortium for Continental Reflection Profiling
COL	Combined License
COLA	Combined License Application
conc.	concentration

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 5 of 33)**  
**Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
CP&L	Carolina Power and Light Company
CPT	cone penetrometer test
cps	counts per second
CR	control room
CR3	Crystal River Unit No. 3 Nuclear Generating Plant
Cr-51	chromium isotope 51
CREC	Crystal River Energy Complex
CRR	Cyclic Resistance Ratio
CRS	Control Room Supervisor
CS	Creedmoor segment
CSDRS	certified design seismic design response spectra
CSR	Cyclic Stress Ratio
CSX	CSX Transportation, Inc.
CU	consolidated-undrained
CVS	Chemical Volume and Control System
d	distance from airport in kilometers (miles)
D	disturbance factor
$d_{max}$	maximum required depth for engineering purposes
$D_r$	relative density
DAC	Derived Air Concentration
DAC-hr	Derived Air Concentration-hr
DAM	Dames & Moore

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 6 of 33)**  
**Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
days <sup>-1</sup>	1 per day
DCD	Westinghouse Electric Company, LLC, AP1000 Design Control Document for the certified design as amended
DE	deaggregation earthquake
DEC	Duke Energy Corporation
DEH	high-magnitude deaggregation earthquake
DEL	low-magnitude deaggregation earthquake
DEM	middle-magnitude deaggregation earthquake
DEM	Digital Elevation Model
DEP	Department of Environmental Protection
DF	design factor
DHBRC	Department of Health, Bureau of Radiation Control
DHQ	mean diurnal high water inequality
DLQ	mean diurnal low water inequality
DNAG	Decade of North American Geology/the Geological Society of America's program that includes the Magnetic Anomaly Map of North America
DOT	Florida Department of Transportation
D/Q	Relative Deposition Factor
DRAP	Reliability Assurance Program for the design phase
DTL	mean diurnal tide level
DTPG	defined test plan groups
E	East

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 7 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
E	elastic Young's modulus
E <sub>50</sub>	half of the failure stress
E <sub>pmt</sub>	rock pressuremeter test modulus
E <sub>rm</sub>	rock mass modulus
E-F	Enhanced-Fujita Tornado Scale
E&I	Environment and Infrastructure
EAB	exclusion area boundary
EAL	Emergency Action Level
ECC-GC	Extended Continental Crust-Gulf Coast
ECCS	Emergency Core Cooling System
ECFS	East Coast fault system
ECL	effluent concentration limit
ECS	Emergency Communications System
EDIS	Economic Development Information System
EDR	Environmental Data Resources. Inc.
EDTA	Ethylenediaminetetraacetic Acid
Emb	expected estimate of body wave magnitude
EnC	Enon fine sand loam occurs on slopes of 6 to 10 percent
ENE	east-northeast
ENS	Emergency Notification System
EOC	Emergency Operations Centers
EOF	Emergency Operations Facility

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 8 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
EOP	emergency operating procedure
EPC	engineering, procurement, and construction
EPRI-SOG	Electric Power Research Institute-Seismic Owners Group
EP-ITAAC	Emergency Planning-ITAAC
EQ	Environmental Qualification
EQMEL	Environmental Qualification Master Equipment List
ERDS	Emergency Response Data System
ERNS	Emergency Response Notification System
ERO	Emergency Response Organization
ESE	east-southeast
ESP	Early Site Permit
ESATCOM	Florida Emergency Satellite Communications system
EST	earth science team
ETSZ	East Tennessee seismic zone
E-W or EW	east-west
EWD	Engineering Weather Data
F <sub>a</sub>	amplification factor
F0	Fujita tornado scale intensity 40 – 72 mph
F1	Fujita tornado scale intensity 73 – 112 mph
F2	Fujita tornado scale intensity 113 – 157 mph
F3	Fujita tornado scale intensity 158 – 206 mph

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 9 of 33)**  
**Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
F4	Fujita tornado scale intensity 207 – 260 mph
F5	Fujita tornado scale intensity 261 – 318 mph
FAC	flow accelerated corrosion
FAA	Federal Aviation Administration
FAS	Floridan aquifer system
FB	Fault B
FC	Fault C
FDEP	Florida Department of Environmental Protection
FDLE	Florida Department of Law Enforcement
Fe-55	iron isotope 55
Fe-59	iron isotope 59
FEM	finite element model
FEMA	Federal Emergency Management Agency
FERC	Federal Energy Regulatory Commission
FFA	flood frequency analysis
FFD	Fitness for Duty
FGDL	Florida Geographic Data Library
FGS	Florida Geological Survey
FGT	Florida Gas Transmission Company
FHA	Fire Hazards Analysis
FHB	Fuel Handling Building
FIPS	Federal Information Processing Standards

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 10 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
FIRS	foundation input response spectra
FMG	Failure Mode Groups
fps	feet per second
FRCC	Florida Reliability Coordinating Council
FRS	Facility Registry Building
FS	factor of safety
FSAR	Final Safety Analysis Report
FSER	Final Safety Evaluation Report
ft.	foot/feet
ft <sup>2</sup>	square feet
ft/day	feet per day
ft <sup>2</sup> /day	square feet per day
ft <sup>3</sup> /day	cubic feet per day
ft/ft	feet per foot
ft/mi	Foot per mile
ft/sec or f/s	feet per second
FTS	Federal Telephone System
g	gram
G	shear modulus
g	gravity acceleration
g/cm <sup>3</sup>	grams per cubic centimeter
Ga	billion per year

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 11 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
gal.	gallon
gal/ft <sup>3</sup>	gallon per cubic foot
GC	clayey gravel
GCSZ	Gulf Coastal Source Zones
GCVSZ	Giles County, Virginia, seismic zone
GG&S	Geotechnical, Geological, and Seismological
GI-LLI	gastrointestinal tract-lower large intestine (ingestion pathway organ)
GIS	Geographic Information System
GL	ground level
GMRS	ground motion response spectrum
GMT	Greenwich Mean Time
gpd	gallon per day
gpd/ft	gallon per day per foot
gpm or gal/min	gallons per minute
gpm/ft	gallon per minute per foot
GSI	geologic strength index
GSU	main setup transformer
GT	Great Diurnal Range
h or hr.	hour
H1	Category 1 hurricane
H2	Category 2 hurricane

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 12 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
H3	Category 3 hurricane
ha	hectares
ha	mangrove-swamp deposits
ha-m	hectare-meter
HAR	Shearon Harris Nuclear Power Plant
HCL	hydrochloric acid
HCLPF	high confidence, low probability of failure
HEC-HMS	Hydrologic Engineering Center-Hydrologic Modeling System
HEC-RAS	Hydrologic Engineering Center – River Analysis System
HE&EC	Harris Energy and Environmental Center
HES	Hurricane Evacuation Studies
HF	high-frequency
HiRAT	High Resolution Acoustic Televiewer probe
HMG	High Mobility Grout
HMR	Hydrometeorological Report
hPa/mb	hectoPascal/milliBar
HPN	Health Physics Network
HQWL	type of rock coring tool
HRHF	hard rock high frequency
hr.	hour
hrs/yr	Hours per year

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 13 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
HSS	Holly Springs segment
HV	high voltage
HWI	Greenwich high water interval (in hours)
Hz	Hertz
I <sub>50</sub>	point load index
I-75	Interstate 75
IBC	International Building Code
ICIS	Integrated Compliance Information System
in.	inch
in/5 min	inch per 5 minutes
in./hr	inches per hour
in/in	inch per inches
ISG	Interim Staff Guidance
ISO	Independent System Operator
ISRM	International Society of Rock Mechanics
ITA	inspections, tests, or analyses
ITP	Initial Test Plan
JOG	Joint Owners Group
JPM	job performance measures
JTG	Joint Test Group
JTWG	Joint Test Working Group
k	standard deviation of In

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 14 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
ka	thousand years before present
kcf	kips per cubic foot
kg	kilogram
kg/m <sup>2</sup>	kilograms per square meter
kg/yr	kilograms per year
kip	kilopound (1000 pounds)
kips/ft <sup>3</sup>	kips per cubic foot
km	kilometer
km <sup>2</sup>	square kilometers
km/h or km/hr	kilometers per hour
kPa	Kilopascals
kPa/sec	kilopascals per second
ksf	kips per square foot
ksi	kips per square inch
KTS	knots
kV	kilovolt
kVA	kilovoltampere
l or L	liter
L/cm <sup>3</sup>	liters per cubic centimeter
l/day or L/day	liters per day
l/min, L/min, lpm	liters per minute

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 15 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
l/yr or L/yr	liters per year
LAN	Local Area Network
LB	lower bound
lb.	pound
lb/ft <sup>2</sup>	pounds per square foot
lb/in <sup>2</sup>	pounds per square inch
lb/m <sup>2</sup>	pounds per square meter
lbs	Pounds
LCD	local climatological data
LCFS	Central Florida South
LCO	Limiting Conditions for Operations
LER	licensee event report
LF	low-frequency, nominally 1 to 2.5 Hz
LFL	Lower flammability limit
LiDAR and LIDAR	light detection and ranging
LLB	Lower Lower Bound
LLNL	Lawrence Livermore National Laboratory
LMG	low mobility grout
LNP 1	Levy Nuclear Plant, Unit 1
LNP 2	Levy Nuclear Plant, Unit 2
LNP or LNP 1 and 2	Levy Nuclear Plant, Units 1 and 2
LOSP	loss of off-site power

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 16 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
LPC	Citrus 1 and Citrus 2
lpd	liters per day
LPG	liquefied petroleum gas
lpm	liters per minute
LPZ	low population zone
LSI	Liquefaction Severity Index
LT	local time
LUST	leaking underground storage tank
LWI	Greenwich low water interval (in hours)
LWSP	Local Water Supply Plan
m	meter
<b>M</b>	moment magnitude
$m_b$	body-wave magnitude
$M_d$	duration magnitude
$m_i$	material constant
$M_l$	intensity magnitude (considered equivalent to M)
$M_l$	local magnitude
$M_{max}$	maximum magnitude
$M_{sw}$	surface wave magnitude
$M_s$	surface-wave magnitude
$M_w$	moment magnitude
m/km	meters per kilometer

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 17 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
m/s or m/sec	meters per second
m <sup>-2</sup>	1/m <sup>2</sup>
m <sup>2</sup>	square meters
m <sup>2</sup> /day	square meters per day
m <sup>3</sup>	cubic meters
m <sup>3</sup> /s	cubic meters per second
Ma	million years before present
MAT	maximum astronomical tide
mb	beach and near shore deposits
mb	millibar
mb/s	millibars per seconds
MCL	Management Counterpart Link
MCS	Monte Carlo Simulations
MCSB	Mid-Cretaceous Sequence Boundary
MCU	Middle Counting Unit
MEOW	maximum envelope of water
MESE	Mesozoic and younger crustal region
mGal	milligal
mgd	million gallons per day
MH	elastic silt
MHHW	mean higher high water
MHW	mean high water

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 18 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
mi.	mile(s)
mi. <sup>2</sup>	square miles
mi. <sup>3</sup>	cubic miles
mi/hr	mile per hour
min	minute
MIS	marine oxygen isotope stage
Mg	milligram
MH	elastic silt
MHHW	mean higher high water
MHW	mean high water
ml	milliliter
ML	Silt
ml/d	milliliters per day
MLE	maximum likelihood estimate
ml/g	milliliters per gram
MLU	Multi-Layer Unsteady State
MLLW	mean lower low water
MLW	mean low water
mm	millimeter
MM	Modified Mercalli
MMI	Modified Mercalli Intensity
mm/h	millimeters per hour

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 19 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
mm/yr	millimeters per year
mm <sup>2</sup> /s	square millimeters per second
MMI	Modified Mercalli Intensity
MN	mean range of tide
MOM	Maximum of Maximum
MPa	megaPascal
mph	miles per hour
MPSSZ	Middleton Place-Summerville seismic zone
MR	Maintenance Rule
mrad	millirad
mrem	millirem
mrem/yr	millirem per year
MSF	magnitude scaling factor
msl	mean seal level
mS/m	Millisiemens per meter
MSPI	mitigating systems performance indicators
mSv	milliSievert
MT	magnetic particle
MTL	mean tide level
MVA	megavoltampere
m.y.	million years
N	SPT blowcount

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 20 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
N	North
N <sub>60</sub>	SPT blow counts corrected for a hammer with 60 percent energy transfer efficiency
NA, N/A	not applicable
Na, NA	not available
NAAQS	national ambient air quality standards
NAMAG	North American Magnetic Anomaly Group
NASA	National Aeronautics and Space Administration
NAV	Avon Park Rock at the north reactor site
NAV-1	LNP 2 Avon Park Limestone
NAVD	North American Vertical Datum
NAVD 1988	North American Vertical Datum of 1988
NAVD88	North American Vertical Datum of 1988
NCDC	National Climatic Data Center
NCEDC	Northern California Earthquake Data Center
NCEER	National Center for Earthquake Engineering Research
ND	no data available/ no data recorded for parameter
NDE	non-destructive examination
NE	northeast
NED	National Elevation Dataset
NEIC	National earthquake Information Center
NERC	North American Reliability Electric Corporation

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 21 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
NESC	National Electric Safety Code
NGA	Next Generation Attenuation Project
NGDC	National Geophysical Data Center
NGS	National Geodetic Survey
NGVD29	National Geodetic Vertical Datum of 1929
NHC	National Hurricane Center
NHVRy	New Hope Valley Railway
NI	nuclear island
NIOSH	National Institute for Occupational Safety and Health
NIST	National Institute of Standards and Technology
NLO	non-licensed operator
NMESE	Mesozoic and older crustal region
NNE	north-northeast
NNW	north-northwest
NOAA	National Oceanic and Atmospheric Administration
NOS	Nuclear Oversight Section
NPD	Nuclear Plant Development
NPDES	National Pollution discharge Elimination System
NQWL	type of rock coring tool
NRC	U.S. Nuclear Regulatory Commission
NRCS	U.S. Department of Agriculture, Natural Resources Conservation Service

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 22 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
N-S	north-south
NS	Non-seismic
NSM	Nuclear Shift Manager
Nuc Ops	Nuclear Operations
NW	northwest
NWS	National Weather Service
OBE	Operating Basis Earthquake
OCB	oceanic convergent boundary
OCL	Operations Center line
OCR	over-consolidation ratio
ODCM	Off-Site Dose Calculation Manual
OE	operating experience information
Ohm-cm	Ohm-centimeter
OJT	on-the-job training
OM	Operations and Maintenance
OSC	Operations Support Center
OTF	oceanic transform fault
P*	Probability an EPRI-SOG seismic source is active
PBSRS	performance based surface horizontal and vertical response spectra
pcf	pounds per cubic foot
PCP	Process Control Program

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 23 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
PE&RAS	Performance Evaluation and Regulatory Affairs Section
PEC	Progress Energy Carolinas, Inc.
PEER	Pacific Earthquake Engineering Research Center
PEF	Progress Energy Florida, Inc.
PEZ	Paleozoic Extended Zone
person-hrs/year	person-hours per year
PGA	peak ground acceleration
PGM	Plant General Manager
pH	hydrogen (ion) concentration
PLS	Public Land Survey
PLT	point-load test
PM <sub>2.5</sub>	particulate matter of 2.5 μm and smaller
PM <sub>10</sub>	particulate matter of 10 μm and smaller
PMCL	Protective Measures Counterpart Link
PMF	probable maximum flood
PMH	probable maximum hurricane
PMP	probable maximum precipitation
PMS	probable maximum surge
PMT	probable maximum tsunami
PMT	pressure meter test
PMWP	probable maximum winter precipitation

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 24 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
POR	period of record
PORC	Plant Owner's Operations Review Committee
PORV	power operated relief valve
ppsm	people per square mile
PR	Peninsula Range
P-S	P- and S-wave (compression and shear wave)
psf	pounds per square foot
PS-ITAAC	Physical Security-ITAAC
PSHA	probabilistic seismic hazard analysis
psi	pounds per square inch
psi/sec	pounds per square inch per second
PST	preservice test
PR	Peninsula Range
PT	liquid penetrant
PTAC	Plant Transmission Activities Coordinator
PT&O	Plant Test and Operation
pu	per unit
P-wave	primary wave
PZR	Pressurizer
Qal	Quaternary alluvium
QAPD	Quality Assurance Program Description

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 25 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
QC	Quality Control
QAPD	Quality Assurance Program Description
QMS	Westinghouse Quality Management System
Q/T	Quaternary/Tertiary
R0	extremely weak rock
R1	very weak rock
R2	weak rock
R3	medium weak rock
R4	strong rock
RAI	request for additional information
RAT	Reserve Auxiliary Transformer
Rb-Sr	rubidium-strontium
RCA	Radiological Controlled Area
RCC	roller compacted concrete
RCPB	reactor coolant pressure boundary
RCRIS	Resource Conservation and Recovery Information Service
RCPB	reactor coolant pressure boundary
RCRIS	Resource Conservation and Recovery Information Service
re	sandy solution residuum
RE	reference (controlling) earthquake

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 26 of 33)**  
**Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
RG	Regulatory Guide
RHR	residual heat removal
RIS	Regulatory Issue Summary
RLME	repeated large magnitude earthquake
RO	Reactor Operator
RP	radiation protection
RPS	Reactor Protection System
RPT	Radiation Protection Technician
RQD	rock quality designation
RRS	required response spectrum
RSCL	Reactor Safety Counterpart Link
RT	radiography techniques
RTDP	Revised Thermal Design Procedure
RTH	Rock Testing Handbook
RTNSS	Regulatory Treatment of Non-Safety Systems
RTO	Regional Transmission Organization
RV	recreational vehicle
S	south
Shmax	maximum horizontal stress axis
S-1	top soil layer
S-2	immediate soil layer

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 27 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
S-3	bottom soil layer
$S_{hmin}$	minimum horizontal stress axis
$S_u$	undrained shear strength
S-SO	Superintendent – Shift Operations
SA	Spectral Acceleration
SAMDA	Severe Accident Mitigation Design Alternatives
SAMG	Severe Accident Management Guidance
SAMSON	Solar and Meteorological Surface Observation Network
SASW	spectral analysis of surface waves
SAV	Avon Park Rock at the south reactor site
SAV-1	LNP 1 Avon Park Limestone
SBO	station blackout
SC	clayey sand
SCBA	self-contained breathing apparatus
SC DOT	South Carolina Department of Transportation
SCOR	soil column outcrop response spectra
SCR	stable continental region
SDP	Significance Determination Process
SE	southeast
Sec	second
$sec/m^3$	seconds per cubic meter
SECY	NRC Office of the Secretary

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 28 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
SEI/ASCE	Structural Engineering Institute/American Society of Civil Engineers
SERC	Southeastern Electric Reliability Corporation
SGTR	steam generator tube rupture
SIWP	Site Investigation Work Plan
SLOSH	Mathematical model that stands for sea, lake, and overland surge from hurricanes
sm	silty sand
SM	Shift Manager
SNC	Southern Nuclear Company
SNM	Special Nuclear Material
SO <sub>2</sub>	sulphur dioxide
SOC	Security Operations Center
SOFIA	Southern Florida Information Access
SOG	Seismic Owners Group
SOV	solenoid-operated valve
SP	poorly graded sand
SPN	shotpoint number
SP-SM	poorly graded sand and silty sand
SPT	standard penetration testing
sq. ft.	square foot
SQG	small quantities generated
SR	soft rock

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 29 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
SR	State Route
Sr-89	Strontium isotope 89
Sr-90	Strontium isotope 90
SRO	Senior Reactor Operator
SRWMD	Suwannee River Water Management District
SSC	Seismic Source Characterization
SSC	Structures, Systems, and Components
SSE	safe shutdown earthquake
SSE	south-southeast
SSHAC	Senior Seismic Hazard Analysis Committee
SS-ITAAC	Site-Specific ITAAC
SSW	south-southwest
STA	Shift Technical Advisor
STP	South Texas Project
STPNOC	STP Nuclear Operating Company
SUB	subduction zone
SV	safety valve
Sv	Sievert
SW	southwest
SWAPP	Source Water Assessment and Protection Program
SWFWMD	South West Florida Water Management District
SWPT	State Warning Point – Tallahassee

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 30 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
T	trace amount
T	transmissivity
Tap	Avon Park Formation
TD	total depth
TD	tropical depression
TE	equivalent period of completeness
TEDE	Total Effective Dose Equivalent
TFR	temporary flight restriction
Tha	Hawthorne Group, Arcadia Foundation
That	Hawthorne Group, Tampa Member
TIP	Trial Implementation Program
TMI	Three Mile Island
TNT	Trinitrotoluene
To	Upper Eocene Ocala Limestone
TOC	top of casing
Ts	Lower Oligocene Suwannee Limestone
TS	Technical Specification(s)
TS	tropical storm(s)
TSO	Transmission System Operator
TSCSR	Truncated Soil Column Surface Response
TSP	Transmission System Provider

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 31 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
TRS	test response spectrum
TVA	Tennessee Valley Authority
TWTT	two-way travel time
UAT	Unit Auxiliary Transformer
UB	upper bound
UCO	Unit Control Operator
UCS	unconfined compressive strength
UCSS	updated Charleston seismic source
UHRS	uniform hazard response spectra
USACE	U.S. Army Corps of Engineers
USBR	U.S. Department of the Interior, Bureau of Reclamation
USCO	Unit Senior Control Operator
USD	Ultimate Strength Design
USDA	U. S. Department of Agriculture
USEPA	U. S. Environmental Protection Agency
USGS	U. S. Geological Survey
UST	underground storage tank
UT	ultrasonic techniques
UTC	Coordinated Universal Time
UTM	Universal Transverse Mercator
$\nu$	Poisson's ratio
V	Volt

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 32 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
V <sub>p</sub>	compressional wave velocity
V <sub>s</sub>	shear wave velocity
V/H	vertical to horizontal
V&V	Verification and Validation
VP-NP&C	Vice President – Nuclear Projects and Construction
VT-1, -2, -3	direct visual
W	West
WAC	Waste Acceptance Criteria
WEC	Westinghouse Electric Company
Westinghouse	Westinghouse Electric Company, LLC
WGC	Weston Geophysical
WLS	liquid radwaste system
WNW	west-northwest
Wo	open water
WNW	west-northwest
WSS	solid radwaste system
WSW	worst meteorological sector
WSW	west-southwest
WTP	water treatment plant
Wts.	weight
WUS	western United States
ww	wastewater

LNP SUP 1.1-5

**Table 1.1-201 (Sheet 33 of 33)  
Acronyms and Abbreviations Used in the FSAR**

Acronym/Abbreviation	Definition
X/Q	atmospheric dilution factor
yrs	Years
zc	decomposition residuum on sand or mixed-composition sand and gravel on upland surfaces
zp	Smectitic-clay decomposition residuum
ZPA	zero period acceleration
ZRA	zone of river anomalies

DRAFT

STD SUP 1.1-3

**Table 1.1-202 (Sheet 1 of 2)  
Left Margin Annotations**

Margin Notation	Definition and Use
STD DEP X.Y.Z-#	<p>FSAR information that departs from the generic DCD and is common for parallel applicants. Each Standard Departure is numbered separately at an appropriate level, e.g.,</p> <p>STD DEP 9.2-1, or STD DEP 9.2.1-1</p>
NPP DEP X.Y.Z-#	<p>FSAR information that departs from the generic DCD and is plant specific. NPP is replaced with a plant specific identifier. Each Departure item is numbered separately at an appropriate subsection level, e.g.,</p> <p>NPP DEP 9.2-2, or NPP DEP 9.2.1-2</p>
STD COL X.Y-#	<p>FSAR information that addresses a DCD Combined License Information item and is common to other COL applicants. Each COL item is numbered as identified in DCD <a href="#">Table 1.8-2</a> and FSAR <a href="#">Table 1.8-202</a>, e.g.,</p> <p>STD COL 4.4-1, or STD COL 19.59.10.5-1</p>
NPP COL X.Y-#	<p>FSAR information that addresses a DCD Combined License Information item and is plant specific. NPP is replaced with a plant specific identifier. Each COL item is numbered as identified in DCD <a href="#">Table 1.8-2</a> and FSAR <a href="#">Table 1.8-202</a>, e.g.,</p> <p>NPP COL 4.4-1, or NPP COL 19.59.10.5-1</p>
NPP CDI or STD CDI	<p>FSAR information that addresses DCD Conceptual Design Information (CDI). Replacement design information is generally plant specific; however, some may be common to other applicants. NPP is replaced with a plant specific identifier. STD is used if it is common. CDI information replacements are not numbered.</p>

STD SUP 1.1-3

**Table 1.1-202 (Sheet 2 of 2)**  
**Left Margin Annotations**

Margin Notation	Definition and Use
STD SUP X.Y-#	FSAR information that supplements the material in the DCD and is common to other COL applicants. Each SUP item is numbered separately at an appropriate subsection level, e.g.,  STD SUP 1.10-1, or STD SUP 9.5.1-1
NPP SUP X.Y-#	FSAR information that supplements the material in the DCD and is plant specific. NPP is replaced with a plant specific identifier. Each SUP item is numbered separately at an appropriate subsection level, e.g.,  NPP SUP 3.10-1, or NPP SUP 9.2.5-1
DCD	FSAR information that duplicates material in the DCD. Such information from the DCD is repeated in the FSAR only in instances determined necessary to provide contextual clarity.

LNP COL 1.1-1

**Table 1.1-203  
Schedule for Construction and Operation of LNP 1 and LNP 2**

Activity	Start	Finish
<b><u>LNP 1</u></b>		
Early Procurement Activities	1 <sup>st</sup> Quarter 2008	
Site Preparation	3 <sup>rd</sup> Quarter 2013	
Commence Construction (Safety-Related Activities)	3 <sup>rd</sup> Quarter 2016 (or later)	
Fuel Load, Commence Start-Up	3 <sup>rd</sup> Quarter 2023 (or later)	
Commence Operation		2 <sup>nd</sup> Quarter 2024 (or later)
<b><u>LNP 2</u></b>		
Site Preparation	3 <sup>rd</sup> Quarter 2013	
Commence Construction (Safety-Related Activities)	3 <sup>rd</sup> Quarter 2016 (or later)	
Fuel Load, Commence Start-Up	1 <sup>st</sup> Quarter 2025 (or later)	
Commence Operation		4 <sup>th</sup> Quarter 2025 (or later)

## 1.2 GENERAL PLANT DESCRIPTION

This section of the referenced DCD is incorporated by reference with the following departures and/or supplements.

### 1.2.2 SITE DESCRIPTION

---

In Subsection 1.2.2 of the DCD, replace the information entitled "Site Plan" with the following text.

#### Site Plan

LNP COL 2.1-1  
LNP COL 3.3-1  
LNP COL 3.5-1

A typical site plan for a single unit AP1000 reference unit is shown in DCD Figure 1.2-2. The directions north, south, east, and west used in this description are the conventions used in the DCD for the orientation of AP1000 structures and equipment and differ from geographic north, south, east and west.

The site plan for LNP 1 and 2 is shown on Figure 1.1-201. Principal structures and facilities, parking areas, and roads are illustrated. Orientation of the two AP1000 units is such that "plant north" faces 45 degrees east from true north. Unless otherwise noted, directions in this FSAR are based on true north. Similarly, plant elevation in the DCD is 100'-0", whereas the plant building floor elevation for NGVD 88 is Elevation 51'-0"; therefore, DCD elevations are to be decreased by 49 ft. to be actual site elevations. The plant building floor elevation for design is NGVD 88 Elevation 51'-0" and corresponds to DCD Elevation 100'-0". The actual plant grade floor elevation will vary to accommodate floor slope and layout requirements.

As stated in DCD Subsection 1.2.1.6.1, the power block complex consists of five principal building structures: the nuclear island, the turbine building, the annex building, the diesel generator building, and the radwaste building. Each of these building structures is constructed on an individual basemat. The nuclear island consists of the containment building, the shield building, and the auxiliary building, all of which are constructed on a common basemat.

DCD Figure 1.2-3 provides a functional representation of the principal systems and components that are located in each of the key AP1000 buildings. This figure identifies major systems and components that are contained in these structures.

Each of the two main cooling tower-circulating water pump complexes consist of mechanical draft cooling towers, a pump basin, circulating water pumps, and associated piping. The cooling towers are located west of the reactors. The circulating pumps are located near the cooling towers. The pumps circulate the cooling water from the pump basin to the main condensers and back to the cooling towers.

The makeup water pumps that provide makeup water to the circulating water system (part of the raw water pump system [RWS], saltwater subsystem) is

Levy Nuclear Plant Units 1 and 2  
COL Application  
Part 2, Final Safety Analysis Report

located south of the plant on the Cross Florida Barge Canal (CFBC). The pumps and wells of the RWS freshwater subsystem that supply the makeup requirements of the other plant systems are located south of the plant.

Road access to the site is from the west.

Construction of the LNP will utilize a barge slip located on the northern bank of the CFBC at the end of the barge slip access road from County Road 40 (CR-40). A heavy haul road will be used to transport equipment and materials from CR-40 to the LNP site.

During construction, a heavy lift crane is used to place major pieces of equipment such as the turbine-generator, the reactor vessel, the steam generators, containment ring sections, large structural modules, and other large or heavy equipment modules.

---

DRAFT

### 1.3 COMPARISONS WITH SIMILAR FACILITY DESIGNS

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

DRAFT

---

## 1.4 IDENTIFICATION OF AGENTS AND CONTRACTORS

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

### 1.4.1 APPLICANT – PROGRAM MANAGER

---

Add the following paragraphs as the first three paragraphs in DCD **Subsection 1.4.1**.

- LNP SUP 1.4-1 Progress Energy Florida, Inc., (PEF) is the applicant for Combined Licenses for Levy Nuclear Plant Units 1 and 2 (LNP 1 and 2) and will own and operate LNP 1 and 2. PEF is a subsidiary of Progress Energy, Inc., an energy company based in Raleigh, North Carolina. Progress Energy, Inc. is a wholly-owned subsidiary of Duke Energy Corporation, an energy company based in Charlotte, North Carolina. PEF provides electricity and related services in central and northern Florida. The company serves more than 1.7 million customers in Florida.
- Duke has over 45 years of experience in the design, construction and operation of nuclear power stations, and currently has twelve nuclear operating units.
- Duke Energy Corporation (DEC), the largest electric power company in the United States, supplies and delivers energy to 7.1 million US customers. The company has over 58,000 megawatts of electric generating capacity in the Midwest, Florida and the Carolinas.
- On December 31, 2008, PEF executed a contract for Engineering, Procurement, and Construction (EPC) of LNP 1 and 2 with a Consortium comprised of Westinghouse and Stone & Webster, Inc. (also referred to herein as Shaw Stone & Webster or simply Shaw). The Consortium will act as the AP1000 provider and architect-engineer for LNP 1 and 2. PEF, as the constructor of LNP, has delegated responsibility for physical construction activities to the Consortium.

---

Add the following paragraphs to the end of DCD **Subsection 1.4.1**:

Contractors participating in the preparation of the COL Application are addressed in **Subsection 1.4.2.8**.

- LNP SUP 1.4-2 Shaw is a Fortune 500 company which has been an active participant in the nuclear industry for nearly 60 years, from providing engineering and design services for Shippingsport, the nation's first commercial nuclear power plant, to the restart of Tennessee Valley Authority's Browns Ferry Unit 1, which at the time was the largest nuclear construction project in the western hemisphere. Shaw continues to prove its leadership role in the nuclear industry by being part of the AP1000 Consortium. Shaw is part of a vertically integrated company, Shaw

---

Group, Inc., which has nearly 180 offices worldwide and over 21,000 employees, of which approximately 3,100 are nuclear professionals offering nuclear services on four continents.

Westinghouse is responsible for the overall plant design, AP1000 Design Certification revisions, procurement of primary NSSS equipment and power block major components including the Turbine Generator, and plant training simulator. Shaw is responsible for site development, construction, site specific design related work, secondary equipment procurement, module fabrication, and supply of bulk materials and commodities. Westinghouse and Shaw are jointly responsible for testing and startup. Fuel supply will be provided by Westinghouse under a separate contract.

---

Add the following new subsection after DCD [Subsection 1.4.2.7](#):

LNP SUP 1.4-3      1.4.2.8      Other Contractors

Contractual relationships have been established with specialized consulting firms to assist in preparing the COL Application for LNP 1 and 2.

1.4.2.8.1      CH2M Hill, Inc.

CH2M Hill, Inc. is a full-service engineering, consulting, construction, and operations firm. They have experience in providing services in siting, licensing, site safety analysis reports, environmental reports, and emergency plans. CH2M Hill has demonstrated expertise with all aspects of nuclear facility development.

CH2M Hill, Inc has provided siting, environmental, emergency planning, site redress, geotechnical field investigation, geological, and seismological services to prepare the COL application for PEF.

1.4.2.8.2      Sargent & Lundy, LLC

Sargent & Lundy, LLC is a full-service architect-engineering firm with considerable nuclear plant expertise. The firm has demonstrated and proven capabilities in the design and licensing of nuclear plants both domestically and overseas. Sargent & Lundy, LLC has engineered, designed, planned, evaluated, and managed large, complex nuclear projects including 30 nuclear units.

Sargent & Lundy, LLC has provided engineering, management, and consulting services to prepare the COL application for PEF. This included project management and engineering services, developing Final Safety Analysis Report sections, developing the security plan, and preparing the COL application.

1.4.2.8.3      WorleyParsons Resources and Energy

WorleyParsons Resources and Energy is a full-service engineering firm with considerable nuclear plant expertise. The firm has demonstrated and proven

---

capabilities in the design and licensing of nuclear plants both domestically and overseas. WorleyParsons Resources and Energy has engineered, designed, planned, evaluated, and managed large, complex nuclear projects including 16 nuclear units and been involved in the development of an early site permit.

WorleyParsons Resources and Energy has provided engineering and consulting services to prepare the COL application for PEF. This included project management and engineering services, developing Final Safety Analysis Report sections, and preparing the COL application.

---

DRAFT

---

## 1.5 REQUIREMENTS FOR FURTHER TECHNICAL INFORMATION

This **section** of the referenced DCD is incorporated by reference with no departures or supplements.

DRAFT

1.6 MATERIAL REFERENCED

This **section** of the referenced DCD is incorporated by reference with the following departures and/or supplements.

---

Add the following text to the end of DCD **Section 1.6**.

STD SUP 1.6-1

**Table 1.6-201** provides a list of the various technical documents incorporated by reference in the FSAR in addition to those technical documents incorporated by reference in the AP1000 DCD.

---

DRAFT

**Table 1.6-201 (Sheet 1 of 2)  
Additional Material Referenced**

	Author/ Report Number <sup>(a)</sup>	Title	Revision	FSAR Section	Document Transmittal	ADAMS Accession Number
STD SUP 1.6-1	Westinghouse/ APP-GW-GL-700	AP1000 Design Control Document	19	All	June 2011	ML11171A500
	NEI 07-08A	Generic FSAR Template Guidance for Ensuring That Occupational Radiation Exposures Are As Low As Is Reasonably Achievable (ALARA)	0	12.1	October 2009	ML093220164
	NEI 07-03A	Generic FSAR Template Guidance for Radiation Protection Program Description	0	Appendix 12AA	May 2009	ML091490684
	NEI 06-13A	Template for an Industry Training Program Description	2	13.2	March 2009	ML090910554
	NEI 07-02A	Generic FSAR Template Guidance for Maintenance Rule Program Description for Plants Licensed Under 10 CFR Part 52	0	17.6	March 2008	ML080910149
	10 CFR Part 52 Appendix D	Design Certification Rule for the AP1000 Design	--	1.1	--	--
LNP SUP 1.6-1	EP	LNP 1 and 2 Emergency Plan	4	13.3	July 2012	TBD
	Security Plans	Physical Security Plan	4	13.6	June 2011	(b)
	Security Plans	Training and Qualification Plan	4	13.6	June 2011	(b)

**Table 1.6-201 (Sheet 2 of 2)  
Additional Material Referenced**

	Author/ Report Number <sup>(a)</sup>	Title	Revision	FSAR Section	Document Transmittal	ADAMS Accession Number
LNP SUP 1.6-1	Security Plans	Safeguards Contingency Plan	4	13.6	June 2011	(b)
	Cyber Security	Cyber Security Plan	2	13.6	September 2011	(b)
	QAPD	Progress Energy New Nuclear Plant Quality Assurance Program Description	5	17.5	July 2012	TBD

STD SUP 1.6-1 a) The NRC-accepted NEI documents identified by the A in the document number include the accepted template, the NRC safety evaluation, and corresponding responses to the NRC Requests for Additional Information. Only the accepted template is incorporated by reference. The remainder of the document is referenced but not incorporated into the FSAR.

LNP SUP 1.6-3 b) These documents are withheld from public disclosure.

(A) Denotes NRC approved document.