

Date: July 26, 2012

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-12-004A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information may not yet be fully verified or evaluated by the Region Staff.

<u>Facility</u>	<u>Licensee Emergency Classification</u>
Exelon Generating Company LLC.	<input checked="" type="checkbox"/> Notification of Unusual Event
Limerick Unit 1	<input type="checkbox"/> Alert
Pottstown, PA	<input type="checkbox"/> Site Area Emergency
Docket: 50-352	<input type="checkbox"/> General Emergency
	<input type="checkbox"/> Not Applicable

SUBJECT: **UPDATE** - NOTIFICATION OF UNUSUAL EVENT DECLARED DUE TO AN ELECTRICAL FAULT IN A NON-SAFETY RELATED TRANSFORMER; ITEM OF POTENTIAL MEDIA INTEREST

On July 18, 2012 at 8:39 a.m., Exelon declared an Unusual Event (UE) at Limerick Unit 1 due to an electrical disturbance on a non-safety related transformer located in the control enclosure inside the Protected Area (PA). The disturbance was caused by a load center electrical flash over that resulted in some deformation and charring on the exterior of the transformer cabinet. Based on the damage, the flash over met the UE criteria for an explosion within the protected area. Safety-related equipment and off-site power sources were not impacted. Exelon exited the UE at 9:46 a.m.

Exelon personnel determined that the electrical disturbance was caused by an internal fault in the non-safety related transformer. The transformer was replaced with an available on-site spare. Exelon staff conducted an extent of condition review of similar transformers in Units 1 and 2 and did not identify concerns with the transformers.

While shutdown, Exelon personnel also replaced the reactor recirculation pump shaft seals on both recirculation pumps. The primary seals on both pumps were showing signs of degrading performance.

The NRC reviewed the licensee's evaluation of the cause of the electrical transient as well as corrective actions taken, and concluded the plant is safe for restart.

On July 24 Exelon personnel performed a startup of Unit 1. The unit reached full power on July 25, 2012 at approximately 5:00 p.m.

The information presented herein has been discussed with Exelon management and is current as of July 25, 2012, at 5:00 p.m.

The Commonwealth of Pennsylvania has been notified. Region I Public Affairs has been responding to media inquiries.

ADAMS Accession Number: **ML12208A090**

CONTACT: Paul Krohn  
(610) 337-5120  
[Paul.krohn@nrc.gov](mailto:Paul.krohn@nrc.gov)

DISTRIBUTIONS:

BY E-MAIL:

OWFN

Chairman Mcfarlane  
Comm. Svinicki  
Comm. Apostolakis  
Comm. Magwood  
Comm. Ostendorff  
OIP  
OCA  
OGC  
EDO  
OE  
NRR  
SECY  
Regional Offices

TWFN

NMSS  
OIG  
RES

By Fax:

DOT:Trans  
INPO  
NSAC  
RI Resident Office  
Licensee: Exelon Generating Company, LLC

DOCUMENT NAME: G:\DRP\PNS\PNO-I-12-004A - UPDATE LIMERICK UNIT1 07-17-12REV1.DOCX

ADAMS Accession No.: **ML12208A090**

<input checked="" type="checkbox"/> SUNSI Review		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		<input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available	
OFFICE	RI/DRP	RI/DRP	RI/SLO	RI/PAO	RI/ORA
NAME	PKrohn	J Clifford/gtd for	NMcNamara	DScrenci	DLew
DATE	07/26/12	07/26/12	07/26/12	07/26/12	07/26/12

OFFICIAL RECORD COPY