

PERFORM DAILY REACTOR COOLANT SYSTEM LEAKAGE TEST

SITE: PRAIRIE ISLAND

JPM TITLE: PERFORM DAILY RCS LEAKAGE TEST

RELATED PRA INFORMATION: PRA Identified Task NONE

K/A NUMBERS: 002 A4.01

APPLICABLE METHOD OF TESTING:

Discussion:

Simulate/walkthrough:

Perform:

EVALUATION LOCATION: In-Plant:

Control Room:

Simulator:

Other:

Lab:

Time for Completion: 15 Minutes

Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO:

RO:

PERFORM DAILY REACTOR COOLANT SYSTEM LEAKAGE TEST

INITIAL CONDITIONS:

- Unit 1 is at 100% power.
- It is 0005 on a Tuesday morning.
- 1R11/12 is selected to the Containment Position.

INITIATING CUES:

- The Shift Supervisor directs you to complete Table 1 SECTION A of SP1001AA, Daily Reactor Coolant System Leakage Test.
- Report to the Shift Supervisor if any additional actions are required.

PERFORM DAILY REACTOR COOLANT SYSTEM LEAKAGE TEST

JPM PERFORMANCE INFORMATION

Required Materials: Table 1 SECTION A of SP1001AA, Daily Reactor Coolant System Leakage Test
ERCS Terminal

General References: SP1001AA, Daily Reactor Coolant System Leakage Test

Task Standards: Candidate determines that current activity on 1R0011A exceeds the 24 hour average by greater than a factor of 3 and SP1001AAA must be initiated.

Start Time: _____

Performance Step: SP 1001AA - Table 1 - Section A
Critical N
1R11/12 CONTAINMENT POSITION SELECTED YES/NO

Standard: Candidate circles YES.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Performance Step: SP 1001AA - Table 1 - Section A
Critical N
Containment Humidity

Standard: Candidate records Containment Humidity as follows:
1Y1080A: 22%

Evaluator Cue: When candidate demonstrates the ability to pull up Containment Humidity on ERCS (point 1Y1080A), then provide the following value: 1Y1080A: 22%

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

PERFORM DAILY REACTOR COOLANT SYSTEM LEAKAGE TEST

Performance Step: SP 1001AA - Table 1 - Section A
Critical N

Containment Sump A Run Time

Standard: Candidate records Containment Sump A Run Times as follows:

11: 18187.40 minutes
12: 640.70 minutes

Evaluator Cue: If asked as the Auxiliary Building Operator for Containment Sump A run times, report the following:

11: 18187.40 minutes
12: 640.70 minutes

If the candidate decides to pull up Containment Sump A Run Times on ERCS (identified as Sump#1 and Sump#2 on ERCS) from the LEAK2 program, then provide the following values:

11: 18187.40 minutes
12: 640.70 minutes

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Performance Step: SP 1001AA - Table 1 - Section A
Critical Y

Using ERCS, trend and average containment particulate (1R0011A) and gas (1R0012A) activity over the last 24 hours.

Standard: Candidate determines, using TREND feature for points 1R0011A and 1R0012A, 24 hour averages and current values are:

1R0011A 24 hour average: 447 cpm
1R0012A 24 hour average: 153 cpm
1R0011A current value: 1800 cpm
1R0012A current value: 352 cpm

PERFORM DAILY REACTOR COOLANT SYSTEM LEAKAGE TEST

Evaluator Cue: When the candidate demonstrates the ability to recall points 1R0011A and 1R0012A, and uses the TREND feature for each point to determine the 24 hour average, then provide the following information:

1R0011A 24 hour average: 447 cpm
1R0012A 24 hour average: 153 cpm
1R0011A current value: 1800 cpm
1R0012A current value: 352 cpm

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Performance Step: SP 1001AA - Table 1 - Section A
Critical Y

Using ERCS, trend data points over the 24 hours for containment particulate activity monitor 1R0011A rate of change (ROC) as listed below. Identify if ROC exceeded threshold values and did not return to zero (0).

Standard: Candidate determines ROC exceeds threshold and did not return to zero.

Evaluator Cue: When candidate demonstrates the ability to trend points 1R0011_4H and 1R0011_1H over the last 24 hour period, then provide ERCS Screenshot provided by simulator driver.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Performance Step: SP 1001AA - Table 1 - Section A
Critical Y

IF the current activity exceeds the average activity for either particulate or gas by a factor of 3 or greater, THEN determine the source of increased activity.

Standard: Candidate determines that the current value of 1R0011A is greater than 3 times the 24 hour average.

Evaluator Cue: When informed of the increased value of 1R0011A and the need to determine the source of increased activity, then inform the examinee that the crew has been unable to determine the source of the increased activity.

PERFORM DAILY REACTOR COOLANT SYSTEM LEAKAGE TEST

Performance: **SATISFACTORY** **UNSATISFACTORY**

Comments: _____

Performance Step: **SP 1001AA - Table 1 - Section A**
Critical Y

Initiate SP1001AAA, Reactor Coolant Leakage Investigation.

Standard: **Candidate determines the need to initiate SP1001AAA.**

Performance: **SATISFACTORY** **UNSATISFACTORY**

Comments: _____

Terminating Cues: **When candidate determines that current activity on 1R0011A exceeds the 24 hour average by greater than a factor of 3 and SP1001AAA must be initiated, then this JPM is complete.**

Stop Time:

REVIEW THE UNIT 1 CONTROL ROOM LOG

SITE: PRAIRIE ISLAND

JPM TITLE: REVIEW THE UNIT 1 CONTROL ROOM LOG

RELATED PRA INFORMATION: NONE

TASK TITLE: MAINTAIN REQUIRED LOGS, RECORDS, CHARTS, STATUS BOARDS

K/A NUMBERS: 2.1.18

APPLICABLE METHOD OF TESTING:

Discussion: **Simulate/walkthrough:** **Perform:**

EVALUATION LOCATION: In-Plant: **Control Room:**

Simulator: **Other:**

Lab:

Time for Completion: 30 Minutes Time Critical: NO

Alternate Path: NO

TASK APPLICABILITY: SRO: **RO:**

REVIEW THE UNIT 1 CONTROL ROOM LOG

INITIAL CONDITIONS:

- Unit 1 is at 100% power.
- All systems are functioning properly.
- No equipment is tagged out.

INITIATING CUES:

- Review the 1800 – 0600 Unit 1 Control Room Log, SP 1001B.
- Inform the evaluator of discrepancies.

REVIEW THE UNIT 1 CONTROL ROOM LOG

JPM PERFORMANCE INFORMATION

Required Materials: Consumable Copy of SP 1001B with discrepancies
Blank sheet of paper for writing down discrepancies
Calculator

General References: SWI O-25, SP 1001B

Task Standards: Candidate identifies out of specifications in the Control Room Log.

Start Time:

Performance Step: Step 5.3, Check >70,000 usable gallons available in each tank.
Critical Y

Standard: Candidate identifies discrepancy and informs the evaluator.

Evaluator Note: 21 CST level is 69,000 Gallons.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Performance Step: Step 20, Control Bank Rod Position, within Deviation Limits.
Critical Y

Standard: Candidate identifies discrepancy and informs the evaluator.

Evaluator Note: Control Bank D rod K-7 (198 steps) is greater than 12 steps deviation from Control Bank D Step Counter (213 steps).

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Performance Step: Step 25.2, Check each accumulator pressure ≥ 710 psig and ≤ 770 psig.
Critical Y

Standard: Candidate identifies discrepancy and informs the evaluator.

Evaluator Note: 12 Accumulator pressure is below 710 psig on both indicators.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

REVIEW THE UNIT 1 CONTROL ROOM LOG

Terminating Cues: When the candidate identifies the out of specifications in the Control Room Log, then the JPM is complete.

Stop Time:

TRANSFER RHR SYSTEM TROUBLE ALARM TO FLANGE SETPOINTS

SITE: PRAIRIE ISLAND

JPM TITLE: TRANSFER RHR SYSTEM TROUBLE ALARM TO FLANGE SETPOINTS

RELATED PRA INFORMATION: PRA Identified Task
NONE

TASK TITLE: OPERATE THE PLANT COMPUTER SYSTEM

K/A NUMBERS: 2.1.19

APPLICABLE METHOD OF TESTING:

Discussion: Simulate/walkthrough: Perform:

EVALUATION LOCATION: In-Plant: Control Room:

Simulator: Other:

Lab:

Time for Completion: **5 Minutes** Time Critical: **NO**

Alternate Path: **NO**

TASK APPLICABILITY: SRO: RO:

TRANSFER RHR SYSTEM TROUBLE ALARM TO FLANGE SETPOINTS

INITIAL CONDITIONS:

- Unit 1 is in Mode 6.
- Reactor vessel level is one foot below the Reactor Vessel Flange.

INITIATING CUES:

- The Shift Supervisor directs you to perform step 5.3.2 of 1C1.6, Shutdown Operations – Unit 1, to transfer the RHR System Trouble Alarm to FLANGE setpoints.

TRANSFER RHR SYSTEM TROUBLE ALARM TO FLANGE SETPOINTS

JPM PERFORMANCE INFORMATION

Required Materials: Copy of Section 5.3.2 of 1C1.6, Shutdown Operations – Unit 1, with step 5.3.1 initialed.

General References: 1C1.6, Shutdown Operations – Unit 1

Task Standards: Candidate transfers the RHR System Trouble Alarm to FLANGE setpoints.

Start Time:

Performance Step: 1C1.6 – Step 5.3.2.A
Critical N
Select D2 – Reduced Inventory screen on ERCS.

Standard: Candidate selects D2 – Reduced Inventory screen on ERCS.

Performance: SATISFACTORY UNSATISFACTORY

Comments:

Performance Step: 1C1.6 – Step 5.3.2.B
Critical Y
Switch the terminal to OVERRIDE mode.

Standard: Candidate switches the terminal to the OVERRIDE mode.

Evaluator Cue: If asked the password for OVRD, then inform the candidate the password is DUTY.

Performance: SATISFACTORY UNSATISFACTORY

Comments:

Performance Step: 1C1.6 – Step 5.3.2.C
Critical N
Select “Valve Positions Are Updated Manually Via D2VU” button.

Standard: Candidate selects “Valve Positions Are Updated Manually Via D2VU” button.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

TRANSFER RHR SYSTEM TROUBLE ALARM TO FLANGE SETPOINTS

Performance Step: 1C1.6 – Step 5.3.2.D
Critical Y

Enter “1” in “New Value” box in “Level Alarm Active/Inhibit Status” section of screen.

Standard: Candidate enters “1” in “New Value” box in “Level Alarm Active/Inhibit Status” section of screen.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Performance Step: 1C1.6 – Step 5.3.2.D
Critical Y

Select “Apply” button.

Standard: Candidate selects “Apply” button.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Terminating Cues: After the candidate transfers the RHR System Trouble Alarm to FLANGE setpoints, this JPM is complete.

Stop Time:

REVIEW AN ESTIMATED CRITICAL CONDITION CALCULATION

SITE: PRAIRIE ISLAND

JPM TITLE: REVIEW AN ESTIMATED CRITICAL CONDITION CALCULATION

RELATED PRA INFORMATION: NONE
PRA Identified Task

TASK TITLE: PERFORM ECC CALCULATIONS

K/A NUMBER: 001 A2.12

APPLICABLE METHOD OF TESTING:

Discussion: **Simulate/walkthrough:** **Perform:**

EVALUATION LOCATION: In-Plant: Control Room:

Simulator: Other:

Lab:

Time for Completion: 60 Minutes **Time Critical:** NO

Alternate Path: NO

TASK APPLICABILITY: SRO: RO:

REVIEW AN ESTIMATED CRITICAL CONDITION CALCULATION

INITIAL CONDITIONS:

- On 3/1/2012 0900, Unit 1 tripped with the following conditions prior to shutdown:
 - 100% power for 90 hours.
 - Boron concentration was 1334.
 - Tave was 560 °F.
 - Control Rods Bank D was at 218 steps.
 - Core Exposure is 150 MWD/MTU.
- A Nuclear Engineer performed an ECC utilizing a hand calculation.
- Unit 1 is in Cycle 27 and the next startup is number 171.
- It is desired to be critical on 3/6/2012 at 0900 with Bank D @ 140 steps.
- The RCS was NOT borated down to Mode 5.

INITIATING CUES:

- Review Fig C1A-1, Estimated Critical Boron Concentration, for accuracy.
- When you find an error, report it to the evaluator.

REVIEW AN ESTIMATED CRITICAL CONDITION CALCULATION

JPM PERFORMANCE INFORMATION

Required Materials: Completed Fig C1A-1, Estimated Critical Boron Concentration, with errors.

General References listed below available to candidate.

Calculator.

General References: C1A, Reactivity Calculations
Fig C1-4A, Differential and Integral Rod Bank Worths – Unit 1.
Fig C1-6A, Xenon Behavior Following Reactor Trip from 100% Power – U1.
Fig C1-7A, Total Power Defect VS Percent Power – Unit 1.
Fig C1-8, Insertion Limits with 100 Step Overlap – Units 1 and 2.
Fig C1-11A, Differential Boron Worth VS Exposure – Unit 1.
Fig C1-12A, Isothermal Temperature Coefficients Hot Zero Power – Unit 1.

Task Standards: Candidate identifies errors with ECC calculation.

Start Time:

Performance Step: FIG C1A-1
Critical Y
Expected Critical Data: Critical Boron Concentration

Standard: Candidate identifies discrepancy and informs the evaluator.

Evaluator Note: The critical boron concentration should be 1891 ppm instead of 1515 ppm.

The error occurred on step 2.6, Xenon Concentration. A value of +49 pcm was used instead of – 2450 pcm.

This error is carried forward on steps 3.3, 3.5, 6.1, 6.2, and 6.3.

Evaluator Cue: When candidate identifies Xenon Concentration discrepancy, hand out completed Fig C1A-1 with this error corrected and inform candidate to review for errors.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

REVIEW AN ESTIMATED CRITICAL CONDITION CALCULATION

Performance Step: FIG C1A-1

Critical Y

Expected Critical Data: Minimum Control Rod Position

Standard: Candidate identifies discrepancy and informs the evaluator.

Evaluator Note: The minimum control rod position should be Bank D @ 29 steps instead of Bank D @ 130 steps.

This error was a result of a math error in step 7.2. A value of 401 pcm was used instead of 1099 pcm for Maximum Rod Insertion Defect.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Terminating Cues: When the candidate identifies the errors with the ECC Calculation, then the JPM is complete.

Stop Time:

APPROVE A CLEARANCE ORDER

SITE: PRAIRIE ISLAND

RELATED PRA INFORMATION: PRA Identified Task **NONE**

TASK TITLE(S): APPROVE A CLEARANCE ORDER

K/A NUMBERS: 2.2.13

APPLICABLE METHOD OF TESTING:

Discussion:

Simulate/walkthrough:

Perform:

EVALUATION LOCATION: In-Plant:

Control Room:

Simulator:

Other:

Lab:

Time for Completion: **15** Minutes Time Critical: **NO**

Alternate Path: **NO**

TASK APPLICABILITY: SRO:

RO:

APPROVE A CLEARANCE ORDER

INITIAL CONDITIONS:

- 11 Cooling Water pump is OOS.
- Maintenance has requested an isolation of 11 Cooling Water Pump to repair the motor.
- The PASSPORT tagging system is OOS.
- The clearance order has been prepared using QF-1109, Paper Based Tagging Form, and is ready for approval.

INITIATING CUES:

- The Shift Supervisor has directed you to verify the clearance order per FP-OP-TAG-01 Step 5.4.2.3.
- Report any discrepancies to the Shift Supervisor.

APPROVE A CLEARANCE ORDER

JPM PERFORMANCE INFORMATION

Required Materials: QF-1109(marked up), NF-39216-1, NF-40002-3, NF-40315-1, NE-40005-43, and FP-OP-TAG-01

General References: FP-OP-TAG-01 and FG-OP-TAG-01

Task Standards: Determines CW-9-1 should be CL-39-1 and BKR 13-10 should be BKR 13-8.

Start Time:

Performance Step: FP-OP-TAG-01
Critical Y Section 5.4 Approving a Clearance Order/Clearance Order Checklist
Refer to Attachment 1, Clearance Order Development

Standard: Determine CW-9-1 should be CL-39-1.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

Performance Step: FP-OP-TAG-01
Critical Y Section 5.4 Approving a Clearance Order/Clearance Order Checklist
Refer to Attachment 1, Clearance Order Development

Standard: Determine BKR 13-10 should be BKR 13-8.

Performance: SATISFACTORY UNSATISFACTORY


Comments: _____

Terminating Cues: When the candidate reports the two errors in the clearance order, this JPM is complete.

Stop Time:

APPROVE A CLEARANCE ORDER

QF-1109 Rev 1 (FP-OP-TAG-01)

	<p style="text-align: center;">Paper Based Tagging Form</p>
---	--

WORK AGAINST/PURPOSE OF TAGGING: Isolate 11 Cooling Water Pump to repair the motor

CLEARANCE ORDER # XYZ1234-1

CLEARANCE ORDER TYPE: WO (Work Order) CC (Configuration Control)

WORK ORDER NUMBER (S): XYZ1234

PREPARED BY: Jerry Smith

NOTES:

Isolation of liquid side is to prevent auto rotation in addition to breaker.

HAZARDS:

Rotation of pump/motor shaft could entangle personnel


Oil spill may affect environment.

STORED ENERGY RELEASED VERIFIED BY:

*The steps of the Clearance Order are the steps (that are hanging) of the checklist (s)

APPROVE A CLEARANCE ORDER

QF-1109 Rev 1 (FP-OP-TAG-01)

	<p>Paper Based Tagging Form</p>
---	---------------------------------

WORK AGAINST/PURPOSE OF TAGGING:

Isolate 11 Cooling Water Pump to repair the motor

CLEARANCE ORDER #: XYZ1234-1

WORK ORDER NUMBER (S): XYZ1234

HOLDER SIGN ON/OFF (use additional sheets as needed)

Page 1 of 1

Holder Name	Sign On	Date/Time	Sign Off	Date/Time

APPROVE A CLEARANCE ORDER



Paper Based Tagging Form

WORK AGAINST/PURPOSE OF TAGGING Isolate 11 Cooling Water Pump to repair the motor

CLEARANCE ORDER CHECKLIST # XYZ1234-1

CLEARANCE TYPE: PC (PERFORM CHECKLIST) FC (FINAL CLEAR)

PREPARED BY: Jerry Smith OPS APPROVED BY: _____

HOLDER APPROVED BY: _____ DISTRIBUTED BY: _____

STEP NO.	TAG NO.	TAG TYPE	ACTION	COMPONENT ID	COMPONENT DESCRIPTION	REQUIRED POSITION	STEP COMPLETE D BY	STEP VERIFIED BY
1	01	Caution Tag (Small)	Pull Out	CS-46051	11 CLG WTR PUMP	PULL OUT		
2	02	Danger Tag	Rack Out	BKR 13-10	11 CLG WTR PMP	DISCONNECT		
3	03	Danger Tag	CLOSE	CW-9-1	11 CLG WTR PMP DISCH	CLOSE		
4	04	Danger Tag	CLOSE	CL-33-1	11 CLG WTR PMP SUCT	CLOSE		
5	05	Danger Tag	CLOSE	CL-94-10	11 CLG WTR PUMP PRIMING TRAP INLET	CLOSE		
6	06	Danger Tag	CLOSE	CH-17-1	HYPOCHL INJECTION TO 11 CLG WTR PMP	CLOSE		

VERIFICATION OF RADIATION WORK PERMIT LIMITS

SITE: PRAIRIE ISLAND

JPM TITLE: VERIFICATION OF RADIATION WORK PERMIT LIMITS

RELATED PRA INFORMATION: NONE

TASK TITLE: APPLY RADIATION AND CONTAMINATION SAFETY PROCEDURES

K/A NUMBERS: 2.3.7

APPLICABLE METHOD OF TESTING:

Discussion:

Simulate/walkthrough:

Perform:

EVALUATION LOCATION: In-Plant:

Control Room:

Simulator:

Other:

Lab:

Time for Completion: **5** Minutes Time Critical: **NO**

Alternate Path: **NO**

TASK APPLICABILITY: SRO:

RO:

VERIFICATION OF RADIATION WORK PERMIT LIMITS

INITIAL CONDITIONS:

- You will be performing testing on 21 Containment Spray Pump.
- The job requires you to be in the area EAST of the 21 CS Pump for 90 minutes.
- Your current year to date exposure is 1990 mrem.
- You are directed to use RWP 1034 for the job.
- A Survey Record of the Unit 2 Containment Spray Pump Room is provided.

INITIATING CUES:

- Determine if any dose limits will be exceeded prior to performing this task.
- Report your findings to the evaluator.

VERIFICATION OF RADIATION WORK PERMIT LIMITS

JPM PERFORMANCE INFORMATION

Required Materials: TE-0236 Radiation Work Permit, RWP Number 1034 00.
Unit 2 Containment Spray Pump Room Supplemental Survey Record
RP-111a.
RCA Trip Ticket.

General References: F2, RADIATION SAFETY.
TE-0236 Radiation Work Permit, RWP Number 1034 00.
Unit 2 Containment Spray Pump Room Supplemental Survey Record
RP-111a.
RCA Trip Ticket.

Task Standards: Determine that the RWP Dose limit and the workers Yearly Administrative
Dose limit will be exceeded.

Start Time:

Performance Step: F2, RADIATION SAFETY, Section 3.5 Radiation Work Permit
Critical Y 3.5.2 Instructions and requirements in RWP's SHALL be followed by all
personnel.

3.5.4 All personnel SHALL be aware of the requirements of the RWP covering
their activity and be familiar with the radiological conditions for the area.

Candidate will determine the following:

RWP dose limit is 10 mrem.
Area east of the 21 CS Pump has dose rate of 10- 12 mrem/hr.
Expected stay time is 90 minutes.
Expected dose for the job is 15 - 18 mrem.

Standard: Candidate determines the RWP dose alarm of 10 mrem will be exceeded.

Evaluator Cue: If candidate indicates he would complete a RCA Trip Ticket for the job;
PROVIDE the candidate the attached RCA Trip ticket copy.

If candidate asks for WO# for RCA Trip Ticket;
INFORM the candidate the WO# is 392277.

If candidate reports the RWP 10 mrem dose alarm will be exceeded;
INFORM the candidate RWP 1037 will be used with a dose limit of 51
mrem.

INFORM the candidate to re-evaluate the information and determine if any dose
limits will be exceeded.

Performance: SATISFACTORY UNSATISFACTORY

Comments: _____

VERIFICATION OF RADIATION WORK PERMIT LIMITS

Performance Step:

Critical Y

Candidate will determine the following:

The Prairie Island yearly administrative dose limit is 2000 mrem.
Your current year to date exposure is 1990 mrem.
Expected dose for the job is 15 - 18 mrem.

Standard:

Candidate determines the expected dose of 15 - 18 mrem will cause the 2000 mrem yearly limit to be exceeded.

Evaluator Cue:

If candidate reports the yearly administrative dose limit will be exceeded;
INFORM the candidate their yearly administrative dose limit has been raised to 2041 mrem.

INFORM the candidate to re-evaluate the information and determine if any dose limits will be exceeded.

Performance:

SATISFACTORY UNSATISFACTORY

Comments:

Terminating Cues:

Candidate has determined the RWP Dose limit and the workers Yearly Administrative Dose limit will be exceeded and reports findings to evaluator.

Stop Time:

EMERGENCY CLASSIFICATION OF A PLANT EVENT

SITE: PRAIRIE ISLAND

RELATED PRA INFORMATION: NONE

TASK TITLE(S): DIRECT EMERGENCY RESPONSE FOR THE EMERGENCY DIRECTOR

K/A NUMBERS: 2.4.41

APPLICABLE METHOD OF TESTING:

Discussion: **Simulate/walkthrough:** **Perform:**

EVALUATION LOCATION: In-Plant: Control Room:

Simulator: Other:

Lab:

Time for Completion: 13 Minutes **Time Critical:** YES

Alternate Path: NO

TASK APPLICABILITY: SRO: RO:

EMERGENCY CLASSIFICATION OF A PLANT EVENT

INITIAL CONDITIONS:

- You are the Shift Manager.
- Unit 1 AND Unit 2 were both at 100% power.
- Two minutes ago, a Control Room evacuation was initiated per 1C1.3 AOP1, Shutdown from Outside the Control Room – Unit 1.

Four control rods did not insert fully during the reactor trip.
The Unit 1 SS has determined 1600 gallon boration is required.
You have relocated to the TSC.

INITIATING CUES:

- Perform the duties of the Emergency Director.
- This JPM is time critical.

NOTE: RECORD THE START TIME ON THE NEXT PAGE AS THE TIME WHEN THE EXAMINEE TELLS YOU THEY ARE READY TO BEGIN. AT THE BOTTOM OF STEP 1, RECORD THE TIME OF DECLARATION AND CALCULATE ELAPSED TIME FROM BEGINNING OF THE JPM. TO BE SATISFACTORY, THE ELAPSED TIME MUST BE LESS THAN 13 MINUTES.

EMERGENCY CLASSIFICATION OF A PLANT EVENT

JPM PERFORMANCE INFORMATION

- Required Materials:** F3-2, Classifications of Emergencies
Consumable Gum Labels
Consumable PINGP 577, Emergency Notification Report Form (2 copies)
An ERCS Screenshot of the EPZ_MAP page showing the following:
 Wind Direction 258°
 Wind Speed 2 miles/hr
 Stability Class F
 Downwind Sectors ALL
- General References:** F3-2, Classifications of Emergencies
PINGP 577, Emergency Notification Report Form
Classification Wall Chart
- Task Standards:** Candidate accurately makes a declaration, with the associated notifications and identifies both applicable EAL classifications.
- Start Time:**

EMERGENCY CLASSIFICATION OF A PLANT EVENT

Performance Step: Fills out PINGP 577 as follows:

Critical: Y*

Circle [A] Initial Report
Circle [B] Drill/Exercise
[C] Prairie Island Nuclear Generating Plant is PRE-CIRCLED
Circle [B] Alert
Circle [A] then Complete the date, time, and EAL HA5.1
Circle [A] None
Circle [A] Not Applicable
Complete from 258 degrees
Complete Downwind Sectors CIRCLE ALL LETTERS
Complete miles/hr: 2
Complete Stability Class F
Circle [A] NONE
Write description or use sticker
Complete approval signature

Standard: Candidate completes form as indicated above OR candidate proceeds to higher EAL declaration. Critical steps are indicated with italics.

Evaluator Cue: Upon completion of step 1 – 9 OR 8 minutes (from JPM start time), have elapsed, inform the candidate of the following:

The Unit 1 SS reports all attempts to borate the required 1600 gallon boration into the RCS have failed.
The Aux Building APEO reports flow noise through the 11 SG Safety and ERCS tailpipe temperatures indicate rising temperatures.

Time candidate informed _____

Evaluator Note: The time critical portion of this JPM begins when the examinee reviews the turnover information and tells the examiner that he is ready to begin.

*This step is only critical if the candidate completes this 577 and submits it for notification.

Evaluator Note: Time of declaration shall be within 13 minutes of JPM start time for satisfactory completion of this step.

Evaluator Cue: When examinee requests Met Data, provide the ERCS EPZ_MAP screenshot.

If examinee requests status of the reactor, then inform the candidate Power is less than 5% with a negative IR SUR.

Performance: SATISFACTORY UNSATISFACTORY

Comments:

PINGP 577 BLOCK 5 _____
TOTAL TIME FOR THIS STEP (PINGP 577 BLOCK 5 – START TIME) _____

EMERGENCY CLASSIFICATION OF A PLANT EVENT

Performance Step:
Critical: Y

Fills out 2nd PINGP 577 as follows:

Circle [A] Initial Report or [B] Emergency Class Change
Circle [B] Drill/Exercise
[C] Prairie Island Nuclear Generating Plant is PRE-CIRCLED
Circle [C] Site Area Emergency
Circle [A] then Complete the date, time, and EAL HS2.1
Circle [A] None
Circle [A] Not Applicable
Complete from 258 degrees
Complete Downwind Sectors CIRCLE ALL LETTERS
Complete miles/hr: 2
Complete Stability Class F
Circle [A] NONE
Write description or use sticker
Complete approval signature

Standard: IF EAL HA5.1 was declared, then candidate need only identify escalation EAL declaration.
IF EAL HS2.1 is to be the initial declaration, then candidate completes form as indicated above.
Critical steps are indicated with italics.

Evaluator Note: The time critical portion of this JPM begins when the examinee reviews the turnover information and tells the examiner that he is ready to begin.

Evaluator Note: Time of declaration shall be within 13 minutes of JPM start time OR 15 minutes from time of candidate being informed of SG Safety flow for satisfactory completion of this step.

Evaluator Cue: When examinee requests Met Data inform them the MET data is unchanged from the EPZ_MAP screenshot previously provided.

Performance: SATISFACTORY UNSATISFACTORY

Comments:

PINGP 577 BLOCK 5 _____

TOTAL TIME FOR THIS STEP (PINGP 577 BLOCK 5 – *START TIME) _____

*Start time is either JPM start time or time at which candidate was informed of boration failure and SG Safety flow.

Performance Step:
Critical Y

Deliver the completed PINGP 577 to the SEC for communication.

Standard: PINGP 577 given to SEC with orders to perform notifications.

Evaluator Note: The examinee shall provide completed PINGP 577 to the SEC within 15 minutes of the time in PINGP 577 BLOCK 5 for the initial declaration made for satisfactory completion of this step.

EMERGENCY CLASSIFICATION OF A PLANT EVENT

Evaluator Cue: As SEC: Accept PINGP 577 and acknowledge order to make notifications.

Performance: SATISFACTORY UNSATISFACTORY

Comments:

TIME WHEN THIS STEP IS COMPLETE _____

TOTAL TIME FOR THIS STEP (STOP TIME - PINGP 577 BLOCK 5) _____

Terminating Cues: When the candidate accurately makes a declaration, with the associated notifications and identifies both applicable EAL classifications, then this JPM is complete.

Stop Time: