

## **Davis-BesseHearingFile Resource**

---

**From:** Sheikh, Abdul  
**Sent:** Tuesday, October 18, 2011 4:14 PM  
**To:** CuadradoDeJesus, Samuel; Cooper, Paula; Morey, Dennis; Auluck, Rajender; Lehman, Bryce; Pelton, David; Wrona, David  
**Cc:** Davis-BesseHearingFile Resource  
**Subject:** RE: DB presentation

As a minimum following should be considered:

1. Chip the cracked areas to expose concrete.
2. Measure and document the length, location, and width of cracks.

This information will be required for disposition and evaluation of the AR.

Abdul

---

**From:** CuadradoDeJesus, Samuel  
**Sent:** Tuesday, October 18, 2011 4:01 PM  
**To:** Cooper, Paula; Morey, Dennis; Auluck, Rajender; Sheikh, Abdul; Lehman, Bryce; Pelton, David; Wrona, David  
**Cc:** Davis-BesseHearingFile Resource  
**Subject:** FW: DB presentation

Attached is a RIII presentation with pictures of the shield building.

---

**From:** Sanchez Santiago, Elba  
**Sent:** Tuesday, October 18, 2011 3:22 PM  
**To:** CuadradoDeJesus, Samuel  
**Subject:** FW: DB presentation

Samuel,

I included comments in the notes section of most of the slides. If you have any question regarding these comments or the pictures let me know.

-Elba

D/ES