

From: [Beltz, Terry](#)
To: ["Wideman Steve G"](#)
Cc: ["wimuile@wcnoc.com"](#); [Burkhardt, Janet](#); [Chen, Qiao-Lynn](#); [Rankin, Jennivine](#)
Subject: Wolf Creek Generating Station - Acceptance Review re: License Amendment Request to Revise Technical Specification Surveillance Requirement 3.6.6.8 (TAC No. ME8676)
Date: Thursday, August 09, 2012 9:03:26 AM

Dear Mr. Wideman:

By letter dated May 2, 2012, (Agencywide Documents Access and Management System Accession No. ML12132A050), the Wolf Creek Nuclear Operating Corporation submitted a license amendment request for the Wolf Creek Generating Station. The proposed amendment would replace the current ten-year surveillance frequency for testing the containment spray nozzles as specified in Technical Specification Surveillance Requirement 3.6.6.8, with an event-based frequency.

The purpose of this e-mail is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-3049.

Sincerely,



***Terry A. Beltz, Senior Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
(301) 415-3049
Terry.Beltz@nrc.gov***