Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

Reliability and PRA Subcommittee

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Friday, July 27, 2012

Work Order No.: NRC-1783 Pages 1-200

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

Ì	1
1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	(ACRS)
6	+ + + +
7	RELIABILITY AND PRA SUBCOMMITTEE
8	+ + + +
9	FRIDAY
10	JULY 27, 2012
11	+ + + +
12	ROCKVILLE, MARYLAND
13	+ + + +
14	The Subcommittee met at the Nuclear
15	Regulatory Commission, Two White Flint North, Room
16	T2B1, 11545 Rockville Pike, at 8:30 a.m., John W.
17	Stetkar, Chairman, presiding.
18	
19	SUBCOMMITTEE MEMBERS PRESENT:
20	JOHN W. STETKAR, Chairman
21	DENNIS C. BLEY, Member
22	HAROLD B. RAY, Member
23	JOY REMPE, Member
24	STEPHEN P. SCHULTZ, Member
25	WILLIAM J. SHACK, Member
l	

1	NRC STAFF PRESENT:
2	JOHN LAI, Designated Federal Official
3	BENJAMIN BEASLEY, NRR
4	STEPHEN DINSMORE, NRR
5	RAY GALLUCCI, NRR
6	DONNIE HARRISON, NRR
7	J.S. HYSLOP, NRR
8	ALEX KLEIN, NRR
9	
10	ALSO PRESENT:
11	PAUL AMICO, SAIC
12	VICTORIA ANDERSON, NEI
13	RAY FINE, PWR Owners Group/FENOC
14	DAVID FINNICUM, PWR Owners Group
15	DENNIS HENNEKE, BWR Owners Group/GEH
16	ANIL JULKA, NextEra Energy
17	GERALD A. LOIGNON, JR., SCANA
18	GEORGE PINNELL, ARS*
19	ROBERT RISHEL, BWR Owners Group
20	IRIR Chair/Duke Energy
21	VINNY RUBANO, NextEra Energy
22	LAURA SWENZINSKI, NextEra Energy
23	RICK WACHOWIAK, EPRI
24	KIANG ZEE, ERIN Engineering
25	*Present via telephone

		3	
1	TABLE OF CONTENTS		
2			
3	Opening Remarks	4	
4	Industry Perspective	4	
5	PWROG Peer Review	75	
6	BWROG Peer Review	107	
7	PRA Transition Issues (Note A)	163	
8	ACRS Members Discussion	192	
9			
10			
11			
12			
13			
14			
15			
16			
17			
18			
19			
20			
21			
22			
23			
24			
25			

PROCEEDINGS

2	(8:29 a.m.)
3	CHAIR STETKAR: The meeting will now come
4	to order. This is the second day of our meeting on
5	NFPA 805 transition, and today we're going to hear
6	from a variety of industry folks from NEI, EPRI, and,
7	I guess, the Owners Groups.
8	So, we'll start off with any one from
9	the staff? Alex, anything to say?
10	MR. KLEIN: No, nothing, not yet.
11	CHAIR STETKAR: I can't wait. With that,
12	we'll start off with NEI. Victoria?
13	MS. ANDERSON: My name is Victoria
14	Anderson. I'm a Project Manager for Risk Assessment
15	with the Nuclear Energy Institute, and I'll be talking
16	about sort of the broader industry perspective with
17	respect to the NFPA 805 transition and fire PRA today.
18	The plants yesterday discussed some of
19	their specific situations and challenges, and today
20	again we're going to be discussing some industry-wide
21	challenges and difficulties. We want to make sure we
22	manage as best possible moving forward with the
23	continued 805 transition and fire PRA development.
24	Specifically, I'm going to be talking a
25	little bit about the interface between technology

advancement for fire PRA and the regulatory process associated with NFPA 805. I know that there isn't much interest in the process issues, but I think it's important to discuss how some of those process issues are impacting potential for technology advancement, so I'll try to keep that to a minimum and discuss sort of the difficulties we're having with technological advancement.

For example, yesterday you heard about some of the uncertainties that utilities are facing with respect to their fire PRA development to support NFPA 805 applications, and we need to make sure we work to foster regulatory stability and continue technological advancement for fire PRAs.

So we'll discuss some of the hiccups we've been facing and some ways that we think we could improve and also a few aspects in which we've already made some improvements and had some good communication with the staff. After I finish up, Rick is going to talk about actually advancing the state of the art.

So, to start off, I think it's important to look at how an NFPA 805 has affected fire PRA development and potential technological advancements. As you heard yesterday, NUREG-6850 is used quite a bit in the development, application development and review

process. For example, licensees are asked to identify difference between 6850 and the methods that they use in their fire PRA.

There are also -- they're being asked for sensitivity studies against 6850, so there's quite a bit of dependence upon NUREG-6850 right now in the review process, and there -- we understand that this staff is very familiar with NUREG-6850, and they have confidence in those methods, but there's -- I think there are some unintended results that we want to make sure we don't keep experiencing.

Again, it can be hard to make improvements and advance technology in the context of NFPA 805 application space. You heard that yesterday that some of the utilities are -- you heard specifically from VC Summer they didn't really pursue much outside of sort of the 6850 box, so it's making advancement of technology a little bit difficult.

I'll talk a little more about how this impacts sensitivity studies and how maybe comparing results that you get using the method that was used in the fire PRA and the results you would get if you used 6850, how those sensitivity studies might not be the most informative.

CHAIR STETKAR: Victoria?

1	MS. ANDERSON: Yes.
2	CHAIR STETKAR: Are you or maybe Rick
3	going to be a little bit more specific about which
4	particular features 6850 because 6850 is just
5	condemning that large body of work. It seems a little
6	bit unfair.
7	MS. ANDERSON: Well, I don't I think
8	Rick's going to talk a little bit about some specific
9	aspects.
10	MR. WACHOWIAK: I have one example that
11	I'll talk about.
12	MS. ANDERSON: And I don't think anybody
13	means to condemn it, and I'll get into this a little
14	bit later, but for it to and it was sort of meant
15	to be a living document, and Rick is going to talk
16	about that.
17	MR. WACHOWIAK: Yes.
18	MS. ANDERSON: We can't have it stuck in
19	space, and we're sort of stuck right now, and that's
20	what the real problem is.
21	CHAIR STETKAR: Okay.
22	MS. ANDERSON: I'm not saying we should
23	take it and set fire to it.
24	CHAIR STETKAR: No, I was just curious.
25	One of the one of the reasons for this whole, you

1	know, gathering of the multitudes is to try to
2	identify if there are specific technical issues, not
3	sort of broad-based things, because I think we're all
4	aware of that.
5	MS. ANDERSON: Right.
6	CHAIR STETKAR: But if there are really
7	specific technical issues that either the staff or in
8	particular the industry sees as a, you know,
9	fundamental impediment, we'd like to understand what
LO	those are. You know, that's why I raised the question
L1	about it.
L2	MS. ANDERSON: Right.
L3	CHAIR STETKAR: If there are specific
L4	elements of that 6850 process or elements of either
L5	the data or the recommended methods and so forth, we'd
L6	like to kind of understand, you know, what they are.
L7	MS. ANDERSON: Yes.
L8	CHAIR STETKAR: And if there are other
L9	parts that are sort of working okay, we'd like to
20	understand that, too, so, Rick, if you can keep that
21	in mind.
22	MR. WACHOWIAK: Yes, I have one example
23	for that, and then we can we can talk about some of
24	the
25	CHAIR STETKAR: Thanks.

1 MS. ANDERSON: And I think -- what I'm 2 going to be talking about in a little bit more detail is where even if we could pursue the research and 3 4 analysis necessary to work on improving those methods, 5 where we're sort of running into some process difficulties with making some of those improvements. 6 7 So there's a point at which people aren't 8 really going to be willing to pursue those 9 technological advancements, because it can look like an exercise in futility of we don't have a really 10 clear process for advancing it. 11 So, another concern is that we think that 12 there's been a little bit of a removal of focus from 13 14 t.he consensus standard for fire PRA technical 15 adequacy, which we think is unfortunate, because a lot of work went into developing that standard. 16 17 That's not to say that it's not being used and that staff isn't paying attention to it, but I 18 19 think we're just losing a little bit of focus on the standard being the figure of merit. So that's another 20 concern we have. 21 As it's probably apparent from what I have 22 noted with some of the difficulties we're having, 23 24 there are some communication issues, and we have been

I think we had a very productive

working on those.

1 meeting with the staff last month in June where we got a better understanding of what everyone meant when we 2 3 were using, you know, different phrases and saying 4 different things and what the staff was expecting. 5 We're getting better, but it's difficult. 6 You know, it's an evolutionary process. 7 So some of the areas where we're having difficulty are 8 well, what constitutes acceptance of a fire PRA 9 What exactly is expected for a sensitivity method? 10 study? We're getting a better idea of that, but 11 it's just been difficult, and for the lead 805 plants, 12 you know, the ones who, you know, have applications 13 14 that they're about to turn in, this is -- it's a 15 little --16 CHAIR STETKAR: I think any -- I suspect. 17 I wasn't around. Bill probably was at the beginning of the license renewal process. I suspect there were 18 19 probably similar difficulties in that process. MEMBER SHACK: I was just sort of sitting 20 here thinking, you know, people with core analyses use 21 codes from the seventies, and they're never in any 22 hurry to update them, as much as the ACRS members 23 24 would like to see them use new modern transportation. 25 You know, it all depends on your

1	perspective as to whether, you know, you like
2	regulatory stability and notions of methods that are
3	accepted or you want to go out and push the frontier
4	a little bit, but it is always a little rough getting
5	new methods through the NRC, but I don't know that
6	it's any different for fire PRA than it would be for
7	a new core analysis code. It's just how much data and
8	how much support you have.
9	MS. ANDERSON: Right. So, one of the
10	specific difficulties we've had are some short
11	turnaround times for supplementary information,
12	whether information is requested through the RAI
13	process or as part of the license acceptance process.
14	Because we haven't really had a clear
15	mutual understanding of what sensitivity studies are
16	expected, some additional studies might be requested
17	with a really short turnaround that can be difficult
18	to deal with.
19	CHAIR STETKAR: Hereto, and I haven't had
20	a chance to look forward too much, but I'd like to
21	understand. You've mentioned sensitivity studies now
22	three times on this one slide.
23	MS. ANDERSON: Yes.
24	CHAIR STETKAR: So I'd like to understand
25	in particular what element of sensitivity studies,

1 because people tend to throw sensitivity --2 MS. ANDERSON: Right. There are sensitivity 3 CHAIR STETKAR: 4 studies, varying parametric values, which is one 5 notion of a sensitivity study. There are also sensitivity studies that we heard about yesterday in 6 7 terms of comparing the results from a particular --I'll call it fire physics model to distinguish from 8 other fire models, one fire physics model compared to 9 anther fire physics model, so if you'd help us to 10 understand a little bit --11 12 MS. ANDERSON: I have an example. CHAIR STETKAR: -- what in that range of 13 14 -- okay. 15 I have an example later, MS. ANDERSON: and we have people in the back who I have informed 16 17 that they might need to back me up with some more Hopefully, they don't run out of the room. 18 19 So, as I said, in particular some of the sensitivity studies can be time-consuming, and so 20 we're running into problems with very little time to 21 resolve them. I think in the future this won't be 22 quite as much of a problem, because the licensees who 23 24 aren't due until, you know, 2014, 2015, they have a little bit more time to adjust and do the work, but 25

some people are really up against the wall right now, and it's a little difficult for them.

I just want to note here before we move on, nobody is arguing against sensitivity studies when appropriate. I want to make sure that that's very clear. Sensitivity studies can give you good insights about where your method impacts your model.

There is no argument against having them.

It's just that we need to make sure we're doing the best ones to give us the best information.

CHAIR STETKAR: That's right, and I suspect if we learn a little bit more about where those particular issues are, at this stage in the process you're also compiling, in some sense, you're compiling a catalog of those sensitivity studies such that one would hope that they don't need to be replicated, you know, 20 or 30 times as additional licensees come in, presuming that they're not using, you know, wildly different methods, but let's see in

MS. ANDERSON: It's possible you could reference an SE. It's possible that you might not need to, but, actually, first, before we get to a lot of the detail on sensitivity studies, I'm going to talk about some of the difficulties licensees are

facing with making advancements to the methods that are currently laid out in NUREG-6850. In particular, right now it's a very long and uncertain process, which is why many licensees are a little bit skittish about pursuing anything that's outside NUREG-6850.

So if you look at the process, you have

So if you look at the process, you have the development process. You have whatever time you need to develop the method. That's probably going to be on the time frame of several months, maybe longer, depending on how intensive data analysis you need to do to support it.

Then there's the consensus review process.

That can take up to a year. Sometimes it's faster,

and then there is the NRC acceptance process, which we

haven't -- we've just started that rolling. That can,

you know, take up to another nine months.

So, you're looking at all that. You put all that together. Now, then you have to account for incorporating it into you fire PRA. You can do that before all of those steps are done, and, in fact, you need to for most of these methods when you're developing the fire PRA.

You're really sort of proceeding with a lot of uncertainty there, and so that's why people are reluctant to do this. So we need to make sure that we

make -- we get some more certainty in these steps and have a better understanding of how everything will work there, and it's potentially unattractive to licensees with some really tight time limitations due to their 805 LAR deadlines.

Again, it would be easier if any of the review processes were faster. I don't think anybody can say that -- I don't think either the industry or the NRC can say, "Well, we reviewed it as quickly as possible."

I don't -- I think we could have been faster than a year, and we could have had a better communication regarding when we were going to hear back from everybody, but we could definitely make some improvements there. In particular, if the consensus review were maybe given a little bit more weight in this process, that might be helpful.

Okay. Now I'm going to talk about everybody's favorite topic, unreviewed analysis methods. This is -- you probably heard it mentioned a couple of times yesterday. Just a little bit of background so that we're clear on what we mean in the context of this discussion, I'm going to walk through what it is.

It's a type of fact and observation used

in the peer review process. It's not the same thing as a method that is different from those described in NUREG-6850, so it's something that a peer review team would note in their evaluation of a fire PRA against the standard.

When this is used is when the review team is in the middle of their review of the fire PRA and they encounter a method that's used and they don't think that they have the collective expertise to assess it. So they're not saying this does or does not meet the standard. They're saying, "We don't possess the technical expertise to assess it."

I think that's a positive that we heard that back from reviewers. I think that speaks positively to the peer review process that we make sure there's a good level of technical fidelity there.

So this was our solution to handling the rapidly improving methods in the fire PRAs, because people had sort of groundbreaking methods in their fire PRAs, and reviewers didn't really have time to get up to speed on it before the peer reviews, so this ensured some consistency in the peer review process.

What happens if a utility gets a UAM -type F&O on the peer review? They send that method over to an industry consensus review panel run by EPRI. There

1	has been NRC participation in the past, so that's sort
2	of a way to ensure that there's consistency, because
3	you have you bring together like the top experts
4	from throughout the field, so you get some consistency
5	there.
6	CHAIR STETKAR: Rick, are you going to
7	talk about that panel?
8	MR. WACHOWIAK: No.
9	CHAIR STETKAR: Is it now operating?
10	MR. WACHOWIAK: It is it has completed
11	its first phase, and we're adjusting the panel process
12	to fold in lessons learned. The next piece that's
13	going to come out of this panel is going to be done a
14	little bit differently, so maybe I will touch on it in
15	one of my points.
16	CHAIR STETKAR: Okay. I wanted to hear a
17	little bit about it, because if you say some of the
18	industry consensus evaluations could help the process,
19	I'd like to understand where the industry is on
20	facilitating those reviews.
21	MEMBER SCHULTZ: And I'd like to know what
22	the schedule is associated with those reviews in the
23	current experience base and what is planned for the
24	future.
25	MR. WACHOWIAK: Okay. Well, I can touch

1 on a couple of those things right now. About a year or so ago we started with four proposed methods to go 2 into this, into the Review Panel. 3 4 What we -- and so we assembled a team, and 5 I think it had six or seven different people with fire 6 background from the industry. We had a 7 representative from NRR on there, and he brought a couple of other fire experts from within NRC and also 8 9 their contractors to talk about these things. 10 We found initially that our first thought on this was that the team would come in and review a 11 method proposed by someone, and it would be like an 12 independent review. It didn't go that way. 13 14 What it turned into was there was a 15 There were some issues with it, and then the review. team set out to fix the issues, so it turned into a 16 17 development panel, a panel developing the method, rather than simply reviewing the method. 18 19 and so from that aspect, Okay, changes the time frame from like a month to, as 20 Victoria said, in one of the cases it was either a 21 year or 13 months, something like that, to get through 22 all of the issues. 23 24 We were looking at why some of the things were taking so long and what was there. 25 There's a few

issues associated with it, but mostly it's because we're trying to solve generic things.

I think with any of these if you had focused it on, "This plant has this problem in their fire PRA, and they need to use this to fix that problem," it probably could have been done in a month.

It didn't have to bring in all the baggage of, "What if it happened at this site with this kind of configuration? What if it happened at this site with this kind of configuration?" It just balloons into something that's quite unwieldy.

So, going forward, and I'll talk about this a little bit later, we need to recognize that there are multiple needs for this sort of thing. There are ones that are there to address a problem that a specific plant has with a specific fire scenario, and then there are others that are saying, "Okay, how can we do this better, faster, cheaper in the future."

There's two different panels or organizations that need to be set up to solve those two different problems, so that's one of the things that I learned in going through this process is that once we start combining those kinds of things, it becomes --

1 CHAIR STETKAR: Well, it's a methods research development, rather than --2 3 MR. WACHOWIAK: It's a method -- it becomes research, rather than review. 4 5 CHAIR STETKAR: Right. MR. WACHOWIAK: So, okay, so that -- so we 6 7 finished the first four that were in that phase. 8 do have another method as proposed by the BWR Owners 9 Group that's going to go into our new development 10 panel recognition because it's a generic method there. The schedule for that at this point is still being 11 12 We need to figure out what needs to be done. worked. Some of the work for that method was 13 14 reviewed in one of the previous panels. There's a 15 second piece where we're going to still need to go 16 back through and look at data records from the 17 database again, and that's a -- that's not a short So I can't answer the second piece of your 18 19 question. MEMBER SCHULTZ: No, but it gives a good 20 perspective about the first two steps that --21 Right. 22 MR. WACHOWIAK: MEMBER SCHULTZ: -- Victoria was 23 24 describing, and it is in a short time frame. One wouldn't necessarily expect it to be unless you could 25

give particular guidance that would lead more to a plant-specific assignment for review versus generic methods development program. MR. WACHOWIAK: Right, and in some these cases when we were going through data recommendated if we locked the seven people in a room, we might come out with five. MEMBER SCHULTZ: Understand. Thank CHAIR STETKAR: The ideal is one. MR. WACHOWIAK: So, it's once we into that sort of a research mode on these things schedules tend to self-destruct.	of ords, only you.
generic methods development program. MR. WACHOWIAK: Right, and in some these cases when we were going through data rec if we locked the seven people in a room, we might come out with five. MEMBER SCHULTZ: Understand. Thank CHAIR STETKAR: The ideal is one. MR. WACHOWIAK: So, it's once we into that sort of a research mode on these things	of ords, only you.
MR. WACHOWIAK: Right, and in some these cases when we were going through data rec if we locked the seven people in a room, we might come out with five. MEMBER SCHULTZ: Understand. Thank CHAIR STETKAR: The ideal is one. MR. WACHOWIAK: So, it's once we into that sort of a research mode on these things	ords, only you.
these cases when we were going through data red if we locked the seven people in a room, we might come out with five. MEMBER SCHULTZ: Understand. Thank CHAIR STETKAR: The ideal is one. MR. WACHOWIAK: So, it's once we into that sort of a research mode on these things	ords, only you.
if we locked the seven people in a room, we might come out with five. MEMBER SCHULTZ: Understand. Thank CHAIR STETKAR: The ideal is one. MR. WACHOWIAK: So, it's once we into that sort of a research mode on these things	you.
8 come out with five. 9 MEMBER SCHULTZ: Understand. Thank 10 CHAIR STETKAR: The ideal is one. 11 MR. WACHOWIAK: So, it's once we 12 into that sort of a research mode on these things	you.
9 MEMBER SCHULTZ: Understand. Thank 10 CHAIR STETKAR: The ideal is one. 11 MR. WACHOWIAK: So, it's once we 12 into that sort of a research mode on these things	get
10 CHAIR STETKAR: The ideal is one. 11 MR. WACHOWIAK: So, it's once we into that sort of a research mode on these things	get
MR. WACHOWIAK: So, it's once we into that sort of a research mode on these things	
into that sort of a research mode on these things	
	the
schedules tend to self-destruct.	•
ll .	
14 MEMBER SCHULTZ: Was there agreemen	ıt at
the outset that this process was going to ho	w was
it how was it expected to weave into an NRC r	eview
process associated with the methodology? There	's NRC
participation, as you mentioned, in the contractor	or and
19 the	
MR. WACHOWIAK: Right.	
21 MEMBER SCHULTZ: review process,	but
22 was that expected to take the place of subse	quent
23 staff review?	
MS. ANDERSON: It would be it wo	uld be
folded into the application, in the portion o	

application where the open facts and observations of the peer review were discussed. What would happen is the licensee would say, "We had a UAM of 11.0, and here is the finding from this panel."

MR. WACHOWIAK: Right, so it was originally intended to fold in with the peer review process, and so the only question that would have been left open to this is not whether the method could be used but did the plant use it correctly. Our thoughts were that that piece of it would be handled by a focused scope peer review, and it wouldn't require further staff resources to go in and look in detail at that.

That was the thought at the outset, and we had some talk with Donnie Harrison, whose staff is the one that does many of these reviews, and we thought it was workable at the time, but that was with the presumption going in that the panel itself wasn't going to be reworking the method. So once we got into that mode, I think everybody's expectations kind of started changing as we were progressing.

CHAIR STETKAR: Are -- having not been involved with this at all, are some of the methods -- you said you'd looked at four. Are they so different that --

1 You know, there's apparently among the 2 collected experts a disparity of confidence, let's 3 say, in the methods. Are they so different from 4 what's been -- what other folks are using, the methods 5 that are essentially endorsed under 6850 that, you know, they are diverging? 6 MR. WACHOWIAK: 7 Yes and no. 8 CHAIR STETKAR: Okay. 9 MR. WACHOWIAK: So there were some that were just -- so, for example, on pump oil fires, okay, 10 there's already a discussion in Supplement 1 of 6850 11 that says, "This is how you treat main feed pump oil 12 pump oil the method on fires 13 and 14 essentially saying, "Okay, let's do the same thing that we did for main feed pumps for all oil-filled 15 16 pumps." 17 Okay, so there it's a, you know, it's a gradual evolution. It's not a -- it's not a complete 18 19 change of anything, and the difficulty with that one, then, was to go through the data records and determine 20 what the right split fractions were for the different 21 pieces in that. 22 23 different So, know, there are you 24 perspectives on what constitutes a large amount of oil

So that's an evolutionary sort of thing.

in a fire.

1 There are -- the electrical cabinet 2 severity factor method is really adding a -- by the 3 time we were done, it was actually adding a scoping 4 step into 6850, so in many of the cases of 6850 you 5 have screening, scoping, detailed analysis. In some of the areas like with the 6 7 electrical cabinets we had screening and detailed 8 analysis. That was it, and over the year of 9 development with that method, what we -- what the 10 panel came up with was essentially the intermediate 11 step. This is what you can do if you want to do 12 screening, scoping, and detailed analysis so that you 13 14 could cull down quite a bit of the detailed analysis when you're looking at electrical cabinet scenarios. 15 So that's quite a -- that's adding a new -- it's still 16 within the framework of 6850, but it's adding a new 17 type of step. 18 19 CHAIR STETKAR: Okay. 20 MR. WACHOWIAK: So that one was a little more on the revolutionary rather than evolutionary 21 scale of things. 22 23 That helps. CHAIR STETKAR: Okay. Thanks. 24 25 MR. WACHOWIAK: It's a spectrum.

CHAIR STETKAR: Okay.

MS. ANDERSON: All right. So, external consensus review is a key component of the treatment of the unreviewed analysis methods identified in the peer review process.

As I noted earlier, there is that next step is where the NRC review comes in. The time lines have been variable. Again, it can -- we had one where it was up to eight months. In some cases, we do hear back much more quickly.

There are also some -- there have been some concerns about the technical basis for some of the review conclusions. There was a sense that the electrical cabinet method that was submitted that we heard back on in June, there was a sense that it wasn't really evaluated on its own merits in the technical evaluation.

There was some discussion of, "Well, there might be other better methods." I guess that was one place where there was some frustration.

Finally, one complication we faced with unreviewed analysis methods is how these are going to be addressed in the LARs. When do they need to be mentioned? When do you need to do sensitivity studies?

1 When is the NRC review done? When does it -- does it need to be done if the panel has made a 2 3 finding? How do you close out the F&O? What exactly 4 do you do with this in the LAR? 5 I think we're getting somewhere with that, so that's being clarified, but it still a little bit 6 7 difficult for the licensees submitting this year. end result is that you might wind up with some work 8 9 that you need to do in a very short amount of time. 10 Speaking of work you might need to do in a short amount of time, sensitivity studies, all 11 right, that everyone has been asking for. Again, I 12 just want to emphasize we recognized that there needed 13 14 -- that they have to be done for risk-informed 15 applications across the board, but where we run into difficulty is what the expectations are, and they 16 17 don't seem to be that clearly documented. discussion of There is some what 18 19 sensitivity studies are expected in Req Guide 1.174, key assumptions, and you need to look at reasonable 20 alternatives, but it's not really that specific or 21 informative for an 805 applicant. 22 So there are, you know, questions of when 23

do you need to do a sensitivity study? What type do

you need to do? Again, do you need to do parametric,

24

or do you need to compare to another method?

In some cases, expectations for comparing to NUREG-6850, particularly if a request comes in a short time frame, that can be pretty impractical, and there is some concern about how the results might be used.

Specifically, there is some concern that there might be some SE conditions that result from a review of a sensitivity study if the sensitivity study isn't really interpreted correctly or not presented as best possible. So that could be difficult with respect to timing and with possibly making some changes that aren't really optimal.

MEMBER BLEY: I'm just thinking if I were in your spot, in the licensee spot, if you -- if one were to get very clearly documented requirements for sensitivity studies, my guess is they'd be rather broadly inclusive.

Without those, it's up to the analyst, it would seem to me, to identify the areas where there is the most uncertainty in what they've done and develop specific sensitivity studies. Seems like you might be asking for something you really won't like if you get it.

MS. ANDERSON: Right. Right. I mean,

1	that is something we have contemplated, but the
2	difficulty is right now people get requests for
3	sensitivity studies that come just with such a short
4	response time frame.
5	MEMBER BLEY: This is primarily due to the
6	short time frame that was there for the whole, this
7	whole effort. Is that right?
8	MS. ANDERSON: Right. That's part of it,
9	but if you get a request for an additional sensitivity
10	as part of the RAI process, you have a serious time
11	limitation there, too.
12	MEMBER BLEY: Is that I'm just curious,
13	because I haven't been involved in this. Where does
14	that time limitation come from? Is it the already-
15	existing schedule, or is it staff says, "You've got to
16	tell us by a month from now?"
17	MS. ANDERSON: There's a I can't really
18	speak to exactly how
19	MEMBER BLEY: I'm just curious as to where
20	that limitation comes from.
21	MS. ANDERSON: When you get a set of RAI,
22	you have a specific time that you're allowed to
23	respond. I don't know how much flexibility the staff
24	has there.
25	MR. KLEIN: This is Alex Klein. With

respect to -- I want to make clear the terminology here, first of all. There is supplementary information, and then there are requests for additional information, two different processes.

The supplementary information is part of our LIC-109 process, and that has a schedule. We've got currently a three-month calendar schedule for the acceptance review, and I think that's probably where the industry is talking about a limited time span.

With respect to RAIs, there's a -- when we issue RAIs after we -- for example, after we're done with our site audits, there's a negotiation that we have with the licensee in terms of how long do they think they need to take. We have discussions with them. You know, "How long do you need to take for these RAIs?"

So, in some -- in some cases, we have RAI response dates out there that go 60 calendar days.

Some are 90 calendar days and I think in some situations up to 120 calendar days.

So if the licensee provides us with a basis why they need to extend that time period, then we'll consider that, but, again, even within that RAI process we're in a LIC-101 process where we have a two-year review schedule, so the staff is also within

1 this time limitation. That two-year review schedule starts when 2 that license amendment request is submitted to the 3 4 NRC, so the clock is ticking from day one, basically, 5 so, yes, there are some time pressures. MS. ANDERSON: 6 Right. 7 CHAIR STETKAR: Are most of, either of 8 you, are most of these time-sensitive requests for 9 sensitivity studies, which Ι think have 10 characterized as, you know, surprises or coming out of the blue, "Can you perform a sensitivity study on 11 this?" --12 Are most of those, are they broad-based, 13 14 you haven't done sufficient sensitivity analyses as 15 part of the LIC-109 review, or are they deriving out 16 of specific issues that are identified during the --17 during the review process as a result of an RAI, for example? You know, I --18 19 MR. WACHOWIAK: So one of the, I think, impractical ones that might be referring to on the 20 slide here is that I quess there was one that I think 21 was in the LIC-109, whatever the --22 CHAIR STETKAR: It's the first part. 23 24 MS. ANDERSON: The supplementary

information request.

1 MR. WACHOWIAK: The process, and my 2 information might be a little dated here, but in this process dated means, you know, three weeks old, so --3 4 The utility used the electrical cabinet 5 screening, scoping detailed analysis process, and the sensitivity came back, "Redo your analysis without the 6 7 scoping part in the middle, so do all the detailed analysis and show us what the differences are." 8 I don't know what the ultimate resolution 9 10 of that was, but to me that seemed like that would be an impractical sensitivity study to do, because it's 11 essentially saying redo the analysis. 12 CHAIR STETKAR: Right, and that was during 13 14 the early part of the --15 MR. WACHOWIAK: Right, so I don't know what's happened since then, and so there may be more 16 17 people in the room that understand that has happened in the negotiations since then, because something 18 19 would have to happen there, and that particular request to me seems impractical and would not be able 20 21 to --That's a surprise to me, 22 MEMBER BLEY: 23 because that's a sensitivity study on process. 24 thought we were talking about sensitivity study on a

couple issues.

1	CHAIR STETKAR: This is that's I
2	guess it would be worthwhile if the staff and folks at
3	you know, you talk about time pressures. If by
4	1:00 we could get a little bit more understanding
5	about issues like that, that's a bit
6	MS. ANDERSON: Right.
7	CHAIR STETKAR: troubling, quite
8	honestly.
9	MS. ANDERSON: And I think and that was
10	there was a lot of time pressure there that came
11	because it was part of the supplementary information
12	request, but even with a 120-day RAI response period,
13	I mean, that would be
14	CHAIR STETKAR: And it was just make
15	sure I understand it correctly. It was broad-based.
16	Basically, go do it for all of the cabinets where you
17	applied the essentially where you applied the
18	scoping.
19	MR. WACHOWIAK: That's my understanding.
20	I'm getting nods from the back.
21	MS. ANDERSON: Actually
22	CHAIR STETKAR: Okay. Thanks.
23	MR. DINSMORE: Hi, this is Steve Dinsmore.
24	MR. WACHOWIAK: Hi, Steve.
25	MR. DINSMORE: Steve Dinsmore, senior

reliability and risk analyst from APLA. I guess there was an understanding from the staff side, and I thought we had communicated to the industry, that if you used an unreviewed method in the development of your LAR, you would provide a sensitivity study with the LAR. There might have been some confusion about that. We realize that these sensitivity studies can take a long time.

MS. ANDERSON: I think that there was some misunderstanding. It wasn't that you needed to do it but what it entailed.

CHAIR STETKAR: I think -- I think we have to be careful here, because people tend to throw words like methods, models, sensitivity studies around pretty glibly, and, as Dennis pointed out, this is -- I'd characterize this as a process, not an analytical method, if you will.

I'd certainly like to understand a little bit more about this issue, only because I'm aware of typically the importance of electrical cabinet fires, the amount of effort that's required to do an electrical cabinet fire evaluation for a plant, and having some confidence that going forward from where we are now in this process that there's a pretty clear understanding, because it could substantially affect

the amount of effort that's required on the part of everybody coming in in the future.

You know, we're not talking here about a particular model for a plume temperature compared to another model for a plume temperature, which, you know, you can look at. This is a -- this is a methodology process type issue. Do you have other examples, or is this the --

MS. ANDERSON: The one example I have in the slide I just brought up is the electrical cabinet method.

CHAIR STETKAR: Okay.

MS. ANDERSON: It sort of walks through why it would be -- why it would take so much time to do such a sensitivity study. This method assigns a conditional probability to reflect the fraction of fires predicted to exhibit the behavior consistent with that that's described in NUREG-6850 based on a thorough analysis of available data.

The reason we selected this is that this was a method that we heard back from the NRC staff that they didn't accept the consensus review panel finding, so right now there would be an expectation that a licensee that used this, that they would do a sensitivity study.

1	So, if you did a sensitivity study
2	comparing the results you obtained using this approach
3	with the results you obtained using the 6850 approach,
4	it would be very time-consuming and cumbersome. I'm
5	not saying impossible but extremely time-consuming.
6	You would be doing looking at doing
7	reanalysis of fire modeling, growth, and suppression
8	for a lot of scenarios. You're looking at a level of
9	effort that could be up to 40 weeks.
10	CHAIR STETKAR: Could be up to our
11	lifetime, depending on how efficiently we work.
12	MS. ANDERSON: Right, you can you can
13	always model more, but just to get and finish
14	documenting the results, you know, then you need to
15	look at, "Well, what did we find out from this
16	comparison? What does this really tell us?"
17	You'll get a risk increase from the non-
18	propagating fires, and you'll basically skew your risk
19	results. It's unclear exactly how you impact your
20	application. So, that would be quite time-consuming,
21	and it's not really clear what the what's gained
22	from that information.
23	CHAIR STETKAR: The I clearly
24	understand the level of effort, regardless of your
25	estimated amount of time. The product of your last

36 1 bullet there, the risk increase from non-propagating 2 fires will decrease, and the bias will skew the risk results and have an unknown impact on applications. 3 4 I guess that sort of supporting bullet I'm 5 not quite sure what you're saying there. I mean, in -- let me say just my vision of the whole process is 6 7 that you start out with something that's fairly simple 8 and hopefully conservative. 9 As you refine the analysis process from, 10 you want to call it screening, scoping, detailed analysis, you become more realistic hopefully 11 reduced uncertainty, and remove some of the most 12 important conservatisms in that process such that your 13 14 detailed analysis should be as realistic as reasonably 15 achievable using the tools and the data and all of that sort of stuff. 16 17 The scoping, the results of the scoping analysis should be somewhere in between. They should 18 19 still have some amount of conservatism inherent in them, and the whole reason you do it is to simplify 20 the process so you don't have to do the detailed 21 So I'd like to understand, since you 22 analysis. brought it up, the product of the comparison in terms 23

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

ANDERSON:

Well, if you're --

of what it might mean.

MS.

24

1 basically, you're looking at back-tracking to you're going to be weighting some of your 2 3 differently, from what I understand, and Kiang Zee 4 just stood up --5 CHAIR STETKAR: Okay. -- and he is going to 6 MS. ANDERSON: 7 kindly explain exactly how this goes down the line. Well, this is Kiang Zee. Maybe 8 MR. ZEE: 9 I can help, and I like trying to portraying some of these not so much in the words that we all struggle 10 with but sort of in sort of visuals. 11 In yesterday's presentation from DC Cook, 12 a picture was shown that showed a series of electrical 13 14 panels along the wall, cable tray coming out of the and one of the words Rick said in this 15 top, 16 presentation was because the panel wasn't sealed, the 17 fire will always propagate up the cable tray. So, the way I like to characterize it from 18 19 big-picture standpoint, when look we electrical cabinet, we look at fires that stay inside 20 the box and fires that get out of the box. 21 If you -- what Rick was saying is because 22 of the rules of 6850 and the characteristic of that 23 24 panel, every fire that occurs in that panel always

There is no fire within the

gets out of the box.

distribution function for heat release rates for that cabinet type that stays entirely within the panel.

So, what we're saying here is because of that treatment, every fire, twelve minutes of growth rate. Every fire comes to some peak heat release rate per the distribution function, but every fire gets out of the box.

What this factor is trying to do is create a partition between fires because of their behavior and experience with respect to not every fire having 12-minute growth rates, not every fire growing a certain way, not every fire having this genericized suppression characteristic.

The experience would exhibit sort of a natural behavior of these fires, and that was what was done when we reviewed all the industry events to try to find those fraction of fires that had this combination of behaviors that would just inherently tend to make the fire stay inside the box. That became sort of a slick fraction, if you will.

Now, if we take the factor out and we say every fire gets out of the box, what that will tend to do is it'll tend to have your risk analysis tell you if you have a critical target that's important to you that's outside the box, it doesn't matter where it is

outside the box. It will always give you the same answer.

So, moving forward in applications, if, for example, I was making a modification and I was rerouting cables, if the analysis is already telling me that every fire gets out of the box, then I can put a new circuit or reroute something and put it anywhere I want near that box, and I get the same answer when inherently we know that's not true.

So, this idea of masking is something that people I think are generally beginning to start talking about, whether some of these things start to drive some of these fire behaviors to always be very, very aggressive, whether it might have this unintended consequence in the other applications where it may be masking something. I think Doug alluded to that a little bit in one of his earlier presentations to the Subcommittee.

CHAIR STETKAR: Thanks, Kiang. Let me -- stand up there, because I'm sure you're going to need to respond to this.

If I start out -- we'll use the box and the cabinet analogy. If I start my analysis during my screening process and I use a 1.0 fraction as recommended in 6850 where all of the fires get out of

1 the box, as you've kind of characterized it, my sense is the scoping process might apply a factor of like 2 .5, maybe .3, maybe .1. 3 I don't care, some number. 4 So let's say 50 percent of the fires get 5 out of the box. That's an improvement. It's not much of an improvement, but it's an improvement. 6 7 If I were to do a detailed analysis, if I were to build myself a little FDS model for that 8 9 cabinet and look at all of the ignition sources and 10 any location in the cabinet and develop heat-release rates and spend, you know, the greater fraction of the 11 gross domestic product of the United States doing 12 that, I might determine that, you know, 1/100th of one 13 14 percent of the fires get out of the box. I might. Ι don't know. 15 What I'm trying to understand from the 16 17 third bullet is my understanding of this sensitivity analysis was a request to say, okay, if you applied 18 19 that -- it's called a .5 factor -- for your scoping, do a sensitivity analysis to show what? How much that 20 difference is from the 1.0 factor or from the detailed 21 analysis that would give me the 1/10th or whatever I 22 said, 100th of one percent? 23 24 That's what I'm trying to understand, you

this notion of risk increases

know,

25

from

1 propagating fires will decrease and biasing the numerical results. I'm not arguing with level of 2 3 effort. 4 MR. ZEE: Right. 5 CHAIR STETKAR: I'm trying to understand what all of this means in terms of understanding the 6 7 risk from the fires compared to doing -- you know, from a scoping analysis compared to the detailed 8 analysis, unless I'm misunderstanding this request for 9 10 the sensitivity study. MR. DINSMORE: Mr. Stetkar, if I could for 11 a second, this is Steve Dinsmore again. I think, 12 actually, what Kiang has discussed is a good example 13 14 of the complexity of these different decisions. So there's a whole series of decisions 15 16 there, and what we were requesting was we would like to know what the answers, all the answers would have 17 been if you'd have used 6850, as opposed to whichever 18 19 method he was proposing or which set of parameters he was proposing. 20 We wanted to do that, because we hadn't 21 reached resolution on whether we would agree with this 22 new set of parameters or not. We wanted to keep 23 24 We needed the licensees to be able to submit.

Many of the licensees had used these other

1	methods, and we realized it would take a long time to
2	go back and fix them, so we said, "Well, go ahead and
3	submit. Give us a sensitivity study so we have
4	something to work with moving forward."
5	CHAIR STETKAR: Sensitivity study, though,
6	in what sense, Steve, sensitivity compared to
7	MR. DINSMORE: To what you would get if
8	you used
9	CHAIR STETKAR: Assuming
LO	MR. DINSMORE: 6850 methods or some of
l1	the facts in the
L2	CHAIR STETKAR: Well, wait a minute. 6850
L3	allows you to do a broad range of anything from it
L4	can't be any more conservative to this to doing very
L5	detailed, specific fire modeling, so don't hang it on
L6	6850, because
L7	MR. DINSMORE: I don't think 68 I don't
L8	think this is 6850.
L9	CHAIR STETKAR: You mean 6850 process?
20	MR. DINSMORE: Okay, I'm starting to
21	because I'm not entirely sure what I thought 6850
22	would not does not
23	CHAIR STETKAR: It doesn't have a scoping
24	step for this particular type of fire, if I recall
25	correct.

1 MR. DINSMORE: We'll talk to Gallucci and 2 ask his --3 CHAIR STETKAR: But that's a process. 4 That's not --MR. DINSMORE: Right, but --5 CHAIR STETKAR: That's some intermediate, 6 7 not such detailed --8 MR. GALLUCCI: Ray Gallucci, NRR. 9 they done a phenomenological approach with detailed fire modeling to begin with, and there was an attempt 10 to pursue and effort like that with the EPRI/SAIC heat 11 release rate report, this entire cabinet factor method 12 would not have even been necessary. There would have 13 14 been no request for sensitivity if that had been the 15 approach that was taken. Because the approach was taken, there was 16 cabinet factor method with which the 17 this NRC dissented, and, by the way, the dissent was known to 18 19 the industry as early as last October. The request is that either perform some sort of phenomenological 20 modeling for your comparison, or, in lieu of that, you 21 go back and you just do not take credit for the 22 factor. 23 24 CHAIR STETKAR: Okay. Thanks, Ray. That in my mind, anyway, helps to kind of 25 least,

understand where that issue is.

MR. ZEE: Well, let me sort of expand on this a little bit, because, John, I think you were headed exactly where I think it should go, but at one point where your mental framework for how the process should work, it went on the other side of the line in terms of being outside of what the industry understands as being what the staff expects.

CHAIR STETKAR: Okay.

MR. ZEE: So, for example, you are absolutely correct. The first step would have been do a 1.0. Every fire gets out of the box. You get an answer. You don't like it. Then do something straightforward with something simple.

Now, what's interesting is, as you were running through your tape, if in that one example we saw that we're looking at the panel on the wall, and with the rules within 6850 with the heat release rate distribution function in 6850, if I envision a table tray about two feet above that cabinet and I did 12-minute growth rate, I use the approved suppression, manual suppression rates. That factor I would get after I have exhausted all my fire modeling tools is, in fact, somewhere between .4 and .6

So, the next step which you describe is

1 that if I went inside the panel, tried to find where the fire was inside the panel, moved things up and 2 3 down within the panel, that the staff would interpret 4 as a new method and would ask for a sensitivity study 5 against the answer you got with the .5 or .6 factor. 6850 doesn't prescribe or describe how to 6 7 go about doing that, and, in fact, if one were to 8 attempt to do that, what would tend to happen is the 9 lower you are in the panel, you would start to damage 10 fewer circuits, but since fires would naturally vertically propagate up, at some point in time you 11 would very rapidly get to the same set of impacts as 12 you would have gotten for a fire that consumed 13 14 everything within the cabinet. 15 So, in some early effort to try to do 16 that, what we discovered was even if you were to try 17 to spend the time to bring out where all the wires were, where they landed, all determination strips, it 18 19 didn't really have a substantive change to what the 20 answer was. 21 CHAIR STETKAR: Okav. So, I guess what I'm trying to 22 MR. ZEE: say is the net impact of exhausting all of your 23 24 available fire modeling tools --STETKAR: Wouldn't make much 25 CHAIR

1	difference compared to that.
2	MR. ZEE: Wouldn't make much difference,
3	so the issue is, and I heard this yesterday I think
4	our issues aren't necessarily with the fire modeling
5	tools or fire modeling technology. I think that's
6	fine. There are empirical relationships. There's
7	many people who spent a lot of time dealing with it.
8	The issue is the source of the input parameter that
9	you feed into that correlation.
10	CHAIR STETKAR: Okay. Thanks.
11	MEMBER BLEY: Mr. Chairman, I'm not sure
12	that we can make any judgments about this sort of
13	thing unless we see some real details on some of the
14	exchanges. I mean
15	CHAIR STETKAR: That's where I was kind of
16	getting to is I think we've probably spent more than
17	enough time on this. I think we spent I think it
18	was productive, because we at least understand that
19	issue that you highlighted, and I agree. It is an
20	important issue, so I think you're right. We should
21	move on.
22	MS. ANDERSON: All right.
23	CHAIR STETKAR: But thank you for bringing
24	it. That was good.
25	MS. ANDERSON: All right. Glad to hear

that that was helpful. So I'll run through the rest of this pretty quickly, because I think we've made our points.

The utilities are pursuing moving targets.

The fire PRAs do remain conservative, which obscures some insights. There is some concern that if you use some specific methods that aren't currently in NUREG-6850 those could wind up causing problems with your SE.

That could eventually make it difficult or impossible to make improvements to your fire PRA in the future after that SE comes out, so there are some concerns about that, and updates could also be difficult.

Again, our big concern is the potential for hampering technology advancement. As we noted, there are some time line issues, and for utilities that need to submit NFPA 805 applications in the near future, pursuing technological advancement and new methods and approaches is not really attractive.

I don't like to whine and not offer suggestions for improvements, so how can we make this better? We have already been in discussions with the NRC staff to make this better and make sure we understand our language and terminology a little bit

1	better, and we appreciate that.
2	I think that's going to do a lot for the
3	applications that are due in 2013-2014, the
4	applications coming in this year, but it's still going
5	to be a little bit shaky, but in the future that'll be
6	helpful.
7	MEMBER BLEY: This was always the intent,
8	as I understood. Is that not true?
9	MS. ANDERSON: Was what always the intent?
10	MEMBER BLEY: That the methodology would
11	evolve.
12	MS. ANDERSON: Yes, we need to pursue a
13	living
14	MR. WACHOWIAK: That's my presentation.
15	MS. ANDERSON: Yes, that's Rick's
16	presentation. He has a good five minutes for it.
17	MEMBER BLEY: I'll be glad to wait for
18	that.
19	MS. ANDERSON: But, yes, that was always
20	the intent, but we're concerned that that's not going
21	to happen because of some of the process issues.
22	We need to make better use of the
23	consensus review process, and, again, we need to make
24	sure we have a mutual understanding of how to approach
25	new methods in the 805 LAR review process and the

1	acceptance process.
2	I think we're getting there. We've had
3	some good conversations with the NRC staff the past
4	couple of months, but it's still going to take a
5	little bit of time.
6	MEMBER SCHULTZ: Victoria, for
7	clarification, what are you shooting at when you're
8	talking about a better use of the peer review process?
9	MS. ANDERSON: The peer review process,
10	you know, compares the fire PRA against the ASME and
11	FPRA standard, but rather than relying on the
12	information from those, there is still some reliance
13	in the LAR development and review process on NUREG-
14	6850, rather than the standard.
15	MEMBER SCHULTZ: Okay. Thank you.
16	MS. ANDERSON: So, that's some of our
17	concern. I think the conclusions at this point are
18	pretty evident. We need to make sure that we're
19	continuing to develop and use realistic fire PRAs, and
20	we need to make sure we have a process for NFPA 805
21	that fosters that. We need to continue pursuing
22	improved methods, and that's what Rick is going to
23	talk about.
24	MR. WACHOWIAK: Okay. So, we all know

this stuff here, so I'll go on. I think we've covered

some of what I was planning on talking about already, so at places I'll try to move along.

I want to -- I want to touch on what it is our issue is with this thing, so a little bit of a background so we get some of our terminology and expectations correct. Then we'll talk about what the vision for 6850, EPRI 1011989 was from the beginning. Then I'll offer some thoughts about how we can move forward from here.

So, just to get everybody on the same page, the process that we use for developing PRA starts with you do a PRA, okay. Simple stuff, do a PRA.

Are the results reasonable? And I'm not talking about here do we have the right number. What I mean is are the results telling us the things that are real that we would get from our model, the insights that make sense in that if we change something in the plant, it would change the PRA model predictably, that sort of thing. If we don't get reasonable results, we go back and iterate back through in that loop.

Then we also go and we do risk-informed applications, and when we do the applications, we find out more things about our model, about our plant,

things like that. Once again, we could find an area where the results aren't reasonable for that application.

We would have to feed back through, and then finally we'd come out and use this. This happens in all the different pieces of the PRA and like that, so it's not really a simple, as simple as I put on this slide.

In the background of all that there is continuous research into new ways of doing things, better ways of doing things, more data collection, that sort of thing. As you go through this process, you tend to fold those sorts of things in.

So, as kind of an example that's been thrown around in terms of things that you learn while you're doing these things into the fire PRA world, let's say we have a room, a fairly large room kind of like this one.

In one corner of the room back in the back there is a risk-important set of cable trays, and it's way off on the side by itself, and we find that in doing the analysis that that scenario where that tray is burned is important. So we want to do something about that. What can we do in the plant to make sure that tray is protected?

With the method that we have in front of us here that we've all used and in many cases trust in this, we can model what we would do to address that cable tray. So one example you would think of, let's put up a fire barrier around that cable try so it's by itself and nothing can -- it's protected.

Just going through the method, we would find that the risk would tend to go up if you build a fire barrier around that because of the way you count the fire areas. Now, there are some ways to mitigate that and stuff like that, but in general if you do that, because it's being taken out of the big fire area and being put into its own, the counting rules get you to a risk increase in that particular space.

However, if you were to put a piece of tape around the area where the cable tray is and just say, "Don't put combustibles there," the method would tend to decrease the risk a little bit.

So that kind of a result that you would -you would find only by doing a real fire PRA at a real
plant and trying to address a risk-significant issue.

It's the only place where you would find anomalies
that come out in the method.

So, we need to take that information that we find those kinds of things and feed it back.

Something is not working correctly there. Maybe it's the way things are averaged out in the counting.

Maybe it's the way the weighting factors are done, but there is something that's going on there that isn't a reasonable result, okay, so thus the need for having this feedback loop, not only at the base PRA section but at the application section, because when you use it, you find things like this. So, that's the background I want to have on this.

Now, the concerns we have that we've seen in some of these instances with the application of 805 along with the building of the fire PRAs is that that traditional process doesn't seem to be either being used or allowed or something. Something is happening here where you get the idea that all of the instructions are in 6850 and the associated documents that go along with that and that that's all you need to know to do this.

We have to have the insights that we gain by building the fire PRAs and by doing this application fed back into the process, and we really can't use it, if you will, as a cookbook. We'll miss some things.

One of the things that it seems like we're getting toward in this particular application is the

fire PRA is being treated similar to the way the DBA LOCA analysis is. We come up with a method that's reliably conservative. It gives us a high result every time.

We know that it's the bounding result, and then we apply that to everything without going the traditional PRA method where we strive to feed back our experience and build realism into the models. It looks like this is some of the concern that the industry has that we're going toward this.

We don't want to do that. I think we want to -- we want to get back into the mind set that we are going to continuously improve the models, we are going to continuously improve the way that we use fire PRA in our application.

So, getting to 6850, EPRI 1011989, there have been things thrown out saying that the industry is trying to -- is trashing 6850 right after it came out and saying we don't want to use it. Maybe the way it's been portrayed sounds that way, but I just want to say that, at least at EPRI, we fully stand behind what's the document that came out as 6850, EPRI 1011989.

That was developed between EPRI and Research, did it in 2003, published in 2005, so it's,

you know, it's graying a little bit, but it was the best practices of things that were available at the time.

Not a lot of new development was done during that process. There was some, but not a lot, and it was arranged in a way that you could easily understand how you would go through the process of doing a fire PRA, and that process, that framework that's in 6850 is robust.

Maybe there's some tweaks, you know, some places where we didn't add a scoping step. We could add a scoping step now, but overall what's arranged in that particular document, that framework, is good, and it probably is going to be good for quite some time. We want to use it, and we want to use it properly.

Okay, so don't -- we're not trashing this.

What we find, though, is that the document put together a set of methods, tools, and data that fit into the framework of doing a fore PRA, and that was done based on the best available information at the time.

We are continuing to get more information, and we're continuing to do the fire PRAs and finding quirks like the one I mentioned there, and there are other ones that are being found that we need to just

figure out how to address those things.

So, in my mind, if the issue is does it need to be -- is 6850 going to be the place where we're going to go for our look at how you do fire PRA for the framework and maybe for the toolbox that does it? We need to make sure that the document actually can be used for that purpose and is being used for that purpose.

One of the other things that I'm going to go through here a minute, maybe some of you recognize this, but this document was intended to be a living document. It wasn't intended to be static and say, "This is how you do it," and 100 years from now this is what we'd be doing.

I have a couple -- I pulled quotes from the thing there, and we can go through these quickly, but the intent is to say that additional developments were anticipated when it was written, and they should be able to be folded into the framework. That's what we believe.

The authors of the document also recognize that as you do fire PRAs you're going to find out things that they didn't know and that the document would need to be updated to address the things that are found by doing fire PRAs.

just the 6850 project itself 1 2 supposed to be done in four phases, and this is 3 documented in the report itself. The third phase, which was supposed to be full-scale pilots of the 4 5 methodology to get those insights that they were talking about and fold it back in, that wasn't done in 6 7 the time frame there. So, because of that, we still -- we have 8 9 to do it now, and we're doing it now in the, you know, with the shadow of these NFPA-805 LARs around us, as 10 It would have been much nicer to have done the 11 pilots outside of a parallel regulatory process, but 12 we are where we are, and we have to deal with this. 13 14 Once again, in the document they say -they talk about the pilot not being done, and one of 15 their conclusions is that the authors of the document 16 weren't able to predict the impact of the overall 17 risk, because they just didn't know, so it was the 18 best available information at the time. 19 20 It was put together in a framework that looked -- that is robust and will work, but there are 21 nuances and quirks and things that couldn't have been 22 predicted at the time of the document, and the authors 23 24 recognized that that was going to happen. So, I think I said all this when I had the 25

quote up there, but one of the keys that they -- I didn't say all of it. The second bullet I didn't get to.

One of the keys, though, they recognized, and we all recognize this, is that if you're going to do something that is methods, tools, and data that's somewhat different from what's in the document right now, the reason that the framework was put together is so that all the pieces would be self-consistent, right.

So, if you're going to do something different from what's in there, you have to make sure that it's also going to be self-consistent with all the rest of things, or you have to change the associated tasks along with it.

So, the document itself, you know, it's kind of like the Constitution. The document itself gives you a way to update the document, so it's part of why I consider that the framework is robust, because it recognizes that it would need to be updated, and here's the kinds of concerns you'd have to deal with when you're updating. This is the quote that goes along with that piece.

So what we've been trying to do over the last two or so years is advance the state of the art

1 associated with how you do fire PRAs. I think --2 well, we've tried different things. 3 There's the fact process that we talked 4 about that some don't like and others do like, and, you know, it's all over the -- the utilities, the 5 vendors develop position papers, and they've done 6 7 their own things, and that sort of thing has happened. 8 EPRI has written some reports and put out 9 quidance for how to do things. We've had the expert 10 panels, which is the review panel sort of thing. We've had other expert panels to address 11 these sorts of things, and then also the research arm 12 of the NRC has been doing more experiments on cable 13 14 trays, and they've been writing NUREGs associated with 15 this sort, these sorts of things. We've had varying degrees of success and 16 17 acceptability with all of these, and some of the, from my perspective, some of it is because we were -- we 18 19 did some of these because we were trying to do things meet the schedules for these LAR 20 quickly to submittals. 21 Some of the things we did because we were 22 address specific things for specific 23 trying to 24 utilities and their configuration. Then when we tried to make it generic to cover everyone, the assumptions 25

and things will break down a little bit, and it makes it more difficult. Once again, the time pressure on this to get these things done quickly has been maybe some of our undoing on these, maybe.

We still need to do this. We need to figure out a way to be able to advance the state of the art, make it acceptable, make sure that we all have the same understanding of what it is we're trying to do going forward, and have a reliable, predictable way of doing this.

So, in thinking about how we would do this, we have to recognize that there are two different needs, and I mentioned this a few times now this morning is that there are things that address a specific issue in a specific configuration at a plant and then there are things that are generic that we want to update the method, tools, data to incorporate new information, new knowledge that we have either gained by doing experiments or by doing fire PRAs.

So, I've been working with the guys in Research in the fire area with Mark Salley, and what we think we need to do is fold the advancement work, the development work, maybe into a process that does the updates to 6850, EPRI 1011989 that were anticipated from the beginning and can bring the

1 people together to look at the interdependencies between the tasks. 2 This is more for the generic sort of thing 3 4 that we're looking at here, and we would still like 5 the plants to address on their own and through the peer review process plant-specific issues that come up 6 7 and get the guirks that are on there. I don't know that the acceptance piece of 8 9 this, the work being done under the MOU, is going to be much better than what we've done with the other 10 methods over the last couple of years, but I think 11 it's worth attempting, and it's probably the most 12 reliable way to bring it all together and keep a 13 14 coherent implementation of the framework that we have. 15 I think I just talked about the So, 16 parallel paths. We have to do all that, and we still 17 need the information coming from the individual PRAs to inform what it is we want to do on a generic basis 18 19 for this. One of the things that I think is a high 20 priority are the electrical cabinet scenarios, and we 21 22 talked about them. It's come up over and over. time we talk about this, it comes up. 23 24 What need to do is we need

understand where the issues are with the electrical

1 cabinet fires. We've, you know, kind of gone off and looked at what we've seen in the past and try to 2 3 adjust the methods to address what we've seen in the 4 past in electrical cabinet fires, and I think we need to take a real hard look, hard dive into this and see 5 6 what's going on. 7 So now that the database project we've 8 talked about previously here is coming to a 9 conclusion, we can pull some of the information from 10 the fires that we've seen out of that and try to make some characterizations. 11 So, in the 1990 to 2000 data, which is the 12 current window, we've looked at -- we've looked for 13 14 electrical cabinet fires, things that would be called electrical cabinet fires, and counted in the frequency 15 for electrical cabinet fires that you would put into 16 scenarios in a fire PRA. 17 There's 150 or so. That's an order of 18 19 magnitude thing. It's probably a little bit more than that, but it's not quite 200. 20 We looked and said, "Okay, so tell me how 21 many of these 150 fires" -- which is a pretty good 22 sampling, right? "How many of these fires have caused 23 24 damage to cable trays?"

We look in the database. The answer is

1	none. Nothing is marked as a cable tray damage, so we
2	said, "Okay. Well, maybe all the cables aren't listed
3	as cable trays. Let's look for damage to cables as
4	the target in the database."
5	What we find is that there were no this
6	is thermal fires, not high-energy arc faults.
7	CHAIR STETKAR: Okay.
8	MR. WACHOWIAK: Make sure that we're all
9	with the same terminology here. The thermal fire is
10	in electrical cabinets.
11	CHAIR STETKAR: Thank you.
12	MR. WACHOWIAK: That's the ones that are
13	causing problems in the fire PRAs. It's not the high-
14	energy arc fault, necessarily, across the board.
15	We looked for cable failures, and we
16	didn't really see anything where the cables failed.
17	We saw a handful where the cables had been damaged,
18	you know, jacket damage, insulation charring, that
19	sort of thing.
20	The percentage is small. It's five, six,
21	three, somewhere around there, depending on how you do
22	the math and what kind of priority you use and that
23	kind of thing. Anyway, so it's small, less than ten
24	percent.
25	CHAIR STETKAR: Rick, we are running a

1	little tight on time here.
2	MR. WACHOWIAK: I'm almost done.
3	CHAIR STETKAR: I know. One quick
4	question, though, and we may decide to have another
5	briefing on this data if you're depending on where
6	you are.
7	Have you started to separate out
8	electrical cabinets from the one-size-fits-all into
9	different categories of electrical cabinets ranging
10	from small, wall-mounted cabinets to 6 kV, 13.8 kV
11	switch gear?
12	MR. WACHOWIAK: That piece has not been
13	done yet. However, however, the way the database is
14	structured doesn't require us to use the same binning
15	that we used previously
16	CHAIR STETKAR: In 6850.
17	MR. WACHOWIAK: So, that can be done. I
18	don't know if it'll be done in the first phase.
19	CHAIR STETKAR: Well, the reason I ask is
20	some of the conclusions that you're drawing regarding
21	consequential damage to cables, that conditional
22	probability of consequential damage to cable may vary
23	significantly, depending on the category of that
24	cabinet.
25	MR. WACHOWIAK: I agree.

1 CHAIR STETKAR: We'll just leave it there if you haven't --2 3 MR. WACHOWIAK: For right now, I didn't do 4 I just looked at, you know, things that would 5 be considered electrical cabinets. So, I had -- I went through an exercise, 6 7 then, of looking at the parametric uncertainty, the full distribution of the heat release rate curve 8 9 that's in 6850 and others. There's a few of them, but 10 for this particular exercise I used the one that we had in the Fire Modeling Applications Guide, so it's 11 the one you're familiar with. 12 they quide, looked 13 In the the 14 probability of a flame reaching the cable tray four 15 feet above the target, and they come up with a 16 probability. But that's not really what we're interested here. 17 That's the -- the flame reaching there is 18 19 the probability that you're going to ignite that What we really want to look at is the plume 20 cable. temperature, the probability that the cable is going 21 to experience a temperature that gets to the place 22 where you could damage the cable. 23 24 The four feet is probably a good model or

a good estimate for this sort of thing, because most

1 cabinets have some sort of cable within, you know, one 2 to four feet away from the top of the cabinet, so 3 that's pretty representative on the upper bound, I 4 guess, of where things would be. 5 So, when I went and did that exercise and propagated the full parametric distribution that's in 6 7 -- that's listed in 6850 for that, we find that 96 percent of the cabinet fires should result in a plume 8 9 temperature at four feet that would damage the cable. 10 So, 96 percent is quite different than a couple of percent that we see in the data. So what 11 did I leave out? So far I left out suppression, 12 because the data includes suppression. 13 14 You can use the same method that's in 15 there to extend that to including the fire suppression curve into the same uncertainty distribution, and we 16 17 find, just as Kiang was saying earlier, that it's 40 to 60 percent of the time that you have an electrical 18 19 cabinet fire you would expect the cables to be damaged. We clearly don't see that in the data. 20 There is a difference of an order of magnitude there. 21 I don't know. 22 So, what's wrong? Is the

growth model wrong? It could be. I don't know.

the fire suppression model wrong? I don't know.

heat release rate wrong? I don't know.

23

24

25

Is

Is the fire

could be.

These are the things that need to be investigated, and we need to figure out how we can move forward on these and find the places where the models clearly don't match up with what we observed in the field and figure out how to change those.

I think there's a utility for things like scoping methods. We know about where the thing is going to be, and we can put a scoping method in between the screening and the details, and we can get a pretty good result based on, you know, actuarial type of data, but then we still need to go in, and we need to understand what's going on here.

Is it the fire growth, heat-release rate?
We can pull some of that information out of the
database. We may have to work with Research on that
to do some more experiments in that area, but we need
to do that.

MEMBER REMPE: But a couple of slides back you said you need to have a schedule to figure all this out, yet you're listing all these uncertainties.

Do you have any idea what kind of schedule it would take to resolve these issues?

MR. WACHOWIAK: Welcome to research.

MEMBER REMPE: I know.

1 MR. WACHOWIAK: Some of the things I think can be done. By a schedule I really mean that we can 2 3 lay out in which years we're going to solve some of 4 these problems and then try to identify what we can do 5 in the interim to do that. I think for the electrical cabinets we 6 7 need to be working on it now, and I think the first 8 part is looking through the data at those particular 9 fires and trying to find out what the fire growth is. 10 Is there enough information there to tell other pieces of it? We need to be working on that part now and 11 have something in the relatively near future for it. 12 MEMBER REMPE: Well years to --13 14 MR. WACHOWIAK: So detailed schedule. 15 A couple of years to make MEMBER REMPE: 16 some progress and then --17 MR. WACHOWIAK: I think a couple of years to solve it. 18 Okay. 19 MEMBER REMPE: But we need something now, 20 MR. WACHOWIAK: 21 so we can't just say we're going to wait a couple years and have this thing solved. 22 We need to come up with some reasonably thoughtful ways in the interim of 23 24 saying, "Well, we think we know where it's going to

and based on this evidence we

25

can put an

intermediate method in place."

There's a couple of things that are out there that have, once again, varying degrees of acceptance, and in this particular area it's probably closer to no degree of acceptance at this point, but we need to -- we need to work on those things and find out where our areas of uncertainties are, what the disagreements are on the different methods, and try to put something in place. So it's not a good answer to your schedule question, but it's probably the best I can do at this point.

So, my last point here was just to say, you know, we think that the framework is viable from 6850, and we can work within it. There is a lot of work that needs to be done in the individual methods, sub-methods, tools, data, and they should be improved. They can be improved. They should be improved.

I think that the insights we find from doing the fire PRAs need to be folded back in. One is the high-risk significance of electrical cabinets in the fire PRAs where the data from the field don't quite support what we see in the fire -- predict in the fire PRAs.

That's an insight that somehow needs to be resolved. Then there's other insights, onesie-twosie

things that have come in from doing now, what, 50 fire PRAs or so that are out there.

We've got to continue to handle the plantspecific things on a case-by-case basis, and we can't
just shut that off. There's got to be an avenue for
a plant to say, "I've got a situation that's different
than what the people who wrote 6850 were thinking of,
and I have to treat it differently, because it doesn't
quite fit what was laid out there.

So, in the discussions with Research, I think what we want to do here is we want to start with a systematic update of 6850. Now, we think that if we were to say, "Okay, we're going to do Rev 1, and we're going to start doing it now," this whole multi-volume document, we'd never get to the end of it.

It would be years and years before we could do a full update like that, so what we're thinking of is looking at a more modular approach where we can address --

So we're presuming that the framework is good, and we're going to attack the methods, submethods, tools, and data, update them with information we have, possibly provide a toolkit where maybe a one-size-fits-all isn't in every place but allows for things that plants could use if they find some sort of

1 a quirk in their area, something like that. 2 So we think that's the right way to go, 3 and it's a manageable way of updating this and yet 4 keeping everything collected in one place, which is 5 strange for PRA, because normally you have to go and do literature searches and get 200,000 documents to 6 7 figure out what you're going to do but maybe try to 8 focus it down into some place where it's more easily referenceable. 9 10 That was -- that was what I had. CHAIR STETKAR: Good. That was quite a 11 Any members have any more questions for Victoria 12 bit. or Rick? 13 14 MEMBER RAY: Well, I've got a comment for 15 Maybe you've done this, too, because you, John. you're much more expert here, but you made the comment 16 that models don't match up with what we've observed in 17 the field. 18 19 In areas that I do know something about, that's not a good -- that's not a good measure of 20 21 whether not you're accurately representing something in a probabilistic model, just because our 22 experience is so limited. So, that was the only query 23 I had. 24

MEMBER BLEY: I've got a few things, John,

and I may as well say them now instead of at the end, because they fit here.

CHAIR STETKAR: Yes.

MEMBER BLEY: The first part of this is going to agree with some of what Rick had to day. Fire PRA is not as immature as many people seem to be claiming. We've got 30 years of experience doing these. Rick said we've had over 50 of them. If you go a little more broadly outside, there are even more.

We tried to formalize what's been done with some improvements in 6850, which, from all the briefings we've had and from my reading of it, seemed to be a reasonable consensus at that time. I don't think it's surprising that when you try to formalize something that big, it doesn't quite work right. You find glitches in the process.

Some of the comments I heard yesterday and some actually not at the table about where some of the disagreements are, even in distributions, say, that are in 6850, kind of hang on the mean values maybe not being right and wrote disagreements on that.

It seems to me -- I hadn't thought about this before -- we could learn something from seismic PRA experience where we had to do some of these things kind of early on where we formalized this idea of Beta

U and Beta R, the randomness and the state of knowledge and uncertainty, and dealt with the fact that we use an almost artificial single parameter for the earthquake to represent a whole range of earthquakes that have that parameter and then talk about the uncertainty of damage that occurs and uncertainty in the excitation over all the earthquakes that could have that same parameter.

Maybe something of that kind of all the fires that can have the characteristic we start with and try to formalize those two ideas might help us. To that end, we might formalize an elicitation process using something like SSHAC to develop probability distributions that represent the consensus of the technical community.

That went a long way on the seismic area to resolve really strong arguments that finally were worked out by coming up with this idea of getting the consensus of the technical community into that distribution and not forcing the argument on the mean but looking at the extremes and the general shape of it.

It's often argued that costs way too much. Well, what's going on now seems to be costing a heck of a lot, and maybe that's not an unreasonable thing

to try.

I also want to say despite the time pressure on the current LARs, that shouldn't stop the refinements that's been talked about and that I think need to come, because it'll apply to a whole range of plants that haven't yet decided to make the shift into new plants in the future. This is something that ought to stand for a long time if you get it done right.

I just wonder. The Subcommittee may wish to review some of those documents that have been mentioned in the last few days that industry submitted and staff reviewed on specific fire issues that, as I understand it, staff rejected the industry positions, but we haven't looked at either the staff's review or those positions. I think that might be something we want to take a look at.

Sorry for the long ramble, but -
CHAIR STETKAR: No, that's good. Keep
that last note for --

MEMBER BLEY: I definitely will.

CHAIR STETKAR: When we finish today, I want to see, you know, where we go moving forward in case we have desires for other Subcommittee meetings on, you know, specific topics. I didn't write fast

1 enough. 2 Anything else? If not, thank you very I very much appreciate that, thought it was a 3 4 good discussion. We're now about half an hour behind 5 schedule, but I'm confident. We will recess until 10:15. 6 7 (Whereupon, the above-entitled matter went 8 off the record at 10:01 a.m. and resumed at 10:14 9 a.m.) 10 CHAIR STETKAR: Let's reconvene. -- we do have a little bit of time pressure. 11 should try to end around 1:00 or not too much later, 12 because folks -- I know folks do have flights that 13 14 they need to run for, so we'll try to mutually keep that time constraint in mind. 15 With that, I quess we'll hear first from 16 the -- I don't know what's on the schedule but -- PWR 17 Some of you folks can talk. Ray or Owners Group. 18 19 Dave? 20 Yes, my name is Ray Fine. MR. FINE: I'm with First Energy, and I'll be talking for the PWR 21 Owners Group Risk Management Subcommittee. 22 23 Roy Linthicum couldn't make it. 24 trapped in airline traffic. What we're going to talk

about is the peer review process.

1 CHAIR STETKAR: Do me favor a little bit. don't know if you're coming through. Move the 2 3 microphone off around the side of your computer there 4 a little bit. It'll pick you up. Just be careful 5 that you don't hit it, because it then explodes in our recorder's ears, and she'll --6 7 MR. FINE: Is that better? 8 CHAIR STETKAR: That's a little better, 9 Thanks. yes. 10 MR. FINE: Okay. So we're going to talk about the peer review process, and I've got moral 11 support of Dave Finnicum, and then Bob Rishel and 12 Dennis will be talking about the same topic for the 13 14 Bs, so you may get quite a bit of repeat here. 15 we're going to go over the peer review process, the schedule for fire PRA peer reviews, lessons learned 16 17 process, and lessons learned technical. The fire PRA peer review process follows 18 19 NEI 07-12 as the written process for the peer review. It's a detailed review, week schedule, and it's a 20 structured report format. Everything is cut-and-paste 21 into this format. The key documents that we use are 22 the ASME/ANS RA-Sa-2009, the Reg Guide 1-200, Revision 23 24 2, with clarifications from the NRC, and consensus

methods.

There's typically an eight-person review team. There's the lead, typically two fire modeling experts, two circuit analysis experts, and the remainder are all PRA experts and HRA, quantification, and general.

The fire PRA peer review process for unreviewed analysis methods. You heard some comments earlier about those methods being if the peer review team did not have sufficient expertise to review that method, then we would write findings on the method, and we would send it up to the expert panel.

As you heard, also, that panel is not working the way it was intended to work right now, and they're trying to fix it. That puts plants in a precarious position, because they have to get to their submittal dates.

The peer review is critical to doing that, so this is an area that we need to improve upon, and we will continue to have discussions with EPRI and the Owners Groups together, because it's a joint effort to fix this.

We rely on the review team to identify during the review those unreviewed methods, and in some cases we do have expertise that can review these methods, and we do not push it up to the Committee.

It just depends on the team.

Then the last bullets here talk about how we treat it, and there is some inconsistency between the Bs and the Ps of how we treat these, and we need to become more consistent in how we treat these, but right now in the Ps what we'll do is we will write a finding and tie that finding to the SR and say the SR is not met for that particular step where that method is applied.

Then for all cascading SRs that are affected by that, we'll connect the finding to them, as well. That's pretty much correct, right? So that's the general methodology we're using.

We need to -- but, you know, like I said, the intent was that those wouldn't stay there as not-mets. It would go up to another group, who would do a focus review and address it, but right now where they're staying is not-mets, because we don't have that functionality.

CHAIR STETKAR: And that pinch point, as you mentioned, is that EPRI penal.

MR. FINE: Right. Here's the current schedule, and I think the point of this schedule is to show how many plants are not transitioning to 805 but are doing fire PRAs. You can see it's a pretty

1 aggressive schedule. This is about as many as we can possibly handle in a given year, and when we throw all 2 3 the Fukushima reviews and stuff that will be coming in 4 the next year, it's going to get quite challenging. 5 CHAIR STETKAR: Ray, is there any -- these are folks who are -- there's a large list here who are 6 7 not transitioning but have scheduled fire PRA reviews. Because of the time pressures that we've heard about 8 9 regarding the transition from both of you folks, are 10 there any priorities? If I come in and say, "I'm transitioning, 11 and I need a peer review, you know, next week, " do you 12 bump somebody who's not, or is it just simply these 13 14 folks are in your schedule? MR. FINNICUM: Well, I want to make a 15 16 slight addition to this slide is that most of the 17 reviews done up to this time were for people who are transitioning. 18 19 CHAIR STETKAR: Okay. So a lot of them are done. 20 MR. FINNICUM: 21 CHAIR STETKAR: Okay. Okav. If somebody comes in and 22 MR. FINNICUM: says, "I need a review," we try not to bump somebody, 23 but we also have several different team leaders that 24 we can bring in, and then it's a scramble to get all 25

1 the other expertise, and we can cap out across the entire industry. 2 3 CHAIR STETKAR: The reason I ask is we had 4 an example yesterday of somebody who had had a review 5 done pretty early, I guess, in their PRA development process and had a large number of F&Os. 6 7 I don't know if there's any folks who 8 might be rethinking the fact that they'd had a review 9 done early, and now, as they get very close to the 10 submittal date, wanted to have a follow-up review, or in many cases it might be more comprehensive than a 11 follow-up review, because they actually have now fully 12 developed analysis. 13 14 Those might come in even though an early 15 review has been done. I don't know if you've had any 16 of those or not. 17 MR. FINNICUM: I think I had one, maybe two follow-up reviews. People wanted to come in. 18 19 suspect there are others who might want to have a follow-up, but they just haven't talked to me yet. 20 CHAIR STETKAR: Yes, that's the reason I 21 was asking about possibly bumping somebody. 22 MR. RISHEL: Also, the BWR Owners Group, 23 24 we can -- we have some experience in that. talk about that when we talk. 25

1	CHAIR STETKAR: Okay. Thanks.
2	MR. FINE: Okay. So, lessons learned, the
3	process, we have discovered that the level of effort
4	and cost to complete a fire PRA is significantly
5	higher than originally believed. I think the original
6	projections were \$4 million to \$5 million, and the
7	average plant is somewhere in the \$20 million range,
8	so it's not a little bit of a change.
9	This also gets cascaded into schedule
10	issues and follow-on reviews and so forth. Since
11	there is schedule pressure, you have to do more work
12	in less time, more money.
13	The other thing is with the schedule
14	pressure you're not likely to leave and do anything
15	unique, special, or innovative. You're going to stick
16	with the known path, because you don't have time for
17	anything else.
18	That's why I think you saw quite a few
19	plants sticking to 6850. It's not because they want
20	to stick to 6850. It's because they must, you know,
21	management direction or what have you, okay.
22	CHAIR STETKAR: I was going to that
23	latter part is important.
24	MR. FINE: So the review requested before
25	the fire PRA is done is addressing the question you

had before, and, you know, the fire PRA peer review or all peer reviews, we're not focused on the number. We're focused on the process, okay. We're focused on the methodologies and are they going about it the correct way.

So, the site gets to decide when they want to have their peer review. Now, if they physically have not quantified and have not done certain sensitivity studies and so forth, you know, they have to meet the requirements of the standard, and if they don't, they get the not-mets, okay.

But it is highly possible to have someone come in for a peer review that has numbers greater than 10-4 for their contribution of fire. I know in my plants, you know, at least one in particular, that's definitely going to be the case.

You know, if a change of methodology to get an acceptable answer is required, then they're going to have to get the follow-on peer review, okay, and I think what we're going to see here in the next several years is quite a few follow-on peer reviews to refine the methods.

That's a burden that we really aren't ready for, either, so, because, you know, everything is moving forward. Everybody wants to get to 4(b),

1 5(b), and 50.69, so in order to get to those 2 applications, we've got to have seismic. We've got to 3 have fire. We've got to have flood. 4 Everybody is moving, and so in that 5 maelstrom, you know, the Owners Groups, which are the very same guys that are building these models, have to 6 7 go review these models, and there's only just so many bodies, so that ends up being the point of issue. 8 9 Everybody's targeting is CDF of 5E-5. Ιf you get there, we're done, and the only reason they're 10 doing that is because that is what has been found to 11 be acceptable to the LIC-109 reviews and so forth. 12 So, it's an arbitrary threshold that everybody is 13 14 drawing on themselves to get to. 15 Good enough is good CHAIR STETKAR: 16 enough. 17 MR. FINE: Right, and no one wants to pay the additional money to get lower, because it's just 18 19 no time, no money, no whatever, no people. 20 partitioning requires complete Plant areas within qlobal 21 coverage of all the plant In a number of cases where plants excluded 22 boundary. obvious areas without providing basis or examples of 23 24 man holes, can contain cables and transient ignition sources, there have been fires in man holes. 25

You know, we're finding things like that missing in the models, and guys have to go fix them, so the -- it's not that common, but every once in a while you find them.

So those are the areas that people pick up in the peer reviews more often than a major methodology issue. It's, you know, did you look at everything you were supposed to look at.

Ignition frequencies requires review for outliers is another thing, the sensitivity studies we were talking about, and we should compare number of events to plants to the expected value, but as Mr. Ray mentioned, you know, what is the expected value? We have a limited knowledge.

We're going to have the same issue when we get to external flooding. You know, if I have to look back 10,000 years, one of my plants was covered with a few hundred feet of ice at that time, so I could only go back so far, you know.

If use of NUREG-6850, Supplement 1, frequencies, we need to perform sensitivity analysis stipulated in the supplement. That goes back to the issue you've been hearing earlier where if I want to use new EPRI data, I still have to go back to other data and do a sensitivity to the other data.

1 In some cases, it's easy to do those sensitivity studies, and in some cases it really 2 3 isn't. You know, we learn as we go, and so the first 4 guys out of the gate -- like Bob here was one of the 5 first out of the gate. You know, he learned a lot, and we all learned from that, but there is a lot more 6 7 yet to go. So, you know, I'm right behind him, and 8 9 there's other guys behind me. It's an evolution, but 10 we know that the answers we're getting don't make sense, so we have to go in. 11 The insights make sense. What we're seeing 12 in the modeling and the insights makes absolute sense. 13 14 Is it that significant? I don't know. 15 Ray, we've heard it a lot, CHAIR STETKAR: 16 and I think Dennis mentioned it yesterday, that the 17 results don't make sense. A couple slides earlier you had a five, E-5 number. 18 19 I challenge you that I don't understand what 5E-5 means, and I have evaluated the frequency of 20 meteorite strikes. So, when things don't make sense 21 in the context of really, really small numbers, I 22 think you need to be a big careful about those broad-23 brush statements. 24

The insights are important.

25

If the

1 insights come out and, say, you look at your plant, and, indeed, yes, it kind of makes sense that I ought 2 to do something about that group of cables over in the 3 4 corner that I didn't really appreciate were there. 5 That's important, regardless of what the numbers are, but this notion of the fact that the 6 7 numerical results, if that's the way 8 characterizing it, don't make sense, I think you need to be a little careful in that area. 9 10 MR. FINE: Well, when I say it doesn't it may work just fine for the 805 11 make sense, application. 12 CHAIR STETKAR: 13 Yes. 14 MR. FINE: But it doesn't work in (a)4. It doesn't work in 50.69. It doesn't work in other 15 16 risk-informed applications that require good, make-17 sense numbers, okay, and, you know, a good level of understanding of what it's telling you. If I've got 18 19 my internal events model being completely swamped by fire, I'm not getting any of the insights from my 20 internal events modeling. 21 I think you might have 22 MEMBER BLEY: missed a little bit of what John was saying, though. 23 24 John's saying from our experience, you know, numbers

10-1, 10-2, borderline 10-3, we see an experience.

kind of have a feel for those. 1 2 MR. FINE: Right. 3 MEMBER BLEY: Once you get well beyond 4 that, the feel we've got is probably coming from other 5 analyses we've seen, which may or may not be in the real world. We don't have a good intuition about 6 7 things at 10-5, 10-6. CHAIR STETKAR: And the other point is 8 9 that, you know, I mentioned these meteorite strikes. Suppose that you had made all of the, you know, spent 10 all of the capital of the free world and made your 11 plant so robust to defend against any conceivable 12 internal event, fires, floods, such that your risk was 13 14 completely dominated by meteorite impacts -- could happen -- at that point, that's the way the world is. 15 Now, you still may be able to use parts of 16 that analysis if you want to evaluate deltas on, you 17 know, a pump maintenance, for example, but the fact is 18 that your overall risk is still dominated by something 19 you don't have a lot of ability to address. 20 So, I think what I'm saying there, too, in 21 terms of this notion of it isn't realistic, there's a 22 23 context that you evaluate going forward potential 24 applications, if you will. interested 25 Ιf you're in fine-tuning

1	maintenance frequencies or allowed outage times and
2	tech specs or things, things that primarily affect,
3	may be affected by fire to some extent but primarily
4	affect normal operations, there may be sections of
5	that risk model that you use that are more important.
6	They aren't going to affect the meteorite damage.
7	So I think there, too, you know, broad
8	generalizations about what makes sense sand why we
9	can't use this stuff, you have to be a little bit
10	careful, because they're application-specific.
11	MR. FINE: Right. We would I would
12	absolutely use the insights from the fire model, but
13	I may not use the numerical result of the fire model.
14	CHAIR STETKAR: Okay.
15	MR. FINE: That's where I was going with
16	it doesn't make sense.
17	CHAIR STETKAR: Okay. Get back to your
18	Owners. You do your review stuff here.
19	MR. FINE: The other technical issues
20	lessons learned is the need for a mean CDF and error
21	bounds, need for mean LERF, and assessment of
22	contributors to uncertainty. A lot of the pre-
23	conditioning of the fire scenarios as we run them have
24	a tendency
25	You know, we get these uncertainties, but
ı	I and the second

1	some models, as you heard, they're so large that they
2	can't quantify them to get all their uncertainties.
3	VC Summer, I think, was that, you know, you have 1,500
4	initiators and FRANX doesn't work, and you can't get
5	the full model.
6	CHAIR STETKAR: Their tool doesn't work.
7	It doesn't their tool couldn't quantify them if you
8	had six.
9	MR. FINE: Well, no, it would quantify if
10	you had six.
11	CHAIR STETKAR: It would?
12	MR. FINE: Yes. It would quantify up to,
13	you know, 600, 700, just beyond that.
14	CHAIR STETKAR: Okay. I didn't I
15	didn't appreciate that, so thanks.
16	MR. FINE: Yes, the yes, because we're
17	using it, and we can get it right now, but I think in
18	the future I'll be where he is. It also depends on
19	the software you're using.
20	The guys who are using FRANX and CAFTA
21	have different limitations than the guys who are using
22	RISKMAN, for example. But we're finding, with my
23	RISKMAN plant, we're even hitting the limits of that
24	software.
25	So, you know, when we start adding, you

1 know, 680 initiators to your model, you know, when 2 originally you only had 50, that's a pretty 3 significant increase in the model. So that's one of 4 the technical issues we're dealing with is 5 quantification, truncation, all that kind of stuff to meet the standard. 6 7 Lessons learned, additional, human reliability analysis. Dependency analysis needs to 8 include all human actions in the model. 9 It needs to evaluate feasibility for new fire-specific actions. 10 Ιt needs to review alarm 11 response procedures to determine if there are any adverse 12 actions due to procedure compliance with one spurious 13 14 indication, and all of human failure probabilities 15 must address the impacts of fire, procedural guidance, accessibility, availability of cues, and increased 16 stress levels. 17 HRA has gone through quite a bit in fire. 18 19 We've improved it considerably, and we've had lots and lots of questions within the Owners Group of how do we 20 improve N with EPRI. How do we improve HRA methods in 21 You know, when do you abandon? When do you do 22 fire? all these things? 23 24 All these questions come up. What are the

levels? Different stations address fires

stress

1 differently as far as who is the fire lead and so forth, so, you know, how much stress is in the control 2 3 room varies and so forth. 4 So, you know, we learn these lessons, and 5 then people will change their processes because they found, "Oh, this other station did it differently, and 6 7 they were able to succeed here, " and so they change. 8 Then, circuit and cable selection. 9 Breaker coordination needs to cover any circuits added 10 to Appendix R list. That's just a statement. I would say probably one of the biggest 11 challenges in fire PRA for most stations is knowing 12 where your cables are. We know where the cabinets 13 14 We know generally where the conduit is and where the cables are in that room, but beyond that we don't 15 16 know exactly what tray it's in. 17 So the few that you do, because of your Appendix R program you knew exactly where it was, you 18 19 can address those, but when you don't, you have to lump them into the closest tray, and that leads to a 20 lot of conservatism and uncertainty in your model. 21 Even if we knew where 50 percent of those were, you'd 22 still have a good bit of conservatism and uncertainty. 23 24 CHAIR STETKAR: Have you found much in

your reviews -- you mentioned the sub-bullet there.

1 It says breaker coordination. Have you found much 2 difficulties in the breaker coordination studies, or 3 is that swamped by the cable --MR. FINNICUM: No, it's one of these 4 5 It was a lessons learned. There were -- a 6 number of the plants did a real good breaker 7 coordination update where they covered everything, but there were a set of plants that forgot about it is 8 9 basically what happened. 10 CHAIR STETKAR: Okay. So, in summary, the use of fire 11 MR. FINE: PRAs for NFP 805 before fire methods models were 12 developed has led to significant rework and additional 13 14 The earlier plants have redone their analysis costs. 15 several times to work the numbers down and get to 16 something more acceptable. 17 need to improve the process with respect to approving unreviewed analysis methods, not 18 19 just to address them for the peer review itself but also to get more methods accepted. We have basically 20 squashed all innovation at this point, and we need to 21 get back to the business of innovating and coming up 22 with new methods. 23 24 CHAIR STETKAR: I'm going to put you on

the spot here, and you have the complete right to say,

1 "I'll defer that." You mentioned -- you know, we've heard both yesterday and today this notion of we're 2 3 stymied in terms of the ability to apply unreviewed 4 analysis methods or NAMs or whatever you want to --5 whatever acronym you want to give them -- in a timely 6 manner to support the LARs. 7 Do you have a solution? I mean, you know, 8 people pointed to a pinch part, pinch point in the 9 EPRI review panel. 10 MR. FINE: Right. CHAIR STETKAR: And I think everyone is 11 aware of that. Is there an alternative solution? 12 know, have you thought about it? 13 14 MR. FINE: Well, right now we pretty much have to work through EPRI and NEI and with the NRC to 15 create this consensus panel, but we need to understand 16 17 it is a consensus panel, and, you know, it's not my opinion or his opinion that matters. 18 It's the 19 consensus opinion, and we need to get there. We haven't gotten there yet, and the same 20 thing goes for the peer review process. 21 consensus, and everybody agrees with that, and we have 22 no issues there, but when it comes to -- you know, 23 24 when we do any other risk-informed application, when

I go to come up with a new method or a new way of

1 doing things --2 I used to work with Rick Grantor, and we 3 always came up with new, creative things, okay, and 4 so, you know, not having the ability to do that in 5 this particular case fast enough to meet my schedules and do everything I've got to do, it's not healthy, 6 7 you know, but we understand the limitation and we move 8 on. 9 CHAIR STETKAR: You know, Ray, that's --10 I used to work with Rick, too, so -- but what you're saying, in those instances the individual plant took 11 the initiative --12 Right. 13 MR. FINE: CHAIR STETKAR: -- and went out and said, 14 15 "We're going to use this method," and asked, you know, 16 for NRC acceptance or whatever. Is it -- are the individual plants being stymied by this process of 17 funneling everything through EPRI and NEI? 18 19 MR. FINE: I wouldn't say they're stymied. I would say that --20 CHAIR STETKAR: Or reluctant, let me say. 21 They're reluctant, not just 22 MR. FINE: because of that one issue. They're also -- they also 23 24 have the management issue, the money issue, the other

issues.

1 All of those lead to this problem that, you know, they just want this application done. 2 3 cost way more than they wanted. Everybody wants to 4 get through it and get on to the next thing, but also, 5 you know, there are plants that are coming up with methods. 6 7 Typically, you're going to see that the non-805 plants are going to be the ones using those 8 9 methods freely, whereas the 805 plants typically will 10 not, because they don't want to risk the RAI issues and the LIC-109 reviews. 11 So, you know, I know our plants the 12 management has decided we will not push the envelope. 13 14 We will do what 6850 says, and we've had several 15 opportunities to, but we aren't doing it. HENNEKE: John, this is Dennis 16 17 Henneke. Let me -- let me speak up to a specific issue that'll give you an idea of the stymied portion 18 19 of it. In 2007, so I was a reviewer on 6850. 20 a peer reviewer, and we recognized a couple 21 6850 was silent on the area of hot short 22 duration. This is a bit issue, because your main hot 23 24 shorts are your PORVs, SRVs, ADS, MSIVs, those sorts

of things and, depending on your plant, could be your

seal cooling for your RCPs.

So, I authored an FAQ, FAQ-51, started in 2007, issued this -- submitted this in March of 2008. It included in it the analysis of CAROLFIRE, which are AC circuits, and some extension of that to some of the testing that showed results I thought would be applicable to DC circuits. Now, DC valves are the most important. Those are the PORVs and the MSIVs and so on.

I submitted this March 2008, all right. So, it was -- it went through some discussion. It was rejected by the NRC. It was an eventual FAQ. I was the author of the FAQ, but the FAQ got changed, so the wording of the FAQ was not my words.

The DC circuit stuff came out. No word.

So, I tried again to submit another FAQ separately,

and I was told, "No, we're doing the DC testing,

DESIREE testing. In the meantime, we're going to wait

until DESIREE Testing is done."

So, in the meantime, so the FAQ came out with the hot shorts and AC circuits, which is not a very useful -- MOVs, a hot short duration, a tenth of a second, MOV would change states. So we issued a GE report, which we eventually got the BWR Owners Group to submit, and we worked that and finished that in

spring of last year.

We submitted that to the EPRI panel June of last year as to methods for cabinet fires which would solve some of the cabinet fire issues, June of last year, and DC circuits, right, some initial analysis of the DESIREE testing, which we had access to at that point.

Both FAQ-51 and the BWR Owners Group report, because of the uncertainty, we skewed them conservatively. I think the results are coming out now of the DESIREE, the DC expert panel that I'm also involved with at the NRC, are showing that the results were conservative that we came out with.

We submitted that June of last year. We provided copies to some of the NRC folks at that point, and they said, "Remove it. We will not approve it. We're not going to do anything on that until DESIREE comes out."

Now, this time next year we'll be lucky to have that expert panel. We're going through a SSHAC process for extra panel to have DC stuff available. In the meantime, the plants are going without.

There's not a single plant that I know of that has put DC hot short duration in, because they're afraid to submit it.

1 Now, the -- so you want a solution. the regulator side off of the decision on PRA methods. 2 3 Put an NRC research person on the process for a 4 consensus. 5 Let them go, and then accept what they do, because what happens is they'll get a person accepting 6 7 it, and then the regulatory side of NRC rejects it and 8 requires all these sensitivity runs. People are 9 afraid of that, because the sensitivity runs means you have to do the work in the first place, and you don't 10 save yourself any money. 11 So that's the broken process right now, 12 and it's -- you know, I had a solution in March of 13 14 2008 for this, and still today we have nothing. That's the frustration of it. 15 16 CHAIR STETKAR: Thanks. 17 MR. FINE: Okay. So, probably one of the biggest lessons learned that we're going to be taking 18 19 forward is future model development. We've worked with the standards committees. 20 We've worked with everybody else and said, 21 you know, "Please do not issue a standard until it's 22 been fully vetted and reviewed and we've done pilots 23 24 and we know what it is. Then, once it's piloted and

we understand it, then issue the standard."

of like, you know, coming up with a standard for how to build a pressure vessel never having built one before.

We think we know what is, you know, the state of the art, but the reality of it is no one's built a fire model to this level before. No one has built a seismic model to the levels we're going to have to build these new seismic models to before. Yes, they've built seismic models but not to this level of detail.

So, even our internal events models are nothing like what I saw ten years ago. They are significantly more advanced than what they were at most stations.

So, we now know that we've got to properly follow a process where we peer review, where we understand, where we improve before we implement. This time, we didn't do that, and we found out just how bloody it can be, and we're going to try not to ever repeat this again, because it's just too difficult.

You know, our research people, EPRI, they're not doing research. They're doing crisis management, just like we are, and that's not where they need to be. You know, they need to be out there

1 doing research on the next thing. Then, applications real pilots prior widespread 2 should have to application, and that's just pretty much repeating 3 4 what I just said. 5 I'd also like to answer a question that, Mr. Stetkar, you brought up yesterday, which goes back 6 7 to peer reviews and F&Os and the staff reviewing F&Os back to the beginning of time of the PRA. 8 9 This is my opinion, not that of the Owners 10 Group, but I don't understand why they're doing that, and that's because the fire PRA has ties back to the 11 internal events models. 12 There's quite a few SRs that tie you back 13 14 to that internal model and verify that the internal 15 model is capable of supporting that fire PRA. know, your foundation has to be good to build this 16 17 model on, okay. So we're going back and re-reviewing sections of the model, okay. 18 19 The other thing is a lot of plants made changes to their models. They've added shutdown 20 They've added additional battery capability. 21 seals. They've added B.5.b or FLEX equipment to their models. 22 They've added a lot of stuff to help them with the 23 24 fire analysis, okay, and they're reviewing those

aspects, as well, of the internal events models.

1 So, to go back to the internal event, peer 2 review doesn't make much sense to me when the fire 3 peer review covered all that, so that's just my two 4 cents. And that's all I have unless you have any 5 questions. Anybody have any questions 6 CHAIR STETKAR: 7 for Ray? If not --8 MEMBER SCHULTZ: Ray, the summary slide 9 that you presented here would suggest that the 10 industry is in strong agreement with the staff in terms of a process which would assure that the models 11 are, in fact, vetted, resolved, understood across the 12 industry as being the appropriate way to proceed, 13 14 reviewed by the staff before they're applied, piloted before widespread application. 15 This is also in agreement with what the staff has asked for. 16 17 MR. FINE: Right. MEMBER SCHULTZ: So I'm -- and we also 18 19 heard yesterday that it seemed that there is frequent communications between the staff and the industry on 20 this particular adventure. 21 So I'm trying to understand why these 22 improvements in model, the improvements to the models 23 24 moving from -- moving from development to application

with approval of the staff, I'm still trying to find

out where that barrier is. 1 MR. HENNEKE: Yes, this is Dennis Henneke 2 3 Let me take the example that Kiang Zee 4 discussed earlier, the cabinet fire one. 5 So, we know that the present 6850 model doesn't do well with cabinet fires, especially when 6 7 there's cables right above the cabinet. We see that, 8 so fire modeling doesn't get you very far. 9 There was a -- there was in process a cabinet fire heat release rate modification which 10 would talk about oxygen-limited cabinets. We reviewed 11 that as part of the EPRI panel. We sent it back for 12 That's being revised as we speak. 13 14 We're not sure that's going to give you 15 the same results of what Kianq's work would do, but 16 Kiang's work was more trying to let's try to get a 17 simplified approach so we can at least get scoping evaluations and do detailed evaluations for 18 19 the ones that pop up to the top. So we go through that almost a year, and 20 then we're told it's rejected by the NRC, because they 21 would like us to use this alternative method or an 22 alternative method, and we'd like to see all the other 23 methods. 24

That's frustrating when you -- let's come

1 to a consensus on what's an acceptable approach for this severity factor. We can't. So, yes, the NRC 2 would like to work with us on it, but in the end, 3 4 they're not, you know, so that's part of 5 frustration. 6 Why can't we come up with an acceptable 7 method that Kiang has come up with for cabinet 8 severities to at least scope it out that's acceptable 9 to the staff, that's not going to have to go through 10 sensitivity studies and the whole thing and be done with it? But in the meantime, a year later we have a 11 rejected approach. 12 But it didn't sound as if 13 MEMBER SCHULTZ: 14 the peer, the industry peer review process really 15 reached completion on that model in particular. 16 MR. HENNEKE: No, we've -- we're done. 17 We've been done. MR. GALLUCCI: This is Ray Gallucci. 18 Ι 19 was on the UAM panel as the NRC representative. convened in April of 2011. We had a face-to-face 20 meeting in downtown DC. I think it was at NEI. 21 22 At that time, we were told we were going to be reviewing four ERIN methods, one of which was an 23 24 electrical cabinet method. At that time, I said,

"Well, I know there's an EPRI heat release rate report

1 method in the process," and Dennis had mentioned that GE had an approach. 2 3 I recommended strongly that we review all 4 three of these concurrently. That recommendation was 5 rejected. We were told we have to do it sequentially, so we proceeded along that line. 6 7 Dennis informally provided the GE 8 approach, which had an electrical cabinet approach. 9 It had hot short duration and other in there. 10 not formally put into the UAM panel process. The EPRI heat release rate report was 11 I looked at it. I felt it was well 12 introduced. beyond the scope of what could be reviewed by the UAM 13 14 panel, so I recommended that it be processed through 15 the MOU, Memorandum of Understanding, with Research in 16 a parallel process. 17 Αt the time, NRC did offer some preliminary comments on that, and they were accepted, 18 19 and we were told that prior to final publication we would be given the chance to do a detailed review. 20 was published in February. We did not do the detailed 21 review until after it was published. 22 The GE methods were never formally given 23 24 to the panel for review. We were knowledgeable of

aspects of them for the electrical cabinet method, but

1	we did not formally review that, and so we were really
2	constrained during the UAM process to just reviewing
3	those four methods, although at least I had hoped that
4	we would review them concurrently.
5	MR. DINSMORE: This is Steve Dinsmore.
6	Could I in general, though, I think what Dennis
7	said, they submitted a FAQ, and we looked at it, and
8	we changed it. We issued it, and industry didn't like
9	it or didn't agree that what we issued was enough or
10	good enough for them, but that's the process we go
11	through.
12	The ASME is a behemoth compared to all
13	these working groups, and we do exactly the same thing
14	with them. They come up with a methodology. They
15	issue it.
16	It's a consensus standard. It comes to
17	us. We review it. Many of them reject. We say,
18	"We're not going to accept that." Many of them we
19	change. Many of them we accept.
20	I mean, it's just a process, and we're
21	following the same process here. It's just there
22	seems to be a bottleneck somewhere between the methods
23	that they're developing and us formally getting to
24	review them.

MR. HENNEKE: But, Steve, Steve Schultz,

1 that goes against what you just mentioned, which is 2 that the NRC wants to work with us and come up with a consensus approach. We come -- we do this, and we do 3 4 all our work. At the end they have right of 5 rejection, and they do quite often reject these. 6 So what are we to do? I mean, just a 7 simple cabinet severity factor that Kiang did, I bet 8 you he probably did two weeks of work on this 9 initially, and I bet you he has probably -- his team 10 has probably spent eight, nine man-months in meetings and conference calls and revisions and all this. 11 So we have these simple methods. 12 are not difficult to develop, but the process to go 13 14 through to get to the point where it's approved by the 15 panel, you spend eight, nine months on that, and then 16 it gets rejected. It's all wasted time. 17 MR. GALLUCCI: This is Ray Gallucci. CHAIR STETKAR: Ray, hold on a second. 18 19 Let me -- let me intercede here and try to get control over this. I think -- I think the Subcommittee has 20 you know, several examples of continuing 21 22 disagreements. Let me put it that way. I think Dennis Bley suggested that perhaps 23 24 we might consider another Subcommittee meeting to look

in more detail at some specific examples so that we

1 can at least better understand the technical issues, kind of both sides of the story so we can --2 3 You know, is it programmatic? 4 procedural? Is it organizational problems, or, you 5 know, where are the distinct technical disagreements? And this isn't the forum to do that. It is the forum 6 7 8 I'm glad that we had the discussion, 9 whole purpose of this because that was the 10 Subcommittee is to identify specific issues or areas where there are perceived or actual impediments, and 11 certainly this morning we've identified a couple of 12 That's why I wanted to just cut off the 13 14 discussion for the moment, because my sense is it 15 could probably go on for a while, and with that we'll 16 get to the BWR folks. 17 MR. RISHEL: Okay, yes, BWR Owners Group, I'm Bob Rishel, now of Duke Energy, formerly of 18 19 Progress Energy, and --CHAIR STETKAR: And you'll say no more. 20 MR. RISHEL: It's getting too much to say 21 now, but I'm working on it. 22 MR. FINNICUM: Soon to be Constellation. 23 24 MR. RISHEL: So, I replaced Greg Kruger in February of this year as the Chairman of the BWR IRIR 25

1 Committee. Greq did a great job, and his responsibilities have driven him a little different 2 3 route there. 4 So we're going to discuss the BWR Owners 5 Group experiences with our peer review process, which not many of the BWRs are going to NFP 805. 6 7 smaller percentage are, and so we're going to talk about the review process, lessons learned, and some 8 9 summary thoughts. 10 I'm going to turn it over to Dennis. Dennis actually led most of the peer review for fire, 11 and so he can relate his experiences in that. 12 I should probably thank 13 MR. HENNEKE: 14 Harold Ray for the path that he led me down some 13 or 15 I got the call from -- I was at San 14 years ago. Onofre at the time and got the call from Tom Hook, 16 said the NFP 805 was looking for somebody that had PRA 17 experience and worked on fire PRA. 18 19 led to working on that NFP 805 Committee, then the Circuit Task Force Committee. 20 Then I was asked to work on the Standard and became 21 Chair of the Standard for the last 12 years. 22 It eventually led me to leading the BWR 23 24 Owners Group peer reviews. I got hired by GE about six years ago, and so for all of the 12-hour, 14-hour 25

1	days for the peer review weeks that we have, I wanted
2	to thank you for that, Harold.
3	CHAIR STETKAR: But as a consultant it's
4	been okay.
5	MR. HENNEKE: So these are difficult
6	things. We make light of them, but these peer reviews
7	are pretty serious things.
8	MR. RISHEL: Yes, I just want to go back
9	one. These peer reviews in the fire PRAs, you know,
10	as we touched on earlier, are a lot more important
11	than just NFP 805, right. They're getting used in
12	SDPs. They're getting used in notices of enforcement
13	discretions, other risk applications.
14	Although we are getting insights into
15	them, at the end of the day the Reg Guides demand a
16	number, and there is a threshold. That's the other
17	concern about getting as, you know, realistic of a
18	number for the fire as possible.
19	CHAIR STETKAR: Bob, out of curiosity, you
20	mentioned that a relatively small fraction of the BWRs
21	are actually transitioning to NFP 805. Are most or
22	all of the BWRs pursuing fire PRAs outside of the NFP
23	805 process to support
24	MR. RISHEL: Yes, they are.
25	CHAIR STETKAR: Okay.

1	MR. RISHEL: On a similar schedule, maybe
2	a bit longer schedule, but most of them are.
3	CHAIR STETKAR: To support the other risk
4	
5	MR. RISHEL: To support the other
6	applications.
7	CHAIR STETKAR: Okay, thank you.
8	MR. HENNEKE: Okay, so I'm going to spend
9	just a couple of slides talking about some specific
10	things that we've done in the BWR Owners Group peer
11	review process to give you kind of an idea of how we
12	try to approach the peer review in order to make it as
13	complete and thorough a process as possible.
14	We'll go through lessons learned, and I'll
15	focus in on some of the best practices, because it'll
16	tell you that we've seen some of the utilities to
17	particular steps very well, and that's how we expect
18	all the plants to do it.
19	The reverse of that is that when you don't
20	do it to that extent, a lot of times that will mean
21	you'll get findings associated with the standard,
22	depending on what category you met.
23	Some definite areas for improvement, and
24	I'll touch upon what we talked about or what Ray
25	talked about about not being ready for the peer

reviews is probably our biggest issue and then some summary thoughts.

So, yes, we follow NEI 07-12, the standard Reg I-1.200. There's a clarification letter that NEI issued on some changes, some specifics on NEIO-712 as provided to the NRC that we also incorporated into our process, which is how to address UAMs. You've heard the discussion on that. We've really only used that twice in our reviews.

The early peer reviews we did beyond 6850 approaches, we wrote findings on those. Then the process was changed in mid-stream, and then we were -- we'd come up to an approach such as the ERIN approach, which was already in review by the EPRI panel. We call those the unreviewed analysis methods.

We also had some clarification after a couple of peer reviews on reference SRS. There are 189 fire-supporting requirements in the standard. There are 212 reference SRs.

Those are SRs, supporting requirements such as perform your fire HRA per the internal events, guidance, in respect to fire, taking into account performance-shaping factors with regard to fire. It refers to a whole series of HRA requirement that you would do similar in internal events.

1 So, how do we review those? Do we take 2 into account they say, "Well, I used the same method we use in internal events," and so you don't review 3 4 If you review them, do you review everything in 5 complete detail, or do you do something in between? The quidance provides us some quidance on that, and 6 7 that is it depends. 8 You know, if you use exclusively the 9 approach it was already peer reviewed in the internal events and there's really nothing new that the fire is 10 doing, there is nothing specific to fire, then you do 11 a fairly cursory review to that. 12 If you're using the same approach, but 13 14 you're modifying it for fire, then you do something kind of in the middle, and if you're using something 15 new for a fire, you made new fault tree changes, new 16 data, then you review it completely for that new data 17 or new method that you've used. 18 So there's kind of three levels at which 19 we do review, and we want it consistently between the 20 Owners Group, and so we issued some quidance and made 21 a revision to NEI 07-12 for that. 22 So it was a very important aspect of 23 standard is that we didn't recreate the wheel on HRA 24

We referred to the internal events, SRs, in

or data.

the fire standard, and how you review that is an important part of it.

Those reference SRs also mean we have about twice as many SRs in an internal events review, so the actual time that we put into a fire peer review is longer than an internal review, which meant for 12-to 14-hour days on the first couple. We've modified our approach more to not do that.

We also had some guidance come out on notmeant versus not-reviewed. So you talk about followon peer reviews. If we have a not-met with a finding
and that finding can be addressed without any new
methodology, then there is not a follow-on peer review
required.

If there's a new method, then there is a follow-on peer review required. If we as a peer review give a not-reviewed, then we are automatically triggering a follow-on peer review, and we have done that several times.

CHAIR STETKAR: Dennis, let me ask you about the first one, make sure I understand it. You said if there's a not-met and the licensee can resolve that without -- I think you said developing new methods or something like that. There's no follow-on peer review. Who determines whether the licensee

1 adequately addressed the initial concern, then? I would say in the submittal 2 MR. RISHEL: 3 that whatever submittal you use, you know, you have to 4 provide the staff with enough detail about how you 5 address the issue, or, you know, the alternative is to say, "For what I'm doing, that one, that doesn't 6 7 The not-met doesn't matter, and I'm going to 8 carry that along." 9 CHAIR STETKAR: Okay, but it's --10 MR. RISHEL: The staff gets to make a judgment on that. 11 12 Yes, what we were really MR. FINE: trying hard not to do is to have people come back for 13 14 follow-on, follow-on, because one of the 15 things you'll see in peer reviews is each team is 16 different. Each team is going to see different things 17 because of their makeup, okay. So I've been really careful that if I did 18 19 have a follow-on, and I did at one of my plants, I've got the same team to come back, okay. That way I had 20 a consistent follow-on, but that's very hard to do. 21 I was going to say that --22 CHAIR STETKAR: I understand both, kind of both sides, but in many 23 24 cases, having done some reviews, unless I'm really

careful about very, very detailed description of my

1	particular concern, in some cases they can be
2	misinterpreted.
3	In other words, somebody thinks they're
4	solving my problem, and they go forward, and they
5	really weren't solving my problem, which is my issue,
6	because I didn't necessarily express the concern
7	correctly or something like that.
8	MR. FINE: We at utilities
9	CHAIR STETKAR: That's important to have
LO	the same person come back and say, "Well, gee, you
l1	didn't really address my concern."
L2	MR. FINE: Yes, we've become
L3	hypersensitive to that in utilities.
L4	CHAIR STETKAR: Okay.
L5	MR. FINE: And, at least I just
L6	finished two peer reviews last week for flooding, and
L7	so I made sure I sat down with the peer reviewers and
L8	understood his words exactly
L9	CHAIR STETKAR: Okay.
20	MR. FINE: and even asked him to
21	rewrite his paragraph so it was in a way that I
22	understood what he was saying but also agreed with
23	what he was thinking.
24	So it's not uncommon now for the feedback
25	loop go through the process to make sure the words are
l	1

1	right. I'm not contesting the finding. I just want
2	to make sure I understand what he's saying.
3	CHAIR STETKAR: Good. Good. That's
4	important, especially when you have a third party
5	trying to compare things.
6	MR. FINE: We also will come back, because
7	they'll give you, you know, "Here is a method to
8	correct it." We may come back with another method to
9	correct it, and we'll ask them before they issue the
10	finding, "Would you consider that an acceptable
11	resolution?"
12	CHAIR STETKAR: This is in real-time?
13	MR. FINE: Yes.
14	CHAIR STETKAR: This is during
15	MR. FINE: Yes.
16	CHAIR STETKAR: During the week.
17	MR. FINE: "Would you accept that as an
18	acceptable resolution?" and they'll put that into
19	their report.
20	CHAIR STETKAR: Okay.
21	MR. HENNEKE: Yes, and you can connect the
22	dots to a lot of the issues that people have talked
23	about. So 6850 doesn't quite do it for us, and we
24	have to do beyond that. It's also a lot more
25	difficult than we thought.
I	I

1 So, in the meantime, we have 805 schedule, which tells us we have to finish by X date. So we get 2 3 -- we come in, and we do a peer review because the 4 schedule says you have to do it, and the utility is 5 not ready. So, we write, like you heard yesterday, 89 6 7 findings. So we write 89 findings as a result of that, and now the utility spends a ton of time fixing 8 it -- it hits the schedule again -- and then gives 9 that to the NRC to review. 10 Now, what kind of -- you know, the NRC 11 won't have very much confidence in that PRA, because 12 there were 89 findings, and that new PRA hasn't been 13 14 peer reviewed, because maybe there wasn't any new methods associated with it. 15 So by process we could do that, but now 16 17 that's going to cause a lot of REIs, a lot of time in the review from the NRC, and the NRC now has to do 18 19 more review than they originally thought. 20 So it's all cascading, and we're kind of in the middle of it, but when you see a lot findings 21 in a peer review, that's just a symptom of the overall 22 process really having issues from start to finish. 23 24 Anyways, talk about that all day.

Last slide on our specific stuff, you

1 know, I'm Chairman of the PRA Standards, so we started a process which we thought was very useful. 2 a two-hour training on the standard, everybody who 3 4 comes in for peer review, and we require that for 5 everybody. Everybody who has taken the training has 6 7 thought that was a really useful thing to come in and 8 go through all the SRs ahead of time and reference SRs and some of our lessons learned that are in there. 9 10 We also, rather than having an eightperson team and 80-hour days -- well, the first one we 11 did I think we had the -- I would think we still have 12 the record of 1:27 a.m. in the morning of finishing on 13 14 one of the days of review, starting at 7:00 in the 15 morning. 16 CHAIR STETKAR: Wimps. 17 MR. HENNEKE: So we had like 80-, 90-hour Rather than do that, we require about 40 or so 18 19 percent of the assessments to be done prior to being onsite, which has led us to shorter days, like 12-hour 20 days. 21 Dennis, something you just 22 CHAIR STETKAR: mentioned, actually, in seriousness, not the 1:27 a.m. 23 24 but for -- I'm assuming that people are joining the

peer review teams in real-time. Is that true?

mean, you have new folks coming in and being trained, or are both Owners Groups now pretty well stable?

MR. RISHEL: There is some new blood, you know, from time to time. Personally, for my utility I get great value out of taking somebody that has not been on a peer review team before but I believe has got the required skills and knowledge and put him in a peer review team, both for his personal development. Also, you know, he will bring a new, a different view of things to that peer review team.

So there is some new, but I'll see on the fire PRA part we are still very hampered by it's very contractor-heavy. The number of utility folks that have enough skills and knowledge is a relatively small pool, and Progress Energy happens to have probably the lion's share of those folks, mostly because we did not use contractors to do the lion's share of the work.

MR. HENNEKE: But the standard and the NEI guidance basically says that in order to be involved in a peer review, you had to have a certain amount of experience, including three years of fire PRA. It also says in order to lead a technical element that you have to have performed that technical element, and there aren't a lot of utility guys out there that meet that.

1	CHAIR STETKAR: What I was leading to is
2	do the Owners Groups maintain a compilation of issues
3	that had been raised during the previous so, for
4	example, if I joined your team, I can at least look
5	at, "These are the sorts of things we found," in an
6	easy way to kind of orient myself
7	MR. HENNEKE: It's in our training.
8	CHAIR STETKAR: in that sense. You
9	always need the new blood. I mean, it is good.
10	MR. RISHEL: Dennis has incorporated many
11	of the "lessons learned" or observations in the
12	training. In addition, we have the Owners Group
13	have put out sort of a generic lessons learned from
14	peer reviews to go out not only just for the peer
15	reviewers but also folks that have not completed their
16	PRA yet. They can incorporate a, you know, "don't
17	forget about melted copper soldered joints," is one
18	example.
19	MR. FINE: There's also a group. All the
20	peer review leads create a group, and that group meets
21	and talks on the phone or in person, and lessons
22	learned flow that way.
23	So the reason we started that was because
24	of inconsistency between reviews. We didn't want one

lead doing something that the others said, and then it

gives him also a point to he can call that group or send an email out to that group during a peer review and go, "Okay, this issue has come up. How am I to address this, because I'm having problems here?" That group can override what's going on.

CHAIR STETKAR: Good. Thank you.

MR. HENNEKE: All right, so let's go through some best practices. In the plant partitioning area, early on we saw some less than adequate review of non-Appendix R barriers, but in more recent ones we've seen some really good work in the area of non-rated barriers, including analysis, walk-downs, and visual inspections of all these non-Appendix R barriers to make sure that they meet the definition of a barrier to contain the fire, so potential containment of fire as required by the standard and by 6850.

In the multiple spurious operation area, we've seen some excelling work on there that follows on the MSO expert panel process where they will take that MSO expert panel process, provide a full description of what the scenario involved, full description of the components involved, what the status of that is in the safe shutdown analysis. Are there single or multiples in the safe shutdown

1 analysis existing, and are those components modeled in the fire PRA? 2 3 We saw basically a full page, page and a 4 half on each MSO that was in the MSO list, and it 5 makes it so easy in review to have that sort of thing, and we're starting to see more and more of that. 6 7 CHAIR STETKAR: Just out of curiosity, 8 since all of you folks have done, obviously, a number 9 of these reviews, I'm aware of the lists. Do you see 10 many individual plant-specific MSOs arising, in other words, things that are outside the list but somebody 11 discovered as they're going through their analysis, or 12 do people pretty well stick to the script? 13 14 MR. HENNEKE: So, in the -- and I'm the 15 author of the BWR Owners Group list, so we maintain 16 that for NEI. So, in general we do see between two 17 and five plant-specific MSOs, and when we do not see it and we come in for the peer review, that's a string 18 19 we see, and we pull it. 20 Almost every time that we've seen no plant-specific MSOs we end up with a finding, because 21 the process really didn't explore it well enough to 22 give us that confidence that there aren't any. 23 24 would say we expect to see plant-specific MSOs.

CHAIR STETKAR: Is that the same over on

1	the PWR? How about you guys?
2	MR. FINNICUM: Not quite but similar.
3	We've updated the PWR-specific MSO list, the generic
4	list, several times to bring in the lessons learned,
5	so now in the last six to eight months of peer reviews
6	I can't remember anybody finding a new MSO that's not
7	covered.
8	MR. FINE: That's because we've done quite
9	a few peer reviews.
LO	CHAIR STETKAR: That's because you're
L1	somewhere pretty well up on the learning curve.
L2	MR. FINNICUM: And I do want to say is one
L3	of the things I'm seeing I'm going to guess that
L4	Dennis is, also that the fire PRAs are improving
L5	from what we saw originally to now. Would you agree,
L6	Dennis?
L7	MR. HENNEKE: Oh, absolutely, yes.
L8	CHAIR STETKAR: Okay. Thanks.
L9	MR. HENNEKE: One of the things we like to
20	see is just a list of the components that are in safe
21	shutdown, a list of the components that are in the PRA
22	and compare them and then have reasoning why, if there
23	is something in the safe shutdown analysis and it's
24	not in the PRA, why that's not true.
25	I would say in IPEEE days that was

1 probably one of our biggest issues. We didn't fully model safe shutdown, and we didn't fully model safe-2 3 shutdown operator actions in the PRA, including 4 spurious operation. 5 You know, we're expecting that if there is a manual action for a spurious operation that's in 6 7 safe shutdown that that's also going to be in the PRA, 8 and if it's not, there really should be a reason why 9 that's not there. 10 So, the best practice is to do that comparison fully, and it makes the equipment selection 11 process so much easier to see that. We're seeing a 12 lot more of that. 13 So, a Category 3 on the standard is to 14 15 include all of the internal events components, active 16 components, into the fire PRA, and we're starting to see more and more of that, including tracing all of 17 the internal events PRA components, the inactive 18 19 components, and do all of the circuit analysis for that. 20 So that would be a Cat 3 PRA to do that. 21 It's very difficult. For a plant that does have a 22 good cable-tracing program, this is a fairly -- I 23 24 don't want to say fairly simple.

It's a little more simple task, but if you

have to go hand-over-hand to trace cables and 16 hours to even find one cable, you wouldn't expect a utility to do this, so you have to -- the Category 2 is to make sure you have everything risk-significant, and that's a more difficult process to prove but would still meet the standard.

So, fire-induced initiating events, so if you have, for example, a loss of DC power, and MSIV closure, feedwater over-feed, for example, if you have a feedwater over-feed and you're going to now determine what components are associated with that, you have a completed equipment listing of that, complete cable-tracing of that or at least some sort of way to identify what fire areas can cause a fire-induced feedwater over-feed event, for example. There are simplified approaches, but the best practice for us is a complete equipment list for every fire-induced initiating event that can happen.

We saw earlier a coordination review for all fire PRA-credited power supplies. We saw that in a number of plants. There are simplifying approaches that you can use. In almost all cases a simplifying approach ends up with conservatism.

For areas that might be mixed trains, for example, you end up failing power supplies on both

sides, A and B train, which cause you to have high CCDPs as a result, so coordination review is not a cheap review, but in the end it does help your overall fire PRA numbers.

As far as NEI 00-01 and NUREG-6850, they talk about how many cables to select even for individual components. You get a very complex circuit for some sub-components where you may require two or three or four spurious operation or to get an undesired end state.

A lot of the approaches that are taken by safe shutdown analysis don't limit the number of cables. If you carry that same approach over to the fire PRA, that's a best practice that we've seen in the Category 3 in that particular requirement.

We've seen some discussion on multi -fire model earlier, so if you look at a lot of the
work that we're talking about, the many, many
thousands of hours, a lot of it is in cable tracing,
sure, but the detailed fire-modeling we talk about
full-room burnout, which is really a single size, but
it's full room. Then you may have a single size for
an individual scenario.

When you have scenarios that pop up to the top, then we would expect to see two fire sizes at a

minimum based on the minimum damaging size and some sort of limiting fire size. The standard and 6850 2 discussed that, but the best practice is to go beyond that. The standard is actually being updated 6

now, so the Addendum B of Revision 2 that is being approved now combines Category 2 and 3 to say a multi-It discusses that as if you have your top fire model. scenario and you have it as a two-point fire model, you may want to think about a three-point fire model.

So if a three-, four-, or five-point model gets you an order of reduction in that scenario, then standard would -- the next revision of standard would guide you to do more, but at present Category 2 is the two-point fire model, but even getting to that is a considerable amount of work.

We've seen -- probably, when your people say they've stopped and they haven't finished, they get a Capability Category 1. They get a finding, a number of findings, actually, that cascade from this. This is where they've stopped the work. They haven't one every significant scenario, the two points.

What ends up happening is when you do twopoint fire modeling and you do growth, you do nonsuppression, putting it all in there, that scenario

1

3

4

5

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

becomes non-significant, and the new scenario becomes
significant, and you keep working and keep working.
By the end of it, you've done detailed analysis for
probably about a third of your scenarios and your fire
PRA in order to finally get down to what meets the
standard.
So, in meeting the standard, this and the
cascading ones for growth and decay and all that, this
is the one harder to meet.
CHAIR STETKAR: Because you're just
looking at the standard for the models, rather than,
"It's good enough to meet my 5E-5."
MR. HENNEKE: That's correct.
CHAIR STETKAR: Because that's good
enough.
MR. HENNEKE: When we started the
standard, one of the things we wanted to do and what
we were tasked with was to get the fire PRAs in
Capability Category 2 to the same level of quality,
completeness, and uncertainty as an internal events
model.
In order to do that, we saw this as kind
of one of the key areas. We're not there. There's no
question we're not there, and by not being there and

having single fire sizes for a lot of your scenarios,

we are conservative.

You asked, I think, yesterday how much conservative. Our best guess is a factor of ten right now, and so these 5E-5 plants are probably 5E-6 when it's all said and done.

CHAIR STETKAR: Any basis for that best quess?

MR. HENNEKE: We've done -- we've done some calculations, comparisons of scenarios that you've done, single-point fire models to two-point with full modeling and then looked at MSO durations, MSO probabilities, and other things.

My personal opinion is the ignition frequencies aren't as bad as we try to put them off to be. They're not a factor of two or three off now.

They're some percentage off and so on, but when you put all that in, as well as suppression and control --

end that we identified in the front of 6850 Volume I.

I was a reviewer and added that one in. We look at
when the fire is actually suppressed, but sometime
earlier they come, and they're controlling it from
damaging further. It's probably a factor of two just
on that issue alone. When you put all those factors
in, we've calculated it out to be about a factor of

130 1 ten. 2 Okay. Thank you. CHAIR STETKAR: MR. HENNEKE: So we've done that a number 3 4 of times when we look at fire PRAs to kind of estimate 5 where they sit. So that particular SR is probably one of the more important ones. People say they've 6 7 stopped, and people -- it's probably one of the ones 8 This is also one of the ones 9 MR. RISHEL: 10 that give you all these high numbers of scenarios, so every time you do that, that's another 11 scenario. 12 Time to -- you know, 13 MR. HENNEKE: Yes. 14 following on from that, you put a multiple in fire You put time-dependent growth, time-dependent 15 model. We've seen people use the time-dependent 16 17 growth and decay in their modeling in pretty good detail in some very nice spreadsheets. We've seen 18 that done well. 19 20 Thermal response, we've only seen that a couple times. 21 I have here, but there's one, the THIEF model the NRC 22

couple times. There's a basic thermal response model I have here, but there's one, the THIEF model the NRC had come out of the CAROLFIRE testing that can be used.

It gives you a time delay, even once you

23

24

1 get to the damage center. You're not immediately going to damage. You have some time before damage 2 3 occurs. 4 If you put that time-dependent thermal 5 response in there, you can get a factor of two or more reduction in some of your modeling. We have not seen 6 7 that very much, but when we do see it, we give it a 8 best practice for that, so it's one of the areas I 9 think PRAs can improve on more is that thermal-10 response model. Detailed analysis of all operator actions, 11 we have seen that in one case. In most cases it's 12 detailed as the significant ones and scoping on the 13 14 non-significant. That's more typical, but some plants have done detail on all of them. 15 MEMBER BLEY: Before you leave this one, 16 17 on the thermal response model, the gains you see there, are they due to over the time the fire is 18 19 burning itself out, or the time-response model allows time for suppression. 20 Suppression. 21 MR. HENNEKE: MEMBER BLEY: Primarily suppression. 22 23 Okay. 24 MR. HENNEKE: Absolutely, because when you look at the suppression curves, and we talked about 25

this, you know, say, 10- to 12-minute growth and so 1 You only get like a factor of 40 percent 2 3 reduction or something like that. 4 If you give yourself like another 13 5 minutes here on your curve, you double your time. can get a factor of three to four reduction in that, 6 7 typically it's a factor of two reduction by 8 including your thermal responses. 9 MEMBER SCHULTZ: Dennis, with respect to 10 operator action, when Ray made his presentation he talked about how important the human reliability 11 analysis was as it particularly related to the fire 12 PRA, because there's different actions that are taken, 13 14 as well as a different environment that operators and 15 personnel are in. 16 here you've listed it 17 practices, detailed analysis of all operator actions. Why isn't that more -- I got from Ray's presentation 18 19 that that was an expectation that one would put more emphasis on a detailed analysis of operator action. 20 Well, we see a couple 21 MR. HENNEKE: We see the 805 plants trying to remove 22 things. operator action credit so that what they're trying to 23 24 do is put probably -- they'll put it in their model

and put probably a 1.0 in there and see if they can

1 live with that so that they don't have to call that a required action for safe shutdown. 2 3 So we see some of that in there, and so 4 you might even get a finding in peer review space for 5 an action that meets a significant, you know, like one percent of CDF. You might get an action that's there 6 7 that they haven't analyzed, because they're trying to remove that from the model, and they haven't quite 8 9 finished everything at that point. 10 So you see some of that but more along the lines of you see the PRA is not done. 11 They've and they just haven't 12 finished the first part, analyzed everything by the time we get there. 13 14 So the trend is, yes, they're going to 15 analyze everything in detail, but by the time the peer review team sees it they've maybe done some sample 16 17 analysis. They've done the top three or top ten, but they have not analyzed everything in full detail. 18 19 MEMBER BLEY: So this thing you just talked about, do you have an estimate of how big an 20 effect that is in the overall PRAs of putting in these 21 intentional conservatism for, I quess you'd call it 22 regulatory convenience? 23 24 MR. RISHEL: I can speak a little bit from 25 experience in that part is that in some cases, you

1 know, there will be a few operator actions that can have some, one, two percent contribution. 2 experience has come in is that more importantly is 3 4 when you go off and you, say, analyze a diesel out of 5 service, so now an operator action that may not have been in your face as important suddenly shows right 6 7 up. In that case, that typically might drive 8 the particular analyst to go off and do that one or do 9 ones like that, but, you know, I guess I would echo 10 Dennis's thing is, you know, a lot of this is driven 11 by good enough. 12 I get to a point, and it's good enough, 13 14 and I stop. Be in time, cost, HRAs are relatively -well, not difficult but long process to do all these. 15 It takes quite a bit of time to do, especially if you 16 start talking about field operator actions. 17 Can I actually get there? Where's the 18 19 Can I send a person there and execute that? Going through that type of -- which isn't really the 20 operator part. It's more the access part, and that 21 part alone takes quite a bit of effort. 22 MR. FINNICUM: There's another issue that 23 24 creeps up in here is that some plants when they have

a fire, they switch from their normal EOPs to FEPs,

1 and almost all of the operator actions that they have to perform and respond to this now has to address two 2 3 sets of procedures, so that adds to it. Right, and then, you know, when 4 MR. FINE: 5 it comes to doing the actual analysis, you don't do your dependency analysis until the very end. 6 7 you've done everything, right before your submittal you're doing your dependency analysis, okay. 8 9 You know, you did a cursory one for peer 10 review to get that done and peer reviewed, but really after you've done your fire risk evaluations and all 11 that stuff you're going to quantify again, and you're 12 going to do decency analysis. 13 14 That's when you're going to start to want to tweak or say, "Oh, geez, I need to go look at that 15 16 HEP deeper. That .1 may have been good enough early 17 on, but now it's not. I've got to go deeper." So those are the refinements I think we're 18 19 going to see a lot here in the near future is I'm not changing my methodology. I'm just going deeper into 20 my methodology and being more specific, more exacting. 21 22 Another biq unknown for us is We don't know where a lot of stuff is, and 23 unknowns. 24 so you end up grouping them right to that closest In these fire scenarios, that adds a 25 cable tray.

1	tremendous amount of uncertainty to your result.
2	MEMBER SCHULTZ: So, I have to ask the
3	question, though. So, when you say something like,
4	"We're going to drive until we get the result to 5 x
5	10-5," and then we're done.
6	MR. FINNICUM: No. No, that was a
7	misinterpretation.
8	MEMBER SCHULTZ: Okay.
9	MR. FINNICUM: What that
10	MEMBER SCHULTZ: I'm glad to hear that so
11	far.
12	MEMBER BLEY: I've heard that a couple of
13	times.
14	MEMBER SCHULTZ: It's a strong statement,
15	and I'm
16	MR. FINNICUM: What the 5E-5 is is,
17	actually it was triggered by some comments that Jaczko
18	made a couple years ago, and what we were seeing is
19	people were coming in for fire PRAs that had 1E-3, 8E-
20	4.
21	You look at that, and you're saying, "This
22	is extremely conservative. It's really not going to
23	do what they want," and saying, "You really need to
24	bring your number down. What the right number is, I
25	don't know, but what we're telling people is you

1 probably want to be in the neighborhood of 5E-5. 2 There are people that have got there that 3 had good PRAs. It's not a stop there. It's not --4 you don't have to get below it, but, you know, if 5 you're looking at 7E-5, that's probably a reasonable number for your plant. There may be conservatives in 6 7 there, but you may have gotten everything out. 8 Vintage of plant makes a difference on 9 what number you can get, but, no, the 5E-5 is not a be-all and end-all. It's just a direction to indicate 10 where you want to go. 11 Ad back to the HEPs, how deep 12 MR. FINE: you have to go in HEPs is dependent completely on your 13 14 plant. One of our plants has a lot of HEPs and a lot 15 dependency on human action, so spend a we 16 tremendous amount of time on the HEP part of the model. 17 Another plant that maybe doesn't have that 18 19 operator actions because they have automatic actuation, they're going to need to do that 20 That's not going to be their driver of their 21 so much. uncertainty and of their model, you know, so it really 22 does depend on many things as to why you're driving 23 24 into that area.

MEMBER BLEY:

25

I'm sitting here with a

funny look on my face because I've been thinking about 1 what Bob was saying about the human reliability 2 analysis, and I quess I could see running a case with 3 4 your HEPs set to one to make an argument, but those 5 things you talked about being hard, the things that 6 preclude access, two sets of procedures, it's not 7 always they jump from one to the other. 8 There's often two sets of procedures are 9 going on at the same time. The complications issued 10 by those things are real safety issues, and they're things that you can learn about by doing this PRA, and 11 if we're not learning those things, it's just we're 12 missing a real opportunity, I think. 13 14 MR. RISHEL: Correct, and, you know, what 15 Dennis was alluding to, you know, one of Progress's 16 goals I heard yesterday was -- or Duke's goals -- was to -- I'm still learning. 17 Old speak. CHAIR STETKAR: 18 19 RISHEL: Was to eliminate manual actions in as much as possible as compensatory actions 20 for fire scenarios. That was a -- that was a goal 21 established early on, and so in that case, you know, 22 that's a big safety benefit. 23 24 Now, the other part is, as you point out,

is that the procedures may not mesh so well or need to

be, and we've frequently fed back to the fire protection organization that procedures need some revision and make that part of the overall project to revise those procedures, be it, "If then, if this, then this," rather than, you know, "Go execute regardless of the fire damage. If I have a fire in this compartment, go do this."

Well, that may not be the best thing. You know, if you have a spurious aux feedwater pump and you're worried about over-feeding, now go do something, rather than disable the aux feed pump early on. So correct on both ends, and I think, you know, this is where PRA and Appendix R philosophies clash in some cases, and it's up to us utilities to try and mesh those two views of the world together.

MR. FINE: We are -- you know, even though a lot of the stations are upset about the way this fire PRA development has gone, because really the PRA aspect of it is a very, very small aspect of it. It's mostly fire analysis that's the big chunk, but, unfortunately, it all gets thrown in. It's the PRA guys.

But it has made people more aware. It has made people more sensitive to what we have to say, and if we go sit down with the operators and we say,

1 "Okay, you see this indication. You see this 2 This is happening. What are you going to indication. 3 do?" you know, they're going to go to the procedures, 4 and they're going to say, "I would do this." 5 You know, and it's interesting like when we were doing internal flooding. 6 We gave them a 7 series of indications, and the operator was just like, "Yes, that's a bad day," and he starts writing a CR, 8 9 you know, so it is working. The process is working. 10 MR. HENNEKE: All right. To answer your question a little more specifically, I haven't seen 11 more than about a 20 percent error because of detailed 12 I mean, if a plant sees that they're trying to 13 14 work something out and it's 50 percent of their CDF, they may have to do detailed -- they have to credit it 15 and then do a detailed operator analysis. 16 They do it, so it's only the couple of 17 percent here and there, so I wouldn't say detailed HRA 18 19 is killing the numbers, but there are a lot of actions down in the one, two, three percent range which we 20 consider significant which require by the standard to 21 have detailed HRA walk-throughs, simulator runs, the 22 whole deal. 23 24 Continuing, best practices, human action for control room evacuation, control room scenarios, 25

141 1 including evacuation and damage to remote shutdown. We've seen a number of plants that have these .1 2 3 number in their analysis. That would be a capability Category 1. 4 5 We'd get a finding for that. That may be sufficient for 805. You know, we're not there to judge that, but 6 some plants have tried to do better analysis and have 7 8 done so, and that would be the best practice in our 9 mind. 10 One of the things that was missed early on are these reference SRs, and the reference SRs have 11 all these review of sequence cut sets, importance 12 measures, review of insignificant cut sets, review of 13 14 insignificant scenarios, and all this stuff that the 15 internal events have done for many, many years. 16 The fire, because the reference SRs are 17 thought of secondary, a lot of the fire PRAs early on didn't have this review for robustness of your 18 19 insignificant cut sets, for example, and so we saw a number of issues there. 20 In more recent ones we're starting to see 21

In more recent ones we're starting to see some excellent reviews, and we're starting to see at least the fire PRA getting closer to the internal events PRAs in the area of documentation and reviews and robustness for logic.

22

23

24

Dependency analysis, I think Ray has mentioned that. We've seen some good evaluations on that. We've seen some where that wasn't done before we got there, and we've seen some where it was kind of done at the last minute. We had some issues with what was done, so we've seen a range of that, but we have seen some pretty good stuff come out of some of these plants.

Uncertainties, characterization of uncertainty, there have been some recent papers. In, for example, the PSA 2011 Conference there was a paper on how to do uncertainties in the area of fire modeling and fire modeling parameters, which can get you quantification of uncertainties in your fire modeling.

We have seen that in one of our peer reviews which allowed you to quantify some of the things that we don't even do in internal events, for example, the thermal hydraulics uncertainties. We don't -- we have uncertainties in thermal hydraulics.

We don't carry that in internal events through quantitatively, but we're asking for them to do that in fire modeling, so it's actually gone beyond what internal events does. We have seen that. It is quite difficult to do.

1 We have seen full quantification. We've 2 seen full uncertainty parameters. We've seen state-3 of-knowledge correlation and correlation 4 parametric studies, full documentation of PRA 5 limitations affecting applications. So that's the sort of thing we would 6 7 expect to see in the uncertainties section.

majority of plants have not done this, especially the early ones, but we have seen at least one plant that has attempted to do this fairly well.

CHAIR STETKAR: I think -- I'm trying to be cognizant of the time here, but it's also too easy, I believe, to generalize the term "model uncertainty." There's a NUREG coming out soon, I hope -- it's out in draft form -- that addresses fire modeling, issues of model uncertainty as part of that process.

There is uncertainty in the fidelity of a particular model to replicate test data. That's kind model uncertainty in my mind. There's also uncertainty in the parameters, the input parameters to that model that affects the results of that model.

The second of the two is something that can be treated, you know, and people tend to lump both of those two together as, "Well, that's all model uncertainty," and I don't know whether you've seen,

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 you know, examples of people trying to address both of those issues. You said you've seen a few. 2 MR. HENNEKE: Yes, we had a -- we had a 3 4 workshop in the spring that just came out. The notes 5 just came out on uncertainty, and included in that was 6 some pretty good discussion on those. There was 7 discussion, actually, of what we call the completeness 8 uncertainty. I mean, "We haven't finished our model, so 9 is that an uncertainty?" Yes, well, it's completeness 10 uncertainty, although the theoretical uncertainty guys 11 wouldn't consider that completeness uncertainty, but 12 in essence it is. 13 14 So we're driven by completeness 15 uncertainty, but, yes, we're seeing -- we're seeing 16 people try to do what they call uncertainty analysis, and we haven't really looked at everything you're 17 talking about. 18 19 CHAIR STETKAR: Okay. MR. HENNEKE: But we do recognize that, 20 and the standard does point to that. We refer back to 21 the internal events one, and in there it looks at all 22 the aspects of uncertainty and assumptions. 23 24 CHAIR STETKAR: Thanks. 25 MR. HENNEKE: Okay, so areas of

improvement, we tried to focus the last couple slides on the things we saw that plants were doing right, at least in some cases. Obviously, the big issue for us is not that they're not complete at the time of the peer review.

Six weeks prior to the peer review being performed, we do a readiness review. We have on a number of cases not gone forward. We have on a number of cases recommended they not go forward and have gone forward, anyways.

The end result of that is 89 findings, which doesn't help, you know, but to date I don't believe -- in comparison to what we would do for an internal events review and how ready the internal events PRAs are done, I have not done a single review where they were ready, which gives us some issues, so we end up averaging more than 50 findings.

When you look back at the internal events peer reviews, you won't see that many findings, so it's a real issue, and it's -- you know, you have a schedule to get it done. You get it. You do it early. You have too many findings, and it ends up working against you with regard to schedule.

We keep trying to tell the utilities not to do it too soon, but when you have the Senior Vice

1	President for the site calling up the BWR Owners Group
2	Chair saying, "We've got to get this done," then
3	that's what we do, but we try to reflect that in our
4	findings, and we do, so we're seeing some high number
5	of findings as a result of that.
6	CHAIR STETKAR: So, can I I'm sorry,
7	Dennis.
8	MEMBER SCHULTZ: Well, just for
9	clarification, Dennis, what I heard you say is if
10	somebody really isn't ready, that's going to be 80, 90
11	findings, but on average you're finding that there's
12	50 findings as you've gone forward here? In other
13	words
14	MR. HENNEKE: I don't know the exact
15	number is more. I would say the average
16	(Simultaneous speakers.)
17	MEMBER SCHULTZ: are really ready?
18	MR. HENNEKE: The average number is about
19	70.
20	MEMBER SCHULTZ: And that's not a good
21	place to be.
22	MR. HENNEKE: No, it's not a good place.
23	MEMBER BLEY: Can I ask you a
24	clarification on findings? I haven't seen any of
25	these peer reviews. I've seen only a few peer reviews

1	of internal events PRAs. I'm pretty sure those, as I
2	recall, and it's been a few years since I saw them,
3	for each issue that they look at, they get a grade.
4	I forget if it's A, B, C, D, or something like that.
5	So, you find something on every one of
6	those issues, but some of them are perfect. Some are
7	good enough. When you say findings, you're counting
8	the things that you identify as deficiencies.
9	MR. HENNEKE: The new, the revised
10	approach, findings are A or B from the previous one,
11	so a C and D would be a suggestion.
12	MEMBER BLEY: Okay.
13	MR. HENNEKE: So when there's 50 findings,
14	there's probably 70 suggestions.
15	MEMBER BLEY: Okay.
16	MR. RISHEL: But the new approach is a
17	finding is written if the SR does not meet Capability
18	Category 2.
19	MEMBER BLEY: Okay.
20	MR. RISHEL: If it meets Category 1,
21	you're still going to get a finding.
22	MR. HENNEKE: Or there is a substantial
23	error
24	MR. RISHEL: Or there is an error.
25	MR. HENNEKE: where you could meet
l	I

1 Capability Category 2, but you have fairly substantial error which affects your results. 2 3 MR. FINE: And a lot of it is style of 4 the peer review. You can have a peer review team that 5 writes one F&O against multiple SRs because it's a common threat, or you could write a finding on each 6 7 one of those SRs individually, okay. That's style, 8 okay, and that's --MEMBER BLEY: So counting findings isn't 9 10 really a good way to evaluate these things. MR. FINE: Yes, counting findings is not, 11 no, not at all, and even the -- what really matters in 12 the findings is the significance of the finding. 13 14 majority of findings are, "Add this sentence," or, "Do this." You know, they're minor editorial in many 15 16 cases, but --17 MR. FINNICUM: I'm going to disagree. I'm going to disagree with that. 18 19 MR. FINE: I'm just saying in my peer 20 reviews --MR. FINNICUM: We wouldn't write a finding 21 on that. 22 In my peer reviews, there has 23 MR. FINE: 24 not been anything of real major meat that says, "I've back and fundamentally do something 25 qot to qo

1 methodologically, " or something like that. Some guys 2 Some guys do get those big ones. 3 So you have to look at the significance of 4 the finding, if it's minor documentation, or is it,

"You need to go back and completely re-do walk-downs and re-do everything from there"? That's -- there's a significance there.

So, we have been consistent MR. HENNEKE: in the BWRs. We do have findings that cover multiple We have -- we try not to write the same issue on multiple SRs over and over, so we do try to combine them, so these are typically combined.

We do have very specific quidance on what a finding is versus what a suggestion is, and if the utility comes back and says, "This isn't significant. Here's our reasoning," then we will revise our findings as suggested, and we have done a couple of those.

But we -- but Ray is correct. example, one of the plants that had less findings than 50, for example, but a number of the findings were as a result of they had something like 2,200 scenarios. They had done great detail analysis and great detail analysis on uncertainty analysis, but once we got into detail, we found some issues. Is it significant?

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

|| it --

You know, so sometimes you get more findings the more detailed the analysis gets, so counting findings doesn't tell you significance. There is no question, but the overall trend of not being ready and having that many findings is an indication that these PRAs aren't ready to be peer reviewed at the time of it.

So whether they trigger follow-ons really depends on whether in correcting things they do a new method. That's up to the utility. It's not up to the Owners Group, so that's not our call.

We have done three follow-on peer reviews, and, unfortunately, two of those we again feel like that the fire PRA wasn't ready for the follow-on peer review, and as a result we had a number of findings come out of those follow-on peer reviews, and it continues -- schedule continues to be really the driving issue here.

MEMBER BLEY: I like to focus on technical issues, but let me ask you one process issue about that. Are you recommending that utilities wait until they are ready, or do they need this process to get ready? Is this such a new thing for them?

MR. HENNEKE: We recommend they're ready.

1	It's just a waste of time for everybody to come and do
2	a peer review and have 89 findings.
3	MR. RISHEL: We have recently we
4	require the utility to submit sort of a readiness
5	letter, so we have beefed up our requirement and our
6	approval of readiness to try and focus on getting
7	farther down the road before we bring in a peer review
8	team.
9	MR. FINNICUM: We've also tried to put in
10	penalties.
11	MR. RISHEL: You know, that success is not
12	yet reportable.
13	MR. FINNICUM: In the early day, we had
14	I think we had three. Dennis said he had some. The
15	team came onsite, and they looked at what was there,
16	and they laughed.
17	CHAIR STETKAR: Really? Seriously?
18	MR. FINNICUM: It was that bad. They
19	couldn't figure out what had been done.
20	MR. HENNEKE: We just we just do not-
21	reviewed, and we finish the review, and then we
22	require the follow-ons. We've never left site, but
23	it's been pretty close.
24	CHAIR STETKAR: Those weren't the 1:27 in
25	the morning reviews.

1 MR. HENNEKE: A lot of the findings, 2 especially the larger numbers of findings, 3 related reference SRs because the initial four or five 4 they didn't look at the reference SRs and didn't look 5 at the non-significant cut sets and all these things, so the documentation wasn't complete or as 6 7 complete as an internal events PRA. 8 For example, the simple thing of 9 importance measures, you expect importance measures to 10 come out of the fire PRA. Importance measures are part of the internal events, and it is a reference SR, 11 so the requirement to do importance measures was not 12 recognized by at least one utility. 13 14 we went in, said, "Where's your 15 importance measures?" "Well, we don't have it. It's not required, " and we said, "Yes, here it is, " and we 16 17 write a finding on it. So, is it a big deal? Well, I mean, it's 18 19 hard to do with FRANX, as you've heard, or FRANK, so it is quite time-consuming to do that. Does it affect 20 the results? No. Is it an insight? 21 Yes, importance measures are part of the insight. 22 So, you read your review, your importance 23 24 measures, for logic to see, "Yes, this event

Why is that, and does it make sense?" so

important.

these reference SRs really hit us early on, but we're seeing better results more recently because we've let the utilities know as part of their self-assessment that they have to review their internal, their reference SRs and provide a self-assessment that ranks their reference SRs.

As you heard, utilities are very rarely doing the supplemental analysis. Like I said, we we've only written two UAMs. We have supplemental analysis in our BWR Owners Group report.

As you heard, we submitted over a year ago. We're waiting in line to be reviewed. Our more recent peer review got a UAM against one of the approaches, but to date, for example, the DC circuit one, I don't believe anybody has used the DC hot short duration in any of the PRAs, even though it's a major conservatism in the results.

So, utilities have recognized and have communicated to us that the time and effort and the issues associated with the 805 transition on using an unapproved method of something beyond 6850.

So, as you can see, you know, we take our peer reviews very seriously. We recognize that our role in all of this is to make sure that we are comprehensively identifying issues, and I think we

1 have been very successful in that. We're part of the overall fire PRA quality process that we think in the 2 3 end we're going to help utilities out and try and get 4 the best product out there, but it's been painful. 5 We do share our best practices with our utilities. 6 We have slide presentations at our Owners 7 Group meeting for this, but still the one we need to 8 improve the most is getting the fire PRA reviews ready 9 before we do peer review. Somehow in all of this we 10 need encourage supplemental analysis innovation, and I think all of the speakers have said 11 So, go ahead. 12 that. Thank you, Dennis. 13 CHAIR STETKAR: 14 the members have any final questions or comments for 15 the presenters? MEMBER BLEY: We still have staff to come. 16 We still have staff to 17 CHAIR STETKAR: come, but I want to make sure that we have the folks 18 19 up front here grilled extensively. What I'd like to do, we have two 20 Good. members who have to leave at noon for whatever 21 22 reasons. MEMBER RAY: Selfish reasons. 23 24 CHAIR STETKAR: Okay, if you want to put it on the record, because they just don't care. 25

1 MEMBER SHACK: Because the schedule showed 2 the meeting ending at noon. In seriousness, typically 3 CHAIR STETKAR: 4 at the end of one of these Subcommittee meetings we usually go around the table and ask each of the 5 6 members if they have any summary comments 7 suggestions, and I want to make sure I capture that 8 from both Bill and Harold before they leave. 9 Bill, do you have any --MEMBER SHACK: Well, I just -- I am 10 encouraged. You know, we've heard a lot of 11 complaints, so I'd be the first to say that the 12 process doesn't seem to be optimal, but it does seem 13 14 to me to be working. I think, you know, we're getting what we 15 really wanted to in a regulatory sense out of this, 16 which was a much better understanding of the fire risk 17 of plants, and I think we seem to be getting that, as 18 19 painfully as it may be. We clearly do need improvements in the process, but that will come. 20 I'm actually very surprised to see the 21 number of plants that are planning to do fire PRAs 22 that aren't transitioning to 805. That was -- that 23 24 was news to me. That was perhaps the most surprising

thing that I saw, which does indicate to me that

1 people see value in the risk-informed applications that are coming up in terms of tech specs and 50.69. 2 So, as painful as this process is, I'm a 3 4 little surprised they're not sort of waiting a little bit for, you know, perhaps some refinements in the 5 but, again, I think we've seen enough 6 7 examples that the process does work. 8 It may not be optimal, but it's doing the 9 job, and we are getting important insights and, I 10 think, a much better understanding of fire risk in I'm generally pretty encouraged. 11 plants. 12 CHAIR STETKAR: Thank you. Harold? MEMBER RAY: Yes, I was more interested in 13 14 the process and what I'll call the generic take-aways 15 here, as opposed to the technical detail, which the Subcommittee is more focused on, as you've indicated. 16 17 think there has been some suggestion by presenters that there are generic conclusions to be 18 19 drawn here, and I believe there are. We should try and grapple with those, as 20 well, even though that may not be the primary aim the 21 Subcommittee is involved in, because I think that this 22 is the first of what may be more efforts to better 23 24 risk inform and perhaps even make a more dramatic

change in how plants are regulated from a safety

standpoint.

So, that being said, I am interested also, for example, in, well, what is the longevity of this? Having, as Dennis mentioned, operated a plant for a while, I can't imagine how I would expect this 5 x 10-5 that's been chosen as a reference point for the industry efforts would be implemented over time as other things change going forward or what even the aim is that we should have in this particular effort, much less a larger effort, because with all the diversity that exists, not only in plant designs but in siting and other things, the bottom line of all of this effort is an enormously diverse set of outcomes.

If you could achieve perfection and calculate a full-scope PRA, including fire and external events and so on, you'd find an enormous range. Well, what do you -- what does that mean? I don't know.

It's a fact, and so, like I say, that's not got anything to do with this particular meeting here, but it does have a role to play, ultimately, in what we're doing, because there's comments that have been made about how much resources are consumed by this effort.

Ultimately, if you're a Senior Vice

1	President at a plant site or something like that, you
2	have to ask yourself, "Why am I doing this? What is
3	it really achieving?"
4	You know, I set up a PRA to manage
5	equipment outage in the plant, among the very first
6	plants to do that, and so I know the value that it has
7	in trying to make sure the plant is maintained with
8	safety margin all the time.
9	So it's not that I don't appreciate PRA,
10	but I'm just not sure where all of this goes
11	ultimately, and so that's just an observation I make.
12	It doesn't require any response. I don't expect it to
13	be part of anything that we're doing specifically
14	right now having to do with fire PRA, but I think this
15	is a great model that we should learn from, and that's
16	basically want I wanted to say.
17	CHAIR STETKAR: Thank you.
18	MEMBER RAY: With that, Bill and I will go
19	meet our airplane.
20	CHAIR STETKAR: You two are now excused.
21	MEMBER RAY: Thank you.
22	CHAIR STETKAR: And I guess we'll have the
23	staff
24	MEMBER RAY: Twelve o'clock right up,
25	straight up.
Į.	I and the second

1 CHAIR STETKAR: You've got ten seconds to get to the elevator. We'll have the staff come up. 2 3 We are ready. We have our necessary 4 number of people, so just proceed. 5 MR. BEASLEY: Okay. I am Ben Beasley. am acting as the Branch Chief for the PRA Licensing 6 7 The real Branch Chief is supporting us over 8 here on the side, Don Harrison, and Ray Gallucci is 9 there, as well. Stephen and JS will give the 10 presentation, but I wanted to just say a couple things to kick it off. 11 You've heard some frustration on the part 12 of the industry. I think you will now hear some 13 14 frustration on the part of the staff, which I'm sure 15 you expected. One other thing is that we are eager, 16 as well, to have processes that work that can review 17 and accept methods, new methods to advance, you know, the state of the technology. 18 19 It is interesting to point out that the FAQ process has worked. There are a dozen or so 20 clarifications and quidance that has come out of that 21 The EPRI UAM panel did work, not as well as 22 was hoped, but of the four items that were 23 24 submitted to it, three were accepted, and, you know,

we would -- those can be used freely now.

1 So those processes do work, and we're eager and willing to continue using those, or if 2 3 industry wants to develop, you know, another process, 4 then we would be happy to consider that, but that was 5 something that I think I'd like to throw out there to 6 set the stage. Our main preference is to not see new 7 methods in an LAR, you know, that being the first time 8 9 that we have an opportunity to review it. That is not our preference. So, with that I will turn it over to 10 Stephen. 11 Before you do --12 MEMBER BLEY: MR. BEASLEY: 13 Yes. MEMBER BLEY: I want to ask something, and 14 either you can answer it or these guys or somebody 15 over here, because it didn't look like it was in the 16 17 slides. Can you give us just a brief overview of how the peer review process is envisioned from the staff 18 side? 19 20 You know, back when it started with the PRAs and with the standard, my understanding was the 21 utility had developed the PRA, had it peer reviewed, 22 and then submitted, I guess, a letter to you saying --23 24 to the NRC saying that their PRA meets the standard.

Then, the review from NRC is limited to some kind of

1 a spot-checking to make sure that, in fact, it does. It sounds like, and it seems reasonable to 2 3 me, that in the case of the fire PRAs after they reach 4 that point that you're doing a much more thorough 5 review, and this is all -- much of this is new, so that doesn't surprise me. I wonder if that's true. 6 7 MR. BEASLEY: Just very briefly, we don't 8 do a detailed review. The main thing we do when we 9 review an application is go through the F&Os and see 10 how they were dispositioned. So that's been a lot of our requests for 11 information is, you know, that it'll say -- you know, 12 an F&O response will be, "This was dispositioned." 13 14 will say, "How?" 15 MEMBER BLEY: It was really a similar 16 process to what you use every day. 17 MR. DINSMORE: Well, it's а similar This is Steve Dinsmore from PRA Licensing 18 19 It's a similar process, but it's the high I mean, we have the opportunity to tailor our 20 review to how important what's being requested is, and 21 most of our stuff has been kind of at the low end. 22 This is one of the first ones that's really up there, 23 24 so it's within the process, but it's at the --MEMBER BLEY: Getting more attention. 25

1 MR. DINSMORE: -- hard end of the process. Okay, thanks. 2 MEMBER BLEY: 3 MR. HARRISON: This is Don Harrison. Ι 4 guess some day I'll be back as Branch Chief of the APLA, but the other perspective there is that, you 5 know, the fire PRA applications here are very complex, 6 7 and I would argue it's more complex than what we've 8 seen from our previous applications that typically 9 have quite a bit of use now, and so there's more 10 reliance on the peer review findings and focusing on those. 11 Here we're seeing a lot of, again, nuances 12 that are showing up in the applications beyond just 13 14 new methods, and that's driving us down into more of 15 a detailed review in those areas, because they are different than what, way, NUREG/CR-6850 number might 16 17 be. So there's, in addition to just peer 18 19 there's also things that may trigger the staff to start pulling the string on the use of a 20 method or a parameter that's different than what we 21 would have seen in the general method. 22 So there's reasons why some things drive us into the details. 23 24 MEMBER BLEY: Okay, thanks. MR. HYSLOP: And I guess the only thing 25

1 I've got to say is that the staff in its reviews has identified some key assumptions. In fact, we have a 2 3 generic set of REIs that we have developed as a part 4 of these reviews. There are about 12 of them, and so 5 these may or may not be picked up in the peer review. This is Ray Gallucci. 6 MR. GALLUCCI: 7 remember that 805 the focus is on the change in risk. Peer reviews are focused on the baseline risk. 8 9 805, the authority having jurisdiction has to pass judgment on the changes in risk, so there's more than 10 just relying on the peer review in an 805 application. 11 The delta risk is not something that's typically 12 covered in the peer review. 13 MR. DINSMORE: Well, it's been a very 14 15 invigorating morning. I'm going to try to walk 16 through these as quickly as possible, and we'll see 17 what happens. The first one, NUREG/CR-6850 provided for 18 19 detailed fire modeling to be used when the simpler methods to determine fire damage produced results that 20 are believed to be too conservative. That was kind of 21 Consistent with the previous ACRS 22 plan. conclusions, the staff continues to believe that 6850 23 is usable as the basis for NFP 805. 24 We think if you follow 6850 and the facts 25

1 and the formal process that you can reach a solution. Most or some licensees have -- that have relied on 2 3 this detailed fire modeling have completed their LAR 4 so that the process works if you really wanted to use 5 it. After I read this next bullet, I have a 6 7 clarification before I get questions. Some licensees 8 have tried alternative methods, assumptions to address 9 perceived excess conservatisms, which introduces 10 additional model uncertainty. We need to kind of set up where this is 11 being used here. This PRA is being used to make 12 really substantive changes to the plant. This hasn't 13 14 been done before. There's many hundreds of VFDRs that are 15 16 brought into the licensing basis using the PRA. 17 part of those VFDRs, a lot of operator actions are disappearing, because they're longer 18 no VFDRs. 19 They're changing from cold shutdown to safe-andstable, which is also kind of in the PRA, and that 20 change, too, is bringing out hundreds of operator 21 actions. 22 This is all good. This is what we 23 24 However, it does place a lot of emphasis on

this PRA, and so that's one of the reasons why this

1 process is becoming maybe more formal than the traditional PRA process where five or six guys say, 2 3 "Well, this thing is too high. It's obviously too 4 Here's a way to get it down. We're going to 5 get it down like that, " and the NRC has kind of not reacted badly to that. 6 7 However, this stuff is different. We want 8 to approve those methods that they're using to bring 9 this stuff down, and the other side of this is they've 10 got these hundreds of things that they don't have to It's not like they're having to fix hundreds of 11 do. things that they -- it's not like they're having to 12 fix hundreds of things. They're only fixing may five 13 14 or ten or 15 of these VFDRs. 15 So, it's not having that huge an impact on the results as we're seeing them, so I guess we're not 16 17 quite as frantic about getting these new methods reviewed, although we'd love to have them, but we 18 19 don't think it's necessary to keep moving. For your purposes to have 20 CHAIR STETKAR: reasonable that the transition is 21 assurance 22 acceptable. Yes, to have confidence 23 MR. DINSMORE:

they did

analysis

authorized.

that

24

25

supports what we

1	CHAIR STETKAR: Okay.
2	MEMBER SCHULTZ: And here your focus is
3	for the NFPA 805
4	MR. DINSMORE: That's correct.
5	MEMBER SCHULTZ: versus the other suite
6	of fire PRAs that are also being performed.
7	MR. DINSMORE: That's correct. When they
8	come in with their own 4.bs and stuff, we might
9	we'll have to deal with that as part of that process.
10	MR. HARRISON: If I can this is Donnie
11	Harrison again. If I can just add one thing, though,
12	it's not just an 805. It's not typically just
13	transition. It's also the use of these methods post-
14	transition for the licensee to do what's referred to
15	as self-approval.
16	CHAIR STETKAR: I think of that as part of
17	the training.
18	MR. HARRISON: So, sometimes you have to
19	you're looking at the method, not knowing exactly
20	how it's going to be used in the future, so that
21	aspect also has to be kind of considered.
22	MR. DINSMORE: Then the next bullet
23	CHAIR STETKAR: Actually, Steve, before
24	Donnie, a bit of a clarification. Once a licensee is
25	approved, you know, makes the transition and then is

1	can do their own self-assessment, you know, self-
2	approval for certain levels of plant changes, as part
3	of that process do they have to provide auditable
4	justification that indeed the model that they're
5	using, you know, is adequate to support that?
6	MR. HARRISON: There's still documentation
7	requirements.
8	CHAIR STETKAR: Yes.
9	MR. HARRISON: It has to be auditable.
10	CHAIR STETKAR: So, in the oversight
11	process, you could come in and audit that and say,
12	"Okay, you self-approved this change. Justify that
13	your model was okay. We have a question about that,"
14	but that's oversight.
15	MR. HARRISON: That would that would be
16	captured probably in Reg Guide 1.205.
17	CHAIR STETKAR: Right.
18	MR. HARRISON: I'm trying to recall. At
19	a low level, they could do self-approval, and if they
20	were to then have a higher level where they had to
21	come back in for approval from the staff
22	CHAIR STETKAR: Well, certainly then you
23	
24	MR. HARRISON: that would trigger a
25	review.

1	CHAIR STETKAR: That's right, but what I
2	was asking in terms of the low level, if they self-
3	approve the change, you know, and as part of that I'm
4	assuming they're going to have to have some sort of
5	internal justification that's available then for staff
6	audit under the
7	MR. HARRISON: Right.
8	CHAIR STETKAR: reactor oversight
9	process, for example, or whatever fire protection
LO	reviews you do perform.
11	So, what I'm asking about is, you know,
L2	some of your concerns about going forward, well, do we
L3	need to look at all of the details of every nuance
L4	because we're worried that they might be misused in
15	the future? Some of that might be caught, picked up
L6	in the future.
L7	MR. HARRISON: Yes, buy you don't you
L8	want to make sure the method starting out is
L9	acceptable. You don't want to find out that the
20	method may have been acceptable for some reason in
21	transition but clearly would not be acceptable in
22	certain circumstances down the road.
23	CHAIR STETKAR: Okay.
24	MR. HARRISON: I think that's why the
25	Oconee review we approved transition but did not

1	approve the self-approval capability
2	CHAIR STETKAR: Yes.
3	MR. HARRISON: because there was a
4	concern about the PRA for its use.
5	CHAIR STETKAR: Yes.
6	MR. HARRISON: So, but, yes, I was
7	reminded that there is a change process that's within
8	805 that licensees would have to follow, and it's got
9	documentation, so the information is there.
10	CHAIR STETKAR: Okay. Thanks.
11	MR. DINSMORE: Okay, the last bullet is
12	somewhat brutal, but we want to make sure that this is
13	clear. We disagree that a peer review team can review
14	and accept any method assumption by not issuing a
15	finding on that.
16	That's kind of the flip side of when you
17	say, "Well, if the peer review team didn't find,
18	didn't issue a finding on this, the staff shouldn't
19	review it." That's another way to say that, and we
20	don't agree with that.
21	Part of it, it's aggravated by the fire
22	stuff, because there is a lot of different opinions
23	about what's the proper method out there, and all
24	these peer review teams are doing these reviews.
25	So we haven't delegated authority to

1 approve methods to the peer review. We always review methods, and the SRP actually directs us to review key 2 assumptions, and the rule requires the use of methods, 3 4 data, and approaches that are acceptable to the NRC, 5 so we're maintaining our authority to go out and look in as much detail as we find is necessary. 6 7 Next page. The staff is finding that some 8 of the new methods/assumptions are somewhat arbitrary 9 and insufficiently justified to be used to support 10 substantive risk-informed changes. That's this NFP 805 in particular. 11 Now, part of our problem is we can't sit 12 here and say, "We like that. We don't like that." We 13 14 have to issue a formal document that says, "This is 15 This isn't okay, " which is best for everybody. 16 The only reason I was able to write this 17 is, as Donnie mentioned, some of these methods were actually used in Oconee. We wrote a draft SE where we 18 19 said, "You can't use this PRA in the future before you come in and ask us again." 20 Oconee withdrew the request to self-21 approval, so that stuff all disappeared, so there's 22 really still no formal position. However, it's pretty 23 24 clear what we would probably do.

So the formal review and acceptance or

1 denial of these new methods has suffered from changing We went from the facts to the UAMs, and now 2 3 we're back to plant-specific. We actually started 4 with plant-specific LAR, because it was the Oconee, 5 and then that didn't work out, so we started with the 6 FAQs, and the FAQs became unpopular. Then we went to 7 the UAMs, and now we're --8 So we need a vehicle. We need a way to 9 get the document in or the method in to look at it, to 10 review it. All these discussions, it depends a lot on personalities and stuff. What you need is the 11 documents. 12 So we're having a -- so we agree 100 13 14 percent with them. We're having a hard time getting 15 these methods in, reviewed, and finished. I quess we 16 disagree to some extent on how much of the review we 17 need to do, but we feel we need to do a fair amount. The one thing I want to add MR. HYSLOP: 18 19 is with the -- we've indicated that the -- this is JS Hyslop. The FAQ process is a process that we've used. 20 It is successful. 21 In fact, as a part of these discussions 22 that we're having with the plant NRC has initiated a 23 24 FAQ related to transient and hot work fires,

that's been presented to the FAQ Panel, and it's been

1	presented to industry. So we're working that, so we
2	do have a process.
3	CHAIR STETKAR: And I think in previous
4	Subcommittee briefings we've heard kind of both sides
5	of that process, you know, some of the things we've
6	heard this morning, elements of frustration about
7	timeliness is reaching, you know, consensus between
8	the industry and the staff, but there is a process.
9	MR. HYSLOP: But I guess the only other
10	thing, even some of the other process, timeliness has
11	been an issue.
12	CHAIR STETKAR: That's
13	MR. HYSLOP: It's been an issue with the
14	UAM, so, you know, these issues when you start getting
15	into developmental concerns and things, they're
16	complex.
17	CHAIR STETKAR: Yes.
18	MR. BEASLEY: And speaking to the
19	timeliness, the FAQ process is faster than submitting
20	a topical report, which is our routine process for
21	reviewing methods.
22	MR. DINSMORE: Yes, the FAQ process is
23	pretty fast, actually.
24	Then the last bullet, the staff
25	differentiates between unreviewed methods and
Į.	I and the state of

assumptions and formally unacceptable ones. What that's trying to say is we are open to changing these methods. We'd like to change them, but if we do it in the SEs particularly, by the time we get to the end of an SE review and the licensee has retained a method that we don't agree with, in the case of Oconee we just said, "Well, you've got such a big change in risk. We don't think that if you did it the way 6850 said that you would be above the guideline, so you can transition, but you can't do self-approval."

In the case of Harris, there was one specific model they were using for incipient detection that we said, "Well, you can't do self-approval on stuff that's affected by incipient detection until you use the model, I believe, that was in effect."

So we kind of need to keep going, moving through these submittals. We have to get SEs. We have to finish, so what I'm trying to say here is if we can finish but we still have a disagreement about a method and we can --

And these sensitivity studies that everybody is talking about, this would be the way for us to say, "Well, okay, we don't agree with the method that you used. It's been a long time. The review should be finished. We have enough information to let

1	you transition. We might not think that you can do
2	self-approval using this model, but you can
3	transition."
4	So that's kind of the nuclear option for
5	the end of one of these reviews, but it is an option
6	that's available, and it was an option which we've had
7	to use already once, and so it would be better to kind
8	of reach some kind of understanding before we get to
9	that point.
10	MEMBER BLEY: I think this is consistent
11	with your practice everywhere. Even though you would
12	prefer no new methods, if you get a submittal that
13	includes a method that's got its justification in it,
14	you review it.
15	MEMBER SCHULTZ: But then that review by
16	process would incorporate a sensitivity study.
17	MR. DINSMORE: A sensitivity study and a
18	lot of requests for justifications and discussions
19	about why this factor is acceptable. Within the staff
20	there's discussions between a dozen people, so it kind
21	of plugs up the process, too.
22	MEMBER SCHULTZ: I didn't want to diminish
23	it, but it would at least require the sensitivity
24	study.
25	MR. DINSMORE: Yes.
	II

1	MEMBER SCHULTZ: That's been pronounced as
2	a part of the process.
3	MR. DINSMORE: That's right. That's what
4	we've
5	MR. BEASLEY: Having it come in as part of
6	an application changes the dialogue a little bit. It
7	changes the setting in which we can work on it.
8	MEMBER BLEY: One o'clock may not be
9	fixed, so you might not be safe looking up there.
LO	MR. DINSMORE: Actually, I was hoping to
11	make you guys happy. Model uncertainty contain
L2	model uncertainty is contained in all phases of this
L3	multi-step analysis, fire frequency, the magnitude of
L4	the fire and the effects of the fire. It just
L5	permeates the whole analysis, and everybody is having
L6	a hard time dealing with that.
L7	CHAIR STETKAR: But, again, I'm really
L8	becoming I don't know what the right word is.
L9	Model uncertainty doesn't have anything to do with
20	fire frequency in the sense that most people think
21	about model uncertainty.
22	MR. DINSMORE: Well, let's see, the NUREG
23	on model uncertainty, what's that called?
24	CHAIR STETKAR: There is.
25	MR. DINSMORE: 1855. I quess it includes

key assumptions.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CHAIR STETKAR: I think we have to -- my only point is going to be I think we hear a lot of generalities, and I think that people too quickly focus on general issues and make general conclusions or general responses to those general issues.

indeed It's true that there are uncertainties associated with all of these elements of an analysis, but by just lumping them together and say there are huge model uncertainties and you need to address model uncertainties, if I were going to address that general issue, I would say, "Well, yes, there are, but if I'm talking about a particular plume model within FDT or CFAST, well, you know, how am I going to address the uncertainty in that model?" whereas if the results from that analysis are driven by uncertainty in a particular input parameter, that's a completely different issue.

I mean, that's -- all I'm trying to do is anchor people here on trying to not be so general about it. Uncertainties are large, and we can't address them, or people aren't adequately addressing model uncertainty because different people are going to have different interpretations of what that word might mean.

1	Unless you, you know, effectively
2	communicate it on both sides, you're just going to
3	have this continuing high-level discussion about
4	things that require too much effort to address because
5	we don't know how to address them. I'll just stop
6	there, but that's
7	MR. DINSMORE: I'll agree with you.
8	MR. HYSLOP: I guess one reason why we
9	might have fire frequency as a model uncertainty,
10	because there are factors that are used to adjust the
11	frequency and modify the frequency directly that are
12	the result of approaches for continuous fire watches,
13	hot work procedure, non-compliance, administrative
14	control.
15	So these factors, they're not related to
16	the magnitude of the fire, necessarily. It affects
17	they modify the frequency directly.
18	CHAIR STETKAR: Allocation of a plant-
19	level fire frequency to a particular fire area, so in
20	that sense that's true.
21	MR. HYSLOP: So I just wanted
22	CHAIR STETKAR: It doesn't affect the
23	plant-level fire frequency or any uncertainty in it.
24	MR. HYSLOP: It might affect the frequency
25	applied to the rest of the scenario.

1 MR. DINSMORE: It could affect the 2 results, too. 3 CHAIR STETKAR: Oh, sure. I'll let you go 4 I just, you know, kind of listening to both 5 sides, a lot -- in some sense, I think a lot of the issues -- perhaps, you know, in the more detailed 6 7 exchanges that you have and in the more focused 8 meetings there isn't --You are communicating more effectively, 9 but certainly a little bit of, I think, what I've 10 heard, anyway, over the last day or so is that there 11 tends to be a little bit of, at least 12 in these presentations, a little bit of too much generality in 13 14 terms of, you know, grouping things together and the people responding, saying, "Well, we can't address all 15 of that. It'll take the rest of our lives and all of 16 17 the money that we can ever think about." MR. DINSMORE: It's driven a bit by the 18 19 language used in all the guidance documents. 20 CHAIR STETKAR: Okay, but the people who wrote the quidance documents, many of them never 21 really did a fire PRA, so you kind of have to get past 22 23 that. MR. DINSMORE: Well, we have to follow the 24 quidance. 25

1 CHAIR STETKAR: You have to interpret the quidance. 2 3 MR. DINSMORE: Well, we have to follow the 4 quidance as we understand it. We can't not follow --5 help. CHAIR STETKAR: You can't not follow the 6 7 guidance, but you can interpret the guidance. 8 MR. DINSMORE: Right. 9 MEMBER BLEY: You do. 10 CHAIR STETKAR: And you always interpret the guidance. 11 MR. DINSMORE: 12 Yes. Really, what I'm hearing 13 MR. HARRISON: 14 from you, John, is what you're hanging up on is really 15 the use of this idea of model uncertainty as opposed There are different 16 to -- there are uncertainties. 17 kind of uncertainties, and you need -- some of those you can address directly. Some of those you can't. 18 19 You address them indirectly or qualitatively, but you need to be aware of all of them. 20 CHAIR STETKAR: You need to be aware of 21 all of them, and broad-brush statements saying, "Well, 22 23 have an RAI because you haven't adequately 24 addressed model uncertainties, " you know, just is not helpful. 25

1	MR. HARRISON: That would be too general.
2	I agree. When we
3	CHAIR STETKAR: Strictly recognizing the
4	fact the guidance says model uncertainty should be
5	addressed.
6	MR. HARRISON: We need to interpret what
7	that really means in an
8	CHAIR STETKAR: You need to interpret what
9	that really means, because you don't know the people
10	who wrote those particular words, what they understood
11	at that time. That's the whole point I'm getting to/
12	MR. HARRISON: As long as we stay away
13	from epistemic and aleatory, I would be happy.
14	MEMBER BLEY: You came to the wrong place.
15	CHAIR STETKAR: You came there are at
16	least 50 percent of us here who won't say anything.
17	MR. HARRISON: But it's just an
18	understanding that when we communicate we need to
19	communicate what the real issue is regarding a
20	particular uncertainty that we're addressing.
21	CHAIR STETKAR: That's the whole point.
22	That's right.
23	MR. HARRISON: So, and I agree with that,
24	clearly.
25	CHAIR STETKAR: Sorry, Steve.

1 MEMBER SCHULTZ: Steve, I think your general comment, and this is your closing slide, I 2 3 believe --4 MR. DINSMORE: Yes. 5 MEMBER SCHULTZ: I'm sure you've got other comments that you might like to make, but I think the 6 7 general presentation of this slide as the last one and 8 to be -- to lead to a statement that this is a lot of 9 what causes the complications that we've discussed 10 both in terms of technical concern, as well as process concern, in terms of trying to identify a path forward 11 12 here. We've talked about, in this session, we've 13 14 talked about the difficulty that the staff has when 15 model changes, improvements come as part of the 16 license amendment requests. I'm still struggling with 17 how effective or what effective ways licensees have to bring models forward otherwise. 18 19 Rick talked in his presentation earlier about that process that's been developed and called 20 for what I heard was some changes in that process so 21 that model development could be brought forward in a 22 way that would be effective for implementation.

example, let's not try to rewrite the document in its

entirety, but let's try to separate out models that

23

24

could be improved, should be improved.

One would hope that industry would be able to identify those that would be the very most important and agree with the NRC on those model changes that would be most important and figure a way to make those changes, get those changes approved outside of the submittal process, because given the time frame that you've described for responses to requests for additional information, there is no way that one could justify a model change of the type that we've heard in two months or three months.

Frankly, that shouldn't be a surprise to the licensee or the NRC. Those are hard changes to come to agreement with and approve, and when you put it on a time frame and time schedule that tight, it makes it intractable, but at the same time we therefore need a process that allows the technical changes to be made outside of that, and there are a couple of key features that are associated with that.

One is that you identify the most important, and that has to be done by industry, to identify what I would think with agreement of the NRC what's most important to achieve in terms of model changes that would really affect a reduction on uncertainty, we'll call it, going forward.

1 Then, secondly, having determined what is 2 most important, how can we -- how can those changes be made effectively with approval of the staff to be 3 4 implemented. 5 Then, the other thing I've heard that I'm trying to figure out is statements made by industry 6 7 that we only -- we want to do this once. We want to 8 get it done so we can move on to other things. 9 Well, this is -- I don't believe that's 10 going to happen, because we are faced with a lot of work that we need to do as a result of Fukushima 11 activities, heightened attention to external events, 12 not just fire but fire, flooding, seismic, others. 13 14 We're going to be facing these issues 15 associated with technical improvements, uncertainty 16 reduction as we move forward in these very, very 17 complicated areas which are similar, as Dennis said, similar activities that have been addressed but still 18 19 need to be addressed again as we move forward. 20 DINSMORE: Yes, so the quickest MR. process is the FAQ process, and that is actually 21 One of the difficulties with the quick 22 available. process is if you don't like where it ends up, it's 23 24 not as attractive.

MEMBER SCHULTZ:

25

That's correct, but then

there ought to be some iterative process that can be put in place that would allow the process to back up, determine where we go next, to reach a technical consensus.

MR. DINSMORE: Yes. The default process is the LAR reviews, and we've kind of fallen into the

CHAIR STETKAR: Steve, one of the things you mentioned I wrote down a note here, and I wanted to ask the staff, and perhaps the industry can weigh in. I've read through several of the FAQs, and, of course, the FAQs have evolved over, you know, five, six years or something like that, and they range in terms of complexity and focus, you know, quite wildly.

default process, because the other ones are not being

used, but, yes, that's all correct.

Have -- you know, now that we're through the two pilot plants and well into the first wave of applications, has there been an effort made --

Have you seen an effort, and has the industry made an effort to actually do something that Steve was suggesting, and that is to say, "Well, there are two or three, not 30 or 40, but two or three real modeling issues that we feel would substantially improve the quality of a large fraction, for example, of the submittals going forward, not minor differences

1	in a model for a, you know, plume temperature but
2	really substantive modeling issues"? Have you seen
3	that coming forward?
4	MR. DINSMORE: I review all of the RAIs,
5	so.
6	CHAIR STETKAR: Yes, but those that's
7	back down to the fine structure. I'm talking at kind
8	of a higher level, a little bit
9	MR. DINSMORE: I'm going to ask the guys
10	who are really digging into these analyses if the
11	industry has approached them. Maybe Alex or
12	MR. GALLUCCI: This is Ray. This is Ray
13	Gallucci. Basically, I'd call them more like tweaks.
14	I don't think we've seen any major attempt at an
15	overhaul of models.
16	The electrical cabinet method was an
17	attempt to combine suppression and propagation into
18	one step, which would be somewhat different from the
19	6850 approach, which kept them separate, but even
20	there it was primarily an attempt to come up with a
21	factor. So, I would say no, I don't believe we've
22	seen
23	I guess the one thing that would come
24	closest to that might be the EPRI/SAIC heat-release
25	rate approach, which was an attempt to come up with a

1	phenomenological statistical-based method to reduce
2	heat release rates based on cabinet ventilation.
3	I would say that would probably and
4	that would have provided for modifications to the heat
5	release rate curve distributions that were in 6850.
6	So that one probably that was a multi-year effort.
7	CHAIR STETKAR: Thanks.
8	MR. FINE: This is Ray Fine. Is this on?
9	CHAIR STETKAR: Yes, it's on.
10	MR. FINE: Ray Fine, First Energy, and I'm
11	going to agree with Ray Gallucci. There is no silver
12	bullet. There is no two or three things. It's little
13	tweaks throughout the entire methodology, from the
14	very beginning to the very end.
15	CHAIR STETKAR: Are those, you know,
16	because you've been involved in the peer reviews, so
17	I'll put you on the spot, are those little tweaks
18	generic little tweaks, or are they little tweaks that
19	tend to be much more plant-specific?
20	MR. FINE: No, these would be generic
21	methods.
22	MR. DINSMORE: Generic. Okay.
23	MR. FINE: You know, things like, you
24	know, you start out the fire scenario with what I'll
25	call deterministic preconditioning, okay. You're

1 saying that that pump breaks. Oil is on the floor, disperses and ignites with a frequency. Does that 2 3 frequency make sense to catastrophic failure frequency 4 that we see in the PRA today? No. 5 Okay, so it's not based on a probability. It's based on it happens, okay, and it goes just 6 7 little tweaks like that all the way through, but that one little thing propagates, and the earlier you start 8 9 the propagation, the more it affects. 10 CHAIR STETKAR: Okay. Thank you. Anybody There are people standing in the back. 11 else? Okay, you're just standing. Thanks. 12 I quess I would add one 13 MR. DINSMORE: 14 thing about excess conservatism. We keep hearing, 15 "Well, if it's too conservative, then it doesn't matter where I put this second cable, " and there were 16 some examples earlier about that. 17 I think some of that might not be totally 18 19 If it's too -- if you're assuming this whole room is burning up, you can't -- and you have a 20 second cable from a different train in there, you're 21 going to have to move that out, so you're going to get 22 a safety increase from that. 23 24 You might not get as much as you'd think,

but just moving it out is going to give you a safety

increase. If that cable is very risk-significant compared to the other one, same thing, so excess conservatism, I'm trying to kind of argue that excess conservatism, per se, is not going to lead you to give the wrong answers.

It might lead you to do more than you would have needed to do if you didn't have it, but there were some initial arguments that, "Well, because there's excess conservatism there, you're going to get the wrong answer, so you have to approve these methods, because they're reducing that excess conservatism." I knew that would start a conversation.

MR. WACHOWIAK: This is Rick Wachowiak from EPRI. You have to look at the application that you're going to use the PRA for. If you're using it for an application that's based on the risk does not exceed a certain level, which is will you move the cable out of that room because it's too much risk, that kind of thing the conservatism doesn't tend to influence.

But if you're doing a type of analysis or a type of application where you're saying, "Is this thing more important than this thing?" then the conservatism tends to either make your answer too high

2 answer if you're doing that type of application. 3 So, if it's a -- so you have to look at 4 the kind of application, and we've seen some of these 5 places where in some of the PRAs it gives you funny results when you look at the second thing where it 6 7 would tend to say that it doesn't matter if you have both diesel generators out of service at the same time 8 because of conservatism in the fire model that burned 9 10 up the entire room when we would recognize that that result cannot possibly be right. So, it's in the 11 application where the conservatism gets you 12 13 concern. 14 CHAIR STETKAR: Thank you. That's all the comments 15 MR. DINSMORE: that we had. 16 17 CHAIR STETKAR: That's it? Any other members' comments, questions for the staff? 18 19 It was less animated than I think we had expected, but that's a good thing. 20 What I'd like to do before -- we usually 21 the table and get final comments 22 around suggestions from the members. I would like to open up 23 24 the bridge line so that we have an opportunity for any comments from folks who may still be out there. 25

or too low or something. It can get you to the wrong

1 While we're doing that, are there comments from people in the room? 2 3 MR. AMICO: Yes, this is Paul Amico from 4 SAIC. You know, I've been doing PRA and developing 5 methodology since about 1977, and I think we all kind of know how methodologies generally get developed is 6 7 that somebody provides a suggestion. 8 You get a bunch of experts together. 9 beat on it until some -- until you reach the point 10 where you've got an answer that nobody is completely satisfied with, but you've got -- but it's something 11 that you can say, "Well, you know, we're not all 12 satisfied, but this is the best we can do right now." 13 14 Everybody's opinion is taken into account, and that's where the uncertainty distribution comes 15 Somebody is going to be out on the tail of the 16 17 curve, because you're never going to get complete agreement on anything. 18 19 So that's kind of the process we've really been following in this whole peer review thing, and 20 it's not just the peer reviewers. Sometimes we go 21 outside the peer review team. I was on both sides of 22 I had a method in, and I had methods I was 23 24 reviewing.

Sometimes we even go outside the peer

review team at the time and get additional comments. On the heat release rate stuff we got 50-something comments from NRC. Let's keep in mind, by the way, it's not -- you're really not getting comments from NRC. It's a person. It's a technical expert or two that they've brought in that has their own opinion, okay.

What happens when you get a letter from the NRC rejecting a method, what that is doing is saying, "The weight of our technical expert is one. The weight of all the other ones is zero," okay, and that's just bad science. That's my comment.

MR. HARRISON: If I can respond, this is

Donnie Harrison. Especially in the context of the UAM

panels, we have a representative that would sit on

those panels, but it's not like that person was in a

void and had no interaction with any other staff or

consultants.

Oftentimes during these panel discussions there would be other people incorporated or brought into the discussions, and so I don't want the ACRS to believe that one staff member made a decision, and somehow that became the NRC position. The NRC staff talk and discuss and even argue with each other about what the right approach is on a method and ultimately

1 would come up with a decision. 2 like as we do endorsement and 3 standards, we have staff that work with standards 4 development organizations. They provide a standard. 5 When that standard comes to the NRC for endorsement, there can be additional clarifications or exceptions 6 7 taken to the standard based upon a broader review. That's no different here than the NRC 8 takes a broader view of a document that comes in, and 9 that broader review results in its rejection. 10 what our job is in that context. So, I just -- I 11 understand the whole frustration, but that is the 12 regulatory perspective. 13 14 CHAIR STETKAR: Thanks, Donnie. Anything 15 else from anyone in the room? If not, if there's 16 anybody out there on the bridge line, I had to keep 17 saying this, but it's the only way we do know. Somebody out there just make a -- say something so we 18 19 can confirm it's open. MR. PINNELL: It is. 20 This is George Pinnell with ARS. 21 Thank you. 22 CHAIR STETKAR: Now, does anybody have a comment? Hearing no comments, I guess 23

we can re-close it just to -- problem is that the

bridge, for those of you out there, when the bridge

24

line is open we get a lot of noise and clacks in here, which is disturbing to a lot of people, so we'll reclose the bridge line.

Thanks again to the staff. Thanks again to the presenters this morning, and before we close what I'd like to do is go around the table and ask for three things from the remaining members. Number one, do you have, as we asked Harold and Bill, do you have any final comments or observations? That's number one.

Number two, and, unfortunately, there are only four of us here, is there any sense of anything that we've heard over the last day and a half that we should bring forward to the full Committee at this time for either a briefing or for the final follow-up?

Number three, should we think about scheduling another Subcommittee meeting on specific topics, just to kind of get that out on the table? So, if we can kind of address those three issues, I'd appreciate it, and, Joy, you're first.

MEMBER REMPE: Okay. Clearly, it's complicated, and I appreciate both the staff and the licensees and the industry organizations for taking the time to not only come here but also giving specific examples on why it's complicated and how

1 they're trying to address things. I think another follow-on meeting would be 2 3 With respect to going to the full Committee, 4 or you mentioned even if there's any letters that 5 should be written, it's contentious enough and there's a lot of issues enough that I think it might be 6 7 worthwhile having a smaller briefing to the full Committee and deciding whether a letter is worthwhile 8 9 at this time. 10 CHAIR STETKAR: Okay. Any -- we'll obviously have to discuss this. Any initial, if we 11 were going to schedule another Subcommittee meeting, 12 any particular topics, or is it too premature 13 14 discuss that in the context of this meeting? 15 I'd rather go outside, but MEMBER REMPE: 16 you had mentioned today about looking at more detail 17 on a couple of issues. CHAIR STETKAR: Okay. 18 19 MEMBER REMPE: And I think those issues would be worthwhile, too. 20 Okay. Thank you. 21 CHAIR STETKAR: Well, I would also like 22 MEMBER SCHULTZ: to express my appreciation to all the presenters, both 23 24 yesterday and today. There's been a lot of very good

discussion related to the processes that have been put

forward, many of the technical issues that are being faced, have been faced by the licensees, as well as the NRC reviewers in this area.

In spite of all those issues, it also appears that a lot has been accomplished, and the process is moving forward. The question is could it be moving forward in a more effective way? And I don't mean that just in terms of process.

I mean in terms of technical issues, as well, because, as I mentioned earlier, the issues that have been concerns, the technical concerns related to fire and especially as it pertains to both the characterization calculation of uncertainty with regard to the fire issues, are also carrying forward in other external event analyses.

Not to repeat, but this is going to gain even more importance as we go forward, so I am encouraged by what we've heard with regard to NEI involvement, EPRI involvement, industry involvement, and NRC involvement in the fire area in particular, and I hope this also carries forward in these other areas, as well.

With regard to bringing this forward to the full Committee, I think it would be better for the Subcommittee to first discuss a next Subcommittee

Dennis?

meeting and then make that determination following that discussion.

CHAIR STETKAR: Thank you.

MEMBER BLEY: Yes, I, too, would like to thank both the staff and folks from the industry for very good presentations and discussions, and even the bickering helped us see what's going on a little better, I think. I hadn't thought about full Committee, but some of the issues that have come up made me think it might be a good idea to get to a full

We in our letters pointed out the problem with rushing through these and having such a tight timetable that we didn't really have pilot studies that informed the rest of the process. What we've heard today goes even further to pointing out some of the problems in this rush through the process, and the reasons that came about aren't ours to talk about here.

There will be life after this rush, and that's where I think it might be important to get involved. Steve Dinsmore's point that now they're under a process that requires them to accept or reject, so they reject if they even don't like a little piece of the method means that for the longer

Committee.

1 term -- and I see why that is happening in the shorter 2 term. 3 For the longer term, some way to get this 4 process organized to get the best possible method and 5 methods in place is important and to have ways to get those issues back on the table and look at them for 6 7 the longer term and reach some degree of consensus. 8 So I think in the not-too-distant future, 9 and I don't think it has to happen in the next couple 10 of months, somewhere even further along through this rush process it would be good to have the full 11 Committee meeting so that we could address some of 12 those issues and give our thoughts both to the staff 13 14 and the Commission on what we think would help this in 15 the longer term. As for Subcommittee meetings, I think it 16 17 would be really useful for us to get a heads-up on the process by beginning to look at some of these reports 18 19 that have been submitted and approved and submitted and rejected so that we're better informed about what 20 the issues are and what the extent of the real 21 technical disagreements are. 22 CHAIR STETKAR: Thanks. I'm a slow 23 24 writer. I didn't write any of it 25 MEMBER BLEY:

1 down, so I'm glad you did. Somebody in the corner is getting every word. 2 3 CHAIR STETKAR: I was going to say John, 4 I hope, can read his own writing, because I can't read 5 mine. That's all right. 6 MEMBER BLEY: You'll 7 get a transcript. CHAIR STETKAR: Yes, but when you read 8 9 those, they don't make any sense. As final comments, again, I said it before, and I really do appreciate 10 all the effort that the staff and the industry, you 11 know, the three licensees put into supporting this 12 meeting, because I do know how much effort goes into 13 14 that, and we really do appreciate that. 15 My own thoughts regarding full Committee 16 and Subcommittee meetings are that I'm kind of on the 17 margin about going to the full Committee now. I think that, personally, and we'll obviously need to discuss 18 19 this among the Subcommittee, you know, offline, I do think that it would be worthwhile to have another 20 Subcommittee meeting. 21 In particular, things that Dennis -- I 22 kind of support Dennis's notion that for us to try to 23 24 at least better understand what some of the technical

issues are that seem to be driving the disparate

opinions about things.

The whole purpose of this Subcommittee meeting was to try to ferret out what some of those issues are, and I think they have a sense of what they may be, but obviously we didn't have enough time to really dig in, so I think another Subcommittee meeting a little more focused on specific technical issues and then the notion of Steve's if there is some way --

You know, I don't think it would be useful to look at ten different equally five-percent contributors, if you will. If there were two or three, and I think the NEI and EPRI presentations started to focus on a couple of issues that might be a little more key or a little more contentious, that might be useful.

I have to think, you know, a little bit more about timeliness of going to the full Committee.

I do support Dennis's notion. I think that it's important for ACRS to look as a full Committee past the current rush to get the LARs approved, because there are bigger issues.

Steve mentioned something about the process as it will apply to looking at floods, looking at seismic events, looking at, you know, other issues that are trailing behind the NFP 805 conversion, and

1	if there is something that the ACRS Committee should
2	weigh in in terms of whether it's a process issue or
3	how technical issues are resolved, that might help.
4	I think that is important going forward, but the
5	timing of a full Committee meeting I think we'll have
6	to discuss a little bit.
7	If there's anything else from any of the
8	Committee members anyone else in the room? If not,
9	thanks again to everyone. I appreciate it. We did
10	make it by 1:00, and the meeting is adjourned.
11	(Whereupon, the above-entitled matter was
12	adjourned at 12:56 p.m.)
13	
14	
15	
16	
17	
18	
19	
20	
21	
22	
23	
24	
25	

Industry Perspective

ACRS Reliability and Probabilistic Risk Assessment Subcommittee

> Victoria Anderson vka@nei.org July 27, 2012



Impacts of NFPA 805 Review Process on FPRA

- Extensive reliance on NUREG 6850 in NFPA 805 LAR review process
 - Complicates incorporation of improved methods in FPRA
 - Continued expectations for use in sensitivity studies
 - Removes focus from evaluation of technical adequacy per the NRCendorsed ASME/ANS PRA Standard
- Communication issues regarding expectations for PRA results supporting NFPA 805
 - Acceptance of FPRA methods
 - Sensitivity studies
- Short turnaround time for supplementary information
 - Additional sensitivity studies
 - LAR acceptance process vs. LAR review process

Timeframe for Development and Implementation of Advanced Methods

- Process
 - Development
 - Consensus review
 - NRC acceptance
 - Incorporation into FPRA
- Each step carries uncertainties
- Potentially unattractive to utilities with time limitations due to NFPA 805 LAR deadlines



Unreviewed Analysis Methods

- Background
 - Type of Fact and Observation used in peer review process
 - Not the same as a method that is different from those described in NUREG 6850
 - Purpose
 - Solution to handling rapidly improving methods in FPRAs
 - Ensured consistency in peer review process
- External consensus review is key component
- NRC review process
 - Timelines
 - Technical basis for review conclusions
- Expectations for addressing in LARs



Sensitivity Studies

- Expectations not clearly documented
 - Scope
 - Necessity
- Expectations for comparison to NUREG 6850
 - Impractical
 - Intended use of results is unclear
- Potential for SE conditions dictating changes to Fire PRA model



Sensitivity Studies: Example

- Electrical cabinet method developed by industry
 - Assigns a conditional probability to reflect the fraction of fires predicted to exhibit behavior consistent with that described in NUREG 6850
 - Based on thorough analysis of industry data
- Sensitivity study comparing results using this method with results obtained using NUREG 6850 would be time consuming and technically cumbersome
 - Re-analysis of fire modeling, growth, and suppression for many scenarios
 - Level of effort could require up to 40 weeks
- Product of comparison
 - Risk increase from non-propagating fires will decrease
 - Bias will skew risk results and have unknown impact on applications

Result of Current Practices

- Utilities pursuing moving targets
- FPRAs remain conservative, obscuring insights
 - Use of specific methods could be tied to SEs, making improvement difficult or impossible
 - Updates could be extraordinarily difficult
- Hampered technology advancement
 - Timelines not supportive of use
 - Not attractive to pursue



Key Potential Improvements

- Pursue a living document in NUREG 6850
 - Update
 - Reflect current state of the art, not a snapshot
- Better use of peer review process
- Utilize consensus review process for advanced methods
- Mutual understanding of approach to new methods in NFPA 805 LAR review process

Conclusions

- Current NFPA 805 LAR review process impedes development and use of realistic FPRAs
- SE conditions may force licensees to make changes to base models
- Pursuit of better process for encouraging continuous improvement to FPRA methods is vital







EPRI Perspectives on the Advancement of Fire PRA

Rick Wachowiak

Sr. Project Manager

ACRS PRA Subcommittee

July 27, 2012


Contents

- Brief background
- Original vision for NUREG/CR-6850 EPRI 1011989
- Advancing the state-of-the-art
- Conclusions



Brief Background

- Traditional PRA process has been iterative
- Processes outlined in literature work for most cases – rarely for all cases
- Analysts learn while performing the baseline PRA and while performing applications
- Continuous research on methods, tools, and data shapes each iteration





Concerns with Fire PRA Process

Industry perceptions include:

- Traditional PRA process does not appear to be available in fire PRA – specifically NFPA 805 applications
- Insights gained by performing the analyses not fed back
- Too much reliance on prescriptive source of methods, tools, and data
- Treated similar to DBA
 - Define a method that reliably yields conservative results
 - Apply that method across the board



NUREG/CR-6850 EPRI 1011989

- Developed under the MOU between EPRI and NRC RES
- Written in 2003 Published in 2005
- Compilation of fire PRA methodology best practices available at the time
- Arranged into a framework that allowed for the evolution of the methods, tools, and data – yet maintained a consistent and coherent structure
- The document acknowledges that the development of methods, tools, and data would continue beyond publication
- The authors clearly intended further development of fire PRA



Quote

The methods documented in this report represent the current state-of-the-art in fire PRA practice. Certain aspects of PRA continue to evolve and likely will see additional developments in the near future. Such developments should be easily captured within the overall analysis framework described here. It is important to emphasize that while specific aspects of the analysis process will likely evolve, the overall analysis framework represents a stable and well-proven platform and should not be subject to fundamental changes in the foreseeable future.

- Volume 1, Page xi



Quote

The methods documented in this report represent the current state of the art in Fire PRA. Fire PRA is an evolving discipline. The most effective way to allow these methods to further evolve is through their use in practical applications.

- Volume 1, Section 3.2



Development of the Methodology

- Project was to include four phases
 - Documentation of current best-practice methods, tools and data
 - Publication of the NUREG/CR-6850 EPRI 1011989
 - Demonstration of the process through full pilot applications, including an update to the document
 - Technology transfer and training
- Third phase was not completed
 - Full pilot demonstration projects not performed
- As a consequence, limited update of the methods, tools, or data



Quote

Critical technical tasks documented in this report were tested individually during pilot demonstration studies. These demonstration studies were intended to ensure the viability and reasonableness of the recommended methods, assess their ease of application, and assess the adequacy of the documentation. It had been intended that the pilot plants would follow through with the balance of their plant analyses and provide feedback and risk insights to the Technical Development Teams. Neither of the two pilot plants completed their full analyses. Based on the demonstration studies performed, quantitative risk insights are limited to specific analysis tasks. No global insights related to plant-wide fire risk estimates or the relative ranking of risk contributors have yet been gained. In the absence of a full application of the recommended procedures, the authors are unable to predict their impact on overall fire risk estimates with high confidence.

- Volume 1, Section 3.1



Alternative Methods, Tools, and Data

- NUREG/CR-6850 EPRI 1011989 project team acknowledged that alternate methods existed and would be developed
- Provided guidance for incorporation into the overall framework
 - Key is to consider the implications for other tasks
 - Task interdependence is also the focus of PRA peer reviews in accordance with the PRA standard



Quote

The authors acknowledge that alternative analysis methods do exist, and that their incorporation into the overall analysis framework presented here may be appropriate. However, implementation of an alternative approach to any given aspect of the analysis should include explicit consideration of the implications for other tasks. It is the analyst's responsibility to ensure that analysis consistency and task independence is maintained, or that any dependencies introduced are appropriately treated.

- Volume 1, Section 2.2



Advancing the State-of-the-Art

- Various processes attempted
 - -FAQ
 - Utility and vendor papers
 - EPRI reports
 - Expert panels
 - Experiments and associated NUREGs
- Varying degrees of success and acceptability
- While difficult, advancement is crucial



How to Advance the State-of-the-Art

- Further development of methods, tools, and data under the MOU appears to yield acceptable results – however:
 - Not as timely as some other processes traditionally used
 - Priorities of EPRI and RES arise from different perspectives – though they often converge
- Continue to work toward alignment
- Establish a process to update the methods, tools, and data in NUREG/CR-6850 EPRI 1011989
 - Make it modular full update would be impractical
 - Best available data experiments and insights from applications
 - Make it predictable lay out a schedule



Parallel Paths for Advancement

- Individual utilities and vendors need to continue with traditional advancement paths
- Find solutions for plant-specific problems difficult to fit into generic prioritization scheme
- Methods, tools, and data should stand on their own merits
- Focus of review of these methods, tools, and data should be on interdependence with other fire PRA tasks
- Can be folded into the overall advancement effort



Electrical Cabinet Scenarios – High Priority

- All current fire PRAs show electrical cabinet fire scenarios as risk drivers
- Models do not comport with observed fires
 - 1990 2009 data show more than 150 cabinet fires
 - None resulted in cable electrical failures
 - A very small percent resulted in insulation damage
 - Current modeling practice (including uncertainty)
 predicts a very large percentage would result in electrical failure
 - Order of magnitude differences
- Current attempts have not been able to resolve this or even acknowledge what needs to be done to resolve this



EPRI Perspective

- Fire PRA framework outlined in NUREG/CR-6850 EPRI 1011989 remains viable
- Individual methods (sub-methods), tools, and data can and should be improved
- Insights from performing fire PRA and fire PRA applications identify issues that were not conceived during the development of the document
 - These can uncover quirks or errors in the methods
 - Some are significant
- Continue to address plant specific issues on a case-by-case basis
- Undertake systematic update of NUREG/CR-6850 EPRI 1011989



Together...Shaping the Future of Electricity



Lessons Learned From Fire PRA Peer Reviews

Risk Management Subcommittee Chairman:

Roy Linthicum (Exelon)

Vice Chairman:

Ray Fine (FENOC)

PWROG Lessons Learned from FPRA Peer Reviews

- Peer Review Process
- Scheduled FPRA Peer Reviews
- Lessons Learned Process
- Lessons Learned Technical

Fire PRA Peer Review Process

- NEI 07-12 is the Written Process
 - Pre-review
 - Detailed Review Week Schedule
 - Structured Report Format
- Key Documents
 - ASME/ANS RA-Sa-2009 (What has to be done)
 - RG 1.200, Revision 2 (NRC Clarifications and Qualifications)
 - Consensus Methods (How to do it)
- Eight Person Review Team
 - Lead, Fire Modeling, Circuits Analysis, HRA, Quantification, General PRA

Fire PRA Peer Review Process

Unreviewed Analysis Method (UAM)

- Any analysis method not endorsed by the NRC or familiar to the Review Team
- Methods endorsed only by EPRI expert panel

Rely on Review Team to Identify During Review

 Is analysis a reasonable modification to NUREG/CR-6850 methodology (judgment call and covered during consensus)

Treatment

- "UAM" Fact and Observation Written against methods that the review team does not have the expertise to review
 - Identify all other SRs affected by methodology
- Other affected SRs assessed as if methodology acceptable but "UAM" F&O referenced.

Scheduled Fire PRA Peer Reviews

Plant	Peer Review Date	NFPA LAR Submittal Date
Palo Verde	October, 2012	N/A (Not Transitioning to NFPA 805)
Salem	November, 2012	N/A (Not Transitioning to NFPA 805)
H. B. Robinson	December 2012	9/30/13
Comanche Peak	March, 2013	Not Scheduled Yet.
Davis Besse	April, 2013	7/1/14
South Texas Project	July, 2013	N/A (Not Transitioning to NFPA 805)
Wolf Creek	July, 2013	N/A (Not Transitioning to NFPA 805)
Seabrook	August, 2013	N/A (Not Transitioning to NFPA 805)
Watts Bar	October 2013	N/A (Not Transitioning to NFPA 805)
Indian Point Units 2 & 3	October, 2013	N/A (Not Transitioning to NFPA 805)
Sequoyah	November, 2013	N/A (Not Transitioning to NFPA 805)
Byron/Braidwood	December, 2013	N/A (Not Transitioning to NFPA 805)
TMI	December, 2014	N/A (Not Transitioning to NFPA 805)

Lessons Learned - Process

- Level of Effort and Cost to Complete FPRA
 Significantly Higher than Originally Believed
 - Cascaded into Schedule Issues and Follow-on Peer Review

Review Requested Before FPRA Done

- Performed all steps in process
- Documented what was done
- CDF > 1.0E-04 so refinements in process
- If change methodology to get acceptable answer, will need follow-on review

Lessons Learned - Technical

- Target CDF is 5.0 E-05
 - If significantly above this value, need to refine the analyses
- Plant Partitioning requires complete coverage of all areas within the global plant boundary.
 - A number of cases where plants excluded "obvious" areas without providing basis
 - Example is "Manholes": Can contain cables and transient ignition sources. There have been fires in manholes.

Lessons Learned - Technical

Ignition Frequency requires review for outliers.

- Should compare number of events at plant to the "expected value."
- If use NUREG/CR-6850, Supplement 1 frequencies, need to perform sensitivity analysis stipulated in the supplement

Quantification

- Need Mean CDF and Error bounds
- Need Mean LERF and assessment of contributors to uncertainty (Error bounds not required for LERF)

Lessons Learned - Technical

Human Reliability Analysis

- Dependency Analysis needs to include all Human actions in model
- Need to evaluate feasibility for new fire-specific actions
- Need to review alarm response procedures to determine if there are any adverse actions due to procedure compliance with one spurious indication.
- All Human Failure Probabilities Must Address the impacts of the fire
 - Procedural guidance
 - Accessibility
 - Availability of Cues
 - Increased Stress levels

Circuit/Cable Selection

 Breaker coordination needs to cover any circuits added to Appendix R list

Summary

- Use of Fire PRAs for NFPA-805 before Fire Methods/Models were Developed has led to significant re-work, additional costs
- Need to Improve Process with Respect to Approving Unreviewed Analysis Methods
- Future External Events Model
 Development/Application should Ensure
 Methods/Models are in Place Prior to Pursuing
 Applications
- Applications should have real Pilots prior to widespread application



BWR Owners' Group Lessons Learned from FPRA Peer Reviews

Robert Rishel BWROG IRIR Chair

Dennis W. Henneke GE Hitachi Consulting Engineer

USNRC ACRS Meeting July 27, 2012



Topics

- Peer Review Process BWROG Specific Approach
- Lessons Learned
 - Best Practices
 - Areas for Improvement
- Summary/Closing Thoughts

BWROG FPRA Peer Review Process

Process follows NEI 07-12, including clarification letters:

- Identification of Unreviewed Analysis Methods (UAMs)
 - Used only twice during the BWROG peer reviews.
- Reference SR (Supporting Requirement) review guidance.
 - Resulted from BWROG initial reviews
- "Not Met" versus "Not Reviewed"

BWROG FPRA Peer Review Process (cont.)

BWROG Specific Process Enhancements:

- 2 hour training on the Fire PRA standard and BWROG lessons learned required for all peer reviewers
- Completion of >40% of SR assessments prior to on-site review week
- BWROG Peer Review database includes RG 1.200 clarifications and UAM designation
- 6-7 person team
 - Includes GEH FPRA Personnel, Consultants and Utility Peers
 - Utility participation less than desired (2-3)

Best Practices* Noted during Reviews:

- Full Evaluation of Non-Appendix R Fire Barriers, including active fire barriers
- MSO review includes description of each scenario, components affected, status of MSO in Safe Shutdown Analysis, and existing PRA modeling
- Full Comparison between Safe Shutdown Analysis and PRA equipment scope

Best Practices (cont.):

- Inclusion of all internal events PRA components into the FPRA, including cable tracing and circuit analysis
- A complete equipment listing for each possible Fire-Induced Initiating Event
- Coordination Review for all FPRA credited Power Supplies
- No limit on number of individual cables that can affect single component


Best Practices (cont.):

Multi-point fire model; Fire Heat Release Rates are varied, based on Significance:

Single size (bounding) fire for insignificant fires



- Three or more fire sizes for highest importance scenarios; for example
 - control room damage or evacuation scenarios.
 - Non-HEAF fire for highest importance cabinets (except where fire size does not impact results.
 - High Risk transient Fires



Best Practices (cont.):

 Time-dependent fire growth for significant cabinet and transient fires (e.g., detailed fire modeling)




Table H-5: Failure Time-Temperature Relationship for Thermoset cables (Table A.7.1 from reference H.6).

- Use of Thermal Response Model to determine time to cable damage →
- Detailed Analysis of all operator action HEPs

Exposure Temperature		Time to Failure
°C	°F	(minutes)
330	625	28
350	660	13
370	700	9
390	735	7
410	770	5
430	805	4
450	840	3
470	880	2
490 (or greater)	915 (or greater)	1

Best Practices (cont.):

- Detailed HEP analysis for control room evacuation scenarios, including actions at remote shutdown panel and impacts of spurious operation
- Development and Review of sequence cutset files similar to the internal events PRA. FPRA readiness requirements sometime were overruled by plant's inflexible 805 submittal schedules.
- Extensive and thorough HFE dependency analysis. Apply the HFE seeding process that calculates an optimal "seed" value for each HFE to be used in quantification.

Best Practices (cont.):

- Full Characterization of uncertainties
 - Sources of uncertainty and model assumptions
 - Uncertainty Parameters for fire-specific basic events
 - Include state-of-knowledge correlation
 - Documentation of FPRA limitations affecting applications

Areas for Improvement:

- Fire PRAs not complete at time of peer review
 - Documentation typically draft or recently issued for the peer review
 - Averaging more than 50 findings and not met SRs per review
 - Significant utility effort to incorporate peer review Findings and Observations
- Even with follow-on peer reviews (focused scope), two of three reviews were performed before FPRA was final

Areas for Improvement (cont.):

- FPRA documentation may not include consideration for reference SRs:
 - Resulting documentation is not as complete as an internal events PRA
- Utilities typically do not perform supplemental analysis (beyond NUREG/CR-6850) even if existing PRA results are unrealistic:
 - Too much time and effort to get new method "approved"

Summary/Closing Thoughts

BWROG FPRA Peer Review Process is comprehensive and identifying issues. Resolution of issues enhances overall FPRA quality

Many best practices are noted and shared within BWROG to improve future efforts

Main area of improvement is the need to complete FPRA before peer review

Need to encourage supplemental analysis and innovation, if FPRA is to be successful and improved



PRA Licensing Branch

Stephen Dinsmore, Sr. Risk Analyst

J.S. Hyslop, Sr. Risk Analyst

Division of Risk Assessment

Office of Nuclear Reactor Regulation

NFPA-805 PRA Observations

Technical Findings on NFPA 805 Transition

ACRS Reliability and PRA Subcommittee Brief

July 26 & 27, 2012

United States Nuclear Regulatory Commission

Protecting People and the Environment

NFPA-805 PRA Observations



- NUREG/CR-6850 provided for detailed fire modeling to be used when the simpler methods to determine fire damage produce results that are believed to be too conservative.
- Some licensees that have relied on detailed fire modeling have completed LARs.
- Some licensees have tried alternative methods/assumptions to address perceived excessive conservatism which introduces additional model uncertainty.
- The NRC staff disagrees that a Peer Review team can review and accept any method/assumption by not issuing a finding on it.

NFPA-805 PRA Observations



(Cont.)

- The NRC staff is finding that some of the new methods/assumptions are somewhat arbitrary and insufficiently justified to be used to support substantive risk-informed changes.
- Formal review and acceptance/denial of these new methods/assumptions has suffered from changing venues (i.e., FAQs to UAMs to plant specific LAR reviews).
- The NRC staff differentiates between unreviewed methods/assumptions, and formally unacceptable ones which must be removed from the PRA (by license condition if necessary).

NFPA-805 PRA Observations (cont.)



- Model uncertainty contained in all phases of multi-step analyses.
 - Fire Frequency
 - Magnitude of Fire
 - Effects of Fire