

CCNPP3eRAIPEm Resource

From: Arora, Surinder
Sent: Tuesday, August 14, 2012 9:38 AM
To: Infanger, Paul; UNECC3Project@unistarnuclear.com
Cc: CCNPP3eRAIPEm Resource; Segala, John; Wilson, Anthony; Vrahoretis, Susan; Thomas, Brian; Jeng, David; Jaffe, David; McLellan, Judith
Subject: CCNPP3 - Draft RAI 367 SEB 6555
Attachments: DRAFT RAI 367 SEB 6555.doc

Paul,

Attached is Draft RAI No. 367 (eRAI No. 6555) pertaining to section 14.3.2 of the Calvert Cliffs Unit 3 FSAR. You have until August 28, 2012 to review it and decide whether you need a conference call to discuss the RAI before the final issuance. After the phone call or after August 28, 2012, the RAI will be finalized and sent to you for your response. You will then have 30 days to provide a technically complete response or an expected response date for the RAI.

Thanks

SURINDER ARORA, PE
PROJECT MANAGER,
Office of New Reactors
US Nuclear Regulatory Commission

Phone: 301 415-1421
FAX: 301 415-6406
Email: Surinder.Arora@nrc.gov

Hearing Identifier: CalvertCliffs_Unit3Col_RAI
Email Number: 246

Mail Envelope Properties (B46615B367D1144982B324704E3BCEEDC9561F4B93)

Subject: CCNPP3 - Draft RAI 367 SEB 6555
Sent Date: 8/14/2012 9:38:24 AM
Received Date: 8/14/2012 9:38:25 AM
From: Arora, Surinder

Created By: Surinder.Arora@nrc.gov

Recipients:

"CCNPP3eRAIEm Resource" <CCNPP3eRAIEm.Resource@nrc.gov>
Tracking Status: None
"Segala, John" <John.Segala@nrc.gov>
Tracking Status: None
"Wilson, Anthony" <Anthony.Wilson@nrc.gov>
Tracking Status: None
"Vrahoretis, Susan" <Susan.Vrahoretis@nrc.gov>
Tracking Status: None
"Thomas, Brian" <Brian.Thomas@nrc.gov>
Tracking Status: None
"Jeng, David" <David.Jeng@nrc.gov>
Tracking Status: None
"Jaffe, David" <David.Jaffe@nrc.gov>
Tracking Status: None
"McLellan, Judith" <Judith.McLellan@nrc.gov>
Tracking Status: None
"Infanger, Paul" <paul.infanger@unistarnuclear.com>
Tracking Status: None
"UNECC3Project@unistarnuclear.com" <UNECC3Project@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	692	8/14/2012 9:38:25 AM
DRAFT RAI 367 SEB 6555.doc		34810

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information 367 (eRAI 6555)

DRAFT

Issue Date: 8/14/2012

Application Title: Calvert Cliffs Unit 3 - Docket Number 52-016

Operating Company: UniStar

Docket No. 52-016

Review Section: 14.03.02 - Structural and Systems Engineering - Inspections, Tests, Analyses, and Acceptance Criteria

Application Section: FSAR 14.3.2

QUESTIONS

14.03.02-20

Supplemental RAI to RAI Number 14.03.02-19 (RAI 334, eRAI 6215) – Sent to NRC on May 22, 2012

In RAI 334, Question 14.03.02-19, the staff requested that the applicant, (1) for all Seismic Category (SC) II structures, include in the FSAR the design information provided in RAI responses to RAI 275, Question 14.03.02-13 and RAI 315, Question 03.07.02-63, (2) clarify the inconsistency between the proposed mark-up for FSAR Subsection 3.7.2.8 and the ITAACs related to SC II structures.

The staff reviewed the RAI response to Question 14.03.02-19 provided in UniStar letter UN#12-038 dated April 20, 2012 (ML12115A181).

The staff determined that the following information is needed to resolve this RAI:

1. The FSAR mark-ups do not include the analysis and conceptual design of the SC II structures, which information will be provided in the response to RAI 315, Question 03.07.02-63. The staff understands that the information may not be available at this time, but the applicant should confirm that the FSAR mark-ups with the information will be submitted for the staff's review on or before the response to RAI 315, Question 03.07.02-63, which is currently scheduled to be submitted on June 5, 2013.
2. In the FSAR mark-ups for the Access Building, Section 1 Building Layout/Details, provided in the response to RAI 334, Question 14.03.02-19 and RAI 275, Question 14.03.02-13, the wording "... layout sketches and details are not included as part of the response" needs to be corrected, because the responses to RAI 334, Question 14.03.02-19 and RAI 275, Question 14.03.02-13 committed to provide in the FSAR the conceptual design of the Access Building.
3. Since the Circulating Water System (CWS) Makeup Water Intake Structure (MWIS) is also an SC II structure, the staff requests that, for the CWS MWIS, the applicant provide in the FSAR the design information comparable to that provided for other SC II structures as shown in FSAR mark-ups for Subsection 3.7.2.8.

The staff needs the above information to be able to conclude in the SER that there is reasonable assurance that the specific COL interface requirements for the CCNPP Unit 3 Seismic Category II structures have been adequately implemented and addressed in the CCNPP Unit 3 COLA.