

## PRELIMINARY NOTIFICATION - REGION III

August 16, 2012

### PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE - PNO-III-12-009

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information may not yet be fully verified or evaluated by the Region III staff.

#### **Facility**

Monticello Nuclear Generating Plant  
Northern States Power Co.  
Monticello, MN  
Docket: 50-263  
License: DPR-22

#### **Licensee Emergency Classification**

Notification of Unusual Event  
 Alert  
 Site Area Emergency  
 General Emergency  
 Not Applicable

SUBJECT: MONTICELLO SHUTDOWN DUE TO DRYWELL UNIDENTIFIED LEAKAGE  
ABOVE TECHNICAL SPECIFICATION LIMITS

#### DESCRIPTION:

On August 10, 2012, the licensee noted that the drywell unidentified leakage rate had increased from a nominal 0.2 gallons per minute to 8.4 gallons per minute, exceeding the Technical Specification limit of 5 gallons per minute. The leakage rate then dropped to < 0.5 gallons per minute after about 15 minutes. The licensee reduced reactor power to 10 percent and remained at this power while workers entered the drywell to identify the source of the leakage. The leakage was coming from a mechanical bolted connection on a section of piping associated with the residual heat removal system. Subsequently, on August 14, 2012, at 12:00 p.m. CDT, the plant was shutdown to commence repairs.

The Technical Specification limit for unidentified leakage allows time for early detection of a problem that could indicate a failure of the reactor pressure boundary. The limit requires that the plant be shutdown if the unidentified leakage rate exceeds 5 gallons per minute and cannot be reduced to below the limit within 4 hours or if there is any indication of pressure boundary leakage. As stated above, the unidentified leakage rate dropped below the Technical Specification limit within 15 minutes. Additionally, the identified leak was not considered pressure boundary leakage.

The NRC resident inspectors were aware of the increase in the unidentified leakage rate and observed the initial power reduction and the subsequent plant shutdown. The resident inspectors were also monitoring the licensee's investigation and repair activities.

This preliminary notification is issued for information only. State and local officials have been informed. The site issued a press release on August 14, 2012, describing the event.

The information presented herein has been discussed with the licensee, and is current as of 9:00 a.m. CDT, on August 16, 2012.

ADAMS Accession Number: ML12229A315

CONTACT: Nirodh Shah  
630-829-9821  
[Nirodh.Shah@nrc.gov](mailto:Nirodh.Shah@nrc.gov)