

PMComanchePeakPEm Resource

From: Monarque, Stephen
Sent: Wednesday, August 15, 2012 11:04 AM
To: Woodlan, Don; John.Only@luminant.com
Cc: Kallan, Paul; Otto, Ngola; ComanchePeakCOL Resource
Subject: RE: RAI 2583 is assigned to you for review

Don,

Regarding your supplemental response, dated July 16, 2012, to RAI 2583 (NRC Letter number 56), the staff has identified the following issue below.

“The supplemental response for 14.03.03-01 and 14.03.03-02 looks okay except for the AC column (this refers to ITAAC 21), Luminant needs to specify the type of report. An acceptable report is an ASME Code Section III Design Report (NCA-3550).”

The staff is working with MHI on similar issue for USAPWR DCD.

Thanks,

Stephen Monarque
Lead Project Manager
Comanche Peak COL
NRO/DNRL/LB2
301-415-1544

Hearing Identifier: ComanchePeak_COL_Public
Email Number: 1725

Mail Envelope Properties (9C2386A0C0BC584684916F7A0482B6CA8C5BE7AAAE)

Subject: RE: RAI 2583 is assigned to you for review
Sent Date: 8/15/2012 11:04:00 AM
Received Date: 8/15/2012 11:04:10 AM
From: Monarque, Stephen

Created By: Stephen.Monarque@nrc.gov

Recipients:

"Kallan, Paul" <Paul.Kallan@nrc.gov>
Tracking Status: None
"Otto, Ngola" <Ngola.Otto@nrc.gov>
Tracking Status: None
"ComanchePeakCOL Resource" <ComanchePeakCOL.Resource@nrc.gov>
Tracking Status: None
"Woodlan, Don" <Donald.Woodlan@luminant.com>
Tracking Status: None
"John.Conly@luminant.com" <John.Conly@luminant.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	623	8/15/2012 11:04:10 AM

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: