



Tennessee Valley Authority, Post Office Box 2000, Soddy Daisy, Tennessee 37384-2000

August 15, 2012

Ms. Christina Morgan
Tennessee Department of Environment
and Conservation
Division of Water Pollution Control
Enforcement & Compliance Section
6th Floor, L & C Annex
401 Church Street
Nashville, Tennessee 37243

Dear Ms. Morgan:

TENNESSEE VALLEY AUTHORITY (TVA) - SEQUOYAH NUCLEAR PLANT (SQN) - NPDES
PERMIT NO. TN0026450 - DISCHARGE MONITORING REPORT (DMR) FOR JULY 2012

Enclosed is the July 2012 Discharge Monitoring Report for Sequoyah Nuclear Plant. There were no exceedances during the monitoring period. During July, natural conditions caused the 24-hour average ambient river temperature to exceed 29.4°C for 18 days, including 7/29 and 7/30 when the Instream Monitoring temperature measured 30.6°C. The plant continued to operate in helper mode throughout this period and complied with the elevated 1-hour average river temperature limit of 33.9°C at the downstream edge of the mixing zone as required by Part 1.A.1.f of the NPDES permit. If you have any questions or need additional information, please contact Brad Love by email at bmlove@tva.gov or by phone at (423) 843-6714.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Sincerely,

Paul R. Simmons
Plant Manager

Signatory Authority for:
John T. Carlin
Site Vice President
Sequoyah Nuclear Plant

Enclosures

cc (Enclosures):

Chattanooga Environmental Field Office
Division of Water Pollution Control
State Office Building, Suite 550
540 McCallie Avenue
Chattanooga, Tennessee 37402-2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

IEAS
NRR

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUBR 01)
 F - FINAL
 DIFFUSER DISCHARGE
 EFFLUENT

TN0026450 **101 G**
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 From **12 07 01** To **12 07 31**

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Brad Love

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	39.4	04	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	Req. Mon. DAILY MAX	DEG. C.		CONTI NUOUS	CALCTD
TEMPERATURE, WATER DEG. CENTIGRADE 00010 Z 0 INSTREAM MONITORING	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	30.6	04	0	31 / 31	MODELD
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	30.5 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C 00016 1 S EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	*****	2	04	0	31 / 31	CALCTD
	PERMIT REQUIREMENT	*****	*****	****	*****	*****	3 DAILY MX	DEG. C.		CONTI NUOUS	CALCTD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	1745	03	*****	*****	*****	**	0	31 / 31	RCORDR
	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MAX	MGD	*****	*****	*****	****		CONTI NUOUS	RCORDR
CHLORINE, TOTAL RESIDUAL 50060 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	*****	**	*****	0.017	0.048	19	0	25 / 31	GRAB
	PERMIT REQUIREMENT	*****	*****	****	*****	0.1 MO AVG	0.1 DAILY MAX	MG/L		FIVE PER WEEK	CALCTD
TEMPERATURE - C, RATE OF CHANGE 82234 1 0 EFFLUENT GROSS	SAMPLE MEASUREMENT	*****	0	62	*****	*****	*****	**	0	31 / 31	CALCTD
	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C/HR	*****	*****	*****	****		CONTI NUOUS	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Paul R. Simmons Sequoyah Plant Manager TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-6502	12	08	15
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 No closed mode operation. Veliger monitoring data is included as an attachment. Natural conditions caused the 24-hour average ambient river temperature to exceed 29.4°C for 18 days, including 7/29 and 7/30 when the Instream Monitoring temperature measured 30.6°C. The plant continued to operate in helper mode throughout this period as required by Part 1.A.1.f of the NPDES permit.

Sample Date	Mean # of ZM/m3	% Settlers	Water Temp. (°C)	Sample Date	Mean# of Asiatic Clams/m3	Water Temp. (°C)	LOCATION	SUB LOCATION	NOTES: % Gravid Asiatic Clam	COLLECTED BY
01/03/2012	14	100	26	01/03/2012	0	26		1-25-545		PKS
01/10/2012	0	0	9	01/10/2011	0	9	RCW			WBE
01/17/2011	0	0	10	01/17/2011	0	10		1-ISV-24-1234		PB
01/24/2012	0	0	13	01/24/2012	0	13		1-25-545		WDT
01/31/2012	0	0	17.6	01/31/2012	0	17.6		1-25-545		CR
02/07/2012	0	0	12	02/07/2012	0	12		1-25-545		BB
02/14/2012	0	0	8.3	02/14/2012	0	8.3		1-24-1234		WE
02/21/2012	0	0	26.5	02/21/2012	0	26.5		1-25-545		CR
02/28/2012	0	0	11.1	02/28/2011	0	11.1		1-ISV-24-1234		WBE
03/06/2012	0	0	11.7	03/06/2012	0	11.7		1-ISV-24-1234		WBE
03/13/2012	0	0	13	03/13/2012	0	13		1-ISV-24-1234		WBE
03/20/2012	0	0	14.6	03/20/2012	0	14.6		1-ISV-24-1234		WBE
03/27/2012	1623	1.3	17.2	03/27/2012	0	17.2		1-ISV-24-1234		WBE
04/03/2012	229	0	18	04/03/2012	0	18		1-ISV-24-1234		PB
04/10/2012	79	20	22	04/10/2012	0	22		1-ISV-24-1234		PB
04/18/2012	326	5	18.8	04/18/2012	0	18.8		1-ISV-24-1234		MJW
May 2012										No Samples Collected
June 2012										No Samples Collected
July 2012										No Samples Collected

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

TN0026450 **101 T**
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 From

YEAR	MO	DAY
12	07	01

 To

YEAR	MO	DAY
12	07	31

F - FINAL
 BIOMONITORING FOR OUTFALL 101
 EFFLUENT

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Brad Love

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP3B 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**	Monitoring Not Required	*****	*****	23			
TRP6C 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Paul R. Simmons Sequoyah Plant Manager TYPED OR PRINTED	I Certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-6502	12	08	15
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 Toxicity was not sampled in July 2012.

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P. O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

TN0026450 **103 G**
 PERMIT NUMBER DISCHARGE NUMBER

F - FINAL
 LOW VOL. WASTE TREATMENT POND
 EFFLUENT

MONITORING PERIOD
 From

YEAR	MO	DAY
12	07	01

 To

YEAR	MO	DAY
12	07	31

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Brad Love

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
PH		*****	*****	**	7	*****	8	12	0	15 / 31	GRAB
00400 1 0 EFFLUENT GROSS		*****	*****	**	6 MINIMUM	*****	9 MAXIMUM	SU		THREE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED		*****	*****	**	*****	6	6	19	0	2 / 31	GRAB
00530 1 0 EFFLUENT GROSS		*****	*****	**	*****	30 MO AVG	100 DAILY MX	MG/L		TWICE/ MONTH	GRAB
OIL AND GREASE		*****	*****	**	*****	<6	<6	19	0	2 / 31	GRAB
00556 1 0 EFFLUENT GROSS		*****	*****	**	*****	15 MO AVG	20 DAILY MX	MG/L		TWICE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT		0.942	1.164	03	*****	*****	*****	**	0	31 / 31	RCORDR
50050 1 0 EFFLUENT GROSS		Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		SEE PERMIT	RCORDR

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Paul R. Simmons Sequoyah Plant Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-6502	12	08	15
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

TN0026450 **110 G**
 PERMIT NUMBER DISCHARGE NUMBER

MONITORING PERIOD
 From

YEAR	MO	DAY
12	07	01

 To

YEAR	MO	DAY
12	07	31

F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

ATTN: Brad Love

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TEMPERATURE, WATER DEG. CENTIGRADE 00010 1 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	*****	REPORT DAILY MX	DEG C		CONTINUOUS	CALCTD
TEMPERATURE, WATER DEG. CENTIGRADE 00010 Z 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
INSTREAM MONITORING	PERMIT REQUIREMENT	*****	*****	**	*****	*****	30.5 DAILY MX	DEG C		CONTINUOUS	CALCTD
TEMP. DIFF. BETWEEN SAMP. & UPSTRM DEG.C 00016 1 0	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		04			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	*****	5 DAILY MX	DEG C		CONTINUOUS	CALCTD
FLOW, IN CONDUIT OR THRU TREATMENT PLANT 50050 1 0	SAMPLE MEASUREMENT	*****		03	*****	*****	*****	**			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	Req. Mon. DAILY MX	MGD	*****	*****	*****	**		CONTINUOUS	RCORDR
CHLORINE, TOTAL RESIDUAL 50060 1 0	SAMPLE MEASUREMENT	*****	*****	**	*****			19			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	**	*****	0.1 MO AVG	0.1 DAILY MX	MG/L		Five per Week	CALCTD
TEMPERATURE - C, RATE OF CHANGE 82234 1 0	SAMPLE MEASUREMENT	*****		04	*****	*****	*****	**			
EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	2 DAILY MX	DEG C	*****	*****	*****	**		CONTINUOUS	CALCTD
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Paul R. Simmons Sequoyah Plant Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-6502	12	08	15
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 No Discharge this Period

PERMITTEE NAME/ADDRESS (Include Facility Name/Location if Different)

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P. O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES)
 DISCHARGE MONITORING REPORT (DMR)

MAJOR (SUBR 01)
 F - FINAL
 RECYCLED COOLING WATER
 EFFLUENT

Form Approved.
 OMB No. 2040-0004

TN0026450			110 T		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
12	07	01	12	07	31

ATTN: Brad Love

*** NO DISCHARGE ***

NOTE: Read instructions before completing this form.

PARAMETER	X	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
IC25 STATRE 7DAY CHR CERIODAPHNIA	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP3B 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
IC25 STATRE 7DAY CHR PIMEPHALES	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	23			
TRP6C 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	*****	*****	****	43.2 MINIMUM	*****	*****	PERCENT		SEMI ANNUAL	COMPOS
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Paul R. Simmons Sequoyah Plant Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-6502	12	08	15
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

No Discharge this Period

Name **TVA - SEQUOYAH NUCLEAR PLANT**
 Address **P.O. BOX 2000**
 (INTEROFFICE OPS-5N-SQN)
SODDY - DAISY, TN 37384
 Facility **TVA - SEQUOYAH NUCLEAR PLANT**
 Location **HAMILTON COUNTY**

TN0026450	118 G
PERMIT NUMBER	DISCHARGE NUMBER

F - FINAL
WASTEWATER & STORM WATER
EFFLUENT

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
From 12	07	01	To 12	07	31

*** NO DISCHARGE ***

ATTN: Brad Love

NOTE: Read instructions before completing this form.

PARAMETER	SAMPLE MEASUREMENT / PERMIT REQUIREMENT	QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
OXYGEN, DISSOLVED (DO)	SAMPLE MEASUREMENT	*****	*****	**		*****	*****	19			
00300 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	2 MINIMUM	*****	*****	MG/L		TWICE/ WEEK	GRAB
SOLIDS, TOTAL SUSPENDED	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		19			
00530 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	*****	*****	100 DAILY MX	MG/L		TWICE/ WEEK	GRAB
SOLIDS, SETTLEABLE	SAMPLE MEASUREMENT	*****	*****	**	*****	*****		25			
00545 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	*****	*****	****	*****	*****	1 DAILY MX	ML/L		ONCE/ MONTH	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT			03	*****	*****	*****	**			
50050 1 0 EFFLUENT GROSS	PERMIT REQUIREMENT	Req. Mon. MO AVG	Req. Mon. DAILY MX	MGD	*****	*****	*****	*		ONCE/ BATCH	ESTIMA
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER Paul R. Simmons Sequoyah Plant Manager TYPED OR PRINTED	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	TELEPHONE		DATE		
		423	843-6502	12	08	15
SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER	YEAR	MO	DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)
 During this reporting period, there has been no flow from the Dredge Pond other than that resulting from rainfall.