

## IPRenewal NPEmails

---

**From:** Pickett, Douglas  
**Sent:** Wednesday, August 22, 2012 10:25 AM  
**To:** rwalpol@entergy.com  
**Cc:** Prussman, Stephen G  
**Subject:** Question on License Renewal

Bob –

I've been asked a couple questions regarding license renewal commitments. Section 1.6 of NUREG-1930 states the following:

### 1.6 Summary of Proposed License Conditions

Following the staff's review of the LRA, including subsequent information and clarifications from the applicant, the staff identified three proposed license conditions.

The first license condition requires the applicant to include the UFSAR supplement required by 10 CFR 54.21(d) in the first UFSAR update required by 10 CFR 50.71(e) following the issuance of the renewed licenses.

The second license condition requires future activities described in the UFSAR supplement to be completed prior to the period of extended operation.

The third license condition requires that all capsules in the reactor vessel that are removed and tested meet the requirements of American Society for Testing and Materials (ASTM) E 185-82 to the extent practicable for the configuration of the specimens in the capsule. Any changes to the capsule withdrawal schedule, including spare capsules, must be approved by the staff prior to implementation. All capsules placed in storage must be maintained for future insertion. Any changes to storage requirements must be approved by the staff, as required by 10 CFR Part 50, Appendix H.

As indicated in the second license condition above, certain actions were to be completed prior to entering the period of extended operations. The questions I've received were (1) is the licensee required to inform the NRC that the actions have been taken and (2) have we received any letters from the licensee in this regard.

My understanding is that when we issued the SER and NUREG-1930, we didn't anticipate that ASLB hearings might be ongoing and the license might not be renewed by the end of the original 40 years.

Could you let me know your understanding?

Thanks - Doug

Douglas V. Pickett, Senior Project Manager  
Indian Point Nuclear Generating Unit  
U.S. Nuclear Regulatory Commission  
301-415-1364  
Email: [douglas.pickett@nrc.gov](mailto:douglas.pickett@nrc.gov)

**Hearing Identifier:** IndianPointUnits2and3NonPublic\_EX  
**Email Number:** 3723

**Mail Envelope Properties** (Douglas.Pickett@nrc.gov20120822102500)

**Subject:** Question on License Renewal  
**Sent Date:** 8/22/2012 10:25:13 AM  
**Received Date:** 8/22/2012 10:25:00 AM  
**From:** Pickett, Douglas

**Created By:** Douglas.Pickett@nrc.gov

**Recipients:**  
"Prussman, Stephen G" <SPrusm@entergy.com>  
Tracking Status: None  
"rwalpol@entergy.com" <rwalpol@entergy.com>  
Tracking Status: None

**Post Office:**

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	2137	8/22/2012 10:25:00 AM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**