



SESSION 1-5

RISK-INFORMED REGULATION CASE STUDY I ROP/SDP

Donnie Harrison

U.S. Nuclear Regulatory Commission

Donnie.Harrison@nrc.gov

301.415.2470

RISK-INFORMED REGULATION SEMINAR
Mexico City, Mexico August 27-31, 2012

LEARNING OBJECTIVES

- To describe NRC's reactor oversight - significance determination process and decision criteria
- To illustrate key aspects of associated risk analysis methods using 2 examples
 - Consideration of multiple hazards
 - Consideration of common cause failure and human performance

Overview

- SDP Objectives
 - To characterize the safety or security significance of inspection findings, using best available risk insights as appropriate
 - To provide all stakeholders an objective and common framework for communicating the potential safety or security significance of inspection findings
 - To provide a basis for timely assessment and/or enforcement actions associated with inspection findings

Overview


- SDP Process
 - Develop inspection findings
 - Characterize significance (initial staff assessment)
 - Obtain licensee perspectives on initial characterization
 - Finalize staff's significance determination
 - Issue final determination letter
 - Provide licensee appeal opportunity

Overview

- Decision criteria
 - Change in:
 - Core damage frequency
 - Large early release frequency
 - Broad ranges



$\Delta\text{CDF} < 1 \times 10^{-6}$
$1 \times 10^{-6} \leq \Delta \text{CDF} < 1 \times 10^{-5}$
$1 \times 10^{-5} \leq \Delta \text{CDF} < 1 \times 10^{-4}$
$\Delta\text{CDF} \geq 1 \times 10^{-4}$

Application Example 1: The Event



- August 23: 5.8 Magnitude (11 miles) at shallow depth.
- Reactor trip & LOOP. All four EDGs (1H, 1J & 2H, 2J) start/loaded.
- Coolant leak observed on Unit 2 EDG “2H”. SBO EDG start/loaded.
- After identifying leak, EDG 2H was repaired and made available (6 hrs)


Application Example 1: The Failure



Fairbanks Morse
Diesel Generators
(Model 38TD8-1/8)

Example 1: The Root Cause


- Root cause evaluation on EDG gaskets found evidence of:
 - gasket to gasket inconsistencies in compression,
 - clear indications that failed gasket had been in the process of moving toward failure for some time,
 - failure most likely due to initial installation problems leading to movement over time.



Example 1: The Performance Deficiency

- Self-revealing, Apparent Violation (AV): failure to establish and maintain EDG maintenance procedures as required by Regulatory Guide 1.33, Appendix A, Section 9, Procedures for Performing Maintenance.
- Contrary to the above, from June 2, 2010 until August 23, 2011, the licensee failed to establish and maintain adequate EDG maintenance procedures.
- Procedure did not provide adequate guidance for installation of the gasket which resulted in the failure of EDG 2H to perform its safety function on August 23, 2011.

Example 1: Exposure Time



Example 1: The Evaluation

- Licensee
 - Exposure Time
 - 28 days based on root cause evaluation findings
 - Common Cause
 - Should be treated as independent failure with nominal common cause
 - Credit for various probabilities
 - Additional credit for operator actions
 - Lower values for component probabilities & common cause
 - Additional credit for recovery curves

- NRC
 - Exposure Time
 - 10 months based on root cause evaluation findings
 - Common Cause
 - Should be treated as a failure with potential for common cause to other EDGs
 - Credit for various probabilities
 - Limited additional credit for operator actions
 - Lower values for component probabilities & common cause not justified
 - Additional credit for recovery curves does not affect results

Example 1: The Outcome


- Example 1
 - Final SDP:
 - White (Unit 1) & White (Unit 2), i.e., low to moderate safety significance (internal and external events)
 - Factors
 - Exposure Time & Common Cause
 - Multiple redundant sources of emergency AC power




Application Example 2: The Inspection Finding

- Improper maintenance of ECCS recirculation line valve(s)
 - Key PRA/SDP aspects
 - Importance of valve in different LOCA scenarios
 - Potential for common cause failure of redundant valve
 - Potential for human action to open valve

Example 2: ECCS recirculation line valve fails to open



Example 2a: ECCS recirculation line valve fails to open



Example 2a: The Evaluation

- Licensee

- Low head safety injection pump would
 - be started with Valve B indicating dual position
- Valve B has a moderate probability of being restored
 - success probability of local manual actions
- Valve A has
 - low random failure probability
 - no increased probability of common cause failure


- NRC

- Low head safety inject pump would
 - Not be started with Valve B indicating dual position
- Valve B has a low probability of being restored
 - success probability of local manual actions
- Valve A has
 - low random failure probability
 - increased probability of common cause failure

Example 2a: The Outcome

- Example 2a
 - Final SDP:
 - Substantive safety significance
 - Yellow
 - Factors
 - Time frame for required operation
 - Low recovery probability of first valve
 - Common cause failure probability of second valve

Example 2b: ECCS recirculation line valve fails to open



Example 2b: The Evaluation

• Licensee

- Recovery for operation of Valve A and B for Medium LOCAs should be credited
 - Adequate time is available to perform recovery actions
- Valve B has a moderate probability of being restored
 - success probability of local manual actions
- Valve A has
 - low random failure probability
 - no increased probability of common cause failure

• NRC

- No recovery for operation of Valve A or B Medium LOCAs should be credited
 - Adequate time is not available to perform recovery actions
- Valve B has a low probability of being restored
 - success probability of local manual actions
- Valve A has
 - random failure probability
 - Increased probability of common cause failure

Example 2b: The Outcome

- **Example 2b**
 - **Final SDP**
 - Low to moderate safety significance
 - White
 - **Factors**
 - Time frame for required operation (timing of RWST drain down and depletion)
 - Low recovery probability of first valve
 - Moderate common cause failure probability of second valve

SUMMARY

- The objective of the significance determination process is to characterize the safety or security significance of inspection findings, using best available risk insights, as appropriate.
- NRC staff perform these evaluations, providing licensee opportunities to provide perspectives.
- SDP evaluations illustrate the importance of having realistic, current PRAs.

The End

Questions & Answers.....

RISK-INFORMED REGULATION SEMINAR
Mexico City, Mexico August 27-31, 2012