

Appendix G Limits on Normal Operations



- **Information needed**
 - PWR heatup and cooldown
 - Need parameterized spectrum of transients
 - BWR heatup and cooldown
 - Not sure, probably the same as for PWRs
 - BWR leak test
 - Need information on actual leak test practices
- **Is this an immediate safety issue?**
 - Shallow flaws: probably not (pending JCO outcome)
 - Leak test: some BWRs may need to raise their leak test temperature
- **Longer term**
 - Technical
 - Shallow flaws: information needed so that PT limits can be efficaciously restricted to be consistent with a 10^{-6} risk limit
 - Leak test: require T_{LEAK} to exceed RT_{NDT} by some margin (≈ 60 °F?)
 - Meetings & bureaucratic
 - Public meeting at NRC on 28th August (afternoon) to discuss
 - Working on modifying NRC/EPRI MoU to include this topic