



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

September 18, 2012

LICENSEE: Union Electric Company
FACILITY: Callaway Plant, Unit 1
SUBJECT: SUMMARY OF AUGUST 29, 2012, PRE-APPLICATION MEETING WITH UNION ELECTRIC COMPANY TO ADD A NEW TECHNICAL SPECIFICATION FOR THE CLASS 1E ELECTRICAL EQUIPMENT AIR CONDITIONING SYSTEM (TAC NO. ME9233)

On August 29, 2012, a Category 1 public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of Union Electric Company (the licensee) at NRC Headquarters, One White Flint North, 11555 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to discuss the licensee's planned submittal of an amendment request for Callaway Plant, Unit 1, for a new Technical Specification (TS) to provide operability and surveillance requirements for the Class 1E electrical equipment air conditioning system. The meeting notice and agenda are located in the Agencywide Documents Access and Management System (ADAMS) at Accession No. ML12227A347.

The licensee presented information on the background and content of the proposed request (ADAMS Accession No. ML12241A292). The licensee described its proposed TS for the Class 1E electrical equipment air conditioning system.

The NRC staff queried the licensee about several aspects of the proposed changes and provided comments for consideration by the licensee in developing its submittal. The licensee's staff acknowledged the NRC staff's questions and comments and stated that they would be considered as the licensee continues to prepare its submittal. Several representatives from other utilities were in attendance or participated by telephone. Industry and NRC staff participating in the meeting recognized the challenges raised by the underlying issues that the new TSs propose to address, but acknowledged that a generic solution has not yet been determined. No regulatory decisions were made at the meeting.

No Public Meeting Feedback forms were received.

- 2 -

Please direct any inquiries to me at 301-415-2296, or Fred.Lyon@nrc.gov.

Carl F. Lyon, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

LIST OF ATTENDEES

AUGUST 29, 2012, PRE-APPLICATION MEETING WITH UNION ELECTRIC COMPANY

TO ADD A NEW TECHNICAL SPECIFICATION FOR

THE CLASS 1E ELECTRICAL EQUIPMENT AIR CONDITIONING SYSTEM

CALLAWAY PLANT, UNIT 1

LICENSEE

S. Maglio
J. Little
R. Andreasen
M. Smith
B. Yates
T. Elwood

NRC

M. Markley
R. Mathew
J. Andersen
H. Walker
K. Scales
S. Som
M. Hamm
G. Armstrong*
F. Lyon

OTHERS

L. Parker, STARS Alliance
T. Weber, Arizona Public Service Company (Palo Verde)
D. Bice, Entergy (ANO)
S. Wideman, Wolf Creek Nuclear Operating Company*
D. Buschbaum, STARS Alliance*
L. Conklin, San Onofre Nuclear Generating Station*
F. Mowasat, San Onofre Nuclear Generating Station*
J. Morris, South Texas Project Nuclear Operating Company*

*by telephone

Enclosure

Please direct any inquiries to me at 301-415-2296, or Fred.Lyon@nrc.gov.

/RA/

Carl F. Lyon, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-483

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC	RidsNrrPMCallaway Resource
LPL4 Reading	RidsOgcRp Resource
RidsAcrcAcnw_MailCTR Resource	RidsRgn4MailCenter Resource
RidsNrrDeEeeb Resource	MHamm, NRR/DSS/STSB
RidsNrrDorl Resource	KScalcs, NRR/DE/EEEE
RidsNrrDorlLpl4 Resource	RMathew, NRR/DE/EEEE
RidsNrrDssSbpb Resource	HWalker, NRR/DSS/SCVB
RidsNrrDssScvb Resource	SSom, NRR/DE/EEEE
RidsNrrDssStsb Resource	GArmstrong, NRR/DSS/SBPB
RidsNrrLAJBurkhardt Resource	SKennedy, EDO RIV

ADAMS Accession Nos. Meeting Notice ML12227A347, Meeting Summary ML12243A392,
Handouts ML12241A292 *via email

OFFICE	DORL/LPL4/PM	DORL/LPL4/LA	DORL/LPL4/BC	DORL/LPL4/PM
NAME	FLyon	JBurkhardt*	MMarkley	FLyon
DATE	9/13/18	9/13/12	9/14/12	9/18/12

OFFICIAL RECORD COPY