

US-APWR Sump Strainer Downstream Effects

Non-Proprietary Version

August 2012

**© 2012 Mitsubishi Heavy Industries, Ltd.
All Rights Reserved**

Revision History

Revision	Page	Description
0	All	Original issued
1	3-5	Changed Equipment Number to be consistent with the latest DCD.
	3-11	Changed valve size and valve number to be consistent with the latest DCD. Editorial correction.
	3-13	Editorial correction.
	3-14	Changed valve size to be consistent with the latest DCD.
	3-25	Correction of reference document number of "GL 2004-02".
	3-26	Changed Equipment Number, valve size and valve number to be consistent with the latest DCD.
	3-28	Added a note "**** Conservative value is assumed in this evaluation"
	4.1-1	Reflection of RAI discussion (04.04-36 and 04.04-37) in UAP-HF-10066 to correct an inaccuracy in the statement. The report of the core inlet blockage test is referred additionally. Editorial correction.
	4.1-6	Change the reference related to response to RAI (question No. 04.04-22 in Appendix G of this report).
	4.1-6	Editorial changes for appropriate explanation.
	4.1-6	Delete a reference for appropriate explanation.
	4.1-27	Correction of titles of figure and vertical axis in Figure 4.1.2-16 to reflect RAI response (04.04-39) in UAP-HF-10066.
	4.1-28	Correction of titles of figure and vertical axis in Figure 4.1.2-17 to reflect RAI response (04.04-39) in UAP-HF-10066.
	4.1-28	Correction of title of figure in Figure 4.1.2-18 to reflect RAI response (04.04-39) in UAP-HF-10066.
	4.1-31	Correction of title of figure in Figure 4.1.2-23 to reflect RAI response (04.04-39) in UAP-HF-10066.
4.1-31	Correction of title of figure in Figure 4.1.2-24 to reflect RAI response (04.04-39) in UAP-HF-10066.	

	4.1-32	Correction of title of figure in Figure 4.1.2-25 to reflect RAI response (04.04-39) in UAP-HF-10066.
	4.1-32	Correction of title of figure in Figure 4.1.2-26 to reflect RAI response (04.04-39) in UAP-HF-10066.
	4.2-1	Reflection of RAI discussion (04.04-36 and 04.04-37) in UAP-HF-10066 to correct an inaccuracy in the statement. The report of the core inlet blockage test is referred additionally. Editorial correction.
	4.2-1	Delete a reference because it is not necessary in this statement.
	4.2-3	Delete a reference because it is not necessary in this statement. Change the reference number due to deletion the previous one.
	4.2-4	Editorial correction.
	4.2-8	Change the reference number due to deletion the previous one.
	4.4-5	Add description according to issuance of MUAP-10021
	6-1, 6-2	Update revision of Reference 3-8 through 3-11
	6-2	Delete reference 4.1-2 related to response to RAI (question No. 04.04-22 in Appendix G of this report).
	6-3	Delete a reference because it is not necessary. Change the reference number due to deletion the previous one.
	D-2	Basis of determination of bypass debris quantity was changed according to Appendix-C of MUAP-10021 R0.
	D-2	Table D-1, Incorporate further reducing debris sources (i.e., fiber insulation) to minimize fiber insulation debris in containment.
	D-2	Table D-1, Change latent particle debris quantity. (Typo.)
	D-2	Change total volume of bypass debris due to the change of Table D-1.
	D-2	Change the reference document due to the change of D.1.
	E-5	Correct the position of water volume of 80 m ³ . (Editorial correction.)
	E-6	Update revision of Reference E-1.
	G-1 – G-71	Add response to RAI (UAP-HF-10066)
2	ii	Editorial correction. “accord” changed to “accordance”

iii	<p>Editorial correction. Capitalization. "inputs" changed to "Inputs"</p> <p>Editorial correction. "ECC and CSS System Flows and Flow Velocities" changed to "ECC and CSS Flows and Flow Velocities"</p> <p>Editorial correction. "Design/ Procurement" changed to "Design / Procurement"</p> <p>Editorial correction. (Typo.) "Affects" changed to "Effects"</p>
iv	<p>Sections 4.1.1 and 4.1.2 were removed because the content of these sections was replaced by MUAP-11022 "US-APWR Core Inlet Blockage Additional Test".</p> <p>Editorial correction. Capitalization. "In-core" changed to "In-Core"</p> <p>Appendix-G was changed "RAI set" to "Boundary Conditions for Cladding Surface Temperature Evaluation"</p> <p>Add appendices H, I and J.</p>
v	<p>Tables 4.1.2-1 through 4.1.2-4, were moved to Appendix-G.</p>
vi	<p>Editorial correction. Capitalization. "flow diagram" changed to "Flow Diagram"</p> <p>Figures 4.1.2-1 through 4.1.2-26, were moved to Appendix-G and Figures 4.1.2-9, 10 and Figures 4.1.2-13 through 4.1.2-26 were deleted because they are not necessary.</p> <p>Editorial correction. Capitalization. "estimation method" changed to "Estimation Method"</p> <p>Editorial correction. Capitalization. "concentrations trend at core inlet" changed to "Concentrations Trend at Core Inlet"</p> <p>Editorial correction. Capitalization. "LOCA scale thickness and fuel cladding temperature" changed to "LOCA Scale Thickness and Fuel Cladding Temperature"</p>
vii	<p>Editorial correction. Capitalization. "containment spray system" changed to "Containment Spray System"</p>
viii	<p>Editorial correction. (Typo.) "S-singal" changed to "S-signal"</p> <p>Editorial correction. Space in. "US.NRC" changed to "US. NRC"</p>
1-3	<p>Editorial correction. "Topical" changed to "Topical Report"</p>
3-1	<p>Editorial correction. "3. " changed to "3.0"</p>
3-4	<p>Editorial correction. Capitalization. "inputs" changed to "Inputs"</p>
3-7	<p>Editorial correction. "ECC and CSS System Flows and Flow Velocities" changed to "ECC and CSS Flows and Flow Velocities"</p>
3-16	<p>Editorial correction. "Design/ Procurement" changed to "Design / Procurement"</p>
3-18	<p>Editorial correction. (Typo.) "Affects" changed to "Effects"</p>
3-27	<p>Editorial changes for appropriate clarification. All values of Brinell Hardness were changed.</p>
3-28	<p>Editorial correction. Add unit "lbm/ft³" for material density of Debris Type RMI.</p> <p>Debris Quantity of Nukon and Epoxy Coating debris was</p>

	changed. Editorial correction. Delete "***" on Latent Particle Fabricated Density because it is not necessary.
3-29	Table is revised due to the amount of Nukon and Epoxy Coating debris was changed.
3-30	Editorial changes for appropriate clarification.
3-31	Editorial changes for appropriate clarification.
3-32	Table is revised due to debris quantity change.
3-33	Editorial changes for appropriate clarification.
3-37	Editorial correction. Capitalization. "flow diagram" changed to "Flow Diagram"
4.1-1 - 4.1-2	Editorial changes for appropriate clarification. Referencing was changed Ref. 4.1-4 to Ref. 4.1-5.
4.1-3 – 4.1-33	Moved to Appendix-G because the purpose of the analysis described in this section was changed to preparation of boundary conditions for the analysis performed in section 4.2.
4.2-1	Referencing was changed Ref. 4.1-4 to Ref. 4.1-5. Because section 4.1 was changed to Appendix-G, referencing was changed accordingly.
4.2-2	Because section 4.1 was changed to Appendix-G, referencing was changed accordingly.
4.2-8	Editorial changes for appropriate clarification. Referencing was changed Ref. 4.1-4 to Ref. 4.1-5.
4.3-1	Editorial changes for appropriate clarification. Referencing was changed Ref. 4.1-4 to Ref. 4.1-5.
4.3-8	Editorial correction. Capitalization. "estimation method" changed to "Estimation Method"
4.3-10	Editorial correction. Capitalization. "concentrations trend at core inlet" changed to "Concentrations Trend at Core Inlet"
4.3-11	Editorial correction. Capitalization. "LOCA scale thickness and fuel cladding temperature" changed to "LOCA Scale Thickness and Fuel Cladding Temperature"
4.4-1	Editorial correction. Capitalization. "In-core" changed to "In-Core"
4.4-2	Editorial changes for appropriate explanation. Referencing was changed Ref. 4.1-4 to Ref. 4.1-5 Because section 4.1 was changed to Appendix-G, referencing was changed accordingly.
4.4-4	Editorial correction. (Typo.)
4.4-5	Referencing was changed Ref. 4.1-4 to Ref. 4.1-5

	4.5-2	Because section 4.1 was changed to Appendix-G, referencing was changed accordingly.
	5-1	Editorial correction. (Typo.)
	6-1 – 6-3	Update revision of Reference 3-8 through 3-12. Delete references 4.1-1 through 4.1-4 because it is not necessary. Add reference 4.1-5, Core Inlet Blockage Additional Test report.
	D-2 – D-3	D.1 title and the contents were overall revised reflecting strainer bypass test results and employment of core bypass method. Reference document was changed due to the contents change.
	E-2	Because section 4.1 was changed to Appendix-G, referencing was changed accordingly.
	E-4 – E-6	Revised water volume due to design change. Revised Figure E-1 due to water volume change. Revised reference document revision.
	G-1 – G-71	Delete response to RAI
	G-1 – G-22	Add Boundary Conditions for Cladding Surface Temperature Evaluation
	H-1 – H-12	Add Conservatism Applied to HL Break Test and HLSO Test Flow Rate Conditions
	I-1 – I-4	Add Methodology for Estimate of Debris Load in Cold-leg Break LOCA
	J-1 – J-8	Add Fibrous Debris Sump Strainer Bypass Amount.
3	6-2 – 6-3	Updated revision of references 3-12 and 3-14. Title of reference 4.1-5 was changed (Editorial correction) from “US-APWR Core Inlet Blockage Additional Test” to “US-APWR Additional Core Inlet Blockage Test”. Added the issue date of reference 4.1-5.
	D-2	Revised description about sump strainer bypass amount. (No technical changes were made)
	D-3	Revised chemical debris amount in Table D-2 reflecting design change of recirculation water flow path.
	E-2 – E-9	Overall revision reflecting design change of recirculation water flow path.
	H-9	Title of reference H-1 was changed (Editorial correction) from “US-APWR Core Inlet Blockage Additional Test” to “US-APWR Additional Core Inlet Blockage Test”. Added the issue date of reference H-1.
4	3-6	Added description regarding water for evaluation.
	3-11	Added description regarding valve qualification.

	3-16	Added description regarding ECCS pump qualification.
	3-16	Added description regarding CS/RHR pump qualification.
	3-29	Editorial correction regarding characteristic size of Table 3.2-3.
	3-30	Added PPM column
	6-2, 6-3	Changed Reference 4.1-5 document to the latest test results.
	A-2	Revised NPSH information, fluid constituent and seal information
	B-2	Revised NPSH information, fluid constituent and seal information
	H-9	Changed Reference H-1 document to the latest test results.

© 2012
MITSUBISHI HEAVY INDUSTRIES, LTD.
All Rights Reserved

This document has been prepared by Mitsubishi Heavy Industries, Ltd. (“MHI”) in connection with the U.S. Nuclear Regulatory Commission’s (“NRC”) licensing review of MHI’s US-APWR nuclear power plant design. No right to disclose, use or copy any of the information in this document, other than by the NRC and its contractors in support of the licensing review of the US-APWR, is authorized without the express written permission of MHI.

This document contains technology information and intellectual property relating to the US-APWR and it is delivered to the NRC on the express condition that it not be disclosed, copied or reproduced in whole or in part, or used for the benefit of anyone other than MHI without the express written permission of MHI, except as set forth in the previous paragraph. This document is protected by the laws of Japan, U.S. copyright law, international treaties and conventions, and the applicable laws of any country where it is being used.

Mitsubishi Heavy Industries, Ltd.
16-5, Konan 2-chome, Minato-ku
Tokyo 108-8215 Japan

Abstract

The intent of this technical report is to assess the US-APWR systems and components downstream of the containment sump strainers to ensure that these systems and components will operate as designed under post Loss-of Coolant Accident Conditions (LOCA).

Downstream systems and components include the Emergency Core Cooling System (ECCS), Containment Spray System (CSS) and the reactor core. This report evaluates the effects of operating with debris-laden, post-LOCA fluid.

This review incorporates the lessons learned as part of the USNRC Generic Safety Issue 191 (GSI-191) and addresses the component and system related concerns identified in Generic Letter (GL) 2002-04. This report has been prepared in accordance with NEI 04-07 and published USNRC staff expectations. The report meets the intent of WCAP-16793-NP, Evaluation of Long-Term Cooling Considering Particulate, Fibrous and Chemical Debris in the Recirculating Fluid. Information and guidance used has been extracted from the noted references and adapted to the US-APWR design.

This technical report is divided into two (2) subject areas: Ex-Vessel and In-Vessel Evaluations.

This report concludes that the US-APWR Emergency Core Cooling System, Containment Spray System and their components are fully capable of performing their intended functions under post-LOCA operating conditions. The ECCS and CSS are fully capable of providing adequate core cooling to ensure the reactor core is maintained in a safe, stable condition following a Loss-of-Coolant Accident (LOCA).

The report concludes that debris-laden post-LOCA fluid will not plug or block the reactor core such that cooling flow is reduced below the required flow to maintain the core in a long-term coolable geometry. The report also shows that chemical induced local blockages or scale formation on the fuel cladding surface on reactor fuel and cladding will not affect the ability to provide adequate decay heat removal. Cladding temperatures are maintained below those required by Section 50.46 of Title 10 of the Code of Federal Regulations (10 CFR).

Table of Contents

1.0	INTRODUCTION	1-1
2.0	OBJECTIVE	2-1
3.0	EX-VESSEL DOWNSTREAM EFFECTS	3-1
3.1	System Descriptions	3-1
3.1.1	Emergency Core Cooling System	3-1
3.1.2	Containment Spray System	3-2
3.2	Design Inputs / Evaluation Assumptions	3-4
3.2.1	LOCA Scenarios	3-4
3.2.2	Mission Time	3-5
3.2.3	Component List	3-6
3.2.4	Post-LOCA Fluid Constituents	3-6
3.2.5	ECC and CSS Flows and Flow Velocities	3-7
3.2.6	Summary of Analysis Conservatisms	3-8
3.3	Piping, Valve and Heat Exchanger Evaluations	3-9
3.3.1	Wear Rate Evaluation Summary	3-9
3.3.2	Heat Exchanger Evaluation	3-9
3.3.3	Valve Wear Evaluation	3-11
3.3.4	Piping and Valve Blockage and Debris Settling Evaluation	3-12
3.3.5	Instrument Clogging Evaluation	3-14
3.3.6	Chemical Effects Evaluation	3-15
3.4	ECCS and CSS Pump Evaluations	3-16
3.4.1	Review of Design / Procurement Specification(s)	3-16
3.4.2	Effects of Air Entrainment	3-18
3.4.3	Seal Leakage	3-19
3.4.4	Chemical Effects Evaluation	3-19
3.5	ECCS and CSS Performance Evaluations	3-20
3.5.1	ECCS Performance Evaluation	3-20
3.5.2	CSS Performance Evaluation	3-20
3.6	Regulatory Summary	3-22
3.7	Confirmation Items	3-24
3.8	Summary of Results	3-25

4.0	IN-VESSEL DOWNSTREAM EFFECTS	4.1-1
4.1	Blockage at the Core Inlet	4.1-1
4.2	Trapping Debris in Fuel Assemblies	4.2-1
4.2.1	Trapping Debris at Grid Spacer	4.2-1
4.2.2	Trapping Debris on Cladding Surface	4.2-8
4.3	Chemical Effects on Fuel Rods	4.3-1
4.3.1	Chemical Deposition on the Cladding	4.3-3
4.4	In-Core Effects	4.4-1
4.4.1	Chemical Effect on Boric Acid Precipitation Evaluation	4.4-1
4.4.2	Fuel Swelling and Blockage	4.4-4
4.4.3	Hot Leg Injection	4.4-5
4.5	Regulatory Summary (In-Vessel)	4.5-1
5.0	CONCLUSIONS	5-1
6.0	REFERENCES	6-1
Appendix A	ECC/CS Strainer / Safety Injection Pump Engineering Design Parameters	Appendix A-1
Appendix B	Containment Spray / Residual Heat Removal Pump Containment Spray / Residual Heat Exchanger Engineering Design Parameters	Appendix B-1
Appendix C	Long-Term Core Cooling Acceptance Basis For GSI-191	Appendix C-1
Appendix D	Volume of Debris for In-Vessel Downstream Effects Evaluation	Appendix D-1
Appendix E	In-Vessel Downstream Effects Evaluation Time	Appendix E-1
Appendix F	Confirmation of Calculation of Deposit Process by the Evaluation Tool	Appendix F-1
Appendix G	Boundary Conditions for Cladding Surface Temperature Evaluation	Appendix G-1
Appendix H	Conservatism Applied to HL Break Test and HLSO Test Flow Rate Conditions	Appendix H-1
Appendix I	Methodology for Estimate of Debris Load in Cold-leg Break LOCA	Appendix I-1
Appendix J	Fibrous Debris Sump Strainer Bypass Amount	Appendix J-1

List of Tables

Table 3.2-1	Components in the Flow Path during a LBLOCA	3-26
Table 3.2-2	Material Hardness Data	3-27
Table 3.2-3	Debris Source Term	3-28
Table 3.2-4	Debris Concentration Components	3-29
Table 3.2-5	Material Wear Rates	3-30
Table 3.2-6	Affected Equipment / Flow Rates	3-31
Table 3.3-1	ECCS and CSS Components Wear vs. Time	3-32
Table 3.3-2	ECCS and CSS Settling Velocities	3-33
Table 3.6-1	Ex-Vessel Downstream Effects Regulatory Review	3-34
Table 4.2.1-1	Cladding Metal Surface Temp. vs Debris Thickness	4.2-5
Table 4.5-1	In-Vessel Downstream Effects Regulatory Review	4.5-2

List of Figures

Figure 3.1-1	Schematic Flow Diagram of ECCS/CSS	3-37
Figure 4.2.1-1	Mitsubishi Grid Spacer (Z3 Type) Schematic View	4.2-6
Figure 4.2.1-2	Schematic Drawing of the Analysis Model	4.2-6
Figure 4.2.1-3	Heat Flux on the Hot Rod at 850 seconds after LOCA Event	4.2-7
Figure 4.2.1-4	Cladding Metal Surface Temp. vs Debris Thickness	4.2-7
Figure 4.3.1-1	Schematic Model	4.3-5
Figure 4.3.1-2	Temperature Estimation Method	4.3-8
Figure 4.3.1-3	Impurity Concentrations Trend at Core Inlet	4.3-10
Figure.4.3.1-4	LOCA Scale Thickness and Fuel Cladding Temperature	4.3-11

List of Acronyms

Al	Aluminum
APWR	Advanced Pressurized Water Reactor
BWG	British Wire Guage
Ca	Calcium
CSS	Containment Spray System
CVCS	Chemical and Volume Control System
DBA	Design Basis Accident
DCD	Design Control Document
DHR	Decay Heat Removal
DVI	Direct Vessel Injection
ECCS	Emergency Core Cooling System
ECC/CS	Emergency Core Cooling and Containment Spray
ESF	Engineered Safety Features
GL	Generic Letter
GSi	Generic Safety Issue
HHIS	High Head Injection System
HVAC	Heating, Ventilating and Air Conditioning
ICET	Integrated Chemical Effects Testing
LBLOCA	Large Break Loss of Coolant Accident
LOCA	Loss of Coolant Accident
LTCC	Long-term Core Cooling
MCR	Main Control Room
MHI	Mitsubishi Heavy Industries, Ltd.
NaTB	Sodium Tetra Borate, decahydrates $\text{Na}_2\text{B}_4\text{O}_7 \cdot 10\text{H}_2\text{O}$
NEI	Nuclear Energy Institute
NPSH	Net Positive Suction Head
NRC	Nuclear Regulatory Commission
PCT	Peak Cladding Temperature
PWR	Pressurized Water Reactor
PWROG	Pressurized Water Reactor Owners Group
RCS	Reactor Coolant System
RHR	Residual Heat Removal

RMI	Reflective Metal Insulation
RWSP	Refueling Water Storage Pit
SBLOCA	Small Break Loss of Coolant Accident
S-signal	Safety Injection Signal
SI	Safety Injection
Si	Silicon
SIS	Safety Injection System
US-APWR	U.S. Advanced Pressurized Water Reactor
US. NRC	US. Nuclear Regulatory Commission
ZOI	Zone of Influence

1.0 INTRODUCTION

Generic Letter (GL) 2004-02, Potential Impact of Debris Blockage on Emergency Recirculation during Design Basis Accidents at Pressurized Water Reactors (Ref. 3-1) was issued by the USNRC requesting holders of operating reactor licenses to evaluate their emergency core cooling system (ECCS) and containment spray system (CSS) recirculation functions in light of events regarding the blockage of containment sump strainers. The GL notes that:

“Debris could also plug or wear close-tolerance components within the ECCS or CSS systems. This plugging or wear might cause a component to degrade to the point where it could not perform its designated function (i.e., pump fluid, maintain system pressure, or pass and control system flow.)

...Third, debris blockage at flow restrictions within the ECCS recirculation flowpath downstream of the sump screen is a potential concern for PWRs. Debris that is capable of passing through the recirculation sump screen may have the potential to become lodged at a downstream flow restriction, such as a high-pressure safety injection (HPSI) throttle valve or fuel assembly inlet debris screen. Debris blockage at such flow restrictions in the ECCS flow-path could impede or prevent the recirculation of coolant to the reactor core, thereby leading to inadequate core cooling. Similarly, debris blockage at flow restrictions in the CSS flowpath, such as a containment spray nozzle, could impede or prevent CSS recirculation, thereby leading to inadequate containment heat removal. Debris may also accumulate in close-tolerance subcomponents of pumps and valves. The effect may be either to plug the subcomponent, thereby rendering the component unable to perform its function, or to wear critical close tolerance subcomponents to the point at which component or system operation is degraded and unable to fully perform its function. Considering the recirculation sump screen’s design function of intercepting potentially harmful debris, it is essential that the screen openings be adequately sized and that the sump screen’s current configuration be free of gaps or breaches which could compromise the ECCS and CSS recirculation functions. It is also essential that system components be designed and evaluated to be able to operate as necessary with debris laden fluid post-LOCA”

The GL requested the following specific information be provided.

“(v) The basis for concluding that inadequate core or containment cooling would not result

due to debris blockage at flow restrictions in the ECCS and CSS flowpaths downstream of the sump screen, (e.g., a HPSI throttle valve, pump bearings and seals, fuel assembly inlet debris screen, or containment spray nozzles). The discussion should consider the adequacy of the sump screen's mesh spacing and state the basis for concluding that adverse gaps or breaches are not present on the screen surface.

(vi) Verification that close-tolerance subcomponents in pumps, valves and other ECCS and CSS components are not susceptible to plugging or excessive wear due to extended post-accident operation with debris-laden fluids”

In response to the GL, the Nuclear Energy Institute, NEI, issued Guidance Report NEI 04-07 (Ref. 3-16) delineating a generic, consistent approach to address the NRC concerns identified in GL 2004-02. The USNRC, in turn, issued a Safety Evaluation clarifying those items to be addressed and endorsing an approach that would be acceptable to the USNRC staff (Ref. 3-2). With respect to downstream effects, the SE states:

1. Licensees should consider that some particles larger than the flow openings in a sump screen will deform and flow through or orient axially and flow through the screen, and determine what percentage of debris would likely pass through the sump screen and be available for blockage at downstream locations.
2. Licensees should consider term of system operating lineup (short or long), conditions of operation, and mission times.
3. Licensees should consider wear and abrasion of pumps and rotating equipment, piping, spray nozzles, instrumentation tubing, and HPSI throttle valves. The potential for wear to alter system flow distribution and/or form plating of slurry materials (in heat exchangers) should be included.
4. An overall ECC or CS system evaluation should be performed considering the potential for reduced pump/system capacity resulting from internal bypass leakage or through external leakage.
5. Licensees should consider flow blockage associated with core grid supports, mixing vanes, and debris filter, and its effect on fuel rod temperature.

And that "... licensees should address chemical effects on a plant-specific basis."

For Ex-Vessel evaluations, the USNRC further clarified specific areas to be addressed with the issuance of an NRC letter entitled "Audit Plan for Verifying the Adequacy of Licensee Responses to Generic Letter 2004-02" (Ref. 3-3). This audit plan was intended to fully address the USNRC concerns identified in Reference 3-2, Final Safety Evaluation for NEI Guidance Report 04-07, regarding the evaluation of ex-vessel components downstream of the containment sump during post-LOCA operation. There are no other regulatory guidance documents that specifically pertain to the evaluation of ex-vessel downstream components. Therefore, addressing the issues identified in the "Audit Guidelines" fully addresses the concerns identified in the GL.

USNRC accepted guidelines and methods for the evaluation the reactor vessel and fuel will be contained in Topical Report TR-WCAP-16793-NP, Evaluation of Long-Term Cooling Considering Particulate, Fibrous and Chemical Debris in the Recirculating Fluid. The USNRC has not yet fully reviewed Topical Report (TR) WCAP-16793-NP, REVISION 1. Once the USNRC has issued their Safety Evaluation on the Topical Report, MHI will review this report and revise it as needed.

This technical report fully meets the intent of and addresses the technical concerns and considerations identified in the current USNRC guidance documents.

2.0 OBJECTIVE

The objective of ex-vessel downstream effects evaluation is to assess the US-APWR Emergency Core Cooling system (ECCS) and Containment Spray System (CSS) to ensure that these systems and their components will operate as designed under post Loss-of Coolant Accident Conditions (LOCA).

The objective of in-vessel downstream effects evaluation is to provide that long-term core cooling (LTCC) would be established and maintained properly during post-LOCA considering the presence of debris in the recirculating coolant delivered to the RCS and core and would be achieved to satisfy the requirements of 10 CFR 50.46 for the US-APWR plant.

3.0 EX-VESSEL DOWNSTREAM EFFECTS

3.1 System Descriptions

The US-APWR engineered safety features (ESF) includes an Emergency Core Cooling System (ECCS) / Safety Injection System (SIS) and a Containment Spray System (CSS). The ECCS is automatically initiated by a safety injection signal (S-signal) and the CSS is automatically initiated by a containment spray signal. Both systems take suction from refueling water storage pit (RWSP). Four ECC/CS strainers are installed in the RWSP; one for each of the four ECC/CS trains. These systems include an accumulator system, pumps, valves, heat exchangers, piping, fittings and other components. These systems and components may be affected by debris that passes through the containment sump strainer during recirculation following a LOCA.

Figure 3.1-1 shows a schematic flow diagram of the ECCS and CSS.

3.1.1 Emergency Core Cooling System

The primary function of the ECCS is to remove stored and fission product decay heat from the reactor core following an accident. The ECCS is designed to meet the acceptance criteria of 10CFR50.46(b).

In meeting 10CFR50.46(b), the ECCS is designed to perform the following major safety-related functions:

- Provides safety Injection flow to the reactor core following a LOCA
- Maintains the reactor in a safe shutdown condition
- Assists in maintaining pH control of the post-LOCA fluid.

The US-APWR ECCS consists of an accumulator system, a high head injection system (HHIS) and an emergency letdown system. The ECCS injects borated water into the RCS following a postulated LOCA to cool the reactor core to prevent damage to the fuel cladding, and to limit the fuel cladding zirconium-water reaction. The accumulator and emergency letdown systems are not active during post-LOCA long-term operation. Therefore, for the purpose of this report, only the HHIS will be discussed.

The HHIS consists of four independent safety trains, each designed as a 50% capacity train. Each train includes a safety injection (SI) pump suction isolation valve, a dedicated, 50% capacity SI pump, a safety injection pump discharge containment isolation valve, a direct vessel safety injection line isolation valve, and a hot leg injection isolation valve. The SI pumps are aligned to take suction from the RWSP and deliver borated water directly to the reactor vessel downcomer. The RWSP is located within the lowest portion of the containment vessel and collects the water from the postulated break and from the containment spray wash down. The RWSP provides a continuous borated water source for the SI pumps, thus avoiding the need to switch the pump suction from a storage water tank to the containment recirculation sump.

The SI pumps are automatically initiated on an S-signal and supply borated water (at approximately 4,000 ppm boron) from the RWSP to the reactor vessel through direct vessel injection (DVI) lines.

The HHIS is realigned to shift the RCS injection from the DVI line to the hot leg injection line after a LOCA in order to prevent boron precipitation. Therefore, both injection lines are in the flow-paths of the water through the ECC/CS strainers. Safety injection pump minimum flow lines are also in these flow-paths, and are always in use when the SI pumps are operating.

The SI pumps continue to supply borated water during long-term cooling. During long-term cooling, core temperatures are reduced to long term, steady state levels associated with the dissipation of residual heat generation. During long term cooling, the HHIS injects into both the RCS hot legs and the reactor vessel to avoid an unacceptably high concentration of boric acid (H_3BO_3) in the core. (Ref. 3-9, Section 6.3)

3.1.2 Containment Spray System

The containment spray system is a dual-function ESF system. The system provides containment spray for fission product removal and containment cooling. The system also provides residual heat removal for normal plant shutdown and refueling operations. The CSS and the Residual Heat Removal System (RHRS) share the containment spray/residual heat removal (CS/RHR) pumps, CS/RHR heat exchangers and some system piping and valves. For the purposes of this report only the specific components used during CSS operation were evaluated.

The CSS has four 50% capacity trains of containment spray, including four CS/RHR RWSP suction lines, four CS/RHR spray pumps, four CS/RHR heat exchangers, and a spray ring header. The spray rings are supplied from the four trains of containment spray.

The CSS is designed to perform the following functions:

- Provide containment spray to assist in containment heat removal.
- Provide fission product removal through atmospheric scrubbing

The CSS is designed to limit and control post-LOCA containment pressure, so that the peak containment accident pressure is kept well below the containment design pressure. With CSS operation, containment pressure is reduced to less than 50% of the peak calculated pressure during the design basis LOCA within 24 hours after the postulated accident.

Following a DBA, the containment pressure approaches atmospheric pressure. When the containment pressure is reduced sufficiently and the operator determines that containment spray is no longer required, the operator terminates containment spray. The operator closes the containment spray header isolation valves and aligns system flow through the full flow test line. The RWSP water is then recirculated and cooled. (Ref. 3-9, Subsection 6.2.2)

The CS/RHR pumps are motor-driven centrifugal pumps with mechanical seals. The pumps are sized to deliver 3,000 gpm at a discharge head of 410 ft. The 100% capacity design flow rate (two of four 50% capacity CS/RHR pumps) is based on a 15.2 gpm flow per nozzle and 348 nozzles in the ring header. The two-pump 100% flow rate is, therefore, 6,000 gpm.

The CS/RHR heat exchangers provide long term cooling by removing heat from the recirculated post-LOCA fluid. The reduced temperature of the RWSP fluid aids in the further reduction of containment pressure.

3.2 Design Inputs / Evaluation Assumptions

3.2.1 LOCA Scenarios

This report addresses ECCS and CSS operation under small-break, and large-break LOCA conditions. Figure 3.1-1 shows a schematic flow diagram of the ECCS and CSS during post-LOCA operation.

The two operational conditions during post-LOCA long-term cooling that are addressed are the maintenance of long-term decay heat removal and the potential for boric acid (H_3BO_3) precipitation. After the quenching of the core at the end of reflood phase, the ECCS supplies borated water from the RWSP to remove decay heat and to keep the core subcritical. Borated water from the RWSP is initially injected through DVI lines (reactor vessel (RV) injection mode). If left uncontrolled, boric acid (H_3BO_3) concentration in the core may increase due to boiling and reach the precipitation concentration in the case of cold leg break. Boric acid precipitation in the core could affect the core cooling. To prevent the boric acid precipitation, the operator switches over the operating DVI lines to the hot leg injection line (simultaneous RV and hot leg injection mode).

3.2.1.1 Small Break LOCA Operational Description

Refer to the simplified ECCS Piping and Instrument Drawing in Figure 3.1-1.

The small break LOCA (SBLOCA) is assumed to occur in the cold leg piping located between the outlet of the RCP and the corresponding RV inlet nozzle, as this break places the most severe performance requirement on the ECCS.

Compared with the large break, the phases of the SBLOCA prior to recovery occur over a longer time period. A SBLOCA can be divided into five phases: blowdown, natural circulation, loop seal clearance, boil-off, and core recovery. The duration of each phase depends on the break size and the performance of the ECCS.

For the purpose of this report the SBLOCA is bounded by the large break LOCA (LBLOCA), recirculation and post-LOCA long-term cooling. The ECCS flows during a SBLOCA are considerably smaller than during a LBLOCA. Also, the debris source term is expected to be

much smaller during a SBLOCA. Therefore, the SBLOCA is bounded by the conditions of the LBLOCA with respect to the evaluation of downstream components.

3.2.1.2 Large Break LOCA Operational Description

Refer to the simplified ECCS Piping and Instrument Drawing in Figure 3.1-1.

The pipe break for the LBLOCA is assumed to occur in the cold leg piping located between the outlet of the reactor coolant pump (RCP) and the corresponding RV inlet nozzle, as this break places the most severe performance requirement on the ECCS. The double-ended cold leg guillotine (DECLG) and split breaks are considered. The LBLOCA is generally divided into three phases; the blowdown phase, refill phase, and the reflood phase.

During a LBLOCA, coolant flow initially is from the four accumulators. Once, accumulator volume is depleted, flow to the core becomes dominant through the SIS. Initially flow is only through DVI. After four hours, flow is through both DVI and the hot-leg injection. The Safety Injection pumps, SIS-MPP-001A, B, C, D, take suction from the RWSP and inject directly into the reactor vessel via SIS-MOV-009A, B, C, D and SIS-MOV-011A, B, C, D or the Hot Leg via MOVs SIS-MOV-009A, B, C, D and SIS-MOV-014A, B, C, D.

The CS/RHR pumps supply the CSS. The CSS flow-path is from the discharge of a CS/RHR Pump, RHS-MPP-001A, B, C, D, through a CS/RHR Heat Exchanger, RHS-MHX-001A, B, C, D to the containment spray header. Recirculation of the post-LOCA fluid is continuous from the start of the event. The RWSP is located in lowest part of containment and is refilled as a result of flow from both the break and CSS operation.

3.2.2 Mission Time

Mission time is defined as the period for which a System, Structure or Component (SSC) is required or credited in performing its safety related function. Mission time, in this context, is not the engineering design or purchase specification operating time. It is the DCD and/or accident analysis credited time.

For the purpose of these evaluations, the mission time for the ECCS and CSS, including post-LOCA long-term operation is defined as 30 days. A 30 day mission time bounds the

descriptions and discussions contained in the US-APWR Design Control Document (DCD) Chapters 6 and 15 (Ref. 3-9 and 3-10).

The duration of the ECCS and CSS operation as indicated in the safety analysis evaluation of the Chapter 15 (Ref. 3-10) events is generally only long enough to assure that the appropriate acceptance criteria have been met and does not typically include the transition to shutdown conditions. Therefore, the event-specific discussion does not typically address long-term cooling.

3.2.3 Component List

Table 3.2-1 lists all components and flow-paths within the scope of the downstream evaluation(s). The tables are organized by LOCA Scenario and System Line-up.

Each table also includes the component materials, hardness values of all wetted surfaces (piping, orifice, heat exchanger, throttle valve plug and seat materials, etc), actual and assumed flow velocities, other information used in the piping, pump, heat exchanger and system evaluations.

Material hardness data is provided in Table 3.2-2. (Ref. 3-18)

3.2.4 Post-LOCA Fluid Constituents

The nominal diameter of the sump strainer holes is equal or less than 0.066”.

Tables 3.2-3, 4 and 5 list the constituents, quantities and properties of the post-LOCA fluid (abrasiveness, solids content and size, fiber content and size, chemical properties, etc). Table 3.1-1 of MUAP 08006-NP, Rev.1, "US-APWR Sump Debris Chemical Effect Test Plan," was used as the input for the PPM calculation in Table 3.2-4. The mass of water used for the PPM calculation was the sum of the minimum post-LOCA recirculation sump water volume (Conservatively used 43,930 ft³ at the long-term sump water temperature of 149 deg F) and the minimum reactor coolant system water volume (699,000 lbm).

This analysis assumes 100% latent debris bypass, 50% fiber bypass and 5% RMI bypass

through the containment sump strainers. The specific quantity, sizes and material properties are referenced either to the DCD Section, technical report to published data, textbook data or vendor data as appropriate.

3.2.5 ECC and CSS Flows and Flow Velocities

The range of system flow and local velocities expected within the ECC and CS piping systems is provided in tabular form in Table 3.2-6 based on LBLOCA conditions. As stated previously, SBLOCA conditions are bounded by LBLOCA due to the higher flows creating more wear and generating a greater debris load.

The US-APWR is a fixed resistance system under valve wide-open conditions. Emergency Operating Procedures do allow for operator action to throttle flow based on main control room (MCR) indication. The range of operation is therefore assumed to be from shutoff head conditions to runout conditions.

Safety Injection Pump flow is assumed to be 200 gpm for the purposes of calculating settling velocities. Flow is assumed to be 2,000 gpm for the purpose of component wear rate evaluations. Engineering design range of flow is 265 gpm at shutoff and 1,540 gpm at runout.

CS/RHR Pump flow is assumed to be 300 gpm for the purposes of calculating settling velocities. Flow is assumed to be 4,000 gpm for the purpose of component wear rate evaluations. Engineering design range of flow is 355 gpm at shutoff and 3,650 gpm at runout.

These values allow for variations during component procurement and define engineering margin for analysis.

The “as procured” Safety Injection Pump runout flow will be verified to be less than 2,000 gpm. Confirmation Item 3.7.1.

The “as procured” CS/RHR Pump runout flow will be verified to be less than 4,000 gpm. Confirmation Item 3.7.2.

Reliability of the ECCS and CSS are considered in the design, procurement, and installation/layout of components. Verification that the pumps meet the flow requirements is considered part of the COL (Ref. 3-11, Subsection 17.4.9).

3.2.6 Summary of Analysis Conservatism

This section summarizes the significant conservative assumptions contained within this evaluation. It is not intended to be all inclusive.

- 3.2.6.1 Safety Injection Pump flow is assumed to be 200 gpm for the purposes of calculating settling velocities. Flow is assumed to be 2,000 gpm for the purpose of component wear rate evaluations. Engineering design range of flow is 265 gpm at shutoff and 1,540 gpm at runout.
- 3.2.6.2 CS/RHR Pump flow is assumed to be 300 gpm for the purposes of calculating settling velocities. Flow is assumed to be 4,000 gpm for the purpose of component wear rate evaluations. Engineering design range of flow is 355 gpm at shutoff and 3,650 gpm at runout.
- 3.2.6.3 Wear is calculated from “time zero”, i.e. start of the event. Worst case fluid properties are assumed to be present. This assumption is conservative since it does not credit debris transport or the slow increase of fluid properties due to long term mixing.
- 3.2.6.4 Fluid velocity through a single CS/RHR heat exchanger tube is assumed to be 15 ft/s. A nominal design and operating heat exchanger velocity range is 3 to 10 ft/s. Therefore the use of 15 ft/s is conservative from a heat exchanger design perspective and bounds the heat exchanger design and procurement specifications.
- 3.2.6.5 This analysis assumes 100% latent debris bypass, 50% fiber bypass and 5% RMI bypass through the containment sump strainers. It is noted that these quantities are greater than those assumed in the in-vessel evaluation and are therefore conservative with respect to the overall downstream evaluation. Reference Chapter 4, In-Vessel Evaluation.

3.3 Piping, Valve and Heat Exchanger Evaluations

This section evaluates ECCS and CSS piping, valves and heat exchangers with respect to wear and blockage.

Reliability of the ECCS and CSS are considered in the design, procurement, and installation/layout of components. Verification that the materials of construction of the piping, valves and heat exchangers meet the requirements specified below is considered part of the COL (Ref. 3-11, Subsection 17.4.9).

3.3.1 Wear Rate Evaluation Summary

Table 3.3-1 contains a summary of the piping and orifice wear calculations. This calculation assumes a 3-Body (free-flowing) wear model.

Piping and component wear is tabulated for 30 day durations.

3.3.2 Heat Exchanger Evaluation

The CS/RHR heat exchangers are designed to cool the reactor coolant during RHR operation. They remove residual heat during normal shutdown, during shutdown in case of loss of external power sources and during safe shutdown. They assist in long-term cooling operation by cooling post-LOCA fluid prior to discharge through the CSS.

The CS/RHR heat exchangers are specified as shell and U-tube units. The heat exchangers are comprised of ¾" OD, BWG 18 (0.049 in.), 304 SS tubes (Ref. 3-8, Table 5.4.7-2). A single unit is provided in each of the four CSS trains.

The reactor coolant discharged from the CS/RHR pump is circulated through the tube side of the CS/RHR heat exchanger, while cooling is provided by circulating Component Cooling Water through the shell side. The tubes are welded to the tube sheet to prevent leakage of the reactor coolant.

The heat exchanger plugging, fouling and wear evaluation are done in the context of the

equipment specification. For velocity, a maximum tube velocity of 15 ft/s is assumed. A nominal design and operating heat exchanger velocity range is 3 to 10 ft/s. Therefore the use of 15 ft/s is conservative from a heat exchanger design perspective and bounds the heat exchanger design and procurement specification(s).

3.3.2.1 Heat Exchanger Plugging

The heat exchanger tubes are ¾" OD, BWG 18 wall. The strainer hole size is 0.066". The heat exchanger tubes are significantly larger than the largest expected particle size. Therefore, a heat exchanger tube will not be plugged or blocked by post-LOCA debris. The flow velocity within a heat exchanger tube is significantly greater than the flow velocity transporting debris to the ECCS inlet piping. Therefore, the particles in solution will remain in solution and not settle out and plug a CS/RHR heat exchanger.

These conclusions are consistent with the referenced NRC Safety Evaluation on WCAP 16406 (Ref. 3-4).

3.3.2.2 Heat Exchanger Performance and Wear

The CS/RHR heat exchangers are sized and specified considering a fouling factor of 0.0005 h ft² °F/Btu for closed cycle condensate water (Ref. 3-15). Post-LOCA fluid does contain small amounts latent debris. However, fouling is considered a long-term phenomenon. CS/RHR heat loads are greatest at the start of the event and decrease rapidly over the first 24 hours. Heat removal capacity is not degraded over this short period. Any potential reduction in capability over the 30 day mission time will be gradual and is well within the nominal heat exchanger design. The CS/RHR heat exchangers are sized considering maximum heat load including fouling. Therefore, the CS/RHR heat exchangers are fully capable of performing their intended function using post-LOCA fluid as the process fluid.

The CS/RHR heat exchanger tubes are specified to be constructed of 304 stainless steel. Stainless steel is appropriate for use as heat exchanger tubing and is standard for use in mildly abrasive applications. The tube material will not significantly degrade considering operation with post-LOCA fluid over an intended mission time of 30 days.

3.3.3 Valve Wear Evaluation

Valve and valve trim materials are specified to be wear resistant. The valve procurement specification will note the constituents of the post-LOCA fluid and require that the valve be able to operate reliably under those conditions for a minimum of 30 days. The valves shall be qualified to QME-1-2007 as endorsed by RG 1.100, Revision 3, for their intended function using the post LOCA fluid.

Reliability of the ECCS and CSS are considered in the design, procurement, and installation/layout of components. Verification that the system valves will meet the fluid wear resistance requirements is considered part of the COL (Ref. 3-11, Subsection 17.4.9). Confirmation Item 3.7.3.

Direct Vessel Safety Injection Line Isolation Valves

Flow balance through the ECCS is controlled through the use of orifice plates and balancing through 4" globe valve SIS-MOV-011A, B, C, D. Due to the presence of downstream flow balancing orifices, the throttle valves are expected to be throttled to a minimum of 1" open between the valve disc and seat. Any potential wear, the opening of a throttle valve and decreasing flow resistance, may be compensated for by throttling the valve from the MCR. Final system start-up testing will confirm that the system will not be in run-out conditions with all system valves wide open.

CS/RHR Pump Full-flow Test Line Stop Valves

A single motor-operated 8" globe valve, RHS-MOV-025 A, B, C, D, with a throttling capability is placed in each of the four RHR return lines. These valves are positioned from the MCR. Any potential wear, the opening of a throttle valve and decreasing flow resistance, may be compensated for by throttling the valve from the MCR. Final system start-up testing with full-flow test line-up condition will confirm that the system will not be in run-out conditions with all system valves wide open.

CS/RHR heat exchanger outlet flow control valves

10" air-operated butterfly valves, RHS-HCV-023 and RHS-HCV-033, are placed in each of two CS/RHR heat exchanger outlet lines. These valves are only adjusted during shutdown

cooling operation and are not throttled during post-LOCA operation.

The rate of the opening of the valves can be manually adjusted from the MCR, and the valves fail in the "open" position to ensure a flow-path of RHRS and CSS. These valves provide the capability to control the flow rates through the heat exchangers by operator's action based on the RCS temperature changes during plant cool down. Any potential wear, the opening of a throttle valve and decreasing flow resistance, may be compensated for by throttling the valve from the MCR. Final system start-up testing will confirm that the system will not be in run-out conditions with all system valves wide open.

3.3.4 Piping and Valve Blockage and Debris Settling Evaluation

The strainer hole size is 0.066". Therefore, when the gap of the components is 0.066"+0.007 (10%) or 0.074" or less than this value, the flow-path or component may be blocked. This is consistent with Reference 3-4. Components that are in the flow-paths during accidents are listed in Table 3.2-1.

Piping

The piping, by design, minimizes low flow areas. The system low points are at the RHR suction. The fluid is generally fully turbulent, lessening the possibility and probability of debris settling.

Pipe diameters are significantly larger than the strainer hole size. Flow velocities in all cases are above the settling velocities of the post-LOCA fluid. Refer to Table 3.2-6. Debris settling is a longer term phenomena and has no short term impact on flow. Therefore, the potential of piping plugging or blockage and its impact on system operation is very low. Reliability of the SIS is considered in the design, procurement, and installation/layout of components. DCD Chapter 17 discusses Quality Assurance (QA) during design, construction and operation. Verification that the system valves will meet the fluid wear resistance requirements is considered part of the COL (Ref. 3-11, Subsection 17.4.9).

Valves

The valve types that are used in the flow-path during an accident are gate, check, globe and

butterfly valves, see Table 3.2-1.

Gate valves

Gate valves are used full-open or full-close. In the US-APWR, gate valve sizes are above 4", see Table 3.2-1. Flow velocities in all cases are above the settling velocities of the post-LOCA fluid. Refer to Table 3.3-2. Reference 3-7, NUREG/CR-6902, states that valve openings significantly larger than the debris size will not clog. The strainer hole size is 0.066". The 4" valve opening is considerably larger than any expected particle passing through the sump strainer. Therefore, the valves will not clog due to post-LOCA insulation debris.

Check valves

Check valves in the US-APWR are used with sufficient flow rate, and check valve sizes are above 4", see Table 3.2-1. Flow velocities in all cases are above the settling velocities of the post-LOCA fluid. Refer to Table 3.3-2. Reference 3-7, NUREG/CR-6902, states that valve openings significantly larger than the debris size will not clog. The strainer hole size is 0.066". The 4" valve opening is considerably larger than any expected particle passing through the sump strainer. Therefore the valves will not clog due to post-LOCA insulation debris.

Globe valves

ECCS and CSS flow is controlled through a combination of orifices and throttled valves. Globe valves normally are full open but may be used for throttling system flow. ECCS and CSS pressure and flow are monitored in the MCR. In general, if a globe valve is in a throttled position and it begins to clog, system flow will decrease. Operator action may be taken to open the valve, thus clearing the potential clog. In the US-APWR, globe valve sizes are above 2", see Table 3.2-1. Flow velocities in all cases are above the settling velocities of the post-LOCA fluid. Refer to Table 3.2-6. Reference 3-7, NUREG/CR-6902, states that valve openings significantly larger than the debris size will not clog. The strainer hole size is 0.066". Throttle valves are expected to be throttled to a minimum of 1" open between the valve disc and seat. The 1" valve opening is considerably larger than any expected particle passing through the sump strainer. Therefore the valves will not clog due to post-LOCA insulation debris.

Butterfly valves

Butterfly valves are used at the outlet of CS/RHR heat exchanger. These valves are used full open and valve sizes are 10". Flow velocities in all cases are above the settling velocities of the post-LOCA fluid. Refer to Table 3.2-6. Reference 3-7, NUREG/CR-6902, states that valve openings significantly larger than the debris size will not clog. The strainer hole size is 0.066". The 10" butterfly valve opening is considerably larger than any expected particle passing through the sump strainer. Therefore the valves will not clog due to post-LOCA insulation debris.

Orifice

ECCS and CSS flow is controlled through a combination of orifices and throttled valves. Orifices are used for throttling system flow. ECCS and CSS pressure and flow are monitored on the MCB. In the US-APWR, orifice sizes are above ½". Flow velocities in all cases are above the settling velocities of the post-LOCA fluid (Table 3.3-2). Therefore, the potential of orifice plugging is very low.

Spray Nozzles

The containment spray nozzles have an inlet orifice 0.375" in diameter. This orifice is the smallest portion of spray nozzle. The strainer hole size is 0.066". Reference 3-7, NUREG/CR-6902, states that valve openings significantly larger than the debris size will not clog. Containment spray nozzles are significantly larger than the strainer hole size. Their one-piece design provides a large, unobstructed flow passage that resists clogging by particles. Therefore, the potential of spray nozzle plugging is very low.

3.3.5 Instrument Clogging Evaluation

Per the USNRC review guidance (Ref. 3-3) instrument connection should be reviewed to determine their susceptibility to clog or plug. Reliability of the ECCS and CSS is considered in the design, procurement, and installation/layout of components. All connections, by design, are either at the horizontal or above. Flow velocities in all cases are above the settling velocities of the post-LOCA fluid (Table 3.3-2). Therefore, the potential for instrument and instrumentation tubing plugging is very low.

3.3.6 Chemical Effects Evaluation

Precipitants and other chemical forms present as a result of the chemical effects testing have no effect on the plugging or wear evaluations.

Chemicals and precipitants are typically soft, non-abrasive, low-shear and readily stay in solution due to the fully developed turbulent flow conditions present within the piping system(s). As such, they do not contribute to plugging or change wear characteristics of piping, pump, heat exchangers or valves downstream of the containment sump (Ref. 3-13 and 3-14).

3.4 ECCS and CSS Pump Evaluations

Reliability of the SIS is considered in the design, procurement, and installation/layout of components.

3.4.1 Review of Design / Procurement Specification(s)

3.4.1.1 ECCS Pumps

Engineering Design Requirements for the ECCS pumps are contained in Appendix A.

The SI pumps are motor-driven horizontal, multistage, centrifugal pumps with mechanical seals. The pumps are sized to deliver 1,540 gpm at a discharge head of 2,756 ft.

The ECCS pumps will be specified to meet the intent of American Petroleum Institute (API) Standard 610 (Ref. 3-17) in the context of rotor dynamic analysis. API-610 provides a standard analysis method for severe service pumps and is a recognized design standard for the design and operation of centrifugal pumps for petroleum, heavy duty chemical and gas industry services (Ref. 3-4). Details will be provided in the procurement specifications. Verification that specification requirements are considered part of the COL (Ref. 3-11, Subsection 17.4.9). Confirmation Item 3.7.4.

The mission time for the ECCS, including post-LOCA long-term operation is defined as 30 days. The ECCS pumps, including the mechanical seal, shall be qualified per QME-1-2007 as endorsed by RG 1.100, Revision 3 to operate in post-LOCA fluid conditions for at least 30 days.

The fluid characteristics listed in Table 3.2-3, 4 and 5 conservatively represent the post-LOCA fluid conditions that an SI pump will experience. At the procurement stage, the pump vendor will provide a table listing the materials and hardness's of all wetted pump surfaces (wear rings, pump internals, bearings, casings, etc). Confirmation Item 3.7.5.

At the procurement stage, the pump vendor will provide a table listing the design or specified opening sizes and internal running clearances. Confirmation Item 3.7.5.

MHI does not intend to specify equipment strainers, cyclone separators or other filtering components as part of the pump design or procurement specification. If a pump vendor supplies a pump with such equipment, the manufacturer will be required to confirm that stated that their design is not susceptible to plug or clog during post-LOCA long-term operation and that there will be no negative impact on pump performance or reliability. - Confirmation Item 3.7.5.

The pump purchase specification will state that there will be no changes in system or equipment operation caused by wear (i.e. pump vibration and rotor dynamics) such that the pump will not be able to perform as specified. Confirmation Item 3.7.5.

Rotor dynamic studies and bearing load models will be required to be submitted as part of the purchase specification and procurement documents. The pump vendor will confirm that internal bypass flow increases due to impellor or casing wear will not affect the ability of the pump to meet its intended function. Confirmation Item 3.7.5.

3.4.1.2 CSS Pumps

Engineering Design Requirements for the CSS pumps are contained in Appendix B.

The CS/RHR pumps are motor-driven centrifugal pumps with mechanical seals. The pumps are sized to deliver 3,000 gpm at a discharge head of 410 ft. The 100% capacity design flow rate (two of four 50% capacity CS/RHR pumps) is based upon a 15.2 gpm flow per nozzle and 348 nozzles in the ring header. The CS/RHR pumps will be specified to meet the intent of American Petroleum Institute (API) Standard 610 (Ref. 3-17) in the context of rotor dynamic analysis. API-610 provides a standard analysis method for severe service pumps and is a recognized design standard for the design and operation of centrifugal pumps for petroleum, heavy duty chemical and gas industry services (Ref. 3-4). Details will be provided in the procurement specifications. Verification that specification requirements are considered part of the COL (Ref. 3-11, Subsection 17.4.9). Confirmation Item 3.7.4

The mission time for the CSS, including post-LOCA long-term operation is defined as 30 days. The CS/RHR pumps, including the mechanical seal, shall be qualified per QME-1-2007 as endorsed by RG 1.100, Revision 3 to operate in post-LOCA fluid conditions for at least 30 days.

The fluid characteristics listed in Table 3.2-3, 4 and 5 conservatively represent the post-LOCA fluid conditions that a CS/RHR pump will experience. At the procurement stage, the pump vendor will provide a table listing the materials and hardness's of all wetted pump surfaces (wear rings, pump internals, bearings, casings, etc). Confirmation Item 3.7.5.

At the procurement stage, the pump vendor will provide a table listing the design or specified opening sizes and internal running clearances. Confirmation Item 3.7.5.

At the procurement stage, the pump vendor will provide a table listing the design or specified opening sizes and internal running clearances. Confirmation Item 3.7.5.

MHI does not intend to specify equipment strainers, cyclone separators or other filtering components as part of the pump design or procurement specification. If a pump vendor supplies a pump with such equipment, the manufacturer will be required to confirm that their design is not susceptible to plug or clog during post-LOCA long-term operation and that there will be no negative impact on pump performance or reliability. - Confirmation Item 3.7.5.

The pump purchase specification will state that there will be no changes in system or equipment operation caused by wear (i.e. pump vibration and rotor dynamics) such that the pump will not be able to perform as specified. Confirmation Item 3.7.5.

Rotor dynamic studies and bearing load models will be required to be submitted as part of the purchase specification and procurement documents. The pump vendor will confirm that internal bypass flow increases due to impellor or casing wear will not affect the ability of the pump to meet its intended function. Confirmation Item 3.7.5.

3.4.2 Effects of Air Entrainment

The scope of this evaluation does not include vortexing at the strainer or system suction. This evaluation discusses the ability of the ECC and CSS pumps to operate under voided conditions.

Reliability of the ECCS and CSS are considered in the design, procurement, and installation/layout of components. DCD Chapter 17 discusses Quality Assurance (QA) during

design, construction and operation. Verification that programmatic controls are in place regarding air entrainment or that design specifications refer to and specify high point vents, continually up sloping lines etc is considered part of the COL (Ref. 3-11, Subsection 17.4.9 and Ref. 3-6).

ECCS / CSS pump suction lines are designed to prevent degradation of pump performance through air ingestion and other adverse hydraulic effects (e.g., circulatory flow patterns, high intake head losses).

RWSP suction strainers are submerged under a minimum of approximately 4 ft. of water during a LOCA. The RWSP recirculation supply is sufficient to preclude adverse hydraulic effects (e.g., vortex formation and high suction head loss). A low approach velocity at the strainer surface also mitigates the risk of vortexing.

3.4.3 Seal Leakage

Both the ECCS and CS/RHR pumps are specified to maintain a leak rate of less than []. Under complete seal failure conditions, the leak rate is specified to be less than 50 gpm. The pump seal vendor will confirm that their design meets or exceeds these conditions. Confirmation item 3.7.6.

The CSS is provided with a leakage detection system to minimize the leakage from those portions of the system outside of the containment that contain or may contain radioactive material following an accident.

A pit (sump) with a leak detector installed in each safeguard component area and alarms to MCR to prevent significant leakage of radioactive recirculation water from the high head injection system to the reactor building. The high head injection system is designed with sufficient redundancy and independence to prevent loss of core cooling function during an accident assuming the isolation of the leaked train after leakage is detected.

The [] leak rate is bounded by the Environmental Qualification (EQ) profile.

3.4.4 Chemical Effects Evaluation

Precipitants and other chemical forms present as a result of the chemical effects testing have

no effect on the plugging, wear or pump performance evaluations.

Chemicals and precipitants are typically soft, non-abrasive, low-shear and readily stay in solution due to the fully developed turbulent flow conditions present within a pump. As such, they do not contribute to plugging or change wear characteristics (Ref. 3-13 and 3-14).

3.5 ECCS and CSS Performance Evaluations

3.5.1 ECCS Performance Evaluation

Based upon the piping wear and pump operation evaluations, it is concluded that the system piping and component flow resistances will change minimally during the course of the LOCA. Therefore flow balances and system performance is not affected in an appreciable manner.

The resulting flows and pressures are consistent or conservative with respect to the accident analysis. The minor resistance changes do not affect the system flow calculations and Design Bases analysis.

The ECCS contains instrumentation to monitor system performance. The following system parameters are monitored in the MCR:

1. SI pump discharge flow rate
2. SI pump minimum flow rate
3. SIS flow rate
4. SI pump suction and discharge pressure indication

Motor operated valves on the SI pump discharge may be throttled as needed to maintain an SI pump in the desired operating range. Therefore, any changes as a result of long-term wear (30 days) or operation will be detected and system performance adjusted as needed.

3.5.2 CSS Performance Evaluation

Based upon the piping wear and pump operation evaluations, it is concluded that the system piping and component flow resistances will change minimally during the course of the LOCA. Therefore flow balances and system performance is not affected in an appreciable manner.

The resulting flows and pressures are consistent or conservative with respect to the accident analysis. The minor resistance changes do not affect the system flow calculations and Design Bases analysis

The CSS/ RHRS contains instrumentation to monitor system performance. The following

system parameters are monitored in the MCR:

1. CS/RHR pump discharge flow rate
2. CS/RHR pump minimum flow rate
3. CS/RHR flow rate
4. CS/RHR heat exchanger inlet and outlet temperature indication
5. CS/RHR pump suction and discharge pressure indication

Therefore, any changes as result of long-term wear (30 days) or operation will be detected.

3.6 Regulatory Summary

Generic Letter (GL) 2004-02, Potential Impact of Debris Blockage on Emergency Recirculation during Design Basis Accidents at Pressurized Water Reactors (Ref. 3-1) was issued by the USNRC requesting holders of operating reactor licenses to evaluate their emergency core cooling system (ECCS) and containment spray system (CSS) recirculation functions in light of events regarding the blockage of containment sump strainers. The GL notes that:

“Debris could also plug or wear close-tolerance components within the ECCS or CSS systems. This plugging or wear might cause a component to degrade to the point where it could not perform its designated function (i.e., pump fluid, maintain system pressure, or pass and control system flow.)

Third, debris blockage at flow restrictions within the ECCS recirculation flow-path downstream of the sump screen is a potential concern for PWRs. Debris that is capable of passing through the recirculation sump screen may have the potential to become lodged at a downstream flow restriction, such as a high-pressure safety injection (HPSI) throttle valve or fuel assembly inlet debris screen. Debris blockage at such flow restrictions in the ECCS flow-path could impede or prevent the recirculation of coolant to the reactor core, thereby leading to inadequate core cooling. Similarly, debris blockage at flow restrictions in the CSS flow-path, such as a containment spray nozzle, could impede or prevent CSS recirculation, thereby leading to inadequate containment heat removal. Debris may also accumulate in close-tolerance subcomponents of pumps and valves. The effect may be either to plug the subcomponent, thereby rendering the component unable to perform its function, or to wear critical close tolerance subcomponents to the point at which component or system operation is degraded and unable to fully perform its function. Considering the recirculation sump screen’s design function of intercepting potentially harmful debris, it is essential that the screen openings be adequately sized and that the sump screen’s current configuration be free of gaps or breaches which could compromise the ECCS and CSS recirculation functions. It is also essential that system components be designed and evaluated to be able to operate as necessary with debris laden fluid post-LOCA”

The GL requested the following specific information be provided.

“(v) The basis for concluding that inadequate core or containment cooling would not result

due to debris blockage at flow restrictions in the ECCS and CSS flow-paths downstream of the sump screen, (e.g., a HPSI throttle valve, pump bearings and seals, fuel assembly inlet debris screen, or containment spray nozzles). The discussion should consider the adequacy of the sump screen's mesh spacing and state the basis for concluding that adverse gaps or breaches are not present on the screen surface.

(vi) Verification that close-tolerance subcomponents in pumps, valves and other ECCS and CSS components are not susceptible to plugging or excessive wear due to extended post-accident operation with debris-laden fluids”

In response to the GL, the Nuclear Energy Institute, NEI, issued Guidance Report NEI 04-07 delineating a generic, consistent approach to address the NRC concerns identified in GL 2004-02. The USNRC, in turn, issued a Safety Evaluation clarifying those items to be addressed and endorsing an approach that would be acceptable to the USNRC staff (Ref. 3-2).

The USNRC further clarified specific areas to be addressed with the issuance of an NRC letter entitled “Audit Plan for Verifying the Adequacy of Licensee Responses to Generic Letter 2004-02” (Ref. 3-3). This audit plan was intended to fully address the USNRC concerns identified in Reference 3-2, Final Safety Evaluation for NEI Guidance Report 04-07, regarding the evaluation of ex-vessel components downstream of the containment sump during post-LOCA operation. There are no other regulatory guidance documents that specifically pertain to the evaluation of ex-vessel downstream components. Therefore, addressing the issues identified in the “Audit Guidelines” will fully address the concerns identified in the GL.

The sections of Table 3.6-1 are excerpted from the Audit Guidelines (Ref. 3-3). Following each section is a reference to the report section where it is addressed and a summary of evaluation.

3.7 Confirmation Items

Reliability of the ECCS and CSS are considered in the design, procurement, and installation/layout of components. Verification that the system components will meet their design specifications is considered part of the COL (Ref. 3-11, Subsection 17.4.9).

3.7.1 Verify the “as procured” Safety Injection Pump runout flow is less than 2,000 gpm.

3.7.2: Verify the “as procured” CS/RHR Pump runout flow is less than 4,000 gpm.

3.7.3 Valve and valve trim materials will be specified to be wear resistant. The valve procurement specification will note the constituents of the post-LOCA fluid and require that the valve be able to operate reliably under those conditions for a minimum of 30 days.

3.7.4 The ECCS and CSS pumps will be specified to meet the intent of American Petroleum Institute (API) Standard 610 in the context of rotor dynamic analysis. API-610 provides a standard analysis method for severe service pumps and is a recognized design standard for the design and operation of centrifugal pumps for petroleum, heavy duty chemical and gas industry services. Details will be provided in the procurement specifications.

3.7.5 ECCS and CSS pump wetted materials and seals will be specified to be wear resistant. The pump(s) procurement specification will note the constituents of the post-LOCA fluid and require that the pump(s) be able to operate reliably under those conditions for a minimum of 30 days. The pump vendor will supply a list of materials, material hardness and design and maximum running clearances.

3.7.6 The ECCS and CS/RHR pumps seal specification will state that the seals be designed to maintain a leak rate of less than { } Under complete seal failure conditions, the leak rate will be specified to be less than 50 gpm.

3.8 Summary of Results

The intent of this technical report is to assess the US-APWR Emergency Core Cooling (ECC) and Containment Spray (CSS) systems to ensure that that these systems and their components will operate as designed under post Loss-of Coolant Accident Conditions (LOCA).

This review incorporates the lessons learned as part of the USNRC Generic Safety Issue 191 (GSI-191) and addresses the concerns identified in Generic Letter (GL) 2004-02 (Ref.3-1). This report has been prepared in accord with NEI 04-07 (Ref. 3-16) and published USNRC staff expectations. Information and guidance used has been extracted from the noted references and adapted to the US-APWR design.

This report concludes that the US-APWR ECC / CS Systems and components are fully capable of performing their intended functions under post-LOCA operating conditions with regard to ex-vessel downstream effects.

Table 3.2-1 Components in the Flow Path during a LBLOCA

Components	Remark
Pumps SIS-MPP-001A,B,C,D RHS-MPP-001A,B,C,D	Multi-stage centrifugal type Centrifugal type
Heat Exchangers RHS-MHX-001A,B,C,D	Shell & tube type
Valves SIS-MOV-001A,B,C,D SIS-VLV-004A,B,C,D SIS-MOV-009A,B,C,D SIS-VLV-010A,B,C,D SIS-MOV-011A,B,C,D SIS-VLV-012A,B,C,D SIS-VLV-013A,B,C,D SIS-MOV-014A,B,C,D SIS-VLV-015A,B,C,D SIS-VLV-023A,B,C,D CSS-MOV-001A,B,C,D CSS-VLV-002A,B,C,D CSS-MOV-004A,B,C,D CSS-VLV-005A,B,C,D RHS-VLV-004A,B,C,D RHS-VLV-013A,B,C,D RHS-HCV-023 RHS-HCV-033 RHS-MOV-021A,B,C,D RHS-VLV-022A,B,C,D RHS-MOV-025A,B,C,D	Gate, 10" Check, 4" Gate, 4" Check, 4" Globe, 4" Check, 4" Check, 4" Globe, 4" Check, 4" Globe, 2" Gate, 14" Gate, 10" Gate, 8" Check, 8" Check, 16" Globe, 3" Butterfly, 10" Butterfly, 10" Gate, 8" Check, 8" Globe, 8"
Orifice SI pump outlet flow instrument orifice SI pump minimum flow orifice Direct vessel injection line orifice Hot leg injection line orifice CS/RHR pump outlet flow instrument orifice CS/RHR pump minimum flow instrument orifice CS/RHR pump minimum flow line orifice Containment spray ring orifice	Hole size of 1/2" is assumed as the smallest of these orifices.
Spray Nozzle Containment Spray Nozzle	Orifice size 0.375 in.

Table 3.2-2 Material Hardness Data

Material	Grade or Type	Component	Brinell Hardness (BHN)
SA-240 SA-479	304/L/LN Stainless Steel	CS nozzles, Valve Bonnets, Valve Disks	149
SA-182	F304/L/LN Stainless Steel	Valve Bodies, Valve Bonnets, Valve Disks,	149
SA-240 SA-312 SA-376 SA-479	316/L/LN Stainless Steel	Valve Bonnets, Valve Disks, Valve Stems	163
SA-182 SA-336	F316/L/LN Stainless Steel	Valve Bodies, Valve Bonnets, Valve Disks, Main Coolant piping,	163
SA-564	630	Valve Disks, Valve Stems	421
Material	Grade or Type	Pipe	Brinell Hardness (BHN)
SA-358	304 STD	SIS-151	149
SA-312	304(SML)	SIS-1501, SIS-2511, RHS-901R, RHS-2511R, CSS-901, CSS-301	149
SA-312	316(SML)	SIS-2501R, RHS-2501R	163

Table 3.2-3 Debris Source Term

Debris Type	Debris Quantity	Fabricated Density	Material Density	Characteristic Size
RMI	106 ft ³ 11,442 ft ² foil surface area	N/A	490* lbm/ft ³	0.003 ft
Nukon	4.5 lbm	2.4 lbm/ft ³	159 lbm/ft ³	7μm Diameter S _v = 1.742e5/ft
Epoxy Coatings	482 lbm	19 lbm/ft ³	94 lbm/ft ³	10μm Diameter S _v = 1.829e5/ft
Latent Fiber	30 lbm	2.4 lbm/ft ³	159 lbm/ft ³	7μm Diameter S _v = 1.742e5/ft
Latent Particle	170 lbm	75 lbm/ft ³	168.6 lbm/ft ³	S _v = 1.06e5/ft

Note: * RMI density is assumed to be that of common stainless steel

Table 3.2-4 Debris Concentration Components

TYPE	Debris Quantity	Density	Mass (lbs)	PPM
NUKON	2.25 lbm	N/A	2.25	1
Latent fiber	30 lbm	N/A	30	9
Epoxy coatings	482 lbm	N/A	482	143
Latent particle	170 lbm	N/A	170	50
RMI	5.3 ft ³	490	2597	773
SUM			3281.25	976

Table 3.2-5 Material Wear Rates (Ref. 3-19)

Material	Wear Rate (inches/year)	
	Coarse Sand	
	7 ft/s	15 ft/s
Steel	0.0256	0.0713
Aluminum	0.0713	0.2945
Polyethylene	0.0024	0.0181
ABS	0.0142	0.0815
Acrylic	0.0390	0.1614
Geometric Wear Ratio with respect to velocity	4.600	

Table 3.2-6 Affected Equipment / Flow Rates

Components	Inner Diameter (inches)	Design Flow Rate (gpm)	Assumed Flow Rate (gpm)	Assumed Flow Rate (ft ³ /s)	Assumed Velocity (ft/s)	Reference
Sump Screen						
	0.066					MUAP 08001
Orifice						
Flow instrument orifice on 4" SIS Line 1501	2	1540	2000	4.456	204.269	DCD Fig. 6.3-2
Orifice on 4" SIS Line 2511	2	1540	2000	4.456	204.269	DCD Fig. 6.3-2
Orifice on 4" SIS Line 2501	2	1540	2000	4.456	202.560	DCD Fig. 6.3-2
Flow instr. orifice on 10" RHRS Line 901	7.5	3650	4000	8.913	29.052	DCD Fig. 6.2.2-1
Spray ring orifice on 8" CSS Line 301	6	3650	4000	8.913	45.395	DCD Fig. 6.2.2-1
Spray Nozzle						
Containment Spray Nozzle	0.375	41.95*	45	0.100	130.732	DCD 6.2.2.2.4
Piping						
10" SIS Line 151R (SS Sch 160)	8.500	1540	2000	4.456	11.309	Pipe Material Sheet / Crane No. 410
4" SIS Line 1501R (SS Sch 160)	3.438	1540	2000	4.456	69.127	Pipe Material Sheet / Crane No. 410
4" SIS Line 2511R (SS Sch 160)	3.438	1540	2000	4.456	69.127	Pipe Material Sheet / Crane No. 410
4" SIS Line 250R (SS Sch 160)	3.438	1540	2000	4.456	69.127	Pipe Material Sheet / Crane No. 410
16" RHS Line 901R (SS Sch 80)	14.312	3650	4000	8.913	7.978	
10" RHS Line 901R (SS Sch 80)	9.562	3650	4000	8.913	17.873	
16" CSS Line 901 (SS Sch 80)	14.312	3650	4000	8.913	7.978	Pipe Material Sheet / Crane No. 410
14" CSS Line 901 (SS Sch 80)	12.500	3650	4000	8.913	10.459	Pipe Material Sheet / Crane No. 410
10" CSS Line 901 (SS Sch 80)	9.562"	3650	4000	8.913	17.873	Pipe Material Sheet / Crane No. 410
8" CSS Line 901 (SS Sch 80)	7.625	3650	4000	8.913	28.107	Pipe Material Sheet / Crane No. 410
8" CSS Line 301 (SS Sch 40S)	7.981	3650	4000	8.913	25.655	Pipe Material Sheet / Crane No. 410
6" CSS Line 301 (SS Sch 40S)	6.065	1825	2500	5.570	27.766	Pipe Material Sheet / Crane No. 410

*The CS nozzle flow rate is the maximum flow rate of both CS/RHR pumps divided by 348 nozzles.

Table 3.3-1 ECCS and CSS Components Wear vs. Time

Components	30 DAYS		
	Dia-metrical (inches)	Wear	Flow Rate Increase (%)
Orifice			
Flow instrument orifice on 4" SIS Line 1501			
Orifice on 4" SIS Line 2511			
Orifice on 4" SIS Line 2501			
Flow instr. orifice on 10" RHRS Line 901			
Spray ring orifice on 8" CSS Line 301			
Spray Nozzle			
Containment Spray Nozzle			
Piping			
10" SIS Line 151 (SS Sch 160)			
4" SIS Line 1501 (SS Sch 160)			
4" SIS Line 2511 (SS Sch 160)			
4" SIS Line 2501 (SS Sch 160)			
16" RHS Line 901R (SS Sch 80)			
10" RHS Line 901R (SS Sch 80)			
16" CSS Line 901 (SS Sch 80)			
14" CSS Line 901 (SS Sch 80)			
10" CSS Line 901 (SS Sch 80)			
8" CSS Line 901 (SS Sch 80)			
8" CSS Line 301 (SS Sch 40S)			
6" CSS Line 301 (SS Sch 40S)			

Table 3.3-2 ECCS and CSS Settling Velocities

Components	Design Flow Rate (gpm)	Assumed Flow Rate (gpm)	Assumed Velocity (ft/s)	Maximum Settling Velocity (ft/s)	Conclusion
Orifices					
Flow instrument orifice on 4" SIS Line 1501	265	200	6.913	0.5	Debris settling will not occur
Orifice on 4" SIS Line 2511	265	200	6.913	0.5	Debris settling will not occur
Orifice on 4" SIS Line 2501	265	200	6.913	0.5	Debris settling will not occur
Flow instr. orifice on 10" RHRS Line 901	355	300	1.340	0.5	Debris settling will not occur
Spray Nozzle					
Spray ring orifice on 8" CSS Line 301	355	300	1.924	0.5	Debris settling will not occur
Spray Nozzle					
Containment Spray Nozzle	1.02	0.862	2.504	0.5	Debris settling will not occur
Piping					
10" SIS Line 151R (SS Sch 160)	265	200	1.131	0.5	Debris settling will not occur
4" SIS Line 1501R (SS Sch 160)	265	200	6.913	0.5	Debris settling will not occur
4" SIS Line 2511R (SS Sch 160)	265	200	6.913	0.5	Debris settling will not occur
4" SIS Line 250R (SS Sch 160)	265	200	6.913	0.5	Debris settling will not occur
16" RHS Line 901R (SS Sch 80)	355	300	0.598	0.5	Debris settling will not occur
10" RHS Line 901R (SS Sch 80)	355	300	1.340	0.5	Debris settling will not occur
16" CSS Line 901 (SS Sch 80)	355	300	0.598	0.5	Debris settling will not occur
14" CSS Line 901 (SS Sch 80)	355	300	0.784	0.5	Debris settling will not occur
10" CSS Line 901 (SS Sch 80)	355	300	1.340	0.5	Debris settling will not occur
8" CSS Line 901 (SS Sch 80)	355	300	2.108	0.5	Debris settling will not occur
8" CSS Line 301 (SS Sch 40S)	355	300	1.924	0.5	Debris settling will not occur
6" CSS Line 301 (SS Sch 40S)	355	300	3.332	0.5	Debris settling will not occur

Table 3.6-1 Ex-Vessel Downstream Effects Regulatory Review

Section 13, Downstream Effects	Response
i. Review the list of all components and flowpaths considered to determine the scope of the licensee's downstream evaluation (pumps, valves, instruments, and heat exchangers, etc).	Report Sections 3.2.1, 3.2.3 and Figure 3.1-1 and Table 3.2-1 list components and flow-paths.
ii. Review design and license mission times and system lineups to support mission-critical systems.	Report Section 3.2.2. Design Bases mission time is 30 days for all components.
iii. Evaluate the vulnerability of the high-pressure safety injection (HPSI) throttle valves to clogging by determining the HPSI system's use?	Report Sections 3.3.3 and 3.3.4. HPSI valves are not vulnerable to clogging due to open design.
iv. Assess whether the leakage through seals, etc., would increase local dose rates so that credited operator actions, if any, cannot be met.	Report Sections 3.4.1 and 3.4.3. Seals will be specified and procured to meet assumed leakage rates.
v. Review all LOCA scenarios (i.e., small-break LOCA, medium-break LOCA, and large break LOCA) to assess system operation. For a large-break LOCA or medium-break LOCA, some plants may not need and/or use the HPSI system.	Report Section 3.2.1. LBLOCA is the limiting scenario.
vi. Review the licensee's evaluation of the extent of air entrainment. Licensee evaluation should include review of plant operating experience. Apart from vortexing, this involves ongoing questions about ECCS and incident report evaluation on the significance of ECCS gas intrusion.	Report Section 3.4.2. System design precludes the formation of gas pockets. Programmatic controls regarding construction and surveillances to assess air ingestion will be submitted as part of the COL.
vii. Review the characterization and properties of ECCS post-LOCA fluid (abrasiveness, solids content, and debris characterization).	Report Section 3.2.4 and Table 3.2-3, 4 and 5.

viii. Review the materials of all wetted downstream surfaces (wear rings, pump internals, bearings, throttle valve plug, and seat materials).	Report Sections 3.3.1 and 3.4.1. Wetted materials will be specified and procured to meet wear resistance requirements.
ix. Review the opening sizes and running clearances in pumps and valves.	Report Sections 3.3.1, 3.3.3 and 3.3.4 for valves. There are no tight clearance valves. Section 3.4.1 addresses pumps. Opening sizes and running clearance will be provided as part of the pump procurement specification.
x. Review the list of system low points and low-flow areas.	Report Sections 3.3.4 and 3.4.2. Flow velocities in all cases are above the settling velocities of the post-LOCA fluid. System design precludes the formation of gas pockets. Programmatic controls regarding construction and surveillances to assess air ingestion will be submitted as part of the COL.
xi. Review the range of fluid velocities within piping systems. What is the minimum velocity used to assess settling? What is the maximum velocity used to assess wear?	Report Section 3.2.5 and Table 3.3-2. System flows in excess of pump runout are assumed for wear rate calculations. Less than design flow is assumed for settling evaluations.
xii. Review the presence and evaluation of equipment strainers, cyclone separators, and other components.	Report Section 3.4.1. MHI does not intend to specify equipment strainers, cyclone separators or other filtering components as part of the pump design or procurement specification. If a pump vendor supplies a pump with such equipment, the manufacturer will be required to confirm that stated that their design is not susceptible to plug or clog during post-LOCA long-term operation and that there will be no negative impact on pump performance or reliability.
xiii. Review the assessment of changes in system or equipment operation caused by wear (i.e., pump vibration and rotor dynamics). Assess whether the internal bypass flow increases, thereby decreasing performance or accelerating internal wear.	Report Section 3.4.1. A wear assessment and a rotor dynamics study will be part of the pump procurement specification.

<p>xiv. Assess whether the system, piping, or component flow resistance changed, altering flow balances.</p>	<p>Report Section 3.5. There are no significant system, piping, or component resistance changes such that flow balances will be appreciably altered.</p>
<p>xv. Assess whether the system piping vibration response changed for any of the above reasons.</p>	<p>Report Section 3.5. There are no significant system, piping, or component resistance changes such that system piping vibration is appreciably altered.</p>
<p>xvi. Review the listing and evaluation of instrument tubing connections.</p>	<p>Report Section 3.3.5 and Table 3.3-2. All instrument connections, by design, are either at the horizontal or above. Programmatic controls regarding construction will be submitted as part of the COL.</p>
<p>xvii. Review ECCS heat exchanger design to identify those with small (i.e., 3/8" or less) tubes and for which the ECCS is on the tube side. What are the clearances and the potential for fouling?</p>	<p>Report Section 3.3.2. Heat exchanger tubing is 3/4" OD. The CS/RHR Heat Exchanger has been specified with a .0005 fouling factor. Fouling is a long term phenomena, CS/RHR heat exchangers are sized considering maximum heat load including fouling.</p>
<p>Section 14. Chemical Effects (partial)</p>	<p>Response</p>
<p>ix. Verify the licensee has considered potential downstream effects related to chemical by-product formation.</p>	<p>Report Section 3.4.4. There are no adverse affects on ECCS or CSS pumps, valves, heat exchangers or piping components as a result of chemical precipitants in the post-LOCA fluid.</p>




Figure 3.1-1 Schematic Flow Diagram of ECCS/CSS (Ref. 3-12)

4.0 IN-VESSEL DOWNSTREAM EFFECTS

4.1 Blockage at the Core Inlet

The following sequence is the US-APWR core cooling path flows in the reactor vessel downstream of the sump strainer. Cooling water will:

1. Come in from ECCS nozzle
2. Pass through the downcomer which is the annulus between the reactor vessel and the core barrel
3. Pass through the lower plenum
4. Pass through the flow holes of the lower core support plate
5. Pass through the fuel assemblies
6. Pass through the holes of the upper core plate
7. Flows out from outlet nozzle

The smallest flow hole in the core cooling flow route of the reactor internals is that of the flow holes of the lower core support plate whose size is []. The flow hole of the bottom nozzle in the fuel assembly is []. This is the narrowest gap downstream of the strainer to core inlet, and dictates that the nominal diameter of the strainer holes shall be sufficiently smaller than this gap. [] percent margin was considered to limit the debris which may pass through this gap, and no larger than 0.071" (1.8mm) of debris are blocked at the strainer. Finally, the strainer supplier's standard perforated plate with 0.066" (1.67mm) was selected to the US-APWR strainer specification.

The flow hole of the lower core support plate is over [] times the size of the strainer holes. Therefore it is not necessary to consider piling up the downstream debris at any flow paths in the reactor internals. The flow hole of the fuel assembly bottom nozzle is [] times the size of the strainer holes. Therefore, the down stream debris may accumulate at the fuel assembly bottom nozzle. The results of the core inlet blockage test using the mock up fuel assembly indicate that the fuel components such as the bottom nozzle and the grid spacer can trap the down stream debris. However, the test results also show that this debris accumulation in the assembly does not block the coolant flow through the fuel components and therefore that the sufficient flow per assembly is secured for the long term cooling. The test results are presented in Ref. 4.1-5. LOCA scenarios, which are needed to consider, are

provided in Appendix-H

4.2 Trapping Debris in Fuel Assemblies

4.2.1 Trapping Debris at Grid Spacer

4.2.1.1 Introduction

The bypass debris that would penetrate the sump strainer might be trapped at the grid spacer of the US-APWR fuel assembly. The grid spacer holds the fuel rod by means of two grid spacer springs and four dimples as shown in Figure 4.2.1-1. The maximum diameter of maximum inscribed circle in the grid spacer is about () mm which is larger than that in the bottom nozzle (() mm).

The intermediate grid spacers have mixing vanes on the top of inner straps to increase the mixing of the primary coolant and increase the heat removal efficiency. The mixing flow interfere debris to adhere at the mixing vanes. The top and bottom grid spacers do not have mixing vanes.

The springs and the dimples on the grid strap sheet make the flow hole open instead of the grid cell surrounded by the grid strap sheet. The debris could pass through the flow hole on the grid strap sheet and the coolant as well. Therefore, the flow hole works in favor of the keeping the coolant flow at the position of the grid spacers.

The bypass debris through the sump strainer will be fine because of the filtering ability of the sump strainers. Since the results of the core inlet blockage test using the mock up fuel assembly indicate that the bypass debris accumulates at the grid spacer, the grid spacer may trap the bypass debris coming through the bottom nozzle in spite of their fine condition. However, the cooling system maintain at the grid spacers (Ref.4.1-5). This analysis demonstrates that the fuel cladding coolability is acceptable even if the bypass debris clogs at the grid spacers.

4.2.1.2 Methodology

The thermal transfer behavior on the fuel cladding surface is analyzed in terms of the debris clogging at the grid. The analyses take into account the radial heat transfer including the effects of accumulated debris reaching the core at the grid. To be consistent, these analyses use the core condition, such as the fuel decay heat and thermal hydraulic condition, based on the results of the WCOBRA/TRAC analysis described at Appendix-G related to the post-LOCA situation as boundary conditions.

The code ABAQUS™ was used for this analysis using a partial flat plate model focused on a fuel rod with solid elements in the steady heat transfer conditions. Figure 4.2.1-2 shows the schematic drawing of the analysis model. Although the thermal flux effecting heat transfer on the surface decreases with an increase of the surface area in contact with the coolant due to accumulating debris on the cladding, the flat plate model considers the constant heat flux

based on the inner cladding diameter conservatively.

The model has one span length with a grid and includes the axial position indicating the maximum heat flux. The grid is located at the center of the model and the cladding has half span length from the grid. The model takes into account the heat flux on the inner cladding surface and the radial thermal transfer between the outer surface of the cladding including the debris and the coolant. Therefore, it is not necessary to consider the pellets and the pellet-cladding gap. It is not assumed that the axial heat transfer exists on both the upper and bottom horizontal surface of the debris, conservatively. The parameters for the analyses are thermal conductivity and the thickness of the debris. This parameter study compares the cladding surface temperature with the acceptable temperature.

It is assumed that the acceptable cladding temperature is up to [] °F as described in the Appendix C. This temperature is based on the results of the autoclave corrosion tests which indicate no-acceleration behavior of the cladding corrosion when the temperature on the cladding metal surface is below this acceptable temperature, [] °F.

4.2.1.3 Inputs

(1) Power Conditions

The power conditions in the analysis are based on the results of the WCOBRA/TRAC analysis described at Appendix-G. It is estimated that 850 seconds after the LOCA event is the minimum time for debris reaching up to the core in the US-APWR. The heat flux at 850 seconds after LOCA event is the highest heat flux in the analyses because the fuel decay heat is decreasing with the time. Figure 4.2.1-3 shows the heat flux profile on the hot rod at that time and the modeling area including the maximum heat flux at the axial position. The uniform value of heat flux, is [] BTU/hr-ft² ([] W/m²), which is based on the inner cladding surface and is applied in the analyses, conservatively.

(2) Thermal Hydraulic Conditions

The Thermal Hydraulic conditions in the analysis are based on the results of the WCOBRA/TRAC analysis at 850 seconds after LOCA event as for 4.2.1.3 (1) above. The uniform value of heat transfer coefficient is [] BTU/hr-ft²-°F ([] W/m²-°C) in the analyses, conservatively. This is the minimum value in the modeling area and the lower value in the grid region. The bulk coolant temperature of the coolant is [] °F ([] °C) as the estimated value in the modeling region.

(3) Geometric Conditions

The outer and inner diameter of the cladding is 0.374 inch (9.50 mm) and 0.329 inch (8.36

mm) as the fabricated value, respectively. These analyses apply the maximum heat flux uniformly based on the inner diameter of the cladding because the cladding diameter affects the value of the heat flux on the cladding surface. The cladding material is ZIRLO™, but there is no impact for the surface temperature of the cladding.

The US-APWR fuel has 11 grids installed the mixing vane except for the top and bottom grid as shown in Figure 4.2.1-1. No.8 grid counted from the bottom is located in the modeling area including the maximum heat flux point as shown in Figure 4.2.1-3. The uniform heat flux is applied on the inner surface of the cladding so that the model considers the maximum value of heat flux at the grid. The grid axial height is the fabricated value, [] inch ([] mm).

+ ZIRLO™ is a registered trademark of the Westinghouse Electric Corporation.

(4) Assumptions

- ✓ All the debris accumulating on the cladding at the grid distributes and accumulates uniformly. Therefore, the thermal properties of the debris have homogeneity in the analyses.
- ✓ The debris assumed in the analyses is wet and there might be some limited amount of convection inside. The analyses conservatively take into account no convection in the debris.
- ✓ The thermal conductivity of the debris is assumed to be same with CRUD thermal conductivity. It is reported that the thermal conductivity of the CRUD is 0.5 BTU/hr-ft-°F (0.29 W/m-°C) (Ref.4.2-1). The analyses apply the parameter study about the thermal conductivity, with values varying from 0.1 BTU/hr-ft-°F (0.058 W/m-°C) to 0.9BTU/hr-ft-°F (0.52W/m-°C) at 0.2BTU/hr-ft-°F (0.12W/m-°C) intervals.
- ✓ The debris thickness varies from 0mils (0µm) to 50mils (1270µm) at 10mils (254µm) intervals. The distance between the cladding surface and the grid strap determine the maximum value of the debris thickness. The grid structures, such as spring and dimple, might define the debris thickness because they are located near by the cladding compared with the grid straps.
- ✓ The inlet is the top or bottom of core region for the bypass debris to reach up to the core. Therefore, the top or bottom grid might have probability for clogging debris compared with the intermediate grids. The analyses conservatively assume that the clogging debris occurs at the maximum heat flux position.
- ✓ An Adiabatic assumption is conservatively applied for the axial heat transfer which might exist on both the upper and bottom horizontal surface of the debris at the grid.
- ✓ The material of the springs and dimples supporting the fuel cladding has the same

thermal conductivity with the accumulating debris. This assumption is conservative because the metal material generally has higher thermal conductivity compared with the debris.

- ✓ The analyses have no heat barrier between each material, such as cladding and accumulating debris.

4.2.1.4 Results

Table 4.2.1-1 and Figure 4.2.1-4 show the maximum temperature at the cladding surface as results of the parameter study varying the thermal conductivity and the thickness of the accumulating debris. The maximum temperature is analyzed at the grid central position. The analyses show that the maximum temperature at the cladding surface with accumulating debris is [] °F ([] °C) in the worst case which uses 0.1 BTU/hr-ft-°F and 50 mils for the minimum thermal conductivity and maximum thickness of the debris, respectively. This temperature bounds the other results of this parameter study. The all analyzed temperatures at the cladding surface meets the acceptable temperature which is [] °F as described in Appendix C. Therefore, the cladding cooling is acceptable in the case of debris clogging at the grid straps after a LOCA. The conservatisms used in the inputs and assumptions described in Section 4.2.1.3, especially in the assumption of the maximum heat flux due to the decay heat, reinforce this result.

Table 4.2.1-1 Cladding Metal Surface Temp. vs Debris Thickness

Debris Thickness (mils)	Debris Thermal Conductivity (BTU/hr-ft-°F)				
	0.1	0.3	0.5	0.7	0.9
	Deg. °F (deg. °C)	Deg. °F (deg. °C)	Deg. °F (deg. °C)	Deg. °F (deg. °C)	Deg. °F (deg. °C)
0					
10					
20					
30					
40					
50					




Figure 4.2.1-1 Mitsubishi Grid Spacer (Z3 Type) Schematic View




Figure 4.2.1-2 Schematic Drawing of the Analysis Model




Figure 4.2.1-3 Heat Flux on the Hot Rod at 850 seconds after LOCA Event



Figure 4.2.1-4 Cladding Metal Surface Temp. vs Debris Thickness

4.2.2 Trapping Debris on Cladding Surface

The cladding temperature should meet the acceptable temperature as described in Appendix C. In the case of the debris accumulating on the cladding surface between each grid, the accumulating debris might affect the cladding surface temperature.

The characteristics of bypass debris of the US-APWR are defined in Appendix D, and in Subsection 3.3 of separate technical report (Ref 3-12). As defined, the bypass debris of the US-APWR consists of NUKON fiber, coating particles, and latent particles. In general, it is considered that the particulate will pass through the fuel region unless the fiber debris bed is formed at cladding and capture the fine particles.

Since the bypass debris (NUKON fiber) is defined as very fine because of the filtering ability of the sump strainers, it is very unlikely that it forms debris bed at cladding (Ref.4.2-2). Therefore, the fibrous debris will pass through the cladding surface between the grids, and no fibrous bed will be formed on the cladding surface. The test results (Ref. 4.1-5) also show that there is no accumulation of fiber debris on the cladding surface between the grids. The effects of the chemical debris are described in Section 4.3.

4.3 Chemical Effects on Fuel Rods

The supply of coolant containing chemical effects products in the recirculation sump water may affect fuel rods in the core after starting post LOCA recirculation. Chemical effects testing were performed to obtain experimental data under simulated plant conditions on the corrosion products that may form in a post-LOCA environment for the US-APWR (Ref. 3-14). The testing provided compositions, characterize properties, and quantify masses of chemical reaction products that may develop in the containment under a representative post-LOCA environment. In regard to coatings it will be unlikely that coatings affect chemically heat removal in the core during a post-LOCA since the standard US-APWR will utilize only DBA epoxy coating systems in containment and the coolant that might contain coatings will not get exposed to such high temperature as likely to have effect on the core.

Epoxy coatings were similarly not considered in the joint USNRC and nuclear industry integrated chemical effects testing – see NUREG-6914, Integrated Chemical Effects Project: Consolidated Data Report (Ref. 4.3-1). Epoxy coatings have been shown to be chemically resistant in both highly acidic and caustic environments. ASTM D-3911 requires the specific conditions anticipated following a loss of coolant accident that would expose the coated surface of the containments to the temperature-pressure environmental parameters described in Reference 4.3-2. Typical DBA testing parameters in that reference shows a temperature condition of [], meaning that epoxy coating systems qualified have been shown to be chemically resistant in high temperature such as [].

After debris-laden RWSP water reaches the core (See Appendix E.), the debris will not affect the ability to provide the required flow to maintain adequate core cooling, as shown in Ref. 4.1-5. Since the core is quenched during the long-term cooling (See Figure. G.2-11 in Appendix G.), the cladding temperatures will be maintained at around a saturation temperature, which is well below [].

Parametric cladding heat-up calculations described in Section 4.2.1 were performed for a blocked grid. These parametric calculations show that for a precipitate with a sufficiently small value for thermal conductivity and a sufficiently large value of deposited thickness, cladding surface temperatures in excess of [] may be predicted. However, these same calculations also demonstrate the temperature of the precipitate surface at the boundary of the coolant, where coatings debris might be expected to collect at higher than a temperature, is

within about 20°F of the adjacent coolant temperature at the time of estimation. From the fuel rod heat-up calculations described in Section 4.2.1, the surface temperature of the precipitate surface is calculated to be less than [] at the time of evaluation with heat transfer considering state of coolant in the core.

Hence epoxy coatings are evaluated to be chemically inert in the post-LOCA chemical environment for the US-APWR and therefore have a negligible effect on post-LOCA precipitant production. Thus, epoxy coatings are evaluated to not present a concern with respect to long-term core cooling.

The following section 4.3.1 discusses predicting the cladding temperature with deposits of chemical impurities after a LOCA.

4.3.1 Chemical Deposition on the Cladding

The supply of coolant containing chemical effects products in the containment vessel may cause precipitation on the cladding after starting post LOCA recirculation. This precipitant on the cladding may reduce the heat transfer from the fuel, thus causing a rise in fuel temperature. In this section, the cladding temperature after LOCA was evaluated using the chemical effect testing data (Ref. 3-14).

4.3.1.1 Introduction

The reactor containment vessel of the US-APWR is designed to seal in radioactive products and to facilitate core cooling after a LOCA. In LOCA scenarios, RWSP collects the water discharged from the break and containment spray water containing chemical impurities and debris. The water is recirculated into the core by the ECCS and into the containment spray by the CSS. Then the chemical impurities and debris resulting from the chemical interaction between coolant and containment materials may move into the core.

The NRC issued specific guidance to the industry for responding to the chemical effects on the core at the GSI-191 Resolution Status Meeting of February, 2007 (Ref. 4.3-4). NRC asked that submittals intended to demonstrate the viability of long-term core cooling should meet the following requirements specific to chemical effects concerns:

1. Chemical concentration effects due to long-term boiling should be assessed.
2. The plate-out of deposits on the fuel rods should be considered.

MHI has carried out the chemical effect testing focusing on the ECCS of US-APWR to determine the chemical concentration effects (Ref. 3-14). The cladding temperature during post-LOCA will be evaluated by the data of chemical impurity concentrations in the chemical effect tests for the US-APWR. MHI chose to evaluate further these issues and their effect on the viability of long-term core cooling for the US-APWR.

4.3.1.2 Objective

The overall methodology deals with calculating the deposition of chemical impurities in the reactor coolant on the cladding surface and then quantifies the impact these deposits for raising the calculated cladding temperature. The purpose of this evaluation is to predict the cladding temperature with deposits of chemical impurities after a LOCA, which are dissolved or suspended in the recirculation sump water during long-term cooling for the US-APWR.

4.3.1.3 Methodology

4.3.1.3.1 Discussion of Major Assumptions

The deposition method makes several assumptions that are conservative, and, as a result, the predictions of deposit thickness and fuel surface temperature should be considered to be bounding rather than a best-estimate.

1. Deposits, once they have been formed, will not be thinned by flow erosion or by dissolution.
2. All deposition takes place on the fuel cladding.
3. Any mist carry-over, which will discharge potential deposits, does not happen in the steam exiting in reactor vessel. Thus, the concentration of such impurities in the core will be maximized, and thicker deposition will be calculated for this elevated concentration of chemical impurities.
4. The boiling point elevation due to the concentration of solutes is not considered. This model will lead to a slight over-estimation of boiling in the core, resulting in a conservative evaluation. In contrast, the boiling point elevation due to head loss caused by the broken loop flow is considered since the less evaporative latent heat is with increasing pressure the more chemical impurities will be deposited.
5. The deposition rate by boiling is equal to the steaming rate times the impurity concentration. When boiling is terminated, decay heat release is conducted by transmission without boiling. The deposition rate by non-boiling is assumed to be proportional to heat flux and is 1/80 of that of boiling deposition at the equal heat flux. This ratio is based on empirical data under boiling and non-boiling conditions (Ref. 4.3-4). For the conservatism starting time of non-boiling is determined based on a time whole the core boiling is terminated.
6. The deposition of impurities on the fuel cladding surface is assumed to be proportional to local heat flux according to the core power distribution. The estimation is conducted at largest heat density position because higher heat flux results in higher temperature and thicker deposition of fuel cladding surface.




Figure 4.3.1-1 Schematic Model

4.3.1.3.2 Debris Dissolution and Corrosion Rates

The chemical impurities concentrations in the containment pool are estimated from a separate series of chemical effect tests. These concentrations are then used as the input concentrations in the recirculation water flowing into the reactor vessel, which forms the basis for the evaluation of downstream deposition in the core.

The chemical reaction product deposition rate in the core is only affected by the concentrations of the impurities in the inflow, not by the upstream (in containment) dissolution rate. In other words, the same concentrations of chemical impurities in the inflow caused by different dissolution rates in containment result in the same rate of core deposition. If the concentrations are lower, then the rate of the core deposition should be less, irrespective of the corrosion rate.

This is an important consideration because the chemical effects tests are modeled without the core, in which the impurities generated within the containment vessel might be deposited. Thus, these experiments do not simulate the effect of the core, which would be to decrease the impurities concentrations of the coolant water that recirculates back through containment via the break flow and the condensated pure steam vaporized in the core. As a result, the evaluation used sump impurities concentrations that are conservatively high because they neglect this concentration lowering effect caused by core deposition.

It should be noted that when the deposition within the core happens, thereby decreasing the impurities concentrations in the return flow to containment, the subsequent dissolution rates of materials in containment, and hence generation of new chemical impurities, may be accelerated because of lowering concentrations relative to their saturation limits. However, even with this increased rate of dissolution, the resulting concentrations are not expected to exceed those determined from experiments in which deposition is not simulated.

4.3.1.3.3 Modeling of the Core

The estimation is conducted at largest heat density position because higher heat flux results in higher temperature and thicker deposition of fuel clad surface. Decay heat power at the highest heat flux identified peaking factor in the core was used.

4.3.1.3.4 Calculation of Deposition Mass and Fuel Temperature

The following process was used in this to determine the quantity of the deposition of impurities. First, the temperature at the zirconium oxide/deposit interface was calculated using

$$T_{o/d} = q * (x_c/k_c + x_l/k_l + 1/h) + T_c \dots \dots \dots (4.3.1-1)$$

where:

$T_{o/d}$ = Temperature at the cladding surface (K)

T_c = temperature of the coolant (K)

q = heat flux at maximum heat load (W/m^2)

x_c = thickness of the initial crud layer (m)

x_l = thickness of the LOCA scale layer (m)

k_c = thermal conductivity of the initial crud layer ($W/m/K$)

k_l = thermal conductivity of the LOCA scale layer ($W/m/ K$)

h = heat transfer coefficient for thermal resistance of coolant at boundary layer ($W/m^2/K$)

The mass of impurity elements deposited during a time step was calculated simply by multiplying the steaming rate times the concentration of that species.

$$dw = q * dt * C / hfg \dots \dots \dots (4.3.1-2)$$

where:

dw = deposit mass for time step at unit area (kg/m^2)

dt =time step (s)

hfg =standard enthalpy of vaporization (Joules/kg)

q = heat flux at maximum heat load (W/m²)

C =concentration of species (kg/kg)

Impurity concentration was treated as a summation of each impurity element.

The thickness added to the LOCA scale was then determined by dividing the mass deposited within the node by the density times the area. Smallest density among assumed deposition elements was used for conservative estimation.

$$dx = dw / D \quad \dots\dots\dots(4.3.1-3)$$

where:

dx is the increase in the deposit thickness for the node

D = density (kg/m³)

If boiling is terminated, growth rate of deposition estimated by (4.3.1-2) is assumed to be 1/80 of that of boiling deposition at the equal heat flux. (Ref. 4.3-4). The core outlet fluid condition is estimated by using minimum safety injection flow rate, core decay heat and core inlet coolant temperature identified with that of recirculation sump water. For the conservatism starting time of non-boiling is determined based on a time whole the core boiling is terminated.

As a result of the chemical equilibrium calculation with OLI StreamAnalyzer™ computer program, the form of the chemical depositions on the cladding are predicted to include: Al(OH)₃, AlOOH, NaAlSi₃O₈, Zn₂SiO₄. The results of the separate effects dissolution experiments will be used to provide quantification of the relative amounts of these species.

The scale layer density which dominates the layer thickness and thermal conductivity are set independently. Thus the lowest density and the lowest thermal conductivity lead to conservative evaluation. The scale deposited on the boiling surface is assumed to be generally from 40 to 58% of porosity with the knowledge described in Ref. 4.3-5, 4.3-6, 4.3-7. Here, the porosity of the deposited scale is assumed to be at 60%.




Figure 4.3.1-2 Temperature Estimation Method

4.3.1.4 Input Condition

The recirculation sump water that interacted with the materials in the containment vessel was assumed to arrive at the reactor vessel at 850 seconds after the beginning of the LOCA (Appendix E). Hence, the evaluation is used the period from 850 seconds to 30 days after LOCA.

4.3.1.4.1 Heat Condition

1. Decay heat

Decay heat is assumed to be based on ANS-1971 x 1.2 fission product decay curve. Heat flux utilized in this estimation is calculated as maximum value taken into account peaking factor.

2. Boiling termination time

Boiling was assumed to be terminated at 8 days (=192 hours) after the beginning of a LOCA by using following assumption.

At the cold leg break LOCA, during which boiling continues for a longest time, Safety Injection water supplies from bottom of core through downcomer. Because core is cooled by safety injection water from bottom, boiling shall be terminated from bottom to top sequentially.

Boiling termination time is assumed to be estimated as the time when the energy increase of core inlet coolant calculated by sensible heat, minimum flow rate and core inlet water enthalpy of safety injection becomes beyond above decay heat of whole core.

Because boiling duration time estimated by global heat balance is longer than that estimated by local thermal hydraulic parameter at the place of maximum heat flux, this estimation concludes to have conservatisms.

3. Fluid temperature of core

Fluid temperature is chosen as 294°F. This temperature is taken into account 10°F margins of maximum temperature in containment vessel in estimated duration. Although fluid temperature decreases as time goes by, fluid temperature assumed to be constant for conservatisms.

4. Initial crud condition

Initial crud thickness utilized in this estimation is assumed as summations of initial maximum oxidation layer thickness ([]) which means allowable maximum cladding oxidation that complies with 10 CFR 50.46 and initial maximum crud layer thickness ([]). Smaller thermal conductivity of initial crud is chosen in order to estimate conservatively.

4.3.1.4.2 Chemical Condition

The chemical debris for calculation are defined by the result of the chemical effect tests that represent the recirculated sump chemical concentrations after a LOCA in the US-APWR. The tests temperatures were controlled to be higher than the estimated temperature to ensure conservative production of corroded material.

The water properties in the ECCS and CSS after a LOCA in the US-APWR will transform as follows:

The sum of the dissolved materials and the precipitation after dissolution from those materials (the total impurities) was used as the input condition of the water entering the core for the evaluation of the deposition during boiling and non-boiling.



Figure 4.3.1-3 Impurity Concentrations Trend at Core Inlet

The procedure used for predicting trends of dissolution is as follows:

1. Prediction is based on the concentration trend of the recirculation test at 149°F for 30 days.
2. Remaining concentration balances of the autoclave test result at transient higher temperature after deduction of the one at constant temperature of 149°F is added to the recirculation test result at 149°F for each element.
3. When the concentration decreased as time progressed, the concentration is kept constant after the maximum point.

Predicting trends of dissolution is shown in Figure 4.3.1-3.

4.3.1.5 Result of Calculation

The calculated results are shown in Figure 4.3.1-4. 0 second in Figure 4.3.1-4 means the beginning of a LOCA and the figure shows the results after 850 seconds.

It is shown that scale gradually increases during the LOCA. However, after boiling termination, LOCA scale growth rate obviously decreases. LOCA scale thickness becomes about 390 microns at 30 days (720 hours) after the LOCA. It is concluded that the deposited LOCA scale will not block coolant flow path and has no influence upon fuel cladding cooling.

Fuel cladding temperature gradually decreases because the effect of the reducing decay heat is larger than temperature increase effect regarding with thermal resistance of scale formed during the LOCA. Maximum temperature of fuel cladding after recirculation was started was []. Fuel cladding temperature was verified to be maintained lower than [] temperature criteria during the entire evaluation period.



Figure.4.3.1-4 LOCA Scale Thickness and Fuel Cladding Temperature

4.3.1.6 Conclusions

Cladding temperature with deposits of chemical impurities after a LOCA environment for the US-APWR was evaluated.

It is concluded that structural integrity of fuel cladding is retained because scale formed during the LOCA will not have effects on the coolability and fuel cladding temperature will be maintained lower than upper criteria limit.

4.4 In-Core Effects

4.4.1 Chemical Effect on Boric Acid Precipitation Evaluation

The US-APWR design uses boron as a core reactor reactivity control method, and there is a procedure that instructs the operators to switch operating DVI lines over to the hot leg injection line (simultaneous reactor vessel and hot leg injection) no sooner than about four (4) hours after the postulated large break LOCA to prevent the core region boric acid concentration from reaching the precipitation point. The switchover time is determined by a method, as described in the DCD Chapter 15, based on assumptions regarding mixing in the reactor vessel (Ref. 3-10).

An analysis method with an appropriate evaluation model is applied to control the boric acid precipitation during long term cooling after LOCA and is similar to that for US representative PWR plants (Ref. 3-10). Generally in the boric acid precipitation evaluation for a PWR plant, only cold-leg break evaluation, which should be the limiting case, is performed,

The limiting scenario for boric acid precipitation is a cold leg break where the core is stagnant with only enough core inlet flow to replace core boil-off. For this scenario, lower plenum flow rate is approximately a factor of 2 to 3 magnitude less than maximum flow rate in the hot leg break case. Furthermore, the spilled SI flow would be repeatedly re-filtered through the sump strainers. Since the volume of settled debris in the lower plenum would be approximately proportional to the flow into the lower plenum, the maximum volume of settled debris in the lower plenum for a cold leg break would be small.

Boric acid precipitation is not an issue for a hot leg break since forced flow into the reactor vessel such that boric acid accumulation will not occur is expected.

Therefore, as for the US-APWR that has similar boric acid concentrating mechanism to that of a representative PWR in the US, the limiting scenario for boric acid precipitation is also a cold leg break.

(1) Effect of Suspended and Settled Sump Debris on Mixing Volume

The suspended debris and settled debris ingested into the core region through the strainers may have some impact on the assumed mixing volume for the evaluation of boric acid concentration during the post-LOCA long term cooling. The debris in the coolant

in the reactor vessel would replace water volume that would otherwise dilute the boric acid in the core region. The amount of debris that bypasses the sump strainer is assumed as some fiber and all of particulate for the US-APWR. The amount of bypass debris that may exist in the mixing volume or that may affect the mixing volume is shown in Appendix-D. The replaced volume of debris shown in Appendix- D would be a small fraction of the liquid mixing volume used for the evaluation of US-APWR boric acid concentration, which is assumed to be that of lower plenum, since the US-APWR has large lower plenum volume of more than one thousand cubic feet.

(2) Effect of Core Inlet Blockage on Mixing Volume

Core inlet blockage due to accumulated sump debris may slightly effect the predicted rate of boric acid concentration accumulation in the core, depending on the specific mixing volume assumptions used in a given boric acid precipitation analysis. However, significant core inlet blockage will not take place, as show in Ref. 4.1-5, and will not impede flow between the lower plenum and the core region. Therefore, the core region liquid inventory would not be significantly affected, and the core region mixing volume used in the US-APWR analyses would remain effective.

(3) Effect of Blockage on Alternate Core Coolant Flow Paths

Sump debris may accumulate sufficiently to block several alternate coolant flow paths to the core that are expected to dilute the boric acid in the core.

Examples of these flow paths are flow through the neutron reflector region, flow through the hot leg nozzle gaps, and flow to the core from the upper plenum (after switchover to hot leg injection). Only the hot leg nozzle gaps are small enough to capture bypass debris. The US-APWR boric acid precipitation analysis method does not credit the hot leg nozzle gaps as dilution flow path assumptions used in that analysis. There will not be the alternate core flow paths that should be considered to be significant blockage for boric acid precipitation evaluation since the flow areas are enough large as mentioned in section 4.1 and are not effective debris traps or filters.

For hot leg breaks, dilution flow is not needed since the core would keep diluted with forced SI flow entering the core through the core inlet. For SI flow to the hot legs after hot leg switch over, the core dilution process would not be impeded unless entire or severe blockage of flow in the upper plenum occurred. Entire or severe blockage between the upper plenum and the core is not expected to occur as described in section 4.4.3.

(4) Effect of Chemical Compounds on Boric Acid Precipitation in the Core Region

Mixing in the core will continue due to convection, diffusion, local turbulence, and bubble mixing phenomena, with little or limited bypass debris accumulating in the core, at the core inlet, or in the lower plenum.

For the flow conditions of the boric acid precipitation scenario, considering chemical compounds of boric acid, there will not be sufficient chemical debris effects on the boric acid to invalidate the licensing basis boric acid precipitation analyses for the US-APWR. Therefore, it is concluded that chemical debris would not significantly affect the boric acid precipitation assessment.

4.4.2 Fuel Swelling and Blockage

Swelling and rupture of the fuel rod cladding during design basis LOCAs is one of the phenomena which licensees are required to evaluate under Appendix K to 10 CFR Part 50. Following a large break LOCA, some of the fuel rods in the core may swell and rupture leaving sharp edges at the rupture locations and a diminished channel flow area. Debris may collect in the restricted channels and at the rough edges of the rupture locations. It is necessary to evaluate the possibility that excessive blockage is produced by the combination of swelling and rupture and debris collection. Such blockage might produce the occurrence of hot spots above the blockage location.

The debris that flows in RCS will pass the bottom nozzle and, based on the expected location of the swelling and rupture, several grids before reaching the rupture location. Therefore, the accumulation of significant debris at the localized rupture location is not generated easily compared with other places where fibers are more likely to gather before the hot leg switchover. Additionally, there would only be a limited number of fuel rod cladding ruptures in the reactor core, and, rupture is most likely to occur in the highest power fuel rods in the highest power assemblies.

Therefore, there is little possibility that significant blockage will occur due to fuel swelling and fuel rupture in the large break LOCA scenario.

4.4.3 Hot Leg Injection

The US-APWR design uses ECCS hot leg injection no sooner than about four (4) hours after occurrence of the postulated LBLOCA. At this switchover time, the coolant in the RWSP is expected to have been circulating through the ECCS and CSS several times. Therefore particulate and fibrous debris, which is generated by the initial RCS break flow and CS water flow back into the RWSP, is expected to be depleted either by capture on the strainer or by settle-out in low flow rate regions, such as the lower plenum. Thus, the amount of debris injected during the hot leg injection mode is expected to be small enough that the core cooling will not be significantly affected by the debris.

Furthermore, core flow rate would be maintained high enough to remove decay heat since the core power at hot leg switch over (HLSO) decreases to around one third of that at the time core quench is completed.

For CL breaks during HLSO mode, coolant is injected into the RV from the HL piping and flows down through the core and goes out the break. Debris entrained in the coolant injected from HL piping may accumulate in the core. However, as described above, core coolability will be maintained since the core flow rate required for decay heat removal decreases and debris is expected to decrease at this switchover time. To confirm the effect on core coolability due to the core blockage during HLSO with CL break such that core flow would be downward, a core blockage test was performed simulating HLSO with CL break (Ref. 4.1-5). This test was conducted with the maximum debris loads. The test result demonstrated that the pressure drop measured is less than what is required to maintain core flow in HLSO mode, consequently, sufficient flow will reach the core to remove core decay heat and core coolability is maintained in the event of downstream debris build up.

4.5 Regulatory Summary (In-Vessel)

As described in section 3.6, the US.NRC requested holders of operating reactor licenses to evaluate their ECCS and CSS recirculation functions in light of events regarding the blockage of containment sump strainer (Ref. 3-1, Ref. 3-2). The discussions in this report have included ex-vessel downstream effects and in-vessel downstream effects, which the US.NRC has clarified with the issuance of reference 3-3 and Reference 4.5-1.

These references were intended to address the US.NRC concerns identified in Reference 3-2. There are no other regulatory guidance documents that specify the evaluation of in-vessel downstream effects appropriately. Therefore, addressing the issues identified in the “Review Guidance”(Ref. 3-3) and “Audit Plan” (Ref. 4.5-1) documents should address the concerns identified in Reference 3-1.

Table 4.5-1 shows sections excerpted from “Review Guidance” (Ref. 3-3) and “Audit Plan” (Ref. 4.5-1) and the section in this report where it is addressed.

Table 4.5-1 (a) In-Vessel Downstream Effects Regulatory Review (Ref. 4.5-1)

Downstream Effects on Fuel Checklist(Ref. 4.5-1)	Response
Analyses that should be provided - Potential to clog lower core due to flow induced debris bed.	Report Section 4.1.
- Potential to clog lower core due to filling the lower vessel with a volume of debris.	Report Section 4.1
- Potential for a mid-core blockage (Potential for capture of debris at grid straps or buildup via adhesion (most likely more of a CL LOCA concern)).	Report Section 4.2.
- Potential for heat transfer loss from a chemical film (interaction of high boric acid concentration with debris characterization).	Report Section 4.3.
- Potential for hot leg recirculation to clog upper core – by flow induced debris bed	Report Section 4.4
- Potential for hot leg recirculation to clog upper core – by volume of debris	Report Section 4.4

Table 4.5-1 (b) In-Vessel Downstream Effects Regulatory Review (Ref. 3-3)

xviii. Review the evaluation of downstream effects on reactor fuel and in-vessel components. (Ref. 3-3)	Response
(1) Volume of debris injected into the reactor vessel and core region	Report Section Appendix D.
(2) Debris types and properties	Report Section Appendix D.
(3) Contribution of in-vessel velocity profile to the formation of a debris bed or clog	Report Section Appendix D.
(4) Fluid and metal component temperature impact	Report Section Appendix G and 4.2.1
(5) Gravitational and temperature gradients	Report Section Appendix G and 4.2.1
(6) Debris and boron precipitation effects	Report Section 4.4.1
(7) ECCS Injection paths	Report Section 4.4.1 and 4.4.3
(8) Core bypass design features	Report Section 4.4.1 and 4.4.3
(9) Radiation and chemical considerations	Report Section 4.3
(10) Debris adhesion to solid surfaces	Report Section 4.2
(11) Thermodynamic properties of coolant	Report Section Appendix G and 4.2.1

5.0 CONCLUSIONS

The intent of this technical report is to assess the US-APWR systems and components downstream of the containment sump strainers to ensure that these systems and components will operate as designed under post Loss-of Coolant Accident (LOCA) Conditions.

Downstream systems and components include the Emergency Core Cooling System (ECCS), Containment Spray System (CSS) and the reactor core. This report evaluates the effects of operating with debris-laden, post-LOCA fluid.

This report concludes that the US-APWR Emergency Core Cooling System, Containment Spray System and their components are fully capable of performing their intended functions under post-LOCA operating conditions. I.E. the ECCS and CSS are fully capable of providing adequate core cooling to ensure the reactor core is maintained in a safe, stable condition following a Loss-of-Coolant Accident (LOCA).

The report concludes that debris-laden post-LOCA fluid will not plug or block the reactor core such that cooling flow is reduced below the required flow to maintain long-term core cooling. The report also shows that chemical induced local scale formation on the fuel cladding surface on reactor fuel cladding will not affect the ability to provide adequate decay heat removal. Cladding temperatures are maintained below those required by Section 50.46 of Title 10 of the Code of Federal Regulations (10 CFR).

6.0 REFERENCES

- 3-1 U.S. Nuclear Regulatory Commission, Potential Impact of Debris Blockage on Emergency Recirculation during Design Basis Accidents at Pressurized Water Reactors, Generic Letter 2004-02, September 2004
- 3-2 U.S. Nuclear Regulatory Commission, Final Safety Evaluation for NEI Guidance Report 04-07, December 6, 2004
- 3-3 T O Martin, Audit Plan for Verifying the Adequacy of Licensee Responses to Generic Letter 2004-02, USNRC Memorandum, T O Martin to M G Evans, December 5, 2006
- 3-4 U.S. Nuclear Regulatory Commission, Final Safety Evaluation for Pressurized Water Reactor Owners Group (PWROG) Topical Report (TR) WCAP-16406-P, December 20, 2007
- 3-5 Water Sources for Long-Term Recirculation Following a Loss-of-Coolant-Accident, Regulatory Guide 1.82 Revision 3, November 2003
- 3-6 U.S. Nuclear Regulatory Commission, Managing Gas Accumulation in Emergency Core Cooling, Decay Heat Removal, and Containment Spray Systems, Generic Letter 2008-01, January 2008
- 3-7 U.S. Nuclear Regulatory Commission, Effects of Insulation Debris on Throttle Valve Flow Performance, NUREG/CR-6902, March 2006
- 3-8 Design Control Document for the US-APWR Chapter 5, Reactor Coolant and Connecting Systems, MUAP-DC005 Revision 3, March 2011
- 3-9 Design Control Document for the US-APWR Chapter 6, Engineered Safety Features, MUAP-DC006 Revision 3, March 2011
- 3-10 Design Control Document for the US-APWR Chapter 15, Transient and Accident Analysis, MUAP-DC015 Revision 3, March 2011

-
- 3-11 Design Control Document for the US-APWR Chapter 17, Quality Assurance and Reliability Assurance, MUAP-DC017 Revision 3, March 2011
 - 3-12 US-APWR Sump Strainer Performance, MUAP-08001-NP Revision 6, May 2012
 - 3-13 US-APWR Sump Debris Chemical Effects Test Plan, MUAP-08006-NP Revision 1, November 2008
 - 3-14 US-APWR Sump Debris Chemical Effects Test Results, MUAP-08011-P Revision 1, May 2012
 - 3-15 Tubular Exchanger Manufacturers Association, Inc., Standards of the Tubular Exchanger Manufacturers Association (TEMA), Eighth edition, 1999
 - 3-16 Pressurized Water Reactor Sump Performance Evaluation Methodology, NEI 04-07 Revision 1
 - 3-17 American Petroleum Institute, Centrifugal Pumps for Petroleum, Heavy Duty Chemical and Gas Industry Services, API Standard 610 (ISO 13709), September 2005 Edition
 - 3-18 Part A Ferrous Material Specifications, ASME Boiler and Pressure Vessel Code, Section II, 2004 Edition.
 - 3-19 Goddard, J., Abrasion Resistance of Piping Systems, ADS-Pipe Technical Note 2.116, Hillard, Ohio, November 1994.

 - 4.1-1 Not used.
 - 4.1-2 Not used.
 - 4.1-3 Not used.
 - 4.1-4 Not used.
 - 4.1-5 US-APWR Core Inlet Blockage Test for Test Conditions With Design Changes in
-

Recirculation Water Flow Path to Refueling Water Storage Pit, MUAP-12004-P,
Revision 0, August 2012

- 4.2-1 L.S.Tong, Y.S.Tang, “Boiling Heat Transfer and Two-Phase Flow”, 1965
- 4.2-2 U.S. Nuclear Regulatory Commission, “Knowledge Base for the Effect of Debris on Pressurized Water Reactor Emergency Core Cooling Sump Performance”, NUREG/CR-6808, February 1996
- 4.3-1. U.S. Nuclear Regulatory Commission, Integrated Chemical Effects Test Project: Consolidated Data Report, Volume 1, NUREG/CR-6914, 2006
- 4.3-2. U.S. Nuclear Regulatory Commission, Standard Test Method for Evaluating Coatings Used in Light-Water Nuclear Power Plants at Simulated Design Basis Accident (DBA) Conditions, ASTM D-3911-03, 2006
- 4.3-3 Walton Jensen, “In-Vessel Downstream Effects”, GSI-191 Resolution Status Meeting, February 7, 2007
- 4.3-4 A. Helaizadeh, H. Muller-Steinhagen, M. Jamialahmadi, “Crystallization Fouling of Mixed Salts During Convective Heat Transfer and Sub-Cooled Flow Boiling Conditions”, ECI Conference on Heat Exchanger Fouling and Cleaning: Fundamentals and Applications, Paper 6, Santa Fe, New Mexico , 2003
- 4.3-5 Energy and Environment Laboratory CRIEP Report, “Study on Measurement Method of Boiler Scale Porosity (Part 2) –Measurement of the Quantity and the Porosity of Boiler Scale by the Electrolytic Exfoliation Method -, 1978
- 4.3-6 The Thermal and Nuclear Power, Vol. 29, No. 6, 571-577, 1978
- 4.3-7 Proc 4th Int. Symp. Environ. Degrad. Mater. Nucl. Power Syst. Water React. 1989, 7.108-7.120, 1990

4.5-1. U.S. Nuclear Regulatory Commission, Draft NRC Staff Review Guidance for Evaluation of Downstream Effects of Debris Ingress into the PWR RCS on Long Term Core Cooling Following a LOCA, November, 2005.

Appendix A

ECC/CS Strainer / Safety Injection Pump Engineering Design Parameters

Table A-1 ECC/CS Strainer and Safety Injection Pump Design Parameters

Description	Specification
ECC/CS Strainer	
Hole diameter of perforated plate	0.066 inch
Equipment Class	2
Seismic Category	I
Safety Injection Pump	
Type	Horizontal multi-stage centrifugal pump
Number	4
Power Requirement	970 kW
Design Flow	1,540 gpm
Design Head	1,640 ft.
Minimum Flow	265 gpm
Design Pressure	2,135 psig
Design Temperature	300°F
Maximum Operating Temperature	Approximately 250°F
Fluid	Boric Acid Water
NPSH Available	See MUAP-08001
NPSH Required	18.8 ft. at 1540 gpm
Material of Construction	Stainless Steel
Equipment Class	2
Seismic Category	I
Post-LOCA Fluid Constituent	See Table 3.2-4
Leak Rate under Normal Seal Condition	< [] cc/h
Failure Leak Rate	< 50 gpm




Figure A-1 Safety Injection Pump Performance Flow Requirement




Figure A-2 High Head Safety Injection Flow Characteristic Curve (Minimum Safeguards)




Figure A-3 High Head Safety Injection Flow Characteristic Curve (Maximum Safeguards)

Appendix B

Containment Spray / Residual Heat Removal Pump Containment Spray / Residual Heat Exchanger Engineering Design Parameters

Table B-1 Containment Spray/Residual Heat Removal Pump Design Parameters

Containment Spray/Residual Heat Removal Pump	
Number	4
Type	Horizontal, centrifugal type
Power Requirement (kW)	400
Design Flow Rate (gpm)	3,000
Design Head (ft)	410
Minimum Flow Rate (gpm)	355
Maximum Flow Rate (gpm)	3,650
Design Pressure (psig)	900
Design Temperature (° F)	400
Material	Stainless Steel
Normal Operating Temperature (° F)	32 ~ 356
Fluid	Reactor coolant, Boric acid water
Radioactive Concentration (kBq/cm ³)	≥ 37
NPSH Available (gpm)	See MUAP-08001
NPSH Required (gpm)	19.7 ft at 3,650 gpm
Equipment Class	2
Post-LOCA Fluid Constituent	See Table 3.2-4
Leak Rate under Normal Seal Condition	< [] cc/hr
Failure Leak Rate	< 50 gpm

Table B-2 Containment Spray/Residual Heat Removal Heat Exchanger Design Parameters

Containment Spray / Residual Heat Exchanger		
Number	4	
Type	Horizontal U-tube type	
Heat Transfer Rate (Btu/h)	17.1 x 10 ⁶	
Overall heat Transfer Coefficient and the effective heat transfer area, UA (Btu/h/° F)	1.852 x 10 ⁶	
	Tube side	Shell side
Design Pressure (psig)	900	200
Design Temperature (° F)	400	200
Design Flow Rate (lb/h)	1.5 x 10 ⁶	2.2 x 10 ⁶
Design Inlet Temperature (° F)	120	99.7
Design Outlet Temperature (° F)	108.7	107.4
Material	Stainless steel	Carbon Steel
Fluid	Reactor coolant, boric acid water	Component cooling water
Radioactive Concentration (kBq/cm ³)	≥ 37	<37
Equipment Class	2	3




Figure B-1 CS/RHR Pump Characteristic Curve

Appendix C

Long-Term Core Cooling Acceptance Basis For GSI-191

The long term core cooling criteria described in this document are based on the requirements of Title 10 of the Code of Federal Regulations, Part 50.46 (10 CFR 50.46). The criteria are to be used with engineering evaluations that demonstrate acceptable and continuous long-term core cooling successfully after established following the initial recovery of the core subsequent to occurrence of LOCA.

An U.S. industry requested NRC clarify its long-term core cooling requirements under Title 10 of the Code of Federal Regulations Part 50.46 (10 CFR 50.46) to use in developing the GSI-191 debris ingestion evaluation method for reactor fuel (Ref. C-1).

It is requested that the US.NRC provides clarification of the requirements and acceptance criteria for long term core cooling once the core has quenched and reflooded.

The US.NRC responded to the request for clarification by the latter(Ref. C-2) that provides the basis for defining long term core cooling requirements that may be used to address long-term core cooling for GSI-191.

As described in the US.NRC response the long term core cooling acceptance bases defined for GSI-191 are applied after the initial quench of the core and consistent with the long-term core cooling requirements stated in 10 CFR 50.46 (b)(4) and 10 CFR 50.46 (b)(5). These acceptance bases provide for demonstrating that local temperatures in the core are stable or continuously decreasing and that debris entrained in the cooling water supply will not affect decay heat removal.

In order to demonstrate the long term core cooling related to the core and fuels of the US-APWR following acceptance bases are applied for cladding temperature in downstream effects evaluation.

The maximum temperature of the fuel cladding is maintained below [] in the situation of the debris reaching up to the core after LOCA. The maximum temperature, [], defines acceleration behavior of the cladding oxidation and the effects of the cladding mechanical properties due to hydrogen absorption. The autoclave corrosion tests for [] days proved that no-acceleration behavior of the cladding corrosion was observed below [] testing temperature. This acceptable temperature is based on the results of zircaloy-4 cladding test, give the conservatism for ZIRLO™ cladding.

REFERENCES

- C-1. “Requested NRC Action from Meeting with Westinghouse on April 12, 2006; Acceptance Criteria for Long-Term Core Cooling following Quenching and Reflooding of the Core; PWR Containment Sump Downstream Effects Resolution of GSI-191,” , LTR-NRC-06-46, July 14, 2006.
- C-2. Nuclear Regulatory Commission, Regarding Pressurized Water Reactor (PWR) Containment Sump Downstream Effects,” (Response to Westinghouse Letter LTR-NRC-06-46 Dated July 14, 2006), dated August 16, 2006

Appendix D

Volume of Debris for In-Vessel Downstream Effects Evaluation

D.1 Core reaching debris amount

This Appendix discusses amount of debris that would reaches core for the US-APWR. Design basis debris that would be generated after LOCA (plant debris) in the US-APWR plant is defined in Technical Report MUAP-08001 (Ref. D-1). Based on the value, core reaching debris amount shall be determined.

For the US-APWR downstream evaluation, following two debris reduction methods can be applied. Other debris reduction like debris trap on the way to core from debris generation point etc. is conservatively neglected.

1) Sump strainer bypass debris

Sump strainers are installed in the recirculation flow path and the strainer shall capture some amount of generated debris. The amount of debris that will be captured is discussed in the Appendix-J and evaluated () fibrous debris shall bypass the strainer. Although particle and chemical debris other than the fibrous debris shall be captured, it is assumed 100 % of them bypass the strainer conservatively.

2) Core bypass debris

In addition to above, core bypass flow could be taken into account only for Cold Leg Break condition. Considering it, all kind of debris (i.e., fibrous, particle, dirt/dust and chemical) can be reduced to () This value is supported by Appendix-I.

Summarizing above two methods, debris amount used for downstream evaluation can be reduced from plant generated debris as following table.

Table D-1 Core reaching debris amount vs. plant debris

--	--


Note

*1: Sump strainer bypass amount

*2: Core bypass debris amount

Based on the plant debris and Table D-1, core reaching debris quantity (DB quantity of downstream debris) will be as in Table D-2.

Table D-2 Core reaching debris quantity

A large empty table frame is shown, consisting of two vertical lines on the left and right sides, connected by short horizontal lines at the top and bottom. The interior of the frame is completely blank, indicating that the table content is missing or redacted.

D.2 References

D-1. US-APWR Sump Strainer Performance, MUAP-08001-P Revision 6, May 2012

Appendix E

In-Vessel Downstream Effects Evaluation Time

E.1 INTRODUCTION


The debris that potentially impacts downstream components of the US-APWR is generated upstream the sump strainer located in the refueling water storage pit (RWSP). The RWSP is provided as the water source for long term core cooling after a LOCA, and is located at bottom elevation of containment in order to collect containment spray and blowdown water by gravity.


The sump strainer system is designed to filter the debris transported to the RWSP. (Ref. E-1) However, a certain amount of fine debris which may pass through the perforated plate of the strainer system will move downstream in the system and reach the reactor vessel (in-vessel).


The purpose of this document is to demonstrate the time required for the debris to reach the reactor vessel after the accident. Shorter and more conservative time values were used for downstream evaluations provided in subsection 4.2.1, 4.3.1 and Appendix-G.


E.2 CALCULATION APPROACH















Figure E-3. Parameters Used in T2 Calculation



E.5 REFERENCE

- E-1 US-APWR Sump Strainer Performance, MUAP-08001(R6), May 2012, Mitsubishi Heavy Industries, LTD.
- E-2 LOCA Mass and Energy Release Analysis Code Applicability Report for US-APWR, MUAP-07012-P-A Rev. 2 and MUAP-07012-NP Rev. 2, June 2009, Mitsubishi Heavy Industries, LTD.

Appendix F

Confirmation of Calculation of Deposit Process by the Evaluation Tool

F.1 Introduction

To investigate confirmation of the evaluation tool with assumption described in session 4.3.1.3.1, deposition process was simulated by the evaluation tool. Experimental results referred by Brahim et al. (Ref. F-1) are chosen as confirmatory calculation.

F.2 Calculation condition

Calcium sulfate was deposited on an electrically heated tube in a laboratory test reported by Brahim et al. In the test, a calcium sulfate solution near saturation entered a tube at 176°F (80°C) and was heated causing precipitation on the heat transfer surface. The temperature of the heat transfer surface was monitored over time as calcium sulfate precipitant. The fouling resistance was calculated and plotted.

Because concentration of Calcium sulfate and heat flux were kept constant, fouling resistance could be expressed as the following equation by the analytical integration of the equation (4.3.1-2),

$$R = x / k = q C t / (D h_{fg}) / k \quad \dots\dots\dots(F-1)$$

where:

- R = fouling resistance (m²K/W),
- x = thickness (m),
- k = thermal conductivity (W/m/K),
- q = heat flux (W/m²),
- C = concentration (kg/kg),
- t = time (s),
- D = density (kg/m³),
- h_{fg} = latent heat (J/kg).

Thermal conductivity of deposition of Calcium sulfate depends on presentation of water in the pores (Ref. F-2). In this estimation, thermal conductivity of deposition was chosen as largest value without the pore.

F.3 Result

The agreement between the prediction by the evaluation tool and the experimental result by Brahim are shown in Figure F-1.

In this calculation, thermal conductivity of deposition was chosen as largest value in order to confirm conservative prediction by the estimation tool. Even if an assumption of largest thermal conductivity was utilized, fouling resistance became larger than the experimental results.

By conservative evaluation of fouling resistance compared with the experiment, it was concluded that this evaluation tool could conservatively predict chemical deposition processes.



Figure F-1 Comparison of Fouling Resistance for Calcium Sulfate Deposition

F.4 Reference

- F-1 Fahmi Brahim, Wolfgang Augustin, Matthias Bohnet, "Numerical simulation of the fouling process", International Journal of Thermal Science, Vol. 42, 2003, 323-334
- F-2 S. Krause, "Fouling of heat-transfer surfaces by crystallization and sedimentation", International Chemical Engineering, Vol. 33, 1993, 355-401

Appendix G

Boundary Conditions for Cladding Surface Temperature Evaluation

This appendix provides the methodology and results of the WCOBRA/TRAC(M1.0) calculation performed to set up boundary conditions for the cladding surface temperature evaluation described in Section 4.2

G.1 Model Description and Assumptions

This section discusses the nodalization and assumptions used for the WCOBRA/TRAC(M1.0) calculation.

G.1.1 Nodalization

The nodalization for the Post-LOCA calculation using WCOBRA/TRAC(M1.0) is same as that described in Reference G-1 and is briefly described as follows.

(1) Vessel Model



(2) Core Model





(3) Loop Model



G.1.2 Assumptions

The assumptions and conditions in the WCOBRA/TRAC(M1.0) calculation are described below.

The conditions and assumptions for the major LOCA parameters used in the boundary conditions calculation using WCOBRA/TRAC(M1.0) are listed in Table G.2-3. Those shown in Table G.2-3 are the same as US-APWR design certification LBLOCA reference transient case (Ref. G-2).

The selection of the limiting break

The limiting break will be a double-ended cold leg break, which has the minimum driving head contributing to the core flow.

The core radial and axial power distribution

The core channel radial and axial power distributions of US-APWR design certification LBLOCA reference transient case (Ref. G-2) used for the boundary conditions calculation are shown in Table G.2-4 and Figure G.2-9. As shown in Table G.2-4, the core radial power distribution is flat other than in the periphery assemblies and the hot assembly. The hot assembly power is conservatively modeled to a high normalized power of []. Moreover the top skewed power shape is limiting in the axial power distribution and this is due to the

longer time for the quench front to approach the elevation with the highest power.

Safety Injection Temperature

The safety injection temperature shown in Figure G.2-10 is used in the boundary conditions calculation to simulate the rise in RWSP water temperature over a long-term period during LOCA. Temperature change shown in Figure G.2-10 is based on the containment maximum pressure evaluation result at the time of LOCA (See DCD for the US-APWR Chapter 6, Engineered Safety Features, MUAP-DC006 Revision 3, March 2011).

The containment back pressure

The containment back pressure used in the boundary conditions calculation is based on the minimum pressure used in US-APWR design certification LBLOCA reference transient case.

G.2 Calculation Results

As shown in Figure G.2-11, the core is quenched about 200 seconds, and the hot rod peak cladding temperature is maintained at around the saturation temperature afterward.

Table G.2-1 Channel Descriptions for US-APWR Vessel Model (1/3)


A large, empty rectangular frame with rounded corners, intended for the table content. The frame is currently blank.

Table G.2-1 Channel Descriptions for US-APWR Vessel Model (2/3)




Table G.2-1 Channel Descriptions for US-APWR Vessel Model (3/3)


A large, empty rectangular frame with a thin black border, positioned centrally on the page. It is intended to contain the data for Table G.2-1, but the content is currently blank.

Table G.2-2 Gap Connections for US-APWR Vessel Model (1/2)




Table G.2-2 Gap Connections for US-APWR Vessel Model (2/2)




Table G.2-3 Calculation Conditions

Parameter	Values
Plant physical configuration	
Fraction of SG tube plugged	10% (maximum)
Hot assembly location	Under the open hole
Power-related Parameters	
Core power	4451MWt (100%)
Peaking factor (F_Q)	2.6
Axial power distribution	Top skewed (Figure G.2-9)
Hot rod assembly power ($F_{\Delta H}$)	1.78
Hot assembly burnup	Beginning of life (BOL)
Fuel assembly type	17 X 17 ZIRLO™ cladding
Initial RCS Fluid Condition	
RCS average temperature	583.8°F
Pressurizer pressure	2250 psia
Primary coolant flow	112,000 gpm/loop (thermal design flow)
Accident Boundary Condition	
Break location	Cold leg (in the loop with pressurizer)
Break type	Double-ended guillotine break
Discharge coefficient	1.0
Offsite Power	Not available
Number of SI pumps available	2
Safety Injection flow rate	Minimum
Safety Injection temperature	Figure G.2-10
Safety Injection delay	118 sec

Table G.2-4 Core Channel Radial Power Distribution





Figure G.2-1 US-APWR Vessel (Vertical View)



**Figure G.2-2 US-APWR Vessel Noding for Hot Assembly Under Open Hole
(Vertical View)**




Figure G.2-3 US-APWR Vessel Sections 1 to 2 (Horizontal View)




Figure G.2-4 US-APWR Vessel Sections 3 to 4 (Horizontal View)




Figure G.2-5 US-APWR Vessel Sections 5 to 6 (Horizontal View)




Figure G.2-6 US-APWR Vessel Sections 7 to 8 (Horizontal View)




Figure G.2-7 US-APWR Vessel Sections 9 to 10 (Horizontal View)




Figure G.2-8 US-APWR WCOBRA/TRAC(M1.0) Model Vessel/Loop Layout






Figure G.2-9 Power Shape



Figure G.2-10 Safety Injection Temperature



Figure G.2-11 Hot Rod PCT

G.3 References

- G-1. Large Break LOCA Code Applicability Report for US-APWR, MUAP-07011-P, Revision 1, March 2011
- G-2. Design Control Document for the US-APWR Chapter 15. Transient and Accident Analysis, MUAP-DC015 Revision 3, March 2011

Appendix H

Conservatism Applied to HL Break Test and HLSO Test Flow Rate Conditions

H.1 LOCA Scenarios

During the post-LOCA long term core cooling (LTCC), the core flow rate and its direction will affect the debris behavior in the core. Break locations and operational modes will affect the driving force related to margin for pressure drop when debris laden.

Table H-1 and Figure H-1 show three (3) representative LOCA scenarios identified in terms of break location and safety injection.

(a) Hot leg break (See Figure H-1(a))

When a Hot Leg (HL) break occurs, all the water injected by the ECCS goes through the core and then out of the break point. If a debris bed begins to build up in the core, the liquid levels begin to rise in the Cold Leg (CL) piping and the SG downflow side U-tubes, depending on the increase in the core pressure loss caused by the debris build-up in the core, and the water level in the SG downflow side U-tubes could finally reach the top of the shortest SG U-tube as shown in Figure H-1(a). This liquid level, which is the maximum possible driving force for the core flow, is determined by the pressure balance between the SG U-tubes and the break point irrespective of the number of operative safety injection (SI) lines (ex. 2xSI or 4xSI). All the injected water by the ECCS goes through the core without spilling over top of the shortest SG U-tube, as long as the core pressure loss is less than the maximum possible driving force. Table H-2(a) shows potential configurations of the SI system considering single failure and On Line Maintenance (OLM). This table also shows the number of operative SI lines. Each of the SI lines is equivalent independent of each other. Maximum core flow rate is provided with the 4xSI case and minimum core flow rate is provided with the 2xSI case considering single failure and OLM.

The LOCA scenario of HL break during the Hot Leg Switchover (HLSO) mode is covered by the HL break case as stated above, because the flow path is the same. Table H-2(d) shows potential configurations of the operating SI system considering single failure and OLM for LOCA scenario of HL break after HLSO.

(b) Cold leg break (See Figure H-1(b))

In the CL case, the downcomer water head is the only driving force for the core flow compensating the core for the steam boiling off in it, the actual driving force for the core flow is defined by manometer balance between the downcomer water level and the core collapsed water level. Since the excess SI flow will bypass the core and spill out of the bottom of the CL, the driving force will be maintained irrespective of the number of operative SI lines, as shown in

Figure H-1(b). Table H-2(b) shows potential configurations of the operating SI system considering single failure and OLM and the number of effective SI lines. Boil off core flow rate is provided with any SI lines because excess SI flow will bypass the core and spill out of the bottom of CL. For CL break the amount of debris that reaches the core is proportional to the amount of boil off core flow (See Appendix-I)

(c) Hot leg switchover (CL break after HLSO) (See Figure H-1(c))

The SI system is designed to switch some of DVIs over to HL injection at an appropriate time in order to prevent boron precipitation. In the case of the CL break, as shown in Figure H-1(c), the driving force for the downward core flow is the water head in the SG U-tubes, which increases in accordance with the increase in the flow resistance in the core. The maximum possible driving force corresponds to the level of top of the shortest SG U-tube on the upflow side and is achieved irrespective of the number of operative HL injection (SI) lines. As to the DVI, the maximum downcomer water level, which is established by the upward flow in the downcomer and prevents the downward flow in the core, corresponds to the bottom of CL piping regardless of the number of operative DVIs due to the core bypass flow through the downcomer to the break. Table H-2(c) shows potential configurations of operating SI system considering single failure and OLM. This table also shows the number of effective SI lines for CL break after HLSO. Maximum core flow rate is provided when 2xSI HL injection case and minimum core flow rate is provided when 1xSI HL injection case for this operative mode considering single failure and OLM.

The actual driving force for the core downward flow is determined in terms of the pressure balance between the downcomer and SG upflow side U-tube, similarly to the HL beak case, and therefore, the maximum driving force from the SG U-tube water head corresponds to the maximum allowable core pressure loss as shown in Figure H-1(c).

H.2 Available Pressure Drop ($DP_{\text{available}}$) Calculation

The available value for the increase in core pressure drop due to debris accumulation for each combination of operational modes and break locations is calculated as the driving force ($DP_{\text{driving force}}$) minus the RCS pressure loss without debris loads (DP_{flow}), as shown in Equation (1) (Reference H-1).

$$DP_{\text{available}} = DP_{\text{driving force}} - DP_{\text{flow}} \quad (1)$$

where

$$DP_{\text{driving force}} = \Sigma(\Delta Z \rho_l) / 144$$

$DP_{\text{driving force}}$: Driving force based on the manometric balance

ΔZ : height differential,

ρ_l : fluid density,

Σ : summation considering gravitational direction

$$DP_{\text{flow}} = K \rho_l v^2 / (288 g_c)$$

DP_{flow} : Pressure drop at core/loops flow rate without debris

K: loss coefficient,

v: flow velocity,

g_c : gravitational constant

As shown in Figure H-1, the driving force in Equation (1) is determined considering the combination of the operational mode and break location. As described in Section H.1, the driving force depends on the operational mode and break location, but not on the core flow rate, that is, the driving force is same for all the core flow rates.

The relationship between the flow rate and the core pressure drop (DP_{flow}) is formulated based on Darcy's law. The Darcy's law equation shows that for the larger the core flow rate, the larger the core pressure drop is calculated. Therefore, pressure drop in Equation (1) is determined by using the maximum flow rate (that is, the maximum pressure drop without debris, DP_{flow}) for each LOCA scenario.

H.3 Flow Rate Conditions for HL Break Tests and HLSO Test

The core blockage test aimed to confirm that the increase in the core pressure drop (Calculated DP) by debris load calculated from the test results is less than the available pressure drop ($DP_{\text{available}}$), as shown by Equation (2) (Reference H-1).

$$DP_{\text{available}} > \text{Calculated DP} \quad (2)$$

(Note: "Calculated DP" is the pressure drop adjusted to assumed actual plant values based on the simplified grid pressure drop test results. Details are described in Reference H-1).

The relationship between flow rate and core pressure drop shows a tendency as described in I.2. Since the core flow rate dominates the core pressure drop, it increases with the core flow rate and the maximum core flow rate yields the maximum core pressure drop. Therefore, it is most conservative to assume the maximum possible core flow rate to evaluate the maximum Calculated DP, so that the maximum possible core flow rate is selected for HL Break Tests and HLSO Test (see Table H-2(a), Table H-2(c)).

H.4 Core Coolability for HLSO post CL breaks and HL breaks

Although the core flow rate after HLSO post CL or HL break varies depending on LOCA scenarios (e.g. single failure, OLM), even one (1) of the available SIs is more than sufficient flow for core cooling compensating for boil-off flow at the point of HLSO when decay heat has sufficiently decreased. Therefore, the number of HL injections after HLSO post CL break has no impact on the core coolability required in 10CFR50.46 Appendix-K.

Table H-1 LOCA Scenarios during LTCC post LOCA

Break Location	Safety Injection System Operational mode	Flow rate	Core Flow Direction	Driving force
Cold Leg	Only DVI injection	Boil off flow rate	Upward	Small
Hot Leg	Only DVI injection	4SI (2SI – 4SI) *1	Upward	Large
Cold Leg	(After HLSO) Simultaneous DVI and HL injection	HL:2SI (HL:1SI – 2SI) ^{*1} (CL: 1SI – 2SI) ^{*1}	Downward	Large

*1 considering single failure and OLM

Table H-2(a) Potential configurations of operating SI system during LOCA (HL break)

Single Failure	OLM	Number of Effective SI trains	Core Flow rate	Note
Non	Non	4	4 SI flow rate	Maximum flow rate
1 SI	Non	3	3 SI flow rate	
Non	1 SI	3	3 SI flow rate	
1 SI	1 SI	2	2 SI flow rate	

- All of operative safety injection flow rate via DVI will go through core for any case.
- Maximum flow rate condition is selected in terms of confirming the allowable pressure drop (Eq.(2)) for HL break test cases and giving minimum allowable pressure drop ($DP_{available}$) (Eq.(1)).

Table H-2(b) Potential configurations of operating SI system during LOCA (CL break)

Single Failure	OLM	Number of Effective SI trains	Core Flow rate	Note
Non	Non	4	Boil off flow rate	Minimum flow rate
1 SI	Non	3	Boil off flow rate	Minimum flow rate
Non	1 SI	3	Boil off flow rate	Minimum flow rate
1 SI	1 SI	2	Boil off flow rate	Minimum flow rate

- All excess SI flow rate more than boil off flow rate will spill out from bottom of CL pipe level.
- Only boil off flow rate will be provided to the core for any case.

Table H-2(c) Potential configurations of operating SI system during LOCA (CL break after HLSO)


Single Failure	OLM	Number of Effective SIS trains	Number of HL injection trains	Number of DVI injection trains	Core Flow rate (HL injection)	Note
Non	Non	4	2	2	2 SI flow rate	Maximum
1 SI	Non	3	1	2	1 SI flow rate	
			2	1	2 SI flow rate	Maximum
Non	1 SI	3	1	2	1 SI flow rate	
			2	1	2 SI flow rate	Maximum
1 SI	1 SI	2	1	1	1 SI flow rate	

- All of operative safety injection flow rate via HL will go through core for any case regardless of number of HL/DVI injection because head of HL injection side has potential higher than that of DVI injection side for this scenario.
- In HLSO operation, number of HL injection trains available for core injection is sure to be one (1) or two (2) to prevent boric acid precipitation.
- Maximum flow rate condition is selected in terms of confirming the allowable pressure drop (Eq.(2)) for HLSO test case and giving minimum allowable pressure drop ($DP_{available}$) (Eq.(1)).


Table H-2(d) Potential configurations of operating SI system during LOCA (HL break after HLSO)

Single Failure	OLM	Number of Effective SIS trains	Number of HL injection trains	Number of DVI injection trains	Core Flow rate (HL injection)	Note
Non	Non	4	2	2	2 SI flow rate	
1 SI	Non	3	1	2	2 SI flow rate	
			2	1	1 SI flow rate	
Non	1 SI	3	1	2	2 SI flow rate	
			2	1	1 SI flow rate	
1 SI	1 SI	2	1	1	1 SI flow rate	


- Core flow direction is the same as HL break case.
- Each core flow rate of any case is covered with HL break cases (Table H-2(a)).
- All of operative safety injection flow rate via DVI will go through core for any case regardless of number of HL/DVI injection because head of DVI injection side has potential higher than that of HL injection side for this scenario.
- In HLSO operation, number of HL injection trains available for core injection is sure to be one (1) or two (2) to prevent boric acid precipitation.



(a) HL break



(b) CL break



(c) CL break after HLSO

**Figure H-1 Illustration of the Post-LOCA Conditions
(Quotation from Reference H-1)**

H.5 References

- H-1. US-APWR Core Inlet Blockage Test for Test Conditions With Design Changes in Recirculation Water Flow Path to Refueling Water Storage Pit, MUAP-12004-P, Revision 0, August 2012

Supplemental Information on Acceptance Criteria calculation

The allowable value is calculated by subtracting the pressure drop from the driving force based on each operational mode and break location, as shown in Eq.(1) (Reference H-1).

$$DP_{\text{available}} = DP_{\text{driving force}} - DP_{\text{flow}} \quad (1)$$

where

$DP_{\text{driving force}} = \Sigma(\Delta Z \rho_i)/144$: Driving force based on the manometric balance

ΔZ : height differentials,

ρ_i : fluid density,

Σ : summation considering gravitational direction

$DP_{\text{flow}} = K\rho_i v^2 / (288 g_c)$: Pressure drop at core/loops flow rate without debris

K: loss coefficient,

v: flow velocity,

g_c : gravitational constant

LOCA scenarios that determine the acceptance criteria post-LOCA is shown in Table H-3.

Table H-3 Representative post-LOCA conditions

Break Location	Safety Injection System Operational mode	Core Flow rate	Core Flow Direction
HL	Direct vessel injection (DVI)	Maximum for 4 SI pumps	Upward
CL	DVI	Minimum required (Boil off flow rate)	Upward
CL	DVI and hot leg injection	Maximum for 2 SI pumps	Downward

1) DP_{flow}

The actual plant flow rate for each operational mode and break location in Table H-3 is used to determine the pressure drop without debris DP_{flow} in Eq.(1). To calculate the pressure drop, flow pass shown in Figure H-1 in section H of this response is considered for each LOCA scenario. Method used to determine the pressure drop for each LOCA scenario is based on Eq. (1) above, which is the same manner with LOCA analysis.

The following are assumed to calculate pressure drop without debris DP_{flow} :

- Flow rate for each LOCA scenario is based on flow rate identified in “ DP_{flow} ” in Table H-4.
- Flow area and loss coefficient for each part is based on the values used in ECCS LOCA analyses.
- Fluid phase is assumed appropriately for each portion of flow path. (e.g. steam phase for upper plenum, HL pipe and SG, two-phase for core)

The following are assumed to boil off flow rate conservatively (CL break case):

- Decay heat : 1971 ANS infinite operation plus 20% is used.
- Decay heat at 850 sec is used to calculate larger boil off flow rate, This time, 850 sec, is consistent with downstream effects evaluation time. (See Appendix-E)
- 102% of rated power is used to calculate larger boil off flow rate.
- Heat up of coolant by sensible heat is ignored.

2) $DP_{driving\ force}$

Method used to determine the driving force based on each operational mode and break location is described in section H.

The following are assumed to calculate driving force:

- Use the minimum head height conservatively (based on each operational mode and break location. See Figure H-1 in section H)
- To apply conservatism, the core void fraction is set as 0 for HL break.
- The core void fraction and downcomer void fraction is set as 0 for HLSO post CL break.
- The core void fraction is set as 0.5 for CL break conservatively.
- Because pressure and temperature during long term core cooling to calculate the liquid density used has little impact on head calculation, the saturated water density at atmospheric pressure is assumed (59.8lb/ft³).

Table H-4 shows the details on how the acceptance criteria were calculated for each LOCA scenario.

Table H-4 Summary of Acceptance Criteria

	$DP_{\text{driving force}}$	DP_{flow}	Acceptance Criteria $DP_{\text{available}}$
HL break	Water level between HL pipe and top of the shortest SG tube [] (see Figure H-1(a) in section H) []	Maximum Flow rate ^{*1} for 4 SI pumps []	[] []
CL break	Water level between CL pipe and core collapsed considering core boiling [] (see Figure H-1(b) in section H) []	Boil off flow rate ^{*2} []	[] []
CL break after HLSO	Water level between CL pipe and top of the shortest SG tube [] (see Figure H-1(c) in section H) []	Maximum Flow rate ^{*1} for 2 SI pumps []	[] []

*1 Maximum Flow rate :1462 (gpm/pump) (Design Control Document for the US-APWR Chapter 6, Figure 6.3-16, Engineered Safety Features, MUAP-DC006 Revision 3, March 2011)

*2 Boil off flow rate :3.5 gpm / fuel assembly


Appendix I

Methodology for Estimate of Debris Load in Cold-leg Break LOCA

PURPOSE

At the Cold-leg break accidental condition, only a part of ECCS water is introduced into the core. The core flowrate is limited by means of the steam generation (boil-off) in the core due to the decay heat. The rest of ECCS injection water flows toward the broken loop and spill out to the RWSP again (core bypass).

This paper is to illustrate the methodology to evaluate the total amount of debris which goes through the core in case of cold-leg break LOCA accident.

FLOW MODELASSUMPTIONS

- All debris (particle, fiber and chemical) is generated during the first 850 seconds after the accident.
- All debris has been completely mixed into the RWSP inventory at 850 seconds.
- No debris is trapped at any part of the flow paths (debris density is constant during recirculation)

The boil off flow for the test is calculated as follows:

$$\begin{aligned} &\text{Boil off flow rate (volumetric flow)} \\ &= \text{Core power} \times \text{Decay heat (total)} \div \text{Enthalpy of Vaporization (} h_{fg} \text{)} \\ &\quad \times \text{Liquid specific volume (} v_L \text{)} \end{aligned}$$

And the pertinent assumptions are:

- Core power is assumed to be 102% in consideration of the uncertainty 2% from the viewpoint of evaluating the boil off flow as larger.
- The decay heat rate used to calculate the boil-off flow rate is total of decay heat ANS-1971 × 1.2 (10CFR50 Appendix-K) fission product decay heat and actinide decay heat.



EQUATIONS

The total amount of boil off water M_{BO} in t_{max} is;

$$M_{BO} = \int_{850}^{t_{max}} W_{BO}(t) \cdot dt .$$

Where t_{max} : the time when ECCS is switched over to hot-leg recirculation mode

The total amount of debris transported by the core flow M_{core} is calculated as follows;


$$M_{core} = M_D \times \frac{M_{BO}}{M_{tot}} .$$

Where M_D : total generated debris amount

M_{tot} : total water inventory in RWSP

PARAMETERS

(Note that the following parameters need to be determined later)



Total water inventory in RWSP	M_{tot}	[]	(kg)
Start hot-leg switch over mode (4 hrs + [] for conservatism)	t_{max}	[]	(sec)
Specific volume of water	-	[]	(m ³ /kg)

CALCULATION

$$M_{BO} = [\quad \quad \quad] \text{ (kg)}$$

$$\frac{M_{core}}{M_D} = \frac{M_{BO}}{M_{tot}} = \left[\quad \quad \quad \right]$$

This result shows the amount of debris transported by the core flow during t_{max} (debris load) is less than [] of total generated debris.

Appendix J

Fibrous Debris Sump Strainer Bypass Amount

J-1 Introduction

Post-LOCA inside containment, debris will be generated as described in section 3.2 of technical report MUAP-08001 (Ref. J-1) and the generated debris will be transported to the core by pipe break flow and containment spray water flow. Under the assumption that all the generated debris will be transported to any one of the four strainers, the amount of bypass debris, namely the debris that reaches the core, was evaluated for the basis of the downstream effect evaluation on the basis of the result of the strainer bypass test.

J-2 Sump Strainer Bypass Test (Fiber Only)

MHI conducted fiber only sump strainer bypass testing. The method, condition and the results are described in Appendix-B of MUAP-08001 "Sump Strainer Performance" (Ref. J-1). The results of the two tests which were performed under the identical conditions are shown in Table J-1. Figure J-1 shows the strainer bypass ratio vs. debris load per sump strainer obtained by the tests. (For more details, refer to Table B-2 in Appendix B of MUAP-08001 (Ref. J-1))

US-APWR has fibrous, particle and chemical debris as design basis debris. However, MHI conservatively assumed all of particle and chemical debris pass through the sump strainers because its size is smaller than strainer mesh size. Therefore, the strainer bypass test was conducted using only fibrous debris.

Table J-1 Fiber Bypass Ratio for Fiber Only Bypass Test




Figure J-1 Fiber Bypass Ratio vs. Debris Load

J-3 Amount of bypass debris per strainer



Table J-2 Debris load per strainer vs. debris bypass ratio and debris bypass amount




Figure J-2 Debris bypass amount per strainer








Figure J-3 Formula for bypass ratio as a function of debris load

J-5 References

J-1. US-APWR Sump Strainer Performance, MUAP-08001-P Revision 5, August 2011