



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**
REGION II
245 PEACHTREE CENTER AVENUE NE, SUITE 1200
ATLANTA, GEORGIA 30303-1257

September 10, 2012

Mr. Thomas D. Gatlin
Vice President - Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
P.O. Box 88
Jenkinsville, SC 29065

**SUBJECT: VIRGIL C. SUMMER NUCLEAR STATION - NOTIFICATION OF INSPECTION
AND REQUEST FOR INFORMATION**

Dear Mr. Gatlin:

From October 22 – October 26, 2012, the Nuclear Regulatory Commission (NRC) will perform the baseline inservice inspection (ISI) at the Virgil C. Summer Nuclear Station. Experience has shown that this inspection is resource intensive for both the NRC inspectors and your staff. In order to minimize the impact to your on-site resources and to ensure a productive inspection, we have enclosed a request for documents needed for this inspection. These documents have been divided into two groups. The first group (Section A of the Enclosure) identifies information to be provided prior to the inspection to ensure that the inspectors are adequately prepared. The second group (Section B of the Enclosure) identifies the information the inspectors will need upon arrival at the site. It is important that all of these documents are up to date and complete in order to minimize the number of additional documents requested during the preparation and/or the on-site portions of the inspection.

We have discussed the schedule for these inspection activities with your staff and understand that our regulatory contact for this inspection will be Mr. John Garza of your organization. Our inspection dates are subject to change based on your updated schedule of outage activities. If there are any questions about this inspection, or the material requested, please contact the lead inspector Robert Williams Jr. at (404) 997-4664 (robert.williams@nrc.gov).

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice," a copy of this letter, and its Enclosure, will be available electronically for public inspection in the NRC Public Document Room, or from the Publicly Available Records (PARS) component of NRC's document system

(ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Steven J. Vias, Chief
Engineering Branch 3
Division of Reactor Safety

Docket No. 50-395
License No. NPF-12

Enclosure:
Pre-Inspection Document Request

cc: (See Page 3)

(ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

Sincerely,

/RA/

Steven J. Vias, Chief
Engineering Branch 3
Division of Reactor Safety

Docket No. 50-395
License No. NPF-12

Enclosure:
Pre-Inspection Document Request

cc: (See Page 3)

PUBLICLY AVAILABLE NON-PUBLICLY AVAILABLE SENSITIVE NON-SENSITIVE
ADAMS: Yes ACCESSION NUMBER: _____ SUNSI REVIEW COMPLETE FORM 665 ATTACHED

OFFICE	RII:DRS	RII:DRS	RII:DRS				
SIGNATURE	RA	RA	RA				
NAME	WILLIAMS	LAKE	VIAS				
DATE	9/10/2012	9/10/2012	9/20/2012	9/ /2012	9/ /2012	9/ /2012	9/ /2012
E-MAIL COPY?	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO	YES NO

cc:

J. B. Archie
Senior Vice President
Nuclear Operations and Chief Nuclear
Officer
South Carolina Electric & Gas Company
Electronic Mail Distribution

George A. Lippard, III
General Manager
Nuclear Plant Operations
South Carolina Electric & Gas Company
Electronic Mail Distribution

Andy T. Barbee
Director
Nuclear Training
South Carolina Electric & Gas Company
Electronic Mail Distribution

Wayne D. Stuart
(Acting) General Manager
Engineering Services
South Carolina Electric & Gas Company
Electronic Mail Distribution

Robin R. Haselden
General Manager
Organizational Development &
Effectiveness
South Carolina Electric & Gas Company
Electronic Mail Distribution

Shaun M. Zarandi
General Manager
Nuclear Support Services
South Carolina Electric & Gas Company
Electronic Mail Distribution

Robert L. Justice
Manager
Nuclear Operations
South Carolina Electric & Gas Company
Electronic Mail Distribution

Bruce L. Thompson
Manager
Nuclear Licensing (Mail Code 830)
South Carolina Electric & Gas Company
Electronic Mail Distribution

Donna W. Railey
Licensing Technician
Nuclear Licensing
South Carolina Electric & Gas Company
Electronic Mail Distribution

Robin J. White
Nuclear Coordinator
S.C. Public Service Authority Mail Code 802
Electronic Mail Distribution

Susan E. Jenkins
SC Department of Health & Environmental
Control
Bureau of Land and Waste Management
Electronic Mail Distribution

Sandra Threatt, Manager
Nuclear Response and Emergency
Environmental Surveillance
Bureau of Land and Waste Management
Department of Health and Environmental
Control
Electronic Mail Distribution

Kathryn M. Sutton, Esq.
Morgan, Lewis & Bockius LLP
Electronic Mail Distribution

Division of Radiological Health
TN Dept. of Environment & Conservation
401 Church Street
Nashville, TN 37243-1532

Senior Resident Inspector
Virgil C. Summer Nuclear Station
U.S. NRC
576 Stairway Road
Jenkinsville, SC 29065

Letter to Thomas D. Gatlin from Steve J. Vias dated September 10, 2012.

SUBJECT: VIRGIL C. SUMMER NUCLEAR STATION - NOTIFICATION OF INSPECTION
AND REQUEST FOR INFORMATION

Distribution w/encl:

RIDSNRRDIRS

PUBLIC

RidsNrrPMSummer Resource

INSERVICE INSPECTION DOCUMENT REQUEST

Inspection Dates: October 22 – 26, 2012

Inspection Procedures: IP 71111.08 "Inservice Inspection (ISI) Activities"

Inspectors: Robert Williams Jr., Reactor Inspector (Lead Inspector)

A. Information Requested for the In-Office Preparation Week

The following information should be sent to the Region II office in hard copy or electronic format (CD or SharePoint preferred), in care of Robert Williams Jr. by October 15, 2012, to facilitate the selection of specific items that will be reviewed during the on-site inspection weeks. The inspector will select specific items from the information requested below and then request, from your staff, additional documents needed during the on-site inspection week (Section B of this Enclosure). We ask that the specific items selected from the lists be available, and ready for review, on the first day of inspection. *Please provide the requested documentation electronically, if possible. If requested documents are large and only hard copy formats are available, please inform the inspectors, and provide subject documentation during the first day of the on-site inspection. If you have any questions regarding this information request, please call the inspector as soon as possible.

A.1 ISI / Welding Programs and Schedule Information

- a) A detailed schedule (including preliminary dates) of:
- i) Nondestructive examinations (NDEs) planned for Class 1 and 2 systems and containment, performed as part of your ASME Section XI, Risk-Informed (if applicable), and augmented ISI Programs during the upcoming outage.

Please include a status summary of the NDE inspection activities versus the required inspection period percentages for this Interval by category per American Society for Mechanical Engineers (ASME) Section XI, IWX-2400. (Do not provide separately if other documentation requested contains this information.)
 - ii) Reactor pressure vessel head (RPVH) examinations planned for the upcoming outage.
 - iii) Examinations planned for Alloy 82/182/600 components that are required by Code Case N770-01. (If applicable)
 - iv) Examinations planned as part of your Boric Acid Corrosion Control Program. (Mode 3 walkdowns, bolted connection walkdowns, etc.)

- v) Welding activities to be completed during the upcoming outage for ASME Class 1, 2, or 3 structures, systems, or components (SSCs).
- b) A copy of ASME Section XI Code Relief Requests and associated NRC Safety Evaluations applicable to the examinations identified above.
- c) A list of NDE reports, (ultrasonic, radiography, magnetic particle, and dye penetrant) that have identified surface or volumetric indications, which were analytically evaluated and accepted for continued service on Code Class 1, 2 and 3 systems since the beginning of the last refueling outage. This should include the previous Section XI pressure test(s) conducted during start up, and any evaluations associated with the results of the pressure tests.
- d) A list, with a brief description (e.g., system, material, pipe size, weld number, and NDE performed), of the welds in Code Class 1, 2, and 3 systems that have been fabricated due to component repair/replacement activities since the beginning of the last refueling outage, or are planned to be fabricated during this refueling outage. Also, please indicate which of those welds are risk-significant.
- e) If reactor vessel shell weld examinations required by the ASME Code are scheduled to occur during the upcoming outage, provide a detailed description of the welds to be examined, and the extent of the planned examination. Please also provide reference numbers for applicable procedures that will be used to conduct these examinations.
- f) A copy of any 10 CFR Part 21 reports applicable to your SSCs, within the scope of Section XI of the ASME Code, that have been identified since the beginning of the last refueling outage.
- g) A list of any temporary non-code repairs in service (e.g., pinhole leaks).
- h) Copies of the most recent self assessments for the ISI, Welding, and Alloy 600 Programs.

A.2 Reactor Pressure Vessel Head (RPVH)

- a) Please provide the detailed scope of the planned NDE of the reactor vessel head which identifies the types of NDE methods to be used on each specific part of the vessel head to meet the augmented inspection requirements of 10CFR50.55a(g)(6)(ii)(D). Also, include examination scope expansion criteria and planned expansion sample sizes if relevant indications are identified. (If applicable)
- b) Please provide a list of the standards and/or requirements that will be used to evaluate indications identified during NDE of the reactor vessel head (e.g., the specific industry or procedural standards that will be used to evaluate potential leakage and/or flaw indications).

- c) Also, include in the list the NDE reports with identified surface or volumetric indications in the RPVH penetration nozzles that have been analytically evaluated and accepted for continued service. The list of NDE reports should include a brief description of the SSC where the recordable indication was identified.

A.3 Boric Acid Corrosion Control Program (BACCP)

- a) Please provide a copy of the procedures that govern the scope, equipment, and implementation of the inspections required to identify boric acid leakage, and the procedures for boric acid leakage/corrosion evaluation.
- b) Please provide a list of leaks (including code class of the components) that have been identified since the last refueling outage and associated corrective action documentation. If during the last cycle, the Unit was shutdown, please provide documentation of containment walkdown inspections performed as part of the BACCP.
- c) Please provide a copy of the most recent self-assessment performed for the BACCP.

A.4 Steam Generator (SG) Inspections

- a) Please provide a copy of the most recent degradation assessment.

A.5 Additional information related to all ISI activities

- a) Please provide a list with a brief description of ISI-, BACCP-, and SG ISI-related issues (e.g., condition reports) entered into your corrective action program since the beginning of the last refueling outage. For example, a list based upon data base searches using key words related to piping or SG tube degradation such as: ISI, ASME Code, Section XI, NDE, cracks, wear, thinning, leakage, rust, corrosion, boric acid, or errors in piping/SG tube examinations.
- b) Please provide names and phone numbers for the following program leads:

ISI (Examination, planning)
 Containment Exams
 Alloy 600/MRP-139
 RPVH Exams
 Snubbers and Supports
 Repair and Replacement Program
 Licensing
 Site Welding
 Boric Acid Corrosion Control Program

B. Information to be provided on-site to the inspector at the entrance meeting (October 22, 2012):

B.1 ISI / Welding Programs and Schedule Information

- a) Updated schedules for ISI/NDE activities, planned welding activities, and schedule showing contingency repair plans, if available.
- b) For ASME Class 1, 2, and 3 welds selected by the inspector from the lists provided from Section A of this Enclosure, please provide copies of the following documentation for each subject weld:
 - i) Weld data sheet (traveler)
 - ii) Weld configuration and system location
 - iii) Applicable Code Edition and Addenda for weldment
 - iv) Applicable Code Edition and Addenda for Welding Procedures
 - v) Applicable Weld Procedures (WPS) used to fabricate the welds
 - vi) Copies of procedure qualification records (PQRs) supporting the WPS from B.1.b.v
 - vii) Copies of mechanical test reports identified in the PQRs above
 - viii) Copies of the nonconformance reports for the selected welds (If Applicable)
 - ix) Radiographs of the selected welds and access to equipment to allow viewing radiographs (If RT was performed)
 - x) Copies of the preservice examination records for the selected welds
 - xi) Copies of welder performance qualifications records applicable to WPS, including documentation that welder maintained proficiency in the applicable welding processes specified in the WPS (At least six months prior to date subject work)
 - xii) Copies of NDE personnel qualifications (VT, PT, UT, RT) (As applicable)
- c) For the ISI related corrective action issues selected by the inspector from Section A of this Enclosure, please provide a copy of the corrective actions and supporting documentation.
- d) For the NDE reports with relevant indications on Code Class 1, 2, and 3 systems selected by the inspector from Section A above, please provide a copy of the examination records, examiner qualification records, and associated corrective action documents.
- e) Please provide a copy of (or ready access to) most current revision of the ISI Program Manual and Plan for the current Interval.
- f) For the NDEs selected by the inspector from section A of this Enclosure, please provide a copy of the NDE procedures used to perform the examinations (including calibration and flaw characterization/sizing procedures). For ultrasonic examination procedures qualified in accordance with ASME Code, Section XI,

Appendix VIII, please provide documentation supporting the procedure qualification (e.g., the EPRI performance demonstration qualification summary sheets). Also, please include documentation of the specific equipment to be used (e.g., ultrasonic unit, cables, and transducers including serial numbers) and NDE personnel qualification records.

B.2 Reactor Pressure Vessel Head

- a) Please provide the NDE personnel qualification records for the examiners who will perform examinations of the RPVH.
- b) Please provide drawings showing the following: (If a visual examination is planned for the upcoming refueling outage)
 - i) RPVH and CRDM nozzle configurations
 - ii) RPVH insulation configuration

The drawings listed above should include fabrication drawings for the nozzle attachment welds, as applicable.

- c) Please provide a copy of NDE reports from the last RPVH examination.
- d) Please provide a copy of evaluation or calculation demonstrating that the scope of the visual examination of the upper head will meet the 95% minimum coverage required by ASME Code Case N-729-1 (If a visual examination is planned for the upcoming refueling outage).
- e) Please provide a copy of the procedures that will be used to identify the source of any boric acid deposits identified on the RPVH. If no explicit procedures exist which govern this activity, provide a description of the process to be followed including personnel responsibilities and expectations.
- f) Please provide a copy of the updated calculation of effective degradation years (EDY) and re-inspection years (RIY) for the RPVH crack initiation and propagation susceptibility parameters.
- g) Please provide a copy of the vendor qualification report(s) that demonstrates the detection capability of the NDE equipment used for the RPVH examinations. Also, please identify any changes in equipment configurations used for the RPVH examinations that differ from that used in the vendor qualification or demonstration report(s).

B.3 Boric Acid Corrosion Control Program

- a) Please provide boric acid walkdown inspection results, an updated list of boric acid leaks identified during the current outage, associated corrective action documentation, and overall status of planned boric acid inspections.

- b) Please provide any engineering evaluations completed for boric acid leaks identified since the end of the last refueling outage. Please include a status of corrective actions to repair and/or clean these boric acid leaks. Please specify which known leaks, if any, have remained in service, or will remain in service, as active leaks.
- c) In accordance with NRC inspection procedure 71111.08, the inspector would like to conduct an independent boric acid walkdown of the Reactor Building early in the inspection week. Please have knowledgeable BACCP staff available to accompany the inspector during the walkdown.

B.4 Codes and Standards

- a) Please provide ready access to: (i.e., copies provided to the inspector to use for the duration of the inspection at the on-site inspection location, or room number and location where available)
 - i) Applicable editions of the ASME Code (Sections V, IX, and XI) for the inservice inspection program and the repair/replacement program.
 - ii) EPRI and industry standards referenced in the procedures used to perform the SG tube eddy current examination.

Inspector Contact Information:

Robert Williams Jr.
Reactor Inspector
404-997-4664
robert.williams@nrc.gov

Mailing Address:
US NRC Region 2
Attn: Robert Williams Jr.
245 Peachtree Center Avenue, Suite 1200
Atlanta, GA 30303