



526 S. Church Street  
Charlotte, NC 28202

Mailing Address:  
EC09D / P.O. Box 1006  
Charlotte, NC 28201-1006

(704) 382-4669

Robert.Wylie@duke-energy.com

August 30, 2012

Ms. Alicia Rowe  
South Carolina Department of Health and Environmental Control  
Water Quality Certification and Wetlands Section  
2600 Bull Street  
Columbia, South Carolina 29201

Subject: William States Lee III Nuclear Station  
Public Notice No.: 2009-122-SIR  
Request for Additional Information

Dear Ms. Rowe:

With reference to your May 24, 2012 letter, attached are Duke Energy's responses to many of your requests for information regarding Duke Energy's Section 401 Water Quality Certification. Additional information responsive to remaining requests will be forthcoming with a transmittal to your office planned in September.

Please contact me at 704 382-4669 if you have questions or need additional information.

Sincerely,

A handwritten signature in blue ink that reads "Robert Wylie".

Robert Wylie  
Environmental Project Manager

Enclosure:

Response to SCDHEC 401 Request for Additional Information

**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

**SCDHEC 401 Request for Information (Letter to Robert Wylie from Alicia Rowe) Letter Dated: May 24, 2012**

**1. SCDHEC Comment:**

Provide an outline of the proposed Drought Contingency Plan.

**Duke Energy Response:**

To minimize withdrawal of water from the Broad River during low-flow periods, a drought contingency pond (Pond C) will be built to complement existing drought contingency Pond B.

During normal flow periods on the Broad River ( $>538$  cfs), Duke Energy will withdraw all of its Lee Nuclear Station operational water requirements from the Ninety-Nine Islands Reservoir through the primary section of the river intake into the existing on site Pond A. The primary section of the river intake will have a design intake flow of 98 cfs. Pond A will provide water for plant processes and cooling tower makeup. Based on the historical Broad River flow conditions, Duke Energy anticipates this will be the water withdrawal scheme employed greater than 95 percent of the time.

As the Broad River flow drops below 538 cfs and begins to approach 483 cfs, Duke Energy will proportionally withdraw its consumptive water requirements ( $\leq 63$  cfs) from Ninety-Nine Islands Reservoir and drought contingency Ponds B and/or C. Pond B will be drawn down first. If Pond B drawdown reaches 30 feet, drawdown from Pond B will cease and water will be withdrawn from Pond C to a nominal drawdown  $\leq 30$  feet.

When Broad River flow is at or below 483 cfs, only non-consumptive cooling water (approximately 23 cfs) will be withdrawn from the Ninety-Nine Islands Reservoir. That water (approximately 23 cfs) will be returned to the reservoir immediately after use in order to maintain adequate flows in the Broad River. The remaining water needed to operate Lee Nuclear Station ( $\leq 63$  cfs) will be drawn from drought contingency Ponds B and/or C. Pond B will be drawn down first. If Pond B drawdown reaches 30 feet, drawdown from Pond B will cease and water will be withdrawn from Pond C to a nominal drawdown  $\leq 30$  feet. Based on modeling using worst case droughts over the 85-year period of record of Broad River flows, Duke Energy does not anticipate that any additional drawdown from Ponds B and C will be required. However, should worse than historical drought conditions persist, any additional drawdown or other water management protocols will be performed pursuant to a drought contingency plan to be developed in accordance with the South Carolina Surface Water Withdrawal Permitting, Use, and



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

Reporting Act and associated regulations after consultation with appropriate regulatory agencies.

During the period of July through February, and only when the Broad River flows are above 483 cfs, Ponds B and/or C will be refilled, as needed, by withdrawing water from the Ninety-Nine Islands Reservoir through the drought contingency section of the river intake. During this period, the water necessary to operate the Lee Nuclear Station will also be withdrawn from the Ninety-Nine Islands Reservoir via the primary section of the river intake.

The drought contingency section of the river intake will have a maximum design intake flow of 206 cfs. However, the actual refill rate will be determined using a flow-sensitive approach to ensure Broad River flows do not fall below 483 cfs due to refill of the drought contingency ponds. Further, regardless of river flows, refilling of Ponds B and C will not occur from March through June, to minimize the potential for entrainment.

**2. DHEC Comment:**

Information regarding minimum flows to London Creek from "Drought Contingency Pond C" (Pond C) during and after construction of the proposed project.

**Duke Energy Response:**

Based on historical flow data collected at London Creek (see Attachment 1), Duke Energy proposes the following minimum seasonal flow releases from Pond C to London Creek downstream of Pond C dam:

January through April - 1.50 cfs

May, June and December - 1.00 cfs

July through November - 0.75 cfs

**SC Department of Natural Resources (Letter to Dr. Richard Darden and Alicia Rowe from Bob Perry) Letter Dated: March 6, 2012**

**3. SCDNR Comment:**

The Applicant proposes a 300-ft buffer around Make-Up Pond C, 50 ft of which is proposed to be cleared, grubbed, grassed, and maintained to prevent debris from washing into the reservoir. DNR concurs with the proposed 300-ft buffer but does not support maintaining a grassed 50-ft shoreline buffer. If a natural shoreline buffer

**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

is maintained, Pond C would naturalize and support a greater variety of aquatic life and wildlife.

Riparian zones perform numerous ecological functions, including providing food, cover, and nesting sites for a variety of wildlife species as well as detritus and woody debris which are an important source of energy and cover for aquatic life. Canopy cover helps to maintain water quality by reducing surface water temperatures and evaporative losses. Riparian zones function as biofilters and remove nutrients and other pollutants from stormwater runoff before it enters rivers, lakes, and streams. Maintenance of the 50-ft buffer likely will contribute to lowered water quality. DNR recommends the Applicant explore alternatives for preventing debris from entering intake structures in order to protect water quality, maximize wildlife habitat and reduce evaporative losses.

**Duke Energy Response:**

Upon further evaluation, Duke Energy now proposes to allow a natural shoreline buffer and install a log boom in order to protect blockage of the Pond C spillway.

**4. SCDNR Comment:**

The Applicant indicates that security fencing will be installed around the perimeter of the pond, and DNR understands that there are no plans for any type of public access to Drought Contingency Pond C. DNR appreciates the sensitive nature of operation and protection of a nuclear generation station. However, London Creek constitutes WOUS and any impacts to it for purposes of a reservoir the size of the one being proposed should include an examination of compatible public use opportunities. These compatible public use opportunities might include boating and fishing opportunities and other compatible appreciative uses along the northern boundary. DNR recommends continued discussion with the Applicant regarding the potential, compatible public use opportunities on a portion of proposed Make-Up Pond C

**Duke Energy Response:**

Duke Energy plans to continue discussion with the SCDNR regarding the potential, compatible public use opportunities on a portion of the proposed drought contingency Pond C.

**5. SCDNR Comment:**

Grassland birds are among the most steeply declining of all bird populations in North America due to loss and degradation of grassland and shrub-scrub habitats. Transmission corridors can provide significant habitat for grassland birds, as well as



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

raptors and small mammals, functioning as linear grassland/shrublands through forest-dominated landscapes. Excellent wildlife habitat, as well as safe and efficient power delivery, can be provided by managing these areas as a combination of native grasses, forbs, and small shrubs through direct seeding or natural regeneration. Any direct seeding of corridors should utilize only native plant materials. Sod-forming grasses like Bermuda grass and fescue, and aggressive non-native forbs provide poor wildlife habitat along the right-of-way and can potentially escape to adjacent woodlands or fields resulting in additional habitat degradation. DNR recommends that, where possible, lands within transmission line corridors be managed for the benefit of wildlife.

**Duke Energy Response:**

Duke Energy will work with the SCDNR to manage the corridors where possible so that habitat will be present for grassland birds and other wildlife.

Duke Energy will construct and maintain the transmission lines in accordance with the Duke Energy Carolinas *Best Management Practices for Stormwater Management and Erosion Control, Policy and Procedures Manual* (Revised 1999) and maintenance procedures described in the *Duke Energy Carolinas Transmission Vegetation Management Program*. Permanent and temporary seeding mixes prescribed in these plans have the primary purpose of providing quick stabilization of the site to prevent erosion and sedimentation into the waterways.

Duke Energy manages the vegetation on its rights-of-way through an Integrated Vegetation Management Program. The program encompasses environmental stewardship and utilizes various right-of-way management tools, including mowing; hand-cutting; removal of dead, diseased, dying or decaying trees; pruning; and the use of environmentally safe herbicides. Herbicide use prevents vegetation from posing a threat to the transmission lines and equipment while promoting power system compatible ecosystems within the right-of-way corridor.

**6. SCDNR Comment:**

DNR has concluded that Applicant has conducted a thorough and exhaustive review of the need for obtaining additional water supply for safe operation of the proposed facility during periods of extreme drought. A number of the alternatives that have been put forward for additional water supply represent engineering solutions exceeding the capability for DNR analysis. DNR is satisfied the Applicant has identified the least damaging alternative to natural resources for provision of additional water supply based on comparison of alternative supplemental water supply options.

**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

**Duke Energy Response:**

Duke Energy appreciates the comment and will continue to partner with SCDNR as the project progresses.

**7. SCDNR Comment:**

The provision of a seasonally-adjusted minimum flow is SCDNR policy and is embraced by the South Carolina Water Withdrawal, Permitting, Use, and Reporting Act (SC Code 33 Ann. 49-4). DNR recommends the Section 404 permit/Section 401 water quality certification be conditioned to include a seasonal minimum flow release from Drought Contingency Pond C Dam that is protective of downstream aquatic resources. The minimum flow should commence with the filling of the pond to avoid and minimize adverse impacts to fish and the macrobenthic community downstream of the dam to the confluence of London Creek with the Broad River.

**Duke Energy Response:**

Based on historical flow data collected at London Creek (see Attachment 1), Duke Energy proposes the following minimum seasonal flow releases from Pond C to London Creek downstream of Pond C dam:

January through April - 1.50 cfs

May, June and December - 1.00 cfs

July through November - 0.75 cfs

**8. SCDNR Comment:**

DNR staff met with Applicant in August 2010 regarding DNR's concern about viewshed impacts from the transmission lines to the Scenic Broad River. During the meeting, the Applicant provided the DNR with a presentation depicting the transmission lines as seen from the Broad River. Based on the depictions, DNR understands that the transmission lines will be minimally visible to the recreating public during winter, leaf-off conditions. Furthermore, DNR understands that impacts can be further reduced through the employment of shorter towers along the Scenic Broad River corridor. DNR requested and was assured of continued consultation during the design phase of the transmission lines; however, as of this date, DNR has not received any such consultation. DNR urges the Licensee to avoid and minimize to the greatest practicable extent through the careful design and



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

placement of transmission lines (e.g., shorter towers and the use of wider buffer in those sections of the corridor along the Scenic Broad River).

**Duke Energy Response:**

During the transmission line siting study for the Lee Nuclear 230 kV and 525 kV Fold-in Lines, Duke Energy conducted an extensive analysis to determine the probable visibility of the various alternate routes from the scenic designated segment of the Broad River. The analysis considered all alternate routes that would possibly be visible from the Scenic Broad River Corridor. The methodology included computer modeling to predict areas along the river that would likely have some degree of view of the future lines. Additionally, potential views from the river were carefully analyzed in the field by inspection from the river during a canoe excursion from the Ninety-Nine Islands Dam to the Highway 211 bridge.

Following the selection of the routes for the 230 kV and 525 kV Fold-in Lines, Duke conducted additional analyses in 2008 that focused on the selected routes and their potential visibility from the scenic designated segment of the Broad River. These analyses were conducted prior to the completion of preliminary line engineering and assumed structure heights that exceed the actual heights of the preliminarily engineered structures. These analyses, which included extensive computer modeling and photographic simulation preparation, revealed that a very minimal number of structures would potentially be visible from the scenic designated segment of the Broad River during winter, leaf-off conditions. It was concluded that, under these initial analyses, any visible portions of the structures during leaf-off conditions would likely be unrecognized by casual viewers.

Due to the reduction in structure height of the preliminarily engineered structures compared to the structure heights used in the initial visual analyses of the 230 kV and 525 kV Fold-in Lines, Duke is confident that the information presented to SCDNR staff during the August 2010 meeting represents a worst case scenario regarding potential views of the 230 kV and 525 kV Fold-in Lines that will not likely occur due to reductions in structure heights that were evaluated during preliminary line engineering. For that reason, Duke believes no further consultation with the SCDNR has been warranted since the August 2010 meeting. Discussions with SCDNR will occur upon the completion of final engineering of the Lee Nuclear Station 230 kV and 525 kV Lines.



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

**9. SCDNR Comment:**

DNR notes that only the discharge proposed for normal operations, 18 cfs, was considered in model scenarios. The maximum discharge of 64 cfs was not modeled. During an interagency meeting with the Applicant on February 17, 2012, DNR was assured that maximum blowdown would occur only during periods of high flows. DNR requests additional information on the duration of such events and the magnitude of the thermal plume produced during anticipated maximum blowdown conditions. DNR urges due diligence by the South Carolina Department of Health and Environmental Control to ensure that the NPDES permit for the Lee Nuclear Station will be conditioned to require appropriate biological and chemical monitoring, to include fish community

**Duke Energy Response:**

The maximum blowdown (62.4 cfs) condition occurs when the cooling towers are operated at two cycles of concentration (COC) due to elevated Total Suspended Solids (TSS) levels in the river water. Based on the correlation of TSS and river flow data, it is estimated that the river flow has to be greater than 17,000 cfs to require a two COC cooling tower operation. At 17,000 cfs the maximum blowdown is less than 0.4 percent of the river flow. With such a great difference between river flow and the maximum blowdown flow, the influence of maximum blowdown on the river is negligible. During maximum blowdown, temperature increase, if any, will typically be less than 0.1 degrees F at the edge of the permitted mixing zone.

**US Department of the Interior: Fish and Wildlife (Letter to Dr. Richard Darden from Jay Herrington) Letter Dated: March 6, 2012**

**10. USFWS Comment:**

Power generation by the William State Lee facility represents potential impacts to the Broad River. These potential impacts were not described in this public notice. However, the USFWS believes that impacts to the river should be an integral consideration as the proposed construction activities will lead into operation of the facility. Therefore, comments were included on potential impacts to the Broad River system.

**Duke Energy Response:**

All cooling water intake structures and wastewater discharges from Lee Nuclear Station to the Broad River will be regulated by the NPDES permit. The NPDES permit is issued by SCDHEC and is drafted to ensure all pertinent regulations are



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

implemented in order to protect the receiving water body. Lee Nuclear Station is installing cooling towers, which significantly reduces water withdrawal needs and thermal loading to the Broad River. Based on the projected operation of the cooling towers, the installation of a diffuser, the historical river flow, and the characteristics of the wastewater, the discharge from Lee Nuclear will not adversely impact the aquatic ecology in the Broad River.

**11. USFWS Comment:**

The USFWS believes that due to the significance, coverage, and magnitude of the impacts, the Applicant should be required to compensate in an equally significant manner. The USFWS recommends that the Applicant prepare a compensation package that will suitably mitigate for impacts that will occur at the landscape level. As stated in the public notice, the Applicant's compensation package is a conceptual plan. Considering the complex nature of this project, the USFWS understands the difficulties in identifying suitable areas to affect appropriate mitigation. Therefore, USFWS believes it would be appropriate to review the proposed mitigation locations during a multi-agency site visit prior to finalizing the proposed impact mitigation.

**Duke Energy Response:**

Similar to the development of a mitigation bank, the development of Duke Energy's permittee-responsible mitigation plan included involvement from state and federal resource and permitting agencies. Multiple meetings were held to solicit input on the mitigation plan from USACE, Nuclear Regulatory Commission (NRC), USEPA, USFWS, NMFS, SCDNR, and SCDHEC, and to also address resource and permitting agency issues and concerns and to ensure 2008 Mitigation Rule compliance. This Agency input was instrumental in the development of the proposed mitigation plan. An interagency meeting was held at USACE in Charleston, SC on February 17, 2012 and a two-day field trip to the proposed mitigation sites in the Sumter National Forest and Turkey Creek was held on April 24-25, 2012. USFWS staff participated in both the interagency meeting and the field trip.

**12. USFWS Comment:**

The USFWS is concerned with the effects of the proposed cooling tower blowdown discharge on the aquatic system of the Ninety-Nine Islands Reservoir and the Broad River downstream of the dam. The blowdown discharge would contain biocides, chemical additives, radioactive waste, and thermal effluent. The chronic and cumulative effect of chemicals and radioactive waste would adversely affect fish and invertebrate spawning and recruitment in the vicinity of the discharge within the reservoir, and downstream of the dam, particularly during periods of low flow.



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

**Duke Energy Response:**

All cooling water intake structures and wastewater discharges from Lee Nuclear Station to the Broad River will be regulated by the NPDES permit. The NPDES permit is issued by SCDHEC and is drafted to ensure all pertinent regulations are implemented in order to protect the receiving water body. Lee Nuclear Station is installing cooling towers, which significantly reduces water withdrawal needs and thermal loading to the Broad River. Based on the projected operation of the cooling towers, the installation of a diffuser, the historical river flow, and the characteristics of the wastewater, the discharge from Lee Nuclear will not adversely impact the aquatic ecology in the Broad River. In addition, the discharge of treated wastewater from Lee Nuclear Station to the Broad River will be governed by 10 CFR Parts 20 and 50.

**13. USFWS Comment:**

Thermal effluent from reactor operations would affect fish and invertebrate spawning, and biological systems through stress and/or direct mortality. It would especially affect non-motile or slow moving invertebrates such as freshwater mussels and other aquatic invertebrates. In addition, the USFWS is concerned that the levels of copper and zinc proposed on the effluent will exceed DHEC criterion maximum concentration for these metals, which may violate SC Water Quality Classifications and Standards that establish maximum concentrations for freshwater.

**Duke Energy Response:**

All cooling water intake structures and wastewater discharges from Lee Nuclear Station to the Broad River will be regulated by the NPDES permit. The NPDES permit is issued by SCDHEC and is drafted to ensure all pertinent regulations are implemented in order to protect the receiving water body. Lee Nuclear Station is installing cooling towers, which significantly reduces water withdrawal needs and thermal loading to the Broad River. Based on the projected operation of the cooling towers, the installation of a diffuser, the historical river flow, and the characteristics of the wastewater, the discharge from Lee Nuclear will not adversely impact the aquatic ecology in the Broad River.

**South Carolina Wildlife Federation (Letter to Dr. Richard Darden from Ben Gregg) Letter Dated: March 6, 2012**

**14. SCWF Comment:**

During major flood events in London Creek and Lake Cherokee, the peak flow will be significantly faster and higher in magnitude because of the lake water body in



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

London Creek. The flood impact on Broad River may not be very significant because the size difference of the drainage area between London Creek and Broad River. However, the flood impact of London Creek will be very significant on property and personnel in the drainage area between Broad River and the proposed dam on London Creek. Flood zone volume should be considered in the design of London Creek dam to catch and store the flood volume and release it downstream in non-flood magnitudes. Releases from the Ninety-Nine Islands Hydroelectric Project should be synchronized with the flood from London Creek to minimize its impact on the Broad River.

**Duke Energy Response:**

Hydrologic/hydraulic modeling of London Creek with the proposed Pond C demonstrates that peak flow will not be faster or higher in magnitude during major flood events. Rather, modeling results show that Pond C would serve as a detention structure that has the ability to store and discharge peak flood waters at significantly lower peak flows than if the reservoir was not constructed. The combination of storage and discharge over the spillway structure would tend to reduce the magnitude of peak flows in London Creek below Pond C and discharging in the Broad River. Proposed operating conditions at Pond C are expected to decrease the peak Pond C basin discharge during the inflow design flood (IDF) (the probable maximum precipitation for the 3.88 sq mi basin) from approximately 31,184 cfs (without Pond C) to 11,360 cfs (peak discharge during the IDF from the proposed spillway).

A comparison of the London Creek basin discharges for the existing and proposed Pond C conditions is provided below in Table 1 and Figure 1. This table provides an assessment of Pond C basin discharge in terms of an equivalent return period on the Broad River below the Ninety-Nine Islands Reservoir. Return period information was calculated based on the synthesized hydrologic data developed during the LNS permitting and design process. The hydrologic data is based on the USGS 02153500 stream gauge located on the Broad River near Gaffney, SC along with two USGS stream gauges, USGS 02153200 Broad River near Blacksburg, SC and USGS 02151500 Broad River near Boiling Springs, NC, used to supplement missing data. The synthesized hydrology set was then prorated to the drainage area of the Ninety-Nine Islands Reservoir.


**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

**Table 1: Pond C Basin Discharge Comparison for Various Storm Events under Existing and Proposed with Pond C Conditions.**

| <b>Frequency Storm</b> | <b>Pond C Basin Discharge, cfs</b> |  | <b>Equivalent Return Period (Years) on Broad River near the Ninety-Nine Islands Reservoir</b> |  |
|------------------------|------------------------------------|--|---|--|
|                        | <b>Existing Conditions</b>         | <b>Proposed with Pond C Conditions</b> | <b>Existing Conditions</b>  | <b>Proposed with Pond C Conditions</b> |
| 10-year                | 1,960                              | 353                                    | 0.90  | 0.83                                   |
| 25-year                | 2,648                              | 458                                    | 0.94  | 0.83                                   |
| 50-year                | 3,146                              | 559                                    | 0.96  | 0.84                                   |
| 100-year               | 3,752                              | 670                                    | 0.99  | 0.84                                   |
| 500-year               | 5,299                              | 1,053                                  | 1.06  | 0.86                                   |
| PMF                    | 31,184                             | 11,360                                 | 3.26  | 1.35                                   |



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**



**Figure 1: Pond C Frequency Storm Discharge Comparison under Existing and Proposed (with Pond C) Conditions.**

Additional analysis has been performed to estimate the impacts of discharges from Pond C at Ninety-Nine Islands Reservoir due to the transposition of contributing Pond C discharges under existing and proposed conditions (Table 2). This analysis conservatively assumes that the large flood events would occur over the Pond C basin while the mean annual flow of 2,580 cfs is being experienced on the Broad River and the Ninety-Nine Islands Reservoir. Reservoir elevations were estimated based on the Ninety-Nine Islands project spillway capacity derived from FERC license documents. This analysis indicates that reservoir levels would be lower under the proposed conditions.

**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

**Table 2: Estimated Ninety-Nine Islands Reservoir Elevation for Various Storm Events Under Existing and Proposed Conditions.**

| Flow Condition                    | Estimated Ninety-Nine Island Reservoir Elevation, ft |                                 |
|-----------------------------------|--|---------------------------------|
|                                   | Existing Conditions                                  | Proposed with Pond C Conditions |
| Mean Annual Flow                  | 511.5  |                                 |
| Mean Annual Flow + 10-year Flows  | 512.0  | 511.6                           |
| Mean Annual Flow + 25-year Flows  | 512.1  | 511.6                           |
| Mean Annual Flow + 50-year Flows  | 512.2  | 511.7                           |
| Mean Annual Flow + 100-year Flows | 512.4  | 511.7                           |
| Mean Annual Flow + 500-year Flows | 512.7  | 511.8                           |
| Mean Annual Flow + PMF            | 516.1  | 513.7                           |

These results are expected, as the Pond C basin only contributes approximately 3.9 sq mi of the 1,550 sq mi that make up the drainage area on the Broad River above the Ninety-Nine Islands Reservoir. This accounts for roughly 0.25% of the total inflow to the Ninety-Nine Islands drainage area.

**15. SCWF Comment:**

Although SCWF applauds the proposed 300 feet buffer zone, SCWF recommends that the Applicant work closely with SCDNR to enhance the 300 feet buffer and its functionality to provide excellent food, cover, and nesting sites for the local wildlife species.

**Duke Energy Response:**

Duke Energy plans to keep the entire 300 ft buffer surrounding Pond C in its natural state and protect the spillway from blockage by debris with the installation of a log boom.

**16. SCWF Comment:**

Lake Cherokee is public property owned by the State of South Carolina, and DNR maintains the use of that lake to provide recreational fishing opportunities to the public. SCWF recommends that the public recreational opportunities in and around



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

the lake not be adversely affected, especially during major flood events. The Applicant should work closely with SCDNR to ensure there will be no adverse effect on the public use of the Lake Cherokee resource.

**Duke Energy Response:**

Duke Energy will continue to work closely with SCDNR to ensure there will be no adverse effect on the public use of the Lake Cherokee resource. Construction of the proposed Pond C reservoir will not impact public access to Lake Cherokee or adversely affect public recreational opportunities in and around the lake, including during major flood events. Current plans for Lake Cherokee include improved public access by providing handicap-accessible paved and gravel parking areas to the east of the auxiliary spillway along with a pedestrian bridge to maintain access to the top of the dam for bank fishing. With respect to major flood events, the project also includes significant improvements to the auxiliary spillway to offset any loss in principal spillway capacity. The modified spillway has a calculated discharge of approximately 3,040 cfs, representing a 20 cfs increase in the Lake Cherokee auxiliary discharge capacity and a net "zero" impact to the total combined project discharge capacity.

**17. SCWF Comment:**

The plume, mixing zone, boundaries and magnitude were established by Duke's consultant based upon 18 cfs discharge. The plume, boundaries, and magnitude should be established during the maximum discharges of 64 cfs to minimize the adversely impact on the fish communities. The frequency of such high discharge should be calculated as well. SCWF also recommends more biological and chemical monitoring both before start-up and after commencement of operations so appropriate changes can be instituted.

**Duke Energy Response:**

All cooling water intake structures and wastewater discharges from Lee Nuclear Station to the Broad River will be regulated by the NPDES permit. The NPDES permit is issued by SCDHEC and is drafted to ensure all pertinent regulations are implemented in order to protect the receiving water body. Lee Nuclear Station is installing cooling towers, which significantly reduces water withdrawal needs and thermal loading to the Broad River. Based on the projected operation of the cooling towers, the installation of a diffuser, the historical river flow, and the characteristics of the wastewater, the discharge from Lee Nuclear will not adversely impact the aquatic ecology in the Broad River.

The maximum blowdown (62.4 cfs) condition occurs when the cooling towers are operated at two cycles of concentration (COC) due to elevated Total Suspended Solids (TSS) levels in the river water. Based on the correlation of TSS and river



**Duke Energy Response to SCDHEC**  
**401 Request for Additional Information**  
**August 30, 2012**

flow data, it is estimated that the river flow has to be greater than 17,000 cfs to require a two COC cooling tower operation. At 17,000 cfs the maximum blowdown is less than 0.4 percent of the river flow. With such a great difference between river flow and the maximum blowdown flow, the influence of maximum blowdown on the river is negligible.

**National Marine Fisheries Service (Letter to Lt. Colonel Edward Chamberlayne from Virginia Fay Letter Dated: March 6, 2012)**

**18. NMFS Comment:**

The Broad River and its tributaries provide important riverine spawning and maturation habitats for public-trust aquatic fisheries and resources. The Broad River flows through the Piedmont region, meeting the Saluda River near Columbia, SC, to form the Congaree River. Diadromous fishes of particular interest to NMFS within the Broad River include American shad, blueback herring, striped bass, American eel, Atlantic sturgeon, and shortnose sturgeon; the latter two species are listed as endangered under the Endangered Species Act.

NMFS identifies the Broad River as a high priority for habitat restoration and recovery of diadromous fishes. While dams along the Congaree River and Broad River currently block diadromous fishes from habitat at and near the site of the proposed nuclear station, the potential for removal of these impediments to passage is high.

**Duke Energy Response:**

In 2008, Duke Energy signed the Santee River Basin Accord (SRBA) in support of the Santee-Cooper Diadromous Fish Passage Restoration Plan. No Atlantic sturgeon or shortnose sturgeon have been found in the vicinity of the Proposed Lee Nuclear site, Pond C or Ninety-Nine Islands Hydroelectric Project.

The NRC issued a letter to the NMFS on August 14, 2012 documenting its no effect determination, its findings relative to diadromous fishes, and NMFS's concurrence with same (Attachment 2). NRC further indicates in the letter that upon construction and operation of the Lee Nuclear Station, it will reinstate consultation with the NMFS in the event of the successful implementation of the fish passage program as described in the SRBA, if there is potential for thermal, chemical, and physical impacts to Federally-protected species from the operations at the Lee Nuclear Station.



**Duke Energy Response to SCDHEC  
401 Request for Additional Information  
August 30, 2012**

**SC Department of Archives & History (Letter to Dr. Richard Darden from  
Rebekah Dobrasko) Letter Dated: January 20, 2012**

**19. State Historic Preservation Office (SHPO) Comment:**

SC Department of Archives & History believes that proposed Lee Nuclear Station, Make-up Pond C, railroad spur, and transmission line corridors will cause no adverse effect on the identified historic properties provided the following conditions are met:

- a. Public access to the cemeteries upon request is not limited
- b. Fencing around cemeteries is maintained
- c. Cemeteries are periodically monitored for vandalism or disturbance
- d. Service Family Cemetery is relocated in consultation with the SC Department of Archives & History and interested parties
- e. Any construction, ground disturbance, or future improvement along the railroad corridor within the boundaries of 38CK0068 (Ellen Furnace Works) are limited to the existing railroad right of way or are coordinated with SC Department of Archives & History

**Duke Energy Response:**

Duke Energy agrees with these conditions.

## **London Creek Minimum Flow Analysis**

### **Background**

The South Carolina Department of Natural Resources (SCDNR) and the South Carolina Department of Health and Environmental Control (SCDHEC) have requested that Duke Energy Carolinas, LLC (Duke Energy) evaluate flow conditions in London Creek and propose a minimum flow regime below the Drought Contingency Pond C (Pond C) Dam that would be protective of downstream aquatic resources. Excerpts from SCDNR and SCDHEC correspondence on Duke Energy's Section 404/401 permit application are provided below.

### **SCDNR Comment**

*The provision of a seasonally-adjusted minimum flow is SCDNR policy and is embraced by the South Carolina Water Withdrawal, Permitting, Use, and Reporting Act (SC Code 33 Ann. 49-4). DNR recommends the Section 404 permit/Section 401 water quality certification be conditioned to include a seasonal minimum flow release from Drought Contingency Pond C Dam that is protective of downstream aquatic resources. The minimum flow should commence with the filling of the pond to avoid and minimize adverse impacts to fish and the macrobenthic community downstream of the dam to the confluence of London Creek with the Broad River.*

### **SCDHEC Comment**

*Information regarding minimum flows to London Creek from "Drought Contingency Pond C" (Pond C) during and after construction of the proposed project.*

### **London Creek Flow Data**

Duke Energy established two flow monitoring locations on London Creek in May 2009. The upper monitoring location is approximately 400 ft downstream from Hwy 329 (Victory Trail Road). The lower monitoring location is approximately 800 ft downstream from the proposed location of the Pond C spillway structure outlet and approximately 1,400 ft upstream from the Centerline Track rail spur crossing. Duke Energy currently plans to release any continuous minimum flow to London Creek via the Pond C spillway structure which is approximately 550 ft



downstream from the toe of the Pond C Dam. The stream distance between the upper and lower monitoring locations is approximately 15,630 ft (2.96 miles).

At each monitoring location, river stage is recorded and converted to a flow based on a discharge rating curve that was developed for each site. Calculated flows above the highest measured flow were eliminated from this analysis due to uncertainty with the discharge rating curve above the upper end of the measured flow regime. For the upper monitoring location, the highest measured flow was 41 cubic ft per second (cfs) (only 0.2 percent of the calculated flows were above this measured flow). For the lower monitoring location, the highest measured flow was 106 cfs (only 0.4 percent of the calculated flows were above this measured flow). The resulting monthly average flow data for the two monitoring locations is provided in Tables 1 and 2.

Table 1. London Creek Upper Monitoring Location – Monthly Average Flow Data

| Year  | Upper London Creek Monthly Average Flow (cfs) |          |       |       |       |       |       |        |           |         |          |          | Yearly<br>Average<br>Flow |
|---|---|----------|-------|-------|-------|-------|-------|--------|-----------|---------|----------|----------|---------------------------|
|   | January                                       | February | March | April | May   | June  | July  | August | September | October | November | December |                           |
| 2009  | -   | -        | -     | -     | 2.4   | 0.7   | 0.2   | 0.2    | 0.1       | 0.3     | 1.5      | 3.6      | 1.1                       |
| 2010  | 3.3   | 3.4      | 3.0   | 1.8   | 1.6   | 1.8   | 1.0   | 0.8    | 0.7       | 0.9     | 1.7      | 1.2      | 1.8                       |
| 2011  | 1.8   | 2.9      | 4.1   | 2.4   | 1.5   | 0.8   | 0.6   | 0.7    | 0.7       | 1.2     | 2.2      | 2.2      | 1.8                       |
| 2012  | 2.7   | 2.3      | 4.1   | 3.1   | 4.6   | 2.4   | -     | -      | -         | -       | -        | -        | 3.21                      |
| Monthly<br>Average<br>Flow<br>Total <sup>1</sup>    | 2.57  | 2.86     | 3.76  | 2.44  | 2.54  | 1.43  | 0.60  | 0.59   | 0.51      | 0.82    | 1.80     | 2.31     | 1.86                      |
| Adjusted<br>Monthly<br>Average<br>Flow <sup>2</sup> | 4.32  | 4.81     | 6.32  | 4.10  | 4.26  | 2.40  | 1.00  | 0.99   | 0.85      | 1.37    | 3.02     | 3.88     | 3.11                      |
| Proposed<br>Minimum<br>Flow <sup>3</sup>            | 1.50  | 1.50     | 1.50  | 1.50  | 1.00  | 1.00  | 0.75  | 0.75   | 0.75      | 0.75    | 0.75     | 1.00     | 1.06                      |
| Difference <sup>4</sup>                             | -2.82   | -3.31    | -4.82 | -2.60 | -3.26 | -1.40 | -0.25 | -0.24  | -0.10     | -0.62   | -2.27    | -2.88    | -2.05                     |

<sup>1</sup>Mean annual flow based on individual monthly averages for the May 2009 – June 2012 period of record<sup>2</sup>Monthly average flow at upper monitoring location adjusted to the Pond C spillway outlet location based on drainage area ratio method<sup>3</sup>Seasonally adjusted, based on meeting a percentage of the MAF each month (40% January-April; 30% May-June and December; 20% July-November)<sup>4</sup>Proposed minimum flow minus the adjusted monthly average flow



Table 2. London Creek Lower Monitoring Location – Monthly Average Flow Data

| Year  | Lower London Creek Monthly Average Flow (cfs) |          |       |       |       |       |      |        |           |         |          |          | Yearly<br>Average<br>Flow |
|---|---|----------|-------|-------|-------|-------|------|--------|-----------|---------|----------|----------|---------------------------|
|   | January                                       | February | March | April | May   | June  | July | August | September | October | November | December |                           |
| 2009  | -   | -        | -     | -     | 7.7   | 2.8   | 1.1  | 1.0    | 0.9       | 1.4     | 4.1      | 8.7      | 3.4                       |
| 2010  | 6.3   | 6.3      | 6.1   | 2.3   | 2.1   | 2.8   | 1.0  | 0.9    | 0.5       | 1.1     | 2.4      | 1.6      | 2.8                       |
| 2011  | 1.9   | 4.1      | 7.0   | 3.2   | 1.6   | 0.7   | 0.1  | 0.9    | 0.4       | 0.8     | 4.4      | 8.2      | 2.8                       |
| 2012  | 8.7   | 5.5      | 7.2   | 4.2   | 7.5   | 1.7   | -    | -      | -         | -       | -        | -        | 7.1                       |
| Monthly<br>Average<br>Flow Total <sup>1</sup>       | 5.62  | 5.29     | 6.75  | 3.21  | 4.71  | 2.01  | 0.73 | 0.90   | 0.60      | 1.10    | 3.62     | 6.17     | 3.39                      |
| Adjusted<br>Monthly<br>Average<br>Flow <sup>2</sup> | 5.59  | 5.26     | 6.72  | 3.19  | 4.69  | 2.00  | 0.73 | 0.90   | 0.60      | 1.10    | 3.60     | 6.14     | 3.38                      |
| Proposed<br>Minimum<br>Flow <sup>3</sup>            | 1.50  | 1.50     | 1.50  | 1.50  | 1.50  | 1.50  | 1.50 | 1.50   | 1.50      | 1.50    | 1.50     | 1.50     | 1.50                      |
| Difference <sup>4</sup>                             | -4.09   | -3.76    | -5.22 | -1.69 | -3.19 | -0.50 | 0.77 | 0.60   | 0.90      | 0.40    | -2.10    | -4.64    | -1.88                     |

<sup>1</sup>Mean annual flow based on individual monthly averages for the May 2009 – June 2012 period of record<sup>2</sup>Monthly average flow at lower monitoring location adjusted to the Pond C spillway outlet location based on drainage area ratio method<sup>3</sup>Seasonally adjusted, based on meeting a percentage of the MAF each month (40% January-April; 30% May-June and December; 20% July-November)<sup>4</sup>Proposed minimum flow minus the adjusted monthly average flow

**London Creek Minimum Flow Recommendation**

Flows from the two monitoring locations were ratioed (based on drainage area) to the proposed location of the Pond C spillway outlet to determine background flows at this location. The drainage areas for the two monitoring locations and the outlet of the Pond C spillway structure are:

- Upper flow monitoring location: 938 acres
- Pond C spillway outlet: 2,513 acres
- Lower flow monitoring location: 2,526 acres

As a result, flows from the upper monitoring location were multiplied by a factor of 1.68  $((2,513 \text{ acres} - 938 \text{ acres})/938 \text{ acres})$  and flows from the lower monitoring location were multiplied by a factor of 0.99  $(2,513 \text{ acres} / 2,526 \text{ acres})$ . The mean annual flow (MAF) for the period of record (May 2009 through June 2012) for the upper and lower monitoring locations (pro-rated to the Pond C spillway outlet location) is:

- Upper flow monitoring location:  $1.86 \text{ cfs} \times 1.68 \text{ multiplier} = 3.12 \text{ cfs}$
- Lower flow monitoring location:  $3.39 \text{ cfs} \times 0.99 \text{ multiplier} = 3.37 \text{ cfs}$

The proposed seasonally-adjusted minimum continuous flow regime for London Creek below the Pond C spillway outlet is provided in Table 3. The same rationale that was used for setting the seasonally-adjusted minimum continuous flow regime below Duke Energy's Ninety Nine Islands Hydroelectric Station was used as the basis for the minimum continuous flow regime for London Creek downstream from Pond C at the spillway outlet. This methodology is based on releasing a percentage of the MAF based on season. Higher minimum flows (i.e., 40 percent of the MAF) are recommended for periods when higher flows would normally occur (i.e., January through April) and lower minimum flows (i.e., 20 percent of the MAF) are recommended for periods when lower flows would normally occur (i.e., July through November). During the "shoulder" months (i.e., May, June, and December), 30 percent of the MAF is proposed as the minimum continuous flow release.



**Table 3. London Creek Proposed Minimum Continuous Flow Regime**

| London Creek Proposed Minimum Continuous Flow Regime |      |  |  |   |                               |
|--|------|--|--|---|-------------------------------|
| Month  | %MAF | Min Flow<br>based on Upper<br>Site (cfs) | Min<br>Flow<br>based on<br>Lower<br>Site (cfs) | Average<br>Upper &<br>Lower Flow<br>(cfs) | Proposed<br>Min Flow<br>(cfs) |
| January  | 40   | 1.25                                     | 1.35   | 1.30                                      | 1.50                          |
| February   | 40   | 1.25                                     | 1.35   | 1.30                                      | 1.50                          |
| March  | 40   | 1.25                                     | 1.35   | 1.30                                      | 1.50                          |
| April  | 40   | 1.25                                     | 1.35   | 1.30                                      | 1.50                          |
| May  | 30   | 0.94                                     | 1.01   | 0.97                                      | 1.00                          |
| June   | 30   | 0.94                                     | 1.01   | 0.97                                      | 1.00                          |
| July   | 20   | 0.62                                     | 0.67   | 0.65                                      | 0.75                          |
| August   | 20   | 0.62                                     | 0.67   | 0.65                                      | 0.75                          |
| September  | 20   | 0.62                                     | 0.67   | 0.65                                      | 0.75                          |
| October  | 20   | 0.62                                     | 0.67   | 0.65                                      | 0.75                          |
| November   | 20   | 0.62                                     | 0.67   | 0.65                                      | 0.75                          |
| December   | 30   | 0.94                                     | 1.01   | 0.97                                      | 1.00                          |

MAF (Mean Annual Flow) based on London Creek field data collected May 2009 – June 2012

Spillway Outlet MAF (based on upper site) = 3.12 cfs

Spillway Outlet MAF (based on lower site) = 3.37 cfs

August 14, 2012

Mr. David M. Bernhart  
Assistant Regional Administrator  
For Protected Resources  
National Marine Fisheries Service  
263 13<sup>th</sup> Avenue South  
Saint Petersburg, FL 33701

SUBJECT: ENDANGERED SPECIES ACT, MAGNUSON-STEVEN'S FISHERY  
CONSERVATION AND MANAGEMENT ACT, AND FISH AND WILDLIFE  
COORDINATION ACT CONSULTATION CLOSE OUT FOR THE WILLIAM  
STATES LEE III NUCLEAR STATION, UNITS 1 AND 2 COMBINED LICENSES  
APPLICATION ENVIRONMENTAL REVIEW

Dear Mr. Bernhart:

The U.S. Nuclear Regulatory Commission (NRC) staff is reviewing an application submitted by Duke Energy Carolinas, LLC (Duke) for a combined license (COL) application for construction and operation of two new nuclear reactors, William States Lee III Nuclear Station, Units 1 and 2 (Lee Nuclear Station), at the Lee Nuclear Station site in Gaffney, South Carolina. As part of its review of the proposed action, the NRC staff prepared a draft environmental impact statement (EIS) (NUREG-2111), which was published in December 2011. The draft EIS is available through the NRC's Agencywide Documents Access and Management System (ADAMS), which is accessible from the NRC's website at <http://www.nrc.gov/reading-rm/adams.html> at ADAMS Accession No. ML113430094. The draft EIS can also be found online at the NRC's Lee Nuclear Station specific webpage at <http://www.nrc.gov/reactors/new-reactors/col/lee/documents/nrc-2011.html>.

During the preparation of the draft EIS, the NRC staff issued a scoping letter to the National Marine Fisheries Service (NMFS) Southeast Regional Office dated April 9, 2008 (ADAMS Accession No. ML080850962), requesting information regarding Federally-protected species and critical habitat under NMFS' jurisdiction and, in support of the Magnuson-Stevens Fishery Conservation and Management Act (MSFCMA), any designated Essential Fish Habitat in the vicinity of the Lee Nuclear Station site. The NRC staff also requested any information considered appropriate under the provisions of the Fish and Wildlife Coordination Act (FWCA). By letter dated May 5, 2008 (ADAMS Accession No. ML081400585) NMFS provided a list of Federally-protected species for the state of South Carolina, which included the shortnose sturgeon (*Acipenser brevirostrum*). Subsequently, effective April 6, 2012, the NMFS listed the Carolina and South Atlantic distinct population segments of Atlantic sturgeon (*A. oxyrinchus oxyrinchus*) as endangered under the Endangered Species Act (ESA).

In the draft EIS, the NRC staff concluded that while not currently present in the vicinity of the Lee Nuclear Station site, two diadromous species (currently without Federal protection), the American eel (*Anguilla rostrata*) and American shad (*Alosa sapidissima*) had a historical presence at the site. Both shortnose and Atlantic sturgeon are not currently present nor were historically present in the vicinity of the site. The draft EIS cites the *Santee River Basin Accord for Diadromous Fish Protection, Restoration, and Enhancement of 2008*, and concludes that in



D. Bernhart

- 2 -

the future, should fish passage facilities be built in the Broad River, including at the Ninety-Nine Islands Dam, there is the possibility for diadromous fish to return to the vicinity of the Lee Nuclear Station.

As documented in an e-mail with Mr. Eric Hawk, ESA Section 7 Coordinator for NMFS, dated May 21, 2012 (ADAMS Accession No. ML12171A581), the NRC staff considers its consultation with NMFS under the ESA, MSFCMA, and FWCA for the Lee Nuclear Station COL application to be complete. However, upon construction and operation of the proposed Lee Nuclear Station and, in the event of the successful implementation of the fish passage program as described in the Santee River Basin Accord, the NRC staff will reinitiate consultation with NMFS, if there is potential for thermal, chemical, and physical impacts to Federally-protected species from operations at the Lee Nuclear Station.

If you have any questions regarding this matter, please contact the NRC environmental project manager, Ms. Sarah Lopas at 301-415-1147, or via e-mail to [Sarah.Lopas@nrc.gov](mailto:Sarah.Lopas@nrc.gov).

Sincerely,

/RA/

William F. Burton, Chief  
Environmental Projects Branch 1  
Division of New Reactor Licensing  
Office of New Reactors

Docket Nos.: 52-018 and 52-019

cc: See next page

D. Bernhart

- 2 -

the future, should fish passage facilities be built in the Broad River, including at the Ninety-Nine Islands Dam, there is the possibility for diadromous fish to return to the vicinity of the Lee Nuclear Station.

As documented in an e-mail with Mr. Eric Hawk, ESA Section 7 Coordinator for NMFS, dated May 21, 2012 (ADAMS Accession No. ML12171A581), the NRC staff considers its consultation with NMFS under the ESA, MSFCMA, and FWCA for the Lee Nuclear Station COL application to be complete. However, upon construction and operation of the proposed Lee Nuclear Station and, in the event of the successful implementation of the fish passage program as described in the Santee River Basin Accord, the NRC staff will reinitiate consultation with NMFS, if there is potential for thermal, chemical, and physical impacts to Federally-protected species from operations at the Lee Nuclear Station.

If you have any questions regarding this matter, please contact the NRC environmental project manager, Ms. Sarah Lopas at 301-415-1147, or via e-mail to [Sarah.Lopas@nrc.gov](mailto:Sarah.Lopas@nrc.gov).

Sincerely,  
/RA/

William F. Burton, Chief  
Environmental Projects Branch 1  
Division of New Reactor Licensing  
Office of New Reactors

Docket Nos.: 52-018 and 52-019

cc: See next page

**DISTRIBUTION:**

PUBLIC

SLopas, NRO

KRoach, OGC

RidsOgcMailCenter

WBurton, NRO

SPrice, OGC

RidsOcaMailCenter

MTonacci, NRO

ARedden, NRO

RidsRgn2MailCenter

BHughes, NRO

RidsNroDnrlEpb1

NKuntzleman, NRO

RidsNroDnrl

RHannah, RII

RidsNroDseaRenv

RKrieg, PNL Team Lead

([Rebekah.Krieg@pnl.gov](mailto:Rebekah.Krieg@pnl.gov))

TMiley, PNL Deputy Team Lead

([Terri.Miley@pnl.gov](mailto:Terri.Miley@pnl.gov))

RDarden, USACE

([Richard.Darden@usace.army.mil](mailto:Richard.Darden@usace.army.mil))

**ADAMS Accession No: ML12173A383**

**NRO-002**

|        |                  |                  |                  |
|--------|------------------|------------------|------------------|
| OFFICE | PM:NRO:DNRL:EPB1 | LA:NRO:DNRL:EPB1 | PM:NRO:DSEA:RENV |
| NAME   | SLopas           | ARedden          | NKuntzleman      |
| DATE   | 6/26/12          | 6/21/12          | 7/31/12          |
| OFFICE | OGC              | BC:NRO:DNRL:EPB1 |                  |
| NAME   | KRoach           | WBurton          |                  |
| DATE   | 8/8/12           | 8/14/2012        |                  |

OFFICIAL RECORD COPY



Lee Environmental Mailing List  
cc:

Mr. Phillip Anderson  
PO Box 710  
Mtn Horn, NC 28758-0710

Mr. Larry Armstrong  
301 Zima Park Dr.  
Spartanburg, SC 29301

Ms. Deb Arnason  
360 Webb Road  
Wadesboro, NC 28170

Mr. J. Holland Belue, Asst. County  
Administrator  
Cherokee Council  
210 N. Limestone Street  
Gaffney, SC 29340

Mr. David Bernhart  
Asst. Regional Administrator for Protected  
Resources  
National Marine Fisheries Service  
Southeast Regional Office  
263 13th Ave., South  
St. Petersburg, FL 33701

Mr. Ray Blanton  
118 Stacy Drive  
Gaffney, SC 29341

Ms. Lily L. Blue  
124 Riverport Drive  
Clemson, SC 29631

Mr. Paul Boger  
PO Box 97  
York, SC 29631

Mr. Will Bowers  
145 Mildred Avenue  
Gaffney, SC 29341

Ms. Susan Broadhead  
328 Martins Creek Rd.  
Barnardsville, NC 28709

Mr. Stephen M. Cain  
3231 Glenn Springs Rd.  
Spartanburg, SC 29302

Mr. Mark A. Caldwell  
U.S. Fish and Wildlife Service  
Ecological Services  
178 Croghan Spur Road  
Suite 200  
Charleston, NC 29407

Mr. Dick Carr Jr.  
16 Fourmile Branch Lane  
Spartanburg, SC 29302

Mr. Ben L. Clary  
County Administrator  
Cherokee County Council  
210 N. Limestone Street  
Gaffney, SC 29340

Mr. Michael Cook  
Executive Director  
United South and Eastern Federation of  
Tribes  
Stewarts Ferry Pike  
Suite 100  
Nashville, TN 37214

Mr. David Cordeau  
105 N. Pine Street  
PO Box 1636  
Spartanburg, SC 29304

Ms. Claudine Cremer  
260 Dula Springs Road  
Weaverville, NC 28787

Mr. Brian Crissey  
1689 Silver Creek Rd.  
Mill Spring, NC 28756

Lee Environmental Mailing List  
cc:

Ms. Mary Crockett  
Broad Scenic River Advisory Council South  
Carolina  
Dept of Natural Resources Land Water and  
Conservation Division  
PO Box 167  
Suite 354  
Columbia, SC 29202

Ms. Rebekah Dorbrasko  
Review and Compliance Coordinator  
South Carolina Department  
of Archives and History  
8301 Parklane Road  
Columbia, SC 29223

Mr. Phillip Ervin  
412 Colonial Avenue  
Gaffney, SC 29340

Mr. R. Michael Gandy  
SC Dept of Health  
& Environmental Control  
2600 Bull Street  
Columbia, SC 29201

Mr. Steven Gilman  
18 Birchwood Lane  
Asheville, NC 28805

Ms. Peggy Guy  
177 Haywood Knolls Drive  
Hendersonville, NC 28791

Dr. Wenonah G. Haire  
Tribal Historic Officer  
Catawba Indian Nation  
Tribal Historic Preservation Office  
1536 Tom Steven Road  
Rock Hill, SC 29730

Cecil & Cynthia Hale  
668 Wofford Road  
Gaffney, SC 29340

Mr. Timothy Hall  
Fish and Wildlife Service  
176 Croghan Spur Road, Suite 200  
Charleston, SC 29407

Mr. Andy Halligan  
350 East Main Street, Suite 500  
Spartansburg, SC 29302

Ms. Judith Hallrock  
11 Digges Road  
Asheville, NC 28805

Mr. Sam Hamilton  
Regional Director  
U.S. Fish and Wildlife Service  
Southeast Region  
1875 Century Blvd, Suite 400  
Atlanta, GA 30345

Mr. Mike Hamrick  
138 Alpine Drive  
Gaffney, SC 29341

Mr. Hillbert Hansborough, Jr.  
244 Keith Haven Lane  
Columbus, NC 28722

Chris Hardy  
York Regional Chamber of Commerce  
PO Box 590  
Rock Hill, SC 29731

Mr. Jeff Harmon  
102 Stonecrest Lane  
Gaffney, SC 29341

Mr. Ray Hearne  
91 Bald Creek Rd.  
Leicester, NC 28748

Mr. Bruce Henderson  
600 S. Tryon St.  
Charlotte, NC 28203



Lee Environmental Mailing List  
cc:

Mr. David Hogue, Mayor  
Town of Blacksburg  
PO Box 144  
Blacksburg, SC 29702

Ms. Cathy Holt  
43 Vermont Ct., #B7  
Asheville, NC 28806

Rev. Posy Jackson  
145 Old Mt. Olivet Rd.  
Zirconia, NC 28790

Ms. Virginia Jenkins  
P.O. Box 2562  
Spartanburg, SC 29304

Mr. David G. Johnson  
Morgan Corporation  
PO Box 3555  
Spartanburg, SC 29304

Mr. Mike Jolly  
P.O. Box 11706  
Rockhill, SC 29708

Mr. Henry L. Jolly, Mayor  
City of Gaffney  
PO Box 2109  
Gaffney, SC 29342

Ms. Leah Karpen  
400 Charlotte Street, Suite 803  
Asheville, NC 28801-1452

Mr. Don Kilma, Director  
Office of Federal Agency Programs  
Advisory Council on Historic Preservation  
Old Post Office Building  
1100 Pennsylvania Avenue, Suite 809  
Washington, DC 20004

Ms. Valerie LeVander  
68 Niles Drive  
Hendersonville, NC 28792

Mr. Ron Linville  
North Carolina Wildlife Resources  
Commission  
Habitat Conservation Program  
3855 Idlewild Road  
Kemersville, NC 27284

Mr. Lanny Littlejohn  
210 Deerwood  
Pacaleet, SC 29372

Thomas J. LoVullo, Chief  
Aquatic Resources Branch  
Div. of Hydropower Administration and  
Compliance  
Federal Energy Regulatory Commission  
888 First Street, NE  
Washington, DC 20426

Mr. David McEntire  
1085 Bridges Rd.  
Blacksburg, SC 29702

Ms. Susie Mitcham  
P.O. Box 755  
Greenville, SC 29602

Mr. Charles Moss  
PO Box 217  
Sharon, SC 29742

Representative Dennis Moss  
306 Silver Circle  
Gaffney, SC 29340

Rep. Dennis Moss  
South Carolina House District 29  
306 Silver Circle  
Gaffney, SC 29340

Charles and Evelyn Nelson  
119 Clary Drive  
Gaffney, SC 29341

Chief Gene Norris  
Piedmont American Indian Assn  
Lower Eastern Cherokee Nation SC  
3688 Warrior Creek Church Road  
Gray Court, SC 29645

Lee Environmental Mailing List  
cc:

Mr. Les Parker  
Columbia Regulatory Field Office  
US Army Corps of Engineers  
1835 Assembly Street  
RM 865, B-1  
Columbia, SC 29201

Mr. Lewis Patrie, MD  
99 Eastmoore Drive  
Asheville, NC 28805

Mark and Penny Patterson  
125 Scenic Drive  
Blacksburg, SC 29702

Mr. Joseph Patterson  
100 Rains Road  
Blacksburg, SC 29702

Sen. Harvey S. Peeler, Jr.  
PO Box 742  
Gaffney, SC 29342

Mr. Billy Pennington  
1566 Victory Trail  
Gaffney, SC 29340

Mr. Robert D. Perry  
Certified Wildlife Biologist Director  
Office of Environmental Programs  
1000 Assembly Street, RM 310A  
PO Box 167  
Columbia, SC 29202

Ms. Michelle Pounds  
Chief Executive Officer  
Rep Pine Hill Indian Community  
Carolina Indian Heritage Association  
4055 Coberg Land  
Orangeburg, SC 29115

Ms. Sandra Reinhardt  
THPO Archaeology Department  
Catawba Indian Nation  
1536 Tom Steven Road  
Rock Hill, SC 29730

Mr. Don Richardson  
577 Windover Dr.  
Brevard, NC 28712

Ms. Amanda R. Rowe  
417 W. Pine St.  
Blacksburg, SC 29702

Mr. Garrett Scott  
300 East Main Street  
Suite 500  
Spartansburg, SC 29302

Mr. Michael Seaman-Huynh  
SC Office of Regulatory Staff  
1441 Main Street  
Suite 300  
Columbia, SC 29201

Mr. Coleman Smith  
P.O. Box 2551  
Asheville, NC 28802

Mr. Pete Smith  
P.O. Box 205  
Drayton, SC 29333

Mr. Clyde E. "Butch" Smith  
Manager  
Cleveland County Water  
439 Casar Lawndale Road  
PO Box 788  
Lawndale, NC 28090

Ms. Laura Sorensen  
40 Green Valley Rd.  
Asheville, NC 28806

Frank & Donna Sossaman  
190 Sossamon Loop  
Gaffney, SC 29340

Mr. Willard Steele  
Tribal Historic Preservation Officer  
Seminole Tribe of Florida  
HS 61 Box 21A  
Clewiston, FL 33440



Lee Environmental Mailing List  
cc:

Mr. James R. Taylor  
Gaffney City Administrator  
PO Box 2109  
Gaffney, SC 29342

Mr. Bill Thomas  
PO Box 272  
Cedar Mountain, NC 28718

Ms. Ruth Thomas  
354 Woodland Dr.  
Columbia, NC 28722

Ms. Ellen Thomas  
P.O. Box 26  
Tryon, NC 28782

Rev. JoAnn Tomberlin  
651 Old Mt. Olivet Rd.  
Zirconia, NC 28790

Mr. Russell Townsend  
Tribal Historic Preservation Officer  
Eastern Band of Cherokee Indians  
PO Box 455  
Cherokee, NC 28719

Ms. Janet Tsiknias  
133 Cherokee National Hwy.  
Gaffney, SC 29341

Chief Glenna J. Wallace  
Eastern Shawnee Tribe of Oklahoma  
PO Box 350  
Seneca, MO 64804

Mr. Rusty Wenerick  
SC Dept of Health and Environmental  
Control  
Bureau of Water  
2600 Bull Street  
Columbia, SC 29201-1708

Ms. Debralee Williams  
9 Neil Price Ave  
Black Mountain, NC 28711

Mr. Clint Wolfe  
Citizens for Nuclear Technology Awareness  
1204 Whiskey Road, Suite B  
Aiken, SC 29803

Ms. Vicki S. Wooten  
Executive Assistant  
Office of the Secretary  
SC Dept of Commerce  
1201 Main Street, Suite 1600  
Columbia, SC 29201

Dr. Joseph W. Zdenek  
752 Harrell St.  
Rock Hill, SC 28730

Mr. Chuck Zimmerman  
28 Waterford Ct.  
Atlanta, GA 30328

Eric Hawk  
Section 7 ESA Coordinator  
National Marine Fisheries Service  
263 13<sup>th</sup> Avenue South  
Saint Petersburg, FL 33701

#### E-Mail

John.Aedo@ferc.gov (John Aedo)  
ehpa@bellsouth.net (Patricia Allison)  
daya@invirodesign.com (Daya Apunte)  
larmstrong@smeinc.com (Larry Armstrong)  
maugspurger@smeinc.com (Mark Augspurger)  
sara@cleanenergy.org (Sara Barczak)  
maubar53@bellsouth.net (Barbara Barnett)  
billbe@charter.net (William Beach)  
dbean@enercon.com (David Bean)  
all@aconsultingengineer.com (Philip J. Bisesi)  
rblanton118@bellsouth.net (Ray Blanton)  
stevenblanton@gmail.com (Steven Blanton, Jr.)  
Rachael.bliss@yahoo.com (Rachael Bliss)  
paulboger@greateryorkchamber.com (Paul Boger)  
bolinj@bellsouth.net (James W. Bolin, Sr.)  
sbreckheimer@gmail.com (Steve Breckheimer)  
aebidges@msn.com (Amy Elliot Bridges)  
s\_broadhead@hotmail.com (Susan Broadhead)  
timothy.brooks@us.nestle.com (Timothy Brooks)  
buscarino.john@gmail.com (John Buscarino)  
stephenmcain@yahoo.com (Stephen Cain)  
richardcarr@charter.net (Dick Carr Jr.)  
sarah.chisholm@gmail.com (Sarah Chisholm)  
tclarkpsy@yahoo.com (Terrence Clark, MD)  
cclaunch@duke-energy.com (Chuck Claunch)  
tomclements329@cs.com (Tom Clements)  
pcoffey01@gmail.com (Peter Coffey)  
grwa2011@yahoo.com (Sky Conard)  
cookj@sccsc.edu (Jim Cook)  
icooper@wpceng.com (Ivan Cooper)  
ennagiarc@gmail.com (Anne Craig)  
cpcrermer@frontier.com (Claudine Cremer)  
brian.crissey@yahoo.com (Brian Crissey)  
Dobrasko@SCDAH.STATE.SC.US (Rebekah Dobrasko)  
joanwdrake@aol.com (Joan Drake)  
nsedwar@regstaff.sc.gov (Nanette Edwards)  
gfair@clemson.edu (Gabriel Fair)  
mark.farris@yorkcountygov.com (Mark Farris)  
mikeforrester@schouse.gov (Rep. Mike Forrester)  
fossmj@appstate.edu (Matthew Foss)  
jpfraedr@duke-energy.com (Lyn Fraedrich)  
pfredrickson@duke-energy.com (Paul Fredrickson)  
Dan@invirodesign.com (Dan Gamble)  
Steven.L.Gilman@gmail.com (Steven Gilman)  
chris.goudreau@ncwildlife.org (Chris Goudreau)  
worldwidewellness@madriver.com (Laura Grala)  
Agrant.pa@gmail.com (Anna Grant)  
jwgmaps@gmail.com (Chip Green)  
ben@scwf.org (Ben Gregg)



bguild@mindspring.com (Bob Guild)  
 peggyguy@morrisbb.net (Peggy Guy)  
 hale.kendall@gmail.com (Kendall Hale)  
 mandy@cleanenergy.org (Mandy Hancock)  
 stonecrestapts@bellsouth.net (Jeff Harmon)  
 jeanhedges2004@hotmail.com (Jean Hedges)  
 Bhenderson@charlotteobserver.com (Bruce Henderson)  
 Katie@cwfn.org (Katie Hicks)  
 Lorena.hildebrandt@gmail.com (Lorena Hildebrandt)  
 hollingj@dnr.sc.gov (Julie Holling)  
 cathyholt@gmail.com (Cathy Holt)  
 robfhow@gmail.com (Robert F. Howarth)  
 rhow@charter.net (Robert Howarth)  
 jaxon07@bellsouth.net (Posy Jackson)  
 majames@regstaff.sc.gov (M. Anthony James, P.E.)  
 mjolly@cityofrockhill.com (Mike Jolly)  
 jonesp@sccsc.edu (Para M. Jones)  
 skeller@cityofgaffney-sc.gov (Scott Keller)  
 kohler1122@yahoo.com (Elizabeth Kohler)  
 Larson\_jean@hotmail.com (Jean Larson)  
 jled43@chesnet.net (Judy Ledford)  
 richardL640@bellsouth.net (Richard LeVander)  
 david.lewis@pillsburylaw.com (David Lewis)  
 patmccall1@aol.com (Pat McCall)  
 mcconney.ramona@epamail.epa.gov (Ramona K. McConney))  
 David\_mcentire@yahoo.com (David McEntire)  
 brian.mcintyre@areva.com (Brian McIntyre)  
 lisamcw2@gmail.com (Lisa McWherter)  
 Julia.millar@gmail.com (Julia Millar)  
 dmillsclan@bellsouth.net (Randy Mills)  
 bmina@morgan.corp.com (Robert Mina)  
 knmominee@firstenergycorp.com (Katharine N. Mominee)  
 comcher@bellsouth.net (Gene Moorhead)  
 dennismoss@schouse.gov (Rep. Dennis Moss)  
 dennismoss@schous.gov (Dennis Moss)  
 stevemoss@schouse.gov (Rep. Steve Moss))  
 ca.nelson@att.net (Charles Nelson)  
 Adam.nygaard@gmail.com (Adam Nygaard)  
 maryo@nirs.org (Mary Olson)  
 tervdog@mindspring.com (Ellen Pauly)  
 hperry@smeinc.com (Howard Perry)  
 Otis.Rawl@scchamber.net (Otis Rawl)  
 sandrar@ccppcrafts.com (Sandra Reinhardt)  
 karich321@yahoo.com (Kitty Katherine Richards)  
 nrichardson.me99@gtalumni.org (Nicole Richardson)  
 gaia@citcom.net (Don Richardson)  
 krobbs@cherokeechamber.org (Kayla Robbs)  
 Arowe@miller-rowe.com (Amanda R. Rowe)  
 Gerald.rudolph@gmail.com (Gerald Rudolph)  
 jwsaye@gmail.com (Jack Saye)

Darrell.scott@scchamber.net (Darrell Scott)  
jlsimage@gmail.com (Jonah Simmons)  
wesmith2@bellsouth.net (William E. Smith)  
seawind161@att.net (Pete Smith)  
newsouthnetwork@gmail.com (Coleman Smith)  
kshoesmith@charter.net (Karen Smith)  
hbsmith1207@bellsouth.net (Brian and Kay Smith)  
dale.smith@duke-energy.com (Dale Smith)  
LSRedoak@gmail.com (Laura Sorensen)  
Tims Spencer9@yahoo.com (Tim Spencer)  
dsteen@comporium.net (Darin Steen)  
bstill@morgan-corp.com (Bow Still)  
distroupe@dukeenergy.com (Dennis Stroupe)  
dsulock@unca.edu (Dot Sulock)  
dcswinton.campaign@gmail.com (D.C. Swinton)  
et@prop1.org (Ellen Thomas)  
Amber.Thomas@SunTrust.com (Amber Thomas)  
Charles.thornton@airgas.com (Charles Thornton)  
John.thrasher@duke-energy.com (John Thrasher)  
Deborah.thrift@shawgrp.com (Deborah Thrift)  
rathroneburg@duke-energy.com (Bob Throneburg)  
htinnaro@gmail.com (Heather Tinnaro)  
jate2531@gmail.com (JoAnn Tomberlin)  
gaffrest@hotmail.com (Janet Tsiknias)  
jtynan@upstateforever.org (John Tynan)  
VejdaniV@dnr.sc.gov (Vivianne Vejdani)  
waraksre@westinghouse.com (Rosemarie E. Waraks)  
steve.ware@us.nestle.com (Steve Ware)  
JASON.WATERS@gw.cherokee1.k12.sc.us (Jason Waters)  
jwatts@charter.net (Jim Watts)  
keith.webb@mcgillengineers.com (Keith Webb)  
weneriwr@dhec.sc.gov (Rusty Wenerick)  
gayleshop@bellsouth.net (Gayle White)  
cwilson@scdah.state.sc.us (Caroline Dover Wilson)  
Robert.wylie@duke-energy.com (Robert Wylie)  
joe.yanes@duke-energy.com (Joe Yanes)  
ryoungblood@yorkcountychamber.com (Rob Youngblood)  
jzdenek@comporium.net (Joseph Zdenek)  
bredl@skybest.com (Louis Zeller)  
czimmjr38@yahoo.com (Chuck Zimmerman)



**From:** [Eric Hawk](#)  
**To:** [Lopas, Sarah](#)  
**Cc:** [Stephanie Bolder](#); [Cathy Tortorelli](#)  
**Subject:** Re: Lee Nuclear Station consultation requirements  
**Date:** Monday, May 21, 2012 2:17:27 PM

---

Hello Ms. Lopas,  
Having read your letter, it appears to me that NRC has a proper basis for making a no-effect determination for sturgeon species, and thus meet their ESA Section 7 consultation responsibilities with NMFS. However, should the fish passage program be successfully implemented (as you mentioned, and is discussed in the Santee River Basin Accord for Diadromous Fish Protection, Restoration, and Enhancement of 2008), then the possibility of sturgeon presence at the Lee Nuclear Station site should be re-addressed. At that time I would recommend that you reinitiate consultation and seek our concurrence that thermal, chemical, and physical impacts from the plant on any life stages of sturgeon present would be minimal. Thank you for your correspondence. If you wish to prepare a letter stating the above, we would be pleased to receive it.

Eric Hawk

On Mon, May 21, 2012 at 11:55 AM, Lopas, Sarah <[Sarah.Lopas@nrc.gov](mailto:Sarah.Lopas@nrc.gov)> wrote:

Hi Mr. Hawk,

I thought it might be a good idea to send you letters related to the Lee Nuclear Station project -- so you have a little background, and then we can set up a time for a quick phone call.

Back in April 2008 (see attached), we sent NMFS a scoping letter requesting:

*To support the EIS preparation process and to ensure compliance with Section 7 of the*

*Endangered Species Act, the NRC requests a list of endangered, threatened, candidate, and*

*proposed species, and designated and proposed critical habitat that may be in the vicinity of the*

*Lee site, which are under the jurisdiction of the National Marine Fisheries Service. In support of*

*the Magnuson-Stevens Fishery Conservation and Management Act, the NRC also requests a*

*list of federally managed species that have designated essential fish habitat in the vicinity of the*

*Lee site. Additionally, please provide any information you consider appropriate under the*

*provisions of the Fish and Wildlife Coordination Act.*

In May, NMFS replied with a list of Federally protected species under the jurisdiction of NMFS for South Carolina (attached). The NRC aquatic biologists determined that there was no historical presence of Sturgeon at the Lee Nuclear Station site. Our EIS does speak to Diadromous Fish Species Potentially Available in the Future (see page 2-114 of Volume 1 of the EIS -- located here:

<http://www.nrc.gov/reading-rm/doc-collections/nuregs/staff/sr2111/>). We also discuss this briefly in Chapter 5, where we discuss operational impacts of the plant - - page 5-37 of Volume 1. We conclude that American eel and American shad could eventually be found in waters near the proposed Lee Nuclear Station,

And finally, the U.S. Army Corps of Engineers, a cooperating agency on the Lee Nuclear Station environmental impact statement, received a comment from NMFS dated March 6, 2012, on their Joint Public Notice (which was issued in December 2011). In the letter (attached), it states:

*Finally, in accordance with section 7 of the Endangered Species Act of 1973, as amended, it is the*

*responsibility of the lead federal agency to review and identify any proposed activity that may affect*

*endangered or threatened species and their habitat. Shortnose and Atlantic sturgeon may be present*

*within the action area during the life of the project. Determinations involving species under NMFS*

*jurisdiction should be reported to our Protected Resources Division at the letterhead address.*

The NRC is the lead agency on the Lee Nuclear Station environmental review. Essentially, I am wondering what else, if anything, we need to do to complete our consultation? I took this project over about half-way through, and I'm guessing that after our aquatic ecologists determined there were no diadromous fish present in the vicinity of the Lee Nuclear Station, and furthermore, no historical presence, it was determined we did not have to pursue consultation. Perhaps we need to finalize our conclusions in a letter to you to formalize this?



Let me know a good time to discuss this. With the exception of being tied up in meetings for most of today, I am free for a call most anytime this week.

Thank you for your help!

-Sarah

Sarah L. Lopas  
Environmental Project Manager

Office of New Reactors

U.S. Nuclear Regulatory Commission  
Office (301) 415-1147

Fax (301) 415-5399

Home (443) 708-7002

*Please consider the environment before printing this email.*

--

Eric G. Hawk  
NMFS Southeast Region  
ESA Section 7 Coordinator