

## PMSTPCOL PEmails

---

**From:** Tai, Tom  
**Sent:** Thursday, September 13, 2012 4:06 PM  
**To:** Tomkins, James  
**Cc:** STPCOL  
**Subject:** STP - Long Term Cooling Clarifications

Jim,

Please confirm the following:

1. The wetwell design temperature is 104 C.
2. The re-analysis of the ABWR DCD containment (due to DCD errors) resulted in higher M&E releases. This increase is not driven by the correction of DCD errors.

I may have a couple more questions later.

Thanks

Tom Tai  
DNRL/NRO  
(301) 415-8484  
[Tom.Tai@NRC.GOV](mailto:Tom.Tai@NRC.GOV)

**Hearing Identifier:** SouthTexas34Public\_EX  
**Email Number:** 3448

**Mail Envelope Properties** (0A64B42AAA8FD4418CE1EB5240A6FED1B0C43A4911)

**Subject:** STP - Long Term Cooling Clarifications  
**Sent Date:** 9/13/2012 4:06:05 PM  
**Received Date:** 9/13/2012 4:06:10 PM  
**From:** Tai, Tom

**Created By:** Tom.Tai@nrc.gov

**Recipients:**  
"STPCOL" <STP.COL@nrc.gov>  
Tracking Status: None  
"Tomkins, James" <jetomkins@STPEGS.COM>  
Tracking Status: None

**Post Office:** HQCLSTR02.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	402	9/13/2012 4:06:10 PM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**