

PMSTPCOL PEmails

From: Foster, Rocky
Sent: Monday, August 20, 2012 9:50 AM
To: Scheide, Richard
Cc: Head, Scott; STPCOL
Subject: Seismic Follow-up Information

Dick,

The following is follow-up information from our August 15, 2012:

The following figures were used from the CEUS-SSC report (<http://www.ceus-ssc.com/Report/Chapter8.html>): Figure 8.2-3j, 8.2-3k, and 8.2-3k. From each figure, the spectral acceleration values were obtained at 10⁻⁴ and 10⁻⁵ annual exceedance frequencies from the black curve (i.e. COLA model 2003 to 2009 for Houston). These hazard values were compared to the STP hazard curves and observed that they are not similar. The GMRS were calculated at 1 Hz, 10 Hz, and PGA for the Houston COLA model and compared these values with the STP "hard rock" GMRS. The comparison shows that the Houston COLA model hard rock GMRS (at the above mentioned frequencies) is significantly lower than the STP hard rock GMRS.

Thanks,

Rocky D. Foster
Project Manager
US Nuclear Regulatory Commission
Office of New Reactors
Division of New Reactor Licensing
Licensing Branch 3 (LB3)
Mai Stop T6D38M
(301) 415-5787
rocky.foster@nrc.gov

Hearing Identifier: SouthTexas34Public_EX
Email Number: 3463

Mail Envelope Properties (26E42474DB238C408C94990815A02F09990E8CB2C8)

Subject: Seismic Follow-up Information
Sent Date: 8/20/2012 9:50:12 AM
Received Date: 8/20/2012 9:50:14 AM
From: Foster, Rocky

Created By: Rocky.Foster@nrc.gov

Recipients:
"Head, Scott" <smhead@STPEGS.COM>
Tracking Status: None
"STPCOL" <STP.COL@nrc.gov>
Tracking Status: None
"Scheide, Richard" <rhscheide@STPEGS.COM>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	1046	8/20/2012 9:50:14 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: