

NRR-PMDAPEm Resource

From: Saba, Farideh
Sent: Tuesday, September 25, 2012 4:45 PM
To: Tomonto, Bob; Hanek, Olga
Subject: Acceptance review for ME9500/1 TURKEY POINT 3/4 - LAR 224 regarding TS 3/4.6.2.3 - Recirculation pH control system and NaTB Basket loading requirement

Importance: High

Bob,

By letter dated September 6, 2012, Florida Power and Light Company (the licensee) submitted for a license amendment request (LAR) to the Renewed Facility Operating Licenses (RFOL) for Turkey Point Units 3 and 4. The proposed LAR would reduce the current TS 3/4.6.2.3 minimum required NaTB mass from 11,061 lbm to 7,500 lbm, leaving more than 1000 lbm of margin to the analyzed minimum of 6,427 lbm. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the request has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

If you have any questions, please contact me at (301) 415-1447 or via email by farideh.saba@nrc.gov.

Farideh E. Saba, P.E.
Senior Project Manager
NRC/ADRO/NRR/DORL
301-415-1447
Mail Stop O-8G9A
Farideh.Saba@NRC.GOV

Hearing Identifier: NRR_PMDA
Email Number: 491

Mail Envelope Properties (Farideh.Saba@nrc.gov20120925164500)

Subject: Acceptance review for ME9500/1 TURKEY POINT 3/4 - LAR 224 regarding TS
3/4.6.2.3 - Recirculation pH control system and NaTB Basket loading requirement
Sent Date: 9/25/2012 4:45:19 PM
Received Date: 9/25/2012 4:45:00 PM
From: Saba, Farideh

Created By: Farideh.Saba@nrc.gov

Recipients:
"Tomonto, Bob" <Bob.Tomonto@fpl.com>
Tracking Status: None
"Hanek, Olga" <Olga.Hanek@fpl.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	1859	9/25/2012 4:45:00 PM

Options
Priority: High
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received: