

## Chang, Richard

---

**From:** Chang, Richard  
**Sent:** Monday, February 07, 2011 8:04 AM  
**To:** Stutzke, Martin  
**Cc:** Schaperow, Jason; Tinkler, Charles  
**Subject:** RE: PRA Information for Surry

Marty,

Any luck in digging into items # 2 and 3 below?

Thanks,  
Richard

---

**From:** Stutzke, Martin  
**Sent:** Tuesday, February 01, 2011 5:00 PM  
**To:** Chang, Richard; Guzman, Richard  
**Cc:** Schaperow, Jason; Tinkler, Charles  
**Subject:** RE: PRA Information for Surry

I'll look into this later this week (RES All-Hands meeting, etc.). Some quick information:

- 1) Surry has a Level 2 and Level 3 PRA for ISLOCA – some information is reported in the SAMA analysis for license renewal (this is dated – circa 2003). The contribution to the CDF from ISLOCAs was  $1.6E-6/y$  (which is also the ISLOCA release frequency). Note that SGTRs were separately reported, and thus not included in the previous sentence.
- 2) I'll have to do some digging on how they assess ISLOCA risk (modeling assumptions, etc.).
- 3) More digging to find the LERF.

Marty

---

**From:** Chang, Richard  
**Sent:** Tuesday, February 01, 2011 4:17 PM  
**To:** Guzman, Richard; Stutzke, Martin  
**Cc:** Schaperow, Jason; Tinkler, Charles  
**Subject:** PRA Information for Surry

Marty and Rich,

For the ISLOCA scenario for Surry:

From our site visit from Surry- we recently were told by the licensee that the catastrophic failure of 2 inline one-way check valves had a frequency of  $1 \times 10^{-8}$ . We were then told that the catastrophic failure of a one-way check valve and leak-by of the other as well as a failure of a third isolation valve had a probability of  $7 \times 10^{-7}$ .

However, Our current report states that the ISLOCA scenario does not meet the SOARCA screening criterion of  $1 \times 10^{-7}$  per reactor-year for a bypass

event. The SPAR model assigns it a frequency of  $3 \times 10^{-8}$ /reactor-year, and the licensee's PRA assigns it a frequency of  $7 \times 10^{-7}$ /reactor-year. The SPAR model's frequency does not meet the SOARCA screening criterion

for bypass events of  $1 \times 10^{-7}$ /reactor-year, but the licensee's PRA frequency does. Therefore, it was retained for analysis. The main reason for the difference is that the licensee assumed the likelihood of subsequent low head

• Injection piping rupture was 1, while the NRC estimated it to be 0.1.

So my questions are this:

1. Does Surry have a level 2 or 3 analysis for ISLOCA?
2. How do they treat ISLOCA?
3. What is their internal events LERF frequency?

**I am trying to avoid going back to plant...so if you guys could help me out, I would appreciate it.**

If not, I will try to give the Plant PRA guys a ring.

Thanks,

Richard Chang  
Program Manager  
RES/DSA/SPB  
301-251-7980