

NRR-PMDAPEm Resource

From: Feintuch, Karl
Sent: Friday, October 05, 2012 5:21 PM
To: Sahay, Prem; 'Browning, Tony'; 'Byrne, Thomas'; 'Pint, Dennis'
Subject: ME8300 - DA - Battery related amendment application - Request for Additional Information

The purpose of this message is to prepare a record of a Request for Additional Information (RAI) regarding the subject license amendment request that includes the requested response date directly below. This message duplicates the same information in an Outlook update message sent a few minutes ago.

===== Update 2012-10-05-1711 ET =====

Regarding the requested response schedule for the RAI items below: Please respond by November 27, 2012.

===== Update 2012-09-27-1120 ET =====

Bridge Line Information:

Phone number: **(305) 552-3000**

Passcode: **8517750**

===== original message =====

Invitation is for 1:00-2:00 PM ET on 9/27/2012

Agenda is draft set of RAI items provided last week.

Please forward this invitation to other expected participants.

===== agenda =====

From: Feintuch, Karl

Sent: Thursday, September 20, 2012 4:23 PM

To: 'Browning, Tony'

Cc: Sahay, Prem

Subject: ME8300 - DA - battery related Tech Spec Surveillance Requirement LAR - conference call invitation; draft RAI items

NRC staff seeks a conference call to discuss the following agenda, which is intended to become a set of RAI items. Please observe that the battery model number(s) are referenced in your application as both LRC-17 and LCR-17. Please confirm if a typographical error accounts for the two designations. If there is a typo, it affects the scope of the RAI item(s), which we would discuss during the call.

Please respond with some windows of opportunity for a call within the period 24-28 Sept 2012 (I recognize that 21Sept 2012 is a DAEC staff day off.) I will confer with the Reviewer (Prem Sahay) to confirm a mutually agreeable time.

Agenda for discussion:

In its application dated March 22, 2012, the licensee proposed to add two new cells (C & D type LRC-17) to the existing 58 cells (C&D type LCR-17).

1 - Confirm if the proposed two new cells are C & D type LRC-17.

- 2 - *Provide a copy of the pages of the battery manufacturer's Instruction Manuals (Publication Numbers RS-1476, Section 12-800, Dated 2003 and 2010) for two new cells (C & D type LRC-17 and / or LCR-17) showing cell discharge characteristic curve (amp hour per positive verses amp per positive), float voltage and specific gravity limits recommended by the cell manufacturer for staff's review.*
- 3 - *Even if there is only one model number, verify whether there are any specification differences or improvements assignable to the expansion cells, relative to the existing cells. Conceivably, this might have resulted from advances in battery technology introduced in later manufacturing production runs. If so, please provide the requested data (See item 2) from the instruction manuals for both technologies installed at Duane Arnold Energy Center.*
- 4 - *The Institute of Electrical and Electronics Engineers (IEEE) Standard (Std.) 450-1987, "IEEE Recommended Practice for Maintenance," Section 7.0 states, "Replacement cells, if used, should be compatible with existing cells and should be tested prior to installation." Discuss how the new C & D type LRC-17 cells are maintained and tested prior to installation.*
- 5 - *In its application dated March 22, 2012, the licensee proposed 60 cells battery configuration by adding two new cells to the existing 58 cells battery. Confirm that the battery maximum equalizing voltage with the proposed 60 cells battery configuration will not exceed the maximum voltage rating of any of the 125 Volt nominal direct current equipment or components connected to the battery.*

===== end RAI items =====

Hearing Identifier: NRR_PMDA
Email Number: 502

Mail Envelope Properties (Karl.Feintuch@nrc.gov20121005172100)

Subject: ME8300 - DA - Battery related amendment application - Request for Additional Information
Sent Date: 10/5/2012 5:21:24 PM
Received Date: 10/5/2012 5:21:00 PM
From: Feintuch, Karl
Created By: Karl.Feintuch@nrc.gov

Recipients:
"Sahay, Prem" <Prem.Sahay@nrc.gov>
Tracking Status:: Response: None : 9/27/2012 12:36:00 PM
"Browning, Tony" <Tony.Browning@nexteraenergy.com>
Tracking Status:: Response: None : 9/24/2012 9:19:00 AM
"Byrne, Thomas" <Thomas.Byrne@nexteraenergy.com>
Tracking Status:: Response: None : 9/24/2012 9:22:00 AM
"Pint, Dennis" <Dennis.Pint@nexteraenergy.com>
Tracking Status:: Response: None : 9/24/2012 9:27:00 AM

Post Office:

| Files | Size | Date & Time |
|--------------|-------------|------------------------|
| MESSAGE | 3713 | 10/5/2012 5:21:00 PM |

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: