

## ArevaEPRDCPEm Resource

---

**From:** Snyder, Amy  
**Sent:** Wednesday, October 10, 2012 7:05 AM  
**To:** 'usepr@areva.com'  
**Cc:** Wu, Cheng-lh; Clark, Theresa; Hearn, Peter; Segala, John; ArevaEPRDCPEm Resource  
**Subject:** U.S. EPR Design Certification Application RAI No. 560 (6808), FSAR Ch. 5  
**Attachments:** RAI\_560\_EMB\_6808.doc

Attached please find the subject requests for additional information (RAI). A draft of the RAI was provided to you on October 2, 2012, and discussed with your staff on October 9, 2012. No change is made to the draft RAI as a result of that discussion. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

Thanks,

Amy Snyder,  
Sr. Project Manager  
NRO/DNRL/LB1

 Office: (301) 415-6822

 Fax: (301) 415-6406

 Mail Stop: T6-C20M

 E-mail: [Amy.Snyder@nrc.gov](mailto:Amy.Snyder@nrc.gov)

**Hearing Identifier:** AREVA\_EPR\_DC\_RAIs  
**Email Number:** 4069

**Mail Envelope Properties** (AF843158D8D87443918BD3AA953ABF78A17A48C7A0)

**Subject:** U.S. EPR Design Certification Application RAI No. 560 (6808), FSAR Ch. 5  
**Sent Date:** 10/10/2012 7:05:12 AM  
**Received Date:** 10/10/2012 7:05:13 AM  
**From:** Snyder, Amy

**Created By:** Amy.Snyder@nrc.gov

**Recipients:**

"Wu, Cheng-lh" <Cheng-lh.Wu@nrc.gov>  
Tracking Status: None  
"Clark, Theresa" <Theresa.Clark@nrc.gov>  
Tracking Status: None  
"Hearn, Peter" <Peter.Hearn@nrc.gov>  
Tracking Status: None  
"Segala, John" <John.Segala@nrc.gov>  
Tracking Status: None  
"ArevaEPRDCPEm Resource" <ArevaEPRDCPEm.Resource@nrc.gov>  
Tracking Status: None  
"usepr@areva.com" <usepr@areva.com>  
Tracking Status: None

**Post Office:** HQCLSTR02.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	880	10/10/2012 7:05:13 AM
RAI_560_EMB_6808.doc	32762	

**Options**

**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**

**Request for Additional Information 560(6808), Revision 0**

Issue Date: 10/10/2012

Application Title: U. S. EPR Standard Design Certification - Docket Number 52-020

AREVA NP Inc.

Review Section: 05.02.01.01 - Compliance With the Codes and Standards Rule, 10 CFR  
50.55a

Application Section: 5.2.1.1

QUESTIONS

05.02.01.01-7

Open Item

Follow-up to RAI 444, Question 05.02.01.01-6

In its response to RAI 444, Question 05.02.01.01-6, the applicant added Code Case N-782 to U.S. EPR FSAR Tier 2, Table 5.2-1. Since N-782 is not yet accepted by the NRC in Regulatory Guide 1.84, based on 50 CFR 50.55a(c)(3)(iv) the applicant is requested to submit justification to demonstrate the use of this code case for EPR satisfying requirements in accordance with 10 CFR 50.55a(a)(3)(i) and (ii).