



**INDIAN POINT UNIT 3**  
**FLOW ACCELERATED**  
**CORROSION**

**3RF13 OUTAGE**

ORIGINAL

**2005**



## Ultrasonic Examination Report

IPEC Unit # 3  
Report No.: 05UT054  
Page 1 of 6

Sys. / Comp. ID: FW-03.1B-08E, FW-03.1B-09P

Exam Item: ELBOW, PIPE

DWG No. or Sketch: EC-H-50047

WR/Mod: IP3-04-13363

QA Category: Non Cat ASME XI Class: N/A Cat: N/A

Procedure: ENN-NDE-9.05

Rev.: 0

Component Configuration: ELBOW, PIPE

Orientation: 0 Degree

Type of Material: Carbon Steel

Angle: 0° Mode: Longitudinal

Size: 18" Sch. 60 Thickness: 0.656"

**Equipment**

Instrument: 103861 Krautkramer DMS-2 Due: N/A

**Vertical Linearity Check**

Signal 1	100	90	80	70	60	50	40	30	20	10
Signal 2	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

(Signal 2 shall equal 50% of signal 1 ± 5% of full scale.)

**Attenuator Linearity Check**

80% - 6 db	80% - 12 db	40% + 6 db	20% + 12 db
N/A	N/A	N/A	N/A
(32 to 48)	(16 to 24)	(64-96)	(64-96)

Transducer: 011790 KBA 8 Mhz 0.38" RND FH2E Dual Wedge: N/A

Search Unit Cable: 6' Self-Cont.

Wedge Meas. Angle: N/A°

Exit Point-Front: N/A "

Couplant: 04225 Sonotech / Ultragel II

Thermometer: 104248

Due: 1/23/2006

Temperature

Calibration Block: 103882 Step Wedge T = .25" - 3" Material: 1018 Steel

79 °F

Simulator Block: N/A

N/A °F

Reference Block: N/A


N/A °F

Entry Surface: OD

Component: 79 °F

**Distance Amplitude Curve**

Each Major Screen Division = 0.2"



Reflector	Orient.	% FSH	Pos.	dB
0.250"	Step	80	1.25	N/A
0.500"	Step	80	2.50	N/A
1.000"	Step	80	5.00	N/A
1.500"	Step	80	7.50	N/A

**Calibration Times:**

1407	1512	1736		
------	------	------	--	--

**Instrument Settings**

Range (in.): 2.0"  
Thick Cal: 2-PT  
Velocity (in./μs): .2341  
Sensitivity (dB): 58  
Scan Sensitivity: maint 80%  
Frequency (mHz): 8  
Reject: Off  
Filter: Fullwave  
Pulse Length: Fixed  
Damping: Fixed  
Mode Select: Dual  
Rep. Rate: Fixed  
DEC/Gate: Off  
Jacks: T/R

Acceptance Standard: Minimum wall thickness = 87.5% of nominal thickness

Recordable Indication(s): No

Recording Level: N/A % DAC Evaluation Level: N/A % DAC

100 % Complete Limitations: No

Remarks: Gridded and examined as per FAC Engineer direction. U/S two grid lines, D/S gridded 36".

Examiner: Ian H. Pedersen

Ian H. Pedersen Level: IIL Date: 3/18/2005

Examiner: \_\_\_\_\_

N/A Level: NA Date: 3/18/2005

Reviewed by: Dave GiesnerLevel: II Date: 3-27-05

ANII Review: \_\_\_\_\_

N/A

Date: 3/18



Entergy

Report No.: 05UT054

Page 2 of 6  
Exam Item: ELBOW PIPE

Sys. / Comp. ID: FW-03.1B-08E, 09P

Material: Carbon Steel  
Size: 18" Sch. 80

High Reading: 0.966"  
Low Reading: 0.661"

DWG No.: EC-H-50047 Rev.2

Thickness: 0.750"

Grid Size: 4"

WR / Mod: IP3-04-13363

Configuration: ELBOW PIPE

Datum Point: Extrados


QA Category: Non-Class

ASME XI Class: N/A Cat: N/A


Acceptance Standard: Min. wall thickness 87.5% of nominal wall thickness = .656"

Procedure: ENN-NDE-9.05

Rev.: 0



LOOKING IN  
DIRECTION OF  
FLOW



VIEW LOOKING EAST

Remarks:

Scan lows (see sketch for locations):

U/S of U/S 0.835" between J+K

D/S of U/S 0.679" between N+O

U/S of D/S 0.823" between C+D

D/S of D/S 0.682" between F+G

Examiner: Ian H. Pedersen Level: III Date: 03/18/05

Examiner: S/A Level: S/A Date: S/A

Reviewed by: S/A Level: S/A Date: 5-27-05

ANII Review: S/A Level: S/A Date: S/A

REA5-01

## -----File Header-----

P.C. File Name : FW031B08E.utm  
Gauge File Name : FW031B08E

Description :  
Memo Comment :  
Creation Date : 3/18/2005  
Date Last Saved : 3/19/2005

Probe : 011790 Cal. Stnd. :  
Temperature :  
Inspector : Company :  
Instrument Type : DMS2 Instrument S.N. : 0116LM

Min. Alarm Val. : 0.000 Max. Alarm Val. : 0.000  
% Loss Alarm Val. : 0.00 % Growth Alarm Val. : 0.00  
Abs. Loss Alarm Val. : 0.000 Abs. Growth Alarm Val. : 0.000  
Units : INCH Velocity (in/us) : 0.2341

: :  
: :

## -----Color Ranges-----

###	0.000 - 0.001	###	0.751 - 9.000
###	0.002 - 0.525	###	9.001 - 9.002
###	0.526 - 0.656	###	9.003 - 9.004
###	0.657 - 0.750	###	9.005 - 9.006

05UT054  
San M. Red 03/18/05  
D. S. 3-27-05

FW031B08E.utm

LOC1

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	0.901	0.909	0.908	0.921	0.938	0.951	0.961	0.966	0.965	0.954	0.946	0.933	0.924	0.910	0.921
2	0.908	0.919	0.921	0.936	0.945	0.947	0.954	0.946	0.947	0.937	0.930	0.922	0.919	0.926	0.911
3	0.937	0.926	0.930	0.935	0.934	0.932	0.920	0.916	0.928	0.934	0.939	0.929	0.942	0.926	0.934
4	0.685	0.707	0.720	0.732	0.745	0.727	0.737	0.744	0.761	0.749	0.745	0.727	0.713	0.709	0.687
5	0.682	0.712	0.725	0.735	0.753	0.740	0.772	0.740	0.761	0.741	0.754	0.728	0.714	0.702	0.683
6	0.679	0.708	0.724	0.742	0.759	0.765	0.749	0.743	0.762	0.759	0.754	0.730	0.711	0.693	0.671
7	0.673	0.718	0.726	0.740	0.752	0.745	0.747	0.756	0.776	0.754	0.756	0.739	0.704	0.706	0.696
8	0.678	0.709	0.726	0.738	0.755	0.747	0.746	0.753	0.777	0.759	0.762	0.740	0.722	0.713	0.681
9	0.669	0.705	0.727	0.764	0.753	0.745	0.748	0.757	0.776	0.750	0.760	0.767	0.721	0.708	0.682
10	0.677	0.719	0.721	0.736	0.743	0.732	0.746	0.752	0.780	0.747	0.760	0.744	0.720	0.721	0.673
11	0.672	0.711	0.714	0.731	0.744	0.751	0.744	0.752	0.773	0.747	0.752	0.760	0.715	0.706	0.661
12	0.670	0.719	0.712	0.728	0.774	0.719	0.731	0.743	0.761	0.743	0.753	0.740	0.717	0.704	0.665
13	0.678	0.695	0.713	0.724	0.732	0.706	0.725	0.741	0.756	0.736	0.744	0.735	0.727	0.714	0.672
14	0.682	0.708	0.711	0.718	0.730	0.702	0.711	0.727	0.756	0.722	0.765	0.735	0.711	0.718	0.674
15	0.683	0.732	0.713	0.718	0.726	0.702	0.704	0.709	0.743	0.726	0.773	0.725	0.729	0.708	0.672
16	0.689	0.721	0.709	0.719	0.713	0.695	0.697	0.696	0.732	0.716	0.741	0.771	0.715	0.716	0.683
17	0.709	0.713	0.736	0.720	0.733	0.698	0.697	0.695	0.711	0.706	0.733	0.720	0.716	0.716	0.700

0567054  
*Don H. Lee* 03/15/05  
 DISCUSS WE 3-23-05

LOC1



## -----File Header-----

P.C. File Name : FW031B09P.utm  
 Gauge File Name : FW031B09P

Description :  
 Memo Comment :  
 Creation Date : 3/18/2005  
 Date Last Saved : 3/19/2005

Probe : 011790 Cal. Stnd. :  
 Temperature :  
 Inspector : Company :  
 Instrument Type : DMS2 Instrument S.N. : 0116LM

Min. Alarm Val. : 0.000 Max. Alarm Val. : 0.000  
 % Loss Alarm Val. : 0.00 % Growth Alarm Val. : 0.00  
 Abs. Loss Alarm Val. : 0.000 Abs. Growth Alarm Val. : 0.000  
 Units : INCH Velocity (in/us) : 0.2336

:  
 :  
 :

## -----Color Ranges-----

###	0.000 - 0.001	###	0.751 - 9.000
###	0.002 - 0.525	###	9.001 - 9.002
###	0.526 - 0.656	###	9.003 - 9.004
###	0.657 - 0.750	###	9.005 - 9.006

05 UT 054  
 2 Jan 2005 03/18/05  
 D-256h 3:27:02

FW031B09P.utm

LOC1

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	0.892	0.886	0.884	0.882	0.881	0.891	0.901	0.904	0.907	0.933	0.907	0.905	0.900	0.894	0.892
2	0.890	0.898	0.894	0.891	0.886	0.896	0.901	0.905	0.903	0.910	0.908	0.893	0.909	0.899	0.895
3	0.898	0.903	0.896	0.885	0.886	0.893	0.902	0.906	0.907	0.912	0.910	0.897	0.915	0.895	0.898
4	0.888	0.887	0.883	0.879	0.887	0.901	0.914	0.910	0.918	0.915	0.914	0.894	0.912	0.895	0.892
5	0.878	0.900	0.910	0.885	0.891	0.901	0.932	0.944	0.926	0.923	0.917	0.877	0.908	0.887	0.876
6	0.880	0.880	0.888	0.890	0.900	0.910	0.925	0.938	0.921	0.919	0.914	0.876	0.912	0.892	0.882
7	0.892	0.900	0.895	0.899	0.914	0.921	0.909	0.916	0.912	0.915	0.901	0.893	0.907	0.891	0.888
8	0.901	0.906	0.903	0.909	0.909	0.915	0.938	0.927	0.902	0.924	0.894	0.891	0.901	0.890	0.893
9	0.909	0.906	0.907	0.902	0.903	0.907	0.900	0.895	0.906	0.904	0.901	0.907	0.894	0.911	0.907
10	0.911	0.927	0.897	0.893	0.889	0.909	0.896	0.890	0.910	0.927	0.907	0.918	0.896	0.906	0.914

05 UT 054

2 Jan 71 Led 03/12/05  
 A-556h 3-2705

LOC1

Page 1

## TRAVELER PACKAGE CHECKLIST

Component FW-03-1B-08E  
Work Order TP3-04-13363

1. Preinspection briefing given by Erosion/Corrosion Engineer

[Signature]  
E/C Eng.

3/18/05  
Date

[Signature]  
UT Tech

                      
UT Tech

                      
UT Tech

                      
UT Tech

2. Traveler package contents

[Signature]  
UT Tech

[Signature]  
E/C Eng.

- a. Copy of procedure ENN-NDE-9.05
- b. Calibration sheet
- c. Drawing with point highlighted
- d. Data sheet
- e. E/C Engineers phone number 736-8356. Pager 445-0253

3. Location verified against drawing:

[Signature]  
UT Tech

                      
E/C Eng.

4. Preinspection point setup per procedure ENN-EP-S-005  
or FAC Engineer direction (If gridding is used)

[Signature]  
UT Tech

- a. Correct grid size used
- b. Grid correctly laid out
- c. Grid lettered and numbered correctly
- d. Area up/downstream of component properly laid out

5. Data Logger

[Signature]  
UT Tech

- a. Inspection point used as file name
- b. Operators ID correct
- c. Instrument ID correct

6. Data Sheet

[Signature]  
UT Tech

- a. Flow direction correct
- b. Sketch drawn correctly
- c. Component number verified

7. Calibration Sheet correct

[Signature]  
UT Tech

8. Daily review complete

03/18/05  
Date

[Signature]  
E/C Eng.

### NOTE:

- UT Technician sign-off is required prior to start of inspection activity.
- Engineering sign-off is required after verification of activity.