

## PMSTPCOL PEmails

---

**From:** STPCOL  
**Sent:** Thursday, October 18, 2012 2:25 PM  
**To:** PMSTPCOL PEmails  
**Subject:** FW: Reference Japanese ABWR

---

**From:** Tai, Tom  
**Sent:** Tuesday, September 18, 2012 12:57 PM  
**To:** Tomkins, James  
**Cc:** STPCOL  
**Subject:** RE: Reference Japanese ABWR

Thanks

Tom Tai  
DNRL/NRO  
(301) 415-8484  
[Tom.Tai@NRC.GOV](mailto:Tom.Tai@NRC.GOV)

---

**From:** Tomkins, James [<mailto:jetomkins@STPEGS.COM>]  
**Sent:** Tuesday, September 18, 2012 12:16 PM  
**To:** Tai, Tom  
**Subject:** Reference Japanese ABWR

As we discussed, the strainer sizing for STP 3 & 4 is based on the reference Japanese ABWR which is Hamaoka 5. We did use containment inspection information from Kashiwazaki-Kariwa Units 6 and 7 to confirm that our debris amounts (for fiber and sludge) were appropriate.

**Hearing Identifier:** SouthTexas34Public\_EX  
**Email Number:** 3467

**Mail Envelope Properties** (377CB97DD54F0F4FAAC7E9FD88BCA6D0B0FD84C445)

**Subject:** FW: Reference Japanese ABWR  
**Sent Date:** 10/18/2012 2:25:19 PM  
**Received Date:** 10/18/2012 2:25:20 PM  
**From:** STPCOL

**Created By:** STP.COL@nrc.gov

**Recipients:**  
"PMSTPCOL PEmails" <PMSTPCOL.PEmails@nrc.gov>  
Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	652	10/18/2012 2:25:20 PM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**