

## IPRenewal NPEmails

---

**From:** Waters, Roger M. [rwater1@entergy.com]  
**Sent:** Thursday, October 18, 2012 7:00 PM  
**To:** Wentzel, Michael  
**Cc:** Daily, John; Pickett, Douglas  
**Subject:** IPEC License Renewal - Clarification of Underground Piping Information  
**Attachments:** NL-12-149.pdf

Mike,

Attached is a pdf version of the subject submittal. The hardcopies will be sent out shortly.

Roger Waters  
IPEC Licensing  
914-254-7714

**Hearing Identifier:** IndianPointUnits2and3NonPublic\_EX  
**Email Number:** 3878

**Mail Envelope Properties** (A121135CD9246F4082BF946E6F9FB039258020F4)

**Subject:** IPEC License Renewal - Clarification of Underground Piping Information  
**Sent Date:** 10/18/2012 7:00:16 PM  
**Received Date:** 10/18/2012 7:00:21 PM  
**From:** Waters, Roger M.

**Created By:** rwater1@entergy.com

**Recipients:**

"Daily, John" <John.Daily@nrc.gov>  
Tracking Status: None  
"Pickett, Douglas" <Douglas.Pickett@nrc.gov>  
Tracking Status: None  
"Wentzel, Michael" <Michael.Wentzel@nrc.gov>  
Tracking Status: None

**Post Office:** jdcxmetsp004.etrsoth.corp.entergy.com

Files	Size	Date & Time
MESSAGE	163	10/18/2012 7:00:21 PM
NL-12-149.pdf	235177	

**Options**

**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**



**Entergy Nuclear Northeast**  
Indian Point Energy Center  
450 Broadway, GSB  
P.O. Box 249  
Buchanan, NY 10511-0249  
Tel (914) 254-2055

---

Fred Dacimo  
Vice President  
Operations License Renewal

NL-12-149  
October 18, 2012

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, DC 20555-0001

SUBJECT: Clarification of Underground Piping Information  
Provided in Letter NL-11-032 Regarding  
the License Renewal Application  
Indian Point Nuclear Generating Unit Nos. 2 & 3  
Docket Nos. 50-247 and 50-286  
License Nos. DPR-26 and DPR-64

REFERENCE: (1) Entergy letter (NL-11-032), "Response to Request for Additional  
Information (RAI) Aging Management Programs," dated March 28, 2011

Dear Sir or Madam:

Reference (1) stated in the response to RAI 3.0.3.1.2-1 Part 5a that "Underground piping and tanks are below grade, but are contained within a tunnel or vault such that they are in contact with air and are located where access for inspection is restricted. In-scope SSCs that are subject to aging management review at IPEC include no underground piping or tanks." Indian Point made this statement because piping located in underground vaults is periodically accessed for visual inspections during pressure tests. However, during a recent review of the NRC Interim Staff Guidance (ISG) for Buried Piping, LR-ISG-2011-03, a question was raised relative to the definition of "restricted" and whether the Indian Point definition was consistent with the intent of the ISG. As a result of this question, Entergy Nuclear Operations, Inc held a conference call with the NRC staff to clarify the definition of "restricted" as used in the ISG. Although definition of the term "restricted" as related to underground piping was not found in NRC guidance documents related to license renewal, during the conference call on October 11, 2012, the NRC Staff indicated that it was intended that piping located in vaults for which access requires more than simply opening a locked access cover should be classified as underground piping.

As a result of this change in understanding of the definition of underground piping, Indian Point has identified portions of the service water, city water and fuel oil systems that are located in vaults that require more than unlocking a hatch or cover for access. This piping will now be considered underground piping as defined in LR-ISG-2011-03. Specifically, this includes

portions of two 24" diameter Indian Point 3 service water inlet headers (approximate total length of 70 feet) that run over the discharge canal, portions of the Indian Point 2 and 3 fuel oil piping (1 1/2", 3" and 4" in diameter) that supply and run between the fuel oil storage tanks and from the storage tanks to each of the emergency diesel generator (EDG) rooms (approximate total length of 160 feet) and a portion of the 3/4" diameter Indian Point 3 city water piping (approximate total length of 40 feet) that runs in the EDG pipe trench.

The above piping will be periodically inspected under the Buried Piping and Tanks Inspection Program at a frequency that meets or exceeds NUREG-1801 Section XI.M41 guidance for underground piping which will ensure the effects of aging are adequately managed. Attachment 1 identifies changes to the service water, city water and fuel oil systems aging management review tables that result from the clarification identified in this letter.

If you have any questions, or require additional information, please contact Mr. Robert Walpole at 914-254-6710.

I declare under penalty of perjury that the foregoing is true and correct. Executed on  
10/18/12.

Sincerely,



FRD/rw

Attachment: 1. Changes to the Indian Point LRA Service Water, City Water, and Fuel Oil Systems Aging Management Review Tables

cc: Mr. William Dean, Regional Administrator, NRC Region I  
Mr. Sherwin E. Turk, NRC Office of General Counsel, Special Counsel  
Mr. Dave Wrona, NRC Branch Chief, Engineering Review Branch I  
Mr. John Daily, NRC Sr. Project Manager, Division of License Renewal  
Mr. Douglas Pickett, NRR Senior Project Manager  
Ms. Bridget Frymire, New York State Department of Public Service  
NRC Resident Inspector's Office  
Mr. Francis J. Murray, Jr., President and CEO NYSERDA

**ATTACHMENT 1 TO NL-12-149**

**CHANGES TO THE INDIAN POINT LRA SERVICE WATER,  
CITY WATER, AND FUEL OIL SYSTEMS AGING MANAGEMENT REVIEW TABLES**

ENTERGY NUCLEAR OPERATIONS, INC.  
INDIAN POINT NUCLEAR GENERATING UNIT NOS. 2 & 3  
DOCKET NOS. 50-247 AND 50-286

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801 Vol. 2 Item	Table 1 Item	Notes
Piping	<u>Pressure boundary</u>	<u>Carbon steel</u>	<u>Condensation (ext)</u>	<u>Loss of material</u>	<u>Buried Piping and Tanks Inspection</u>	<u>VII.1-11 (A-81)</u>	<u>3.3.1-58</u>	<u>E</u>

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801 Vol. 2 Item	Table 1 Item	Notes
Piping	<u>Pressure boundary</u>	<u>Carbon steel</u>	<u>Air – outdoor (ext)</u>	<u>Loss of material</u>	<u>Buried Piping and Tanks Inspection</u>	<u>VII.H1-8 (A-24)</u>	<u>3.3.1-60</u>	<u>E</u>

Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801 Vol. 2 Item	Table 1 Item	Notes
Piping	<u>Pressure boundary</u>	<u>Carbon steel</u>	<u>Air – outdoor (ext)</u>	<u>Loss of material</u>	<u>Buried Piping and Tanks Inspection</u>	<u>VII.H1-8 (A-24)</u>	<u>3.3.1-60</u>	<u>E</u>

Table 3.3.2-17-IP3: City Water								
Component Type	Intended Function	Material	Environment	Aging Effect Requiring Management	Aging Management Programs	NUREG-1801 Vol. 2 Item	Table 1 Item	Notes
<u>Piping</u>	<u>Pressure boundary</u>	<u>Copper Alloy</u>	<u>Air - outdoor (ext)</u>	<u>Loss of material</u>	<u>Buried Piping and Tanks Inspection</u>	--	--	<u>G</u>