

Official Transcript of Proceedings

NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
Subcommittee on Fukushima

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Wednesday, October 3, 2012

Work Order No.: NRC-1921

Pages 1-375

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1 UNITED STATES OF AMERICA

2 NUCLEAR REGULATORY COMMISSION

3 + + + + +

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

5 (ACRS)

6 + + + + +

7 SUBCOMMITTEE ON FUKUSHIMA

8 + + + + +

9 WEDNESDAY

10 OCTOBER 3, 2012

11 + + + + +

12 ROCKVILLE, MARYLAND

13 + + + + +

14 The Subcommittee met at the Nuclear
15 Regulatory Commission, Two White Flint North, Room
16 T2B3, 11545 Rockville Pike, at 8:30 a.m., Stephen P.
17 Schultz, Chairman, presiding.

18
19 SUBCOMMITTEE MEMBERS:

20 STEPHEN P. SCHULTZ, Chairman

21 J. SAM ARMIJO, Member

22 SANJOY BANERJEE, Member

23 DENNIS C. BLEY, Member

24 CHARLES H. BROWN, JR. Member

25 MICHAEL L. CORRADINI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 DANA A. POWERS, Member
2 HAROLD B. RAY, Member
3 JOY REMPE, Member
4 MICHAEL T. RYAN, Member
5 WILLIAM J. SHACK, Member
6 JOHN D. SIEBER, Member
7 GORDON R. SKILLMAN, Member
8 JOHN W. STETKAR, Member
9

10 NRC STAFF PRESENT:

11 ANTONIO DIAS, Designated Federal Official
12 SUDHAMAY BASU, RES/DSA
13 JEROME BETTLE, NRR/DSA
14 TIM COLLINS, NRR/DSS
15 ROBERT DENNIG, NRR/DSA
16 ROBERT FRETZ, NRR/JLD
17 ED FULLER, RES/DRA
18 TINA GHOSH, RES/DSA
19 JOHN MONNINGER, NRR/JLD
20 AJ NOSEK, RES/DSA
21 ALLEN NOTAFRANCESCO, RES/DSA
22 WILLIAM RULAND, NRR
23 MARTY STUTZKE, RES/DRA
24 AARON SZABO, NRR/DPR
25

1 ALSO PRESENT:

2 NATHAN BIXLER, Sandia National Laboratories

3 PAUL GUNTER, Beyond Nuclear*

4 MARK LEYSE*

5
6 *Participating via telephone
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1	A-G-E-N-D-A	
2	Opening Remarks	5
3	Steve Schultz, ACRS	
4	Introduction	9
5	Robert Fretz, JLD	
6	Design and Regulatory History, and	
7	Foreign Experience	14
8	Robert Dennig, DSS	
9	Filtered Containment Venting System (FCVS) in Severe	
10	Accident Management	67
11	Jerry Bettel, DSS	
12	MELCOR Analysis	116
13	Sud Basu, RES	
14	MACCS2 Analysis	153
15	Tina Ghosh, RES	
16	Nathan Bixler, Sandia	
17	Risk Evaluation	219
18	Marty Stutzke, RES	
19	Regulatory Analysis	276
20	Aaron Szabo, DSS	
21	Qualitative Arguments	317
22	Tim Collins, DSS	
23	Next Steps	362
24	Robert Fretz, JLD	
25	Public Comment	362

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

P-R-O-C-E-E-D-I-N-G-S

8:30 a.m.

CHAIR SCHULTZ: Good morning. This meeting will now come to order. This is a meeting of the Advisory Committee on Reactor Safeguards Subcommittee on Fukushima. I am Stephen Schultz, chairman of the subcommittee.

Members of the subcommittee in attendance are Jack Sieber, Sanjoy Banerjee, Dick Skillman, Dennis Bley, Dana Powers, Harold Ray, Sam Armijo, John Stetkar, Michael Ryan, Bill Shack, Charlie Brown, Joy Rempe and Mike Corradini.

The purpose of today's meeting is to receive a briefing and hold discussions with the staff on the development of a position paper addressing the value of filtered vents.

The entire meeting will be open to public attendance. Rules for the conduct of participating in this meeting have been published in the Federal Register as part of the notice for this meeting.

The subcommittee will hear presentations by and hold discussions with representatives of the NRC staff and other interested persons regarding this matter. The subcommittee will gather

1 information, analyze relevant issues and facts,
2 formulate proposed positions and actions as
3 appropriate for deliberation by the full committee.

4 Another subcommittee meeting on the same
5 briefing is scheduled for October 31st followed by a
6 full committee briefing in November. The staff is
7 currently developing a position paper that is due to
8 the Commission by the end of November.

9 Antonio Dias is the Designated Federal
10 Official for the meeting. A transcript of the
11 meeting is being kept and will be made available as
12 stated in the Federal Register notice. We request
13 that all speakers first identify themselves and then
14 speak with sufficient clarity and volume so that
15 they can be readily heard.

16 We have received no written comments
17 from the public. We have received requests for time
18 to make oral statements from Mr. Mark Leyse and Mr.
19 Paul Gunter. I understand that there are other
20 stakeholders in the audience as well as on the
21 bridge line today who are listening in on today's
22 proceedings and they will also be given the
23 opportunity to address the subcommittee at the end
24 of the briefing.

25 As stated we have future meetings

1 established for hearing additional information
2 related to this topic. We have already had two
3 meetings of the subcommittee, one an introduction to
4 the topic held earlier this year and another
5 subcommittee meeting held just recently. But this
6 is the most developed presentation that we have had
7 so far and so we look forward to today's discussion.

8 We'll now proceed with the meeting and I
9 will call upon Mr. Bill Ruland from the Office of
10 Nuclear Reactor Regulation to open the
11 presentations. Bill? Thank you.

12 **MR. RULAND:** Thank you, Mr. Chairman and
13 good morning to everyone.

14 The staff is here today to discuss the
15 regulatory analysis it has prepared to inform a
16 Commission decision on the need for additional
17 improvements to the containment venting systems that
18 were ordered for BWR Mark I and Mark II plants in
19 March of this year.

20 The staff was directed by the Commission
21 to provide backfit analyses under the current
22 regulatory analysis framework for two incremental
23 changes.

24 First, modify the current ordered
25 reliable hardened vent such that the vent will be

1 functional in severe accident conditions. The
2 current requirements do not include severe accidents
3 capability, only station blackout functionality.

4 Second, require that a high-efficiency
5 external filter be included as part of the severe
6 accident capable vent system.

7 Today the staff will provide you with
8 considerable information gathered and the analysis
9 performed for these options to support the
10 Commission's decision.

11 As you alluded to, or as you stated, Mr.
12 Chairman, in future meetings the staff will present
13 its recommendations. We'd like to receive a letter
14 of course from the committee after those meetings.

15 I believe it's fair to say at the outset
16 that while the per-plant cost using available
17 technology is not judged prohibitive the staff
18 expected that the filtered containment venting
19 system would not pass the quantitative cost-
20 beneficial test under the current regulatory
21 analysis framework. Also, a conclusive argument for
22 adequate protection was not anticipated.

23 The findings that we present today are
24 consistent with those expectations. Consequently,
25 the staff's recommendation will depend heavily on

1 consideration of other qualitative factors. This
2 weighing of qualitative factors is ongoing and is
3 the key task before the staff now.

4 The staff will speak today for all of
5 the matters I've touched on in this brief
6 introduction as well as as to how the EPRI analysis
7 in the recently published technical report have been
8 considered.

9 We look forward of course to your
10 questions. Bob, do you want to introduce the team,
11 please?

12 MR. FRETZ: Sure. Thank you, Bill, and
13 thank you, Dr. Schultz and the committee for giving
14 us the opportunity to brief you on this subject.

15 With me here at the table is John
16 Monninger. I guess you can introduce yourself.

17 MR. MONNINGER: Good morning. I'm John
18 Monninger, the associate director of the Japan
19 Lessons Learned project director within the Office
20 of Nuclear Reactor Regulation.

21 MR. DENNIG: Bob Dennig, chief of the
22 Containment and Ventilation Branch at NRR.

23 MR. BETTLE: Jerome Bettle. I work for
24 Bob Dennig in the Containment and Ventilation
25 Branch.

1 MR. FRETZ: Good morning. Again as this
2 slide suggests the purpose of our presentation is to
3 brief you on at least the preliminary results of our
4 regulatory analysis regarding the issue of filtered
5 venting. And again, looking at our analysis related
6 to the BWR Mark I and Mark II containment designs
7 only.

8 And here's a slide on the proposed
9 schedule. I understand that in order to accommodate
10 members of the public as well as other proposed
11 speakers we will not be following this. We'll be
12 following the actual agenda that was published and
13 placed on there. But again, this is our proposed
14 schedule. It's a very challenging schedule.

15 Again, the outline for today's
16 discussions is shown on slide 4. And as you can see
17 by the materials that we handed out for today's
18 briefing there's a lot of material to discuss.

19 I guess the good news is that there will
20 be one or two speakers speaking so that we will be
21 able to present you with the various experts from
22 each of the areas that provided their input and
23 expertise in the various matters.

24 Again, as mentioned earlier some of this
25 material we have discussed before but we felt that

1 it was very important to go over some of the things
2 we talked about in previous meetings to at least
3 provide the opportunity for just discussion on those
4 matters. We had additional questions -- been
5 thought of from the previous meetings.

6 And again, we will finalize the
7 discussion with our next steps, pretty much where do
8 we go from here.

9 And as mentioned earlier, this whole
10 effort culminates with an IOU to the Commission to
11 provide its recommendations by November 30th. That
12 seems like a couple of months from now but there's a
13 lot to do between now and then. As previously
14 alluded, we will be coming before the subcommittee
15 at the end of this month as well as the full
16 committee on the following day.

17 And again we appreciate the coordination
18 that we've had between the staff and the ACRS
19 regarding scheduling of those meetings. I know it's
20 been a challenge to make sure that everyone was
21 available to at least hear what the staff said. So
22 again, there's a lot to do.

23 The staff has a number of interactions
24 that it will have with the Fukushima Steering
25 Committee between now and the time we speak next.

1 And again it all culminates to submitting a
2 Commission paper by the end of November. Next
3 slide, slide 6.

4 Again, the purpose of the paper is
5 known. As mentioned by Bill Ruland we are going to
6 be looking at a number of options including whether
7 or not to install severe accident-capable vents or
8 filtered vents. And another option that we are
9 looking at is a performance-based approach. And
10 that will be discussed during the subsequent
11 discussions today.

12 Our SECY paper outline essentially
13 follows our discussion that we had today. This
14 slide might be a little bit familiar from our
15 previous things, but the staff -- there's a lot of
16 information to present.

17 And the staff intends to provide the
18 bulk of the details relating to various subject
19 matters in enclosures to a SECY paper that will
20 summarize essentially what's in the enclosures. We
21 felt that there's a lot of information to present
22 and we wanted to present it to the Commission in a
23 clear way so that they can again be informed on the
24 various aspects of it.

25 The first three enclosures are really

1 intended to provide sort of a foundation or lay a
2 common understanding of venting and severe accident
3 management and how they all relate.

4 The technical analysis enclosure will
5 provide information relating to essentially the
6 information that was important for coming up with
7 this regulatory analysis and the conclusions from
8 the regulatory analysis. Again, we will discuss an
9 evaluation of various options that we are
10 presenting.

11 And finally, we do plan to discuss our
12 involvement with stakeholders. We felt that that's
13 been a very important part of the process, to engage
14 not only the regulated industry but as well as
15 members of the public during this whole entire
16 process.

17 Current status. One of the things we
18 want to stress is that our technical and policy
19 assessments are ongoing. We are still working on
20 some of the results. In fact, as a bit of
21 housekeeping, as an attachment to your slides we do
22 have a 3-page addendum highlighting some of the
23 latest information that we have gotten regarding the
24 MELCOR analysis. So again, we are right now only in
25 the preliminary stage. Again, this is what we hope

1 to share with you today.

2 Again, as I mentioned earlier the staff
3 will continue to engage the Fukushima Steering
4 Committee on developing the path forward. And again
5 we will be making recommendations once this
6 assessment is complete.

7 I'd like to turn the presentation over
8 to Bob Dennig who is the chief of the Containment
9 and Ventilation Branch in the Office of Nuclear
10 Reactor Regulation.

11 CHAIR SCHULTZ: Thank you, Bob. Bob,
12 before you start I'd just like an administrative
13 item to be handled.

14 Those of you who are on the bridge line,
15 please if you have mute capability on your phones
16 please use them. We are getting some feedback in
17 the room from individuals turning pages. And we
18 also get static if the phones are not on mute. So
19 please take advantage of that and put your phones on
20 mute until there is an opportunity for comment later
21 today.

22 Thank you. Bob?

23 MR. DENNIG: Thank you. I'm going to
24 move quickly through a high-level summary of
25 basically regulatory history from Mark I's and Mark

1 II's. The technical implications and details of
2 some of these aspects will be talked about by
3 subsequent speakers from the Office of Research.
4 First slide, please.

5 At the beginning, basically Mark I
6 containments have been on the radar screen for quite
7 some time. Probabilistically it goes back to WASH-
8 1400. The nominal characteristics that put it on
9 the radar screen is the inability to handle severe
10 accident overpressure challenges and this is because
11 of the inability to deal with gas buildup in a
12 severe accident, and the fact that BWRs have three
13 times the quantity of zirconium as PWRs which gives
14 the potential for generating a substantial amount of
15 hydrogen gas during a severe accident. Next slide,
16 please.

17 All of the containments were looked at
18 as you well know in the Containment Performance
19 Improvement Program and the Mark I was sort of the
20 flagship or the origin of that program. Coming out
21 of that program the staff recommended several
22 modifications to improve the robustness or the
23 performance of the Mark I containment in severe
24 accident conditions and those include the improved
25 hardened vent.

1 By "hardened" we mean that -- the plants
2 always had the capability to vent through a low-
3 pressure standby gas treatment path, but that was
4 judged to be unreliable and would not take the
5 pressures post accident. And so "hardened" means
6 that it will take higher pressures reliably.

7 Reactor pressure vessels
8 depressurization system improvements. This had to
9 do with extended dc power for operating SRVs. This
10 has been addressed by the SBO capability that's in
11 the new order.

12 Provide alternate water supply to
13 reactor pressure vessel and drywell sprays. You'll
14 hear later how this has been folded into the
15 response to 9/11 and more recently in mitigating
16 strategies. And then of course improve emergency
17 procedures and training.

18 Coming out of that SECY paper was 89-17.
19 The Commission at that time approved the hardened
20 vent as a feature that could be put into -- be
21 installed under 50.59 by BWR Mark I's and so that
22 resulted in the issuance of the Generic Letter 89-
23 16. And that gets us to where we were before
24 Fukushima.

25 The other recommendations were parsed

1 off to be included in the IPE program which was
2 ongoing at that time. Next slide, please.

3 MEMBER SIEBER: Just as a matter of
4 clarification, this hardened vent is seismically
5 capable?

6 MR. DENNIG: No.

7 MEMBER SIEBER: No, okay.

8 MR. DENNIG: No.

9 MEMBER SIEBER: If it's not seismically
10 capable how capable of handling deflagration or
11 detonation?

12 MR. DENNIG: The generic letter said
13 that it should be able to deal with that. That was
14 in the generic letter.

15 MEMBER SIEBER: Okay.

16 MR. DENNIG: So to the extent that --

17 MEMBER SIEBER: Were they designed that
18 way? The ones that were installed.

19 MR. DENNIG: The staff's overview was to
20 look at the responses to the generic letter
21 following the BWR Owners Group guidance and I
22 believe that included that factor. I don't know to
23 what extent anybody did any check calculations or
24 anything like that.

25 MEMBER SIEBER: Well, to me that's an

1 important factor and one that I would like to
2 personally look into further.

3 MR. DENNIG: Well that currently is not
4 part of what's in the order.

5 MEMBER SIEBER: Okay.

6 MR. DENNIG: Next slide, please. A
7 similar accident signature profile to the Mark I.
8 The exception that was noted is that the TW sequence
9 was not as predominant for Mark II's. Interestingly
10 the risk profile was dominated by early failure with
11 a release that --

12 MEMBER BLEY: I'm not sure that
13 everybody knows the TW. Could you?

14 MR. DENNIG: It's a loss of containment
15 heat removal capability with not necessarily losing
16 core-cooling capability.

17 Anyway, the risk profile was dominated
18 by early failure with release that bypasses the
19 suppression pool. For that reason at that time the
20 venting that was being considered for the Mark I was
21 considered for the Mark II but it was not brought
22 forward because it would require, in the view of the
23 people doing the analysis it would require an
24 external filter similar to the one that was being --
25 that had just been installed in all the Swedish

1 plants which is the MVSS, Multi-Venturi Scrubbing
2 System.

3 So one aspect of this is we have an
4 order out there that has a vent that's not filtered
5 for Mark II's so there's some need to revisit this
6 observation with regard to filtering for Mark II's.

7 Again, we didn't go forward with the
8 generic backfit hardened vent. It was spun off into
9 the IPE program. Next slide, please.

10 With regard to -- this is a very quick,
11 breezy summary of filtered containment vents here.
12 You can track back to a TMI action item that was
13 enshrined in 50.34(f) that provided one or more
14 dedicated containment penetrations sized to a single
15 3-foot, et cetera, et cetera, et cetera. So there
16 was some provision going forward for filtering.

17 Shoreham submitted a supplemental
18 feature for their containment that was basically the
19 Barseback filtration system which is -- Jerry will
20 talk later about this. It's a very large, large,
21 large, large containment cylinder of gravel.

22 I've mentioned that the possibility of
23 filters came up during the CPIP. It wasn't pursued
24 at that time. There wasn't any detailed cost-
25 benefit analysis done. The filters that were

1 available included Venturi scrubbers but that wasn't
2 looked at. We were still looking at large, large
3 gravel field-bed sand beds as a primary concept.

4 MEMBER CORRADINI: Just an information
5 question. So all these various designs you're
6 speaking about have tested decontamination factors?
7 There is data out there to look at if one were to
8 install it the decontamination factor would be X, Y
9 or Z?

10 MR. DENNIG: The ones that are installed
11 elsewhere and are available now, yes. Jerry will
12 talk about that when we get to his presentation.
13 You notice that anything I don't want to talk about
14 is Jerry's.

15 (Laughter)

16 MEMBER POWERS: Well, I think it's
17 important to understand, Mike, that when they say a
18 decontamination factor of so much -- and depending
19 on what you're putting into this.

20 MEMBER CORRADINI: Well, I was going to
21 say it depends on the input, the input isotopes.

22 MEMBER SIEBER: And physical forms.

23 MEMBER POWERS: Well, I mean most of
24 these things depends actually on the particle size.
25 If I put marbles in I'd probably have very high

1 decontamination factors for most filtration systems.
2 If I put atoms in I don't have any decontamination
3 factor at all. So these have been tested against
4 some --

5 MEMBER SIEBER: Input distribution and
6 flow.

7 MEMBER POWERS: -- input material. I
8 mean, we have not -- I keep hoping for a RAND but
9 apparently we don't have any filtered vents hooked
10 up to reactors that have accidents. So we don't
11 really have a test on the actual material going in.

12 And what goes into the filtered vent
13 depends on everything that's occurred before it gets
14 to that filter. So, you've got to put a codicil on
15 all these decontamination factors that people quote
16 because kind of the way people in the business of
17 marketing filtered systems tend to quote rather high
18 decontamination factors and they're absolutely
19 accurate given what they put into it.

20 MR. DENNIG: Next slide, please. Just a
21 recap of the order that was issued in, what was it,
22 February? EA-12-050, Reliable Hardened Vent Capable
23 of Performing During Prolonged SBO. And it is
24 designed for use prior to onset of core damage
25 designed for the prevention of core damage, to

1 remove heat from the containment and depressurize
2 the containment.

3 Severe accident conditions were not
4 folded in. We did ask that they be designed to
5 minimize operator actions but we didn't do anything
6 by way of making sure that they would be protected
7 from post-accident high radiation and could perform
8 those operations. And we did stipulate that it
9 would discharge at a release point above the main
10 plant structures.

11 The installed vents in some cases did
12 not do that so we made sure that that was covered in
13 the current order. But again, hydrogen is not part
14 of the mix there. Next slide, please.

15 I think we've spoken with the committee
16 on a number of occasions on our foreign information-
17 gathering and the report. The paper will have an
18 enclosure that talks about all that and seeks to
19 summarize it, pull it all together.

20 One I guess general observation was that
21 what we heard in talking to regulators and licensees
22 overseas was basically what one could find in the
23 1988 CSNI report, "Specialist's Meeting on Filtered
24 Containment Venting Systems." Again, that was from
25 1988.

1 And I would direct your attention to
2 that. It does talk at length about submicron
3 particles and testing for efficiencies with
4 submicron particles. I'm pretty sure that the data
5 to independently confirm that isn't there but it at
6 least gives you a sense that the topic was
7 addressed.

8 The other insight was that the filtered
9 containment venting system is considered as part of
10 a severe accident management system that is there to
11 as passively as possible control containment
12 pressure while you are trying to restore containment
13 flooding and core cooling. And so they see it as a
14 suite if you will of capabilities. Get water in,
15 make sure that the containment takes care of itself,
16 we don't have to manage that.

17 MEMBER BANERJEE: Is that CSNI report
18 available?

19 MR. DENNIG: Oh, sure.

20 MEMBER BANERJEE: Relatively readily?

21 MR. DENNIG: Yes.

22 MEMBER BANERJEE: Could we get hold of
23 it?

24 MEMBER POWERS: There is that report,
25 but there's also a specialist report on the status

1 of aerosol science. And there's an appendix on
2 filtered vent in that. And it's actually pretty
3 decent, more of a status report than it is, you
4 know, here's how these things work and here's how
5 well they work. But it updates.

6 MEMBER BANERJEE: Any experimental
7 results?

8 MEMBER POWERS: There are lots of
9 various things. Is there an experiment on a full-
10 blown filter system? Well, there's some on a
11 Venturi system, a scrubber, Venturi scrubber,
12 especially water-injection Venturis were done at SKI
13 but not as much as you would like.

14 There are lots and lots of issues on how
15 well these perform, especially with radioactive
16 materials.

17 MEMBER BANERJEE: So most of the tests,
18 Dana, were done with surrogates?

19 MEMBER POWERS: Technically, yes.

20 MEMBER BANERJEE: Thanks.

21 CHAIR SCHULTZ: Is the timing of that
22 report that you mentioned about the same?

23 MEMBER POWERS: No, no, no, it was
24 written --

25 MR. DENNIG: 2009 I think is the --

1 MEMBER POWERS: Yes, in the two
2 thousands or something, and it updates.

3 MR. DENNIG: I think it's 2009, CSNI
4 something something.

5 MEMBER POWERS: It has a superb
6 discussion of aerosol physics. Truly insightful.

7 MEMBER STETKAR: Did you write that
8 part?

9 (Laughter)

10 MEMBER BANERJEE: I presume that we know
11 the author.

12 MEMBER CORRADINI: I'm glad there's no
13 pride of authorship. Let me ask a different
14 question. So, taking away the experimental data for
15 -- I think I had asked this when I think you guys
16 were here in July. I don't remember exactly when
17 you were talking about foreign experiments. But I
18 thought it was asked at that time that you were
19 going to check into whether we pick any of these in
20 Sweden for example. Do they at least go through a
21 consistent set of calculations with their dominant
22 sequences --

23 MR. DENNIG: Yes.

24 MEMBER CORRADINI: -- that show the
25 performance?

1 MR. DENNIG: Yes.

2 MEMBER CORRADINI: So that you actually
3 see differences with and without?

4 MR. DENNIG: They are currently
5 requiring their plants that are being uprated to
6 perform a full, I think all the way at level 3 PRA
7 to confirm that with the 3 it will operate as a
8 standard.

9 So, and at the time that this was done
10 there was a program called the MITRA that was a
11 joint program with industry and the Swedish
12 regulator in which all these kinds of calculations
13 were done. One of the prescriptions in the 1980-81
14 government order was that they would examine all
15 overpressure sequences probabilistically and also
16 that if there was any alternative to using a filter
17 that that would be brought forward as this program
18 went on. So that was written into the law. So yes,
19 they have done all this.

20 MEMBER STETKAR: Do you know the results
21 of those comparative studies?

22 MR. DENNIG: In the sense of -- well,
23 the bottom line was there wasn't -- I don't have the
24 details of what they looked at and what they found,
25 but the outcome was that they didn't find an

1 alternative. That much we were told.

2 MEMBER CORRADINI: I guess what I'm
3 asking --

4 MEMBER STETKAR: Release categories with
5 and without the filter is what I was asking about.

6 MEMBER CORRADINI: Right.

7 MEMBER STETKAR: Right.

8 MR. DENNIG: Yes.

9 MEMBER STETKAR: With and without a
10 filter what is the profile of their release
11 categories?

12 MR. DENNIG: Those calculations were
13 done and they are available and we can get them from
14 the regulator but we have not scrutinized them.

15 MEMBER STETKAR: Why not?

16 MR. DENNIG: As a matter of time I
17 suppose as much as anything else, plus they pretty
18 much run the same codes as we do and they do the
19 same kinds of analysis. A lot of their work was
20 based on NRC work.

21 MEMBER CORRADINI: I mean, I don't know
22 where John is going with this but where I'm going
23 with it is if there's not data as Dana said based on
24 some sort of surrogate set of materials with the sur
25 inventory and distribution that you can -- I was

1 just at another meeting yesterday that some people
2 were really worried about surrogates.

3 MEMBER BANERJEE: Why is that, Mike?

4 MEMBER CORRADINI: Well, I'm saying the
5 inherent data in this case, I'd want to see a
6 consistent calculation. I guess staff would -- I
7 would have expected staff to look at a set of
8 consistent calculations. Because with these
9 calculations you can run a computer program but
10 these computer programs, you can get almost anything
11 you want out of it if you tweak the knobs a certain
12 way. So I'd like to see --

13 MR. DENNIG: Well, you'll from Research
14 we have done calculations with and without filters
15 here that you'll be able to scrutinize.

16 MEMBER CORRADINI: Okay. But just to
17 summarize, you know that these exist but you haven't
18 looked at the details of them is I think what John -
19 - was your answer to John. Is that correct?

20 MR. DENNIG: Right. We have not read
21 the MITRA report or pulled the addendums and
22 appendices thereto. We have gotten some analyses of
23 recent uprates that include filtering and passed
24 those onto Research for scrutiny at like the MELCOR
25 MAAP-level analysis. So there has been some of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that.

2 Some of the calculations are done, you
3 know, done by the licensee and the authority is not
4 eager to put them out in the public domain so
5 there's that issue all the time. So, for a variety
6 of reasons we haven't been at that level but
7 Research will talk about how they have modeled
8 things and the results they've gotten with and
9 without filters.

10 MEMBER BANERJEE: Is it the general
11 feeling that sufficient data and validation exist so
12 that these things can be designed properly?

13 MR. DENNIG: Well, I think that's the
14 consensus of folks outside of our realm. I think
15 that's the consensus.

16 MEMBER BANERJEE: And that would be
17 something Research will address for us today?

18 MR. DENNIG: They're going to talk about
19 how they've modeled DFs and calculated
20 decontamination factors within MELCOR.

21 As far as the testing that's been done
22 the -- like I said, the CSNI report talks in detail
23 about high-efficiency scrubbing of submicron
24 particles and alludes to having to address that
25 problem. The Venturi scrubbing system is

1 specifically selected as having the capability to do
2 that where other systems, other approaches do not.
3 Coolants and sprays will not do that.

4 So, in consequence of that the -- and
5 the Swedes are the ones that started it. They went
6 off and looked at particulate-scrubbing technology
7 that came out of air quality which is wet Venturi
8 scrubbing. It was an old technology when they
9 looked at it but they adapted it to the purpose of
10 capturing submicron particles to the degree that
11 they needed to whereas other processes would not.
12 It was a specific design requirement for this.

13 MEMBER BANERJEE: So the pools would
14 not. If you had bubbles --

15 MR. DENNIG: In some cases to some
16 degree they will and Dana knows more than I do. But
17 I think when we look at the research results later
18 you will see that, if they show that, that the large
19 things drop out. If you look at it by particle size
20 class the large things drop out and the smaller
21 things tend to go through. So it makes sense.

22 MEMBER POWERS: What happens in nearly
23 all filtration systems is the big stuff is pretty
24 easy to do. Very, very tiny stuff is very easy to
25 do because it diffuses rapidly. And there is a

1 minimum. If I plot the filter efficiency as a point
2 -- size there is a minimum. It is not zero, okay.
3 So that you, if you make your pool deep enough
4 you'll get everything. But they can be very, very
5 deep.

6 What the -- what we observed in sprays
7 is that minimum shifts with the droplet size. So
8 that by using a distribution of droplets you do
9 better than you do with a single droplet size.

10 What the Venturi does is it creates a
11 little bit of droplet mist in there that is a
12 particularly good size for getting the aerosol
13 particles that are most difficult or have the
14 minimum kind of efficiency of capture.

15 MEMBER CORRADINI: So it basically
16 creates what it needs to remove some class of size.

17 MEMBER POWERS: That's right. Now, if
18 you plot the efficiency of a water-injection Venturi
19 as a function of particle size there's still a
20 minimum in the efficiency. That's almost
21 unavoidable, okay, and it's just how shallow that
22 minimum is. And it happens to be less shallow than
23 passive kinds of systems.

24 MEMBER BANERJEE: It also creates
25 turbulence. That helps.

1 MEMBER POWERS: These particles that
2 you're worried about, it takes awfully intense
3 turbulence to get them to cross stream lines.

4 MEMBER BANERJEE: What is the typical
5 size, Dana?

6 MEMBER POWERS: Typically around 0.1
7 micron, 0.1-0.2 microns are the problem particles.

8 MEMBER BANERJEE: Okay. Thank you.

9 MR. BASU: Bob, can I clarify one thing
10 just in my mind?

11 MR. DENNIG: Please.

12 MR. BASU: Sud Basu from the Office of
13 Research. In MELCOR we do calculate DF of whole
14 scrubbing, we do calculate the capture efficiency of
15 spray, so on and so forth. We don't calculate DF of
16 external filter.

17 So what I understand, most of the
18 discussion if not the entire discussion is centered
19 around the DF of external filter. We actually use a
20 number in MELCOR for external filter, a preassigned
21 or prescribed DF number. So, just for
22 clarification.

23 MR. DENNIG: This is -- the slide's up
24 there now. It's just illustrative of the general
25 statement about the reason for pursuing Venturi

1 scrubbers for submicron particles, one of the things
2 that it does if you can't do electrostatic removal.

3 And at the point where Sweden was
4 deciding how to pursue this, there are two tacks
5 basically. One has to do with sands and gravels,
6 large-bank filters that comes out of like a defense
7 establishment filtering production plants and
8 reprocessing plants. And the other branch goes off
9 into wet Venturi scrubbing. And we didn't follow
10 the former branch to any great degree. And others
11 followed the Venturi scrubbing branch, and that's
12 what's developed at the present time. So you can
13 take that down.

14 MEMBER SKILLMAN: Bob, in your answer to
15 Dr. Banerjee's question relative to is this notion
16 going to work or is it going to be successful you
17 answered those outside of this community think so,
18 or words to that effect. May I ask you to expand on
19 that answer a little bit, please?

20 MR. DENNIG: As I'll talk about later
21 the majority of other countries have installed
22 Venturi scrubbing systems either after TMI, after
23 Chernobyl, after Fukushima. They all have
24 requirements for minimum DFs. They all scrutinize
25 and accredit the designs that their licensees have

1 put in as meeting those criteria and believe that
2 that is an effective answer to -- if you're going to
3 have to vent a containment that is an effective
4 answer to minimizing the release in a practical way
5 at a practical cost. And so that's where things
6 have settled.

7 MEMBER SKILLMAN: Okay, I understand
8 that. So, that is those outside the community.
9 Now, what's the thinking of those inside the
10 community?

11 MR. DENNIG: Well, the basic -- how
12 shall I characterize this? There's skepticism about
13 two things, the capability that's being promoted by
14 vendors, DFs of 10,000 or so.

15 MEMBER SKILLMAN: This is technical
16 skepticism?

17 MR. DENNIG: Technical skepticism. And
18 I think we had PSI in here talking to you about what
19 they did and how they did it and where they came out
20 on it. So that's their perspective. And we don't
21 have any firsthand -- PSI has not given us their
22 data, okay. AREVA has not given us their data. But
23 they do want and they have been accepted by the
24 regulators as doing the job.

25 MEMBER BANERJEE: PSI is the Paul

1 Scherrer Institute?

2 MR. DENNIG: Paul Scherrer Institute.

3 MEMBER SKILLMAN: Thank you, Bob. That
4 explained what I was asking for. Thank you.

5 MEMBER BANERJEE: But they didn't give
6 you the data because it's sponsored by some
7 subgroup?

8 MEMBER STETKAR: It's actually CCI.
9 It's a private company.

10 MEMBER BANERJEE: Oh, that's completely
11 different from PSI.

12 MEMBER STETKAR: Right. And apparently
13 PSI -- PSI I think has been contracted by them to
14 run some tests. But it's CCI for whoever they --

15 MEMBER BANERJEE: PSI is a fairly
16 reliable organization.

17 MEMBER BLEY: But they're together. PSI
18 came to talk to us.

19 MR. MONNINGER: This is John Monninger
20 from the staff. I think there's a lot of good
21 questions here on the experiments that have been
22 done, the data that has been collected as a
23 prototypical, as a representative, et cetera.

24 You know, one of my thoughts is thinking
25 of the other things that we do within -- to address

1 severe accidents is the state of technology in
2 filters much, you know, is it significantly
3 different from how we have addressed disposition or
4 resolved other severe accident issues out there?
5 Whether it's decisions the staff has made from
6 vendors submitting a corium debris cooling systems
7 within the lower cavity, whether it's the
8 installation and testing of PARS, passive
9 autocatalytic recombiners. You know, whether it's
10 the external reactor vessel cooling system that
11 Westinghouse has.

12 I think this is not within the design
13 basis accident spectrum, this is within the severe
14 accident spectrum. And from the meetings I've been
15 involved in, you know, we can't say it's a complete
16 suite of testing but it appears to be comparable to
17 the other state of knowledge and testing that the
18 staff has looked at in resolving and addressing
19 other types of severe accident issues.

20 That's just meant to put it in some
21 level of perspective. And the Agency has proceeded
22 with rulemakings and to impose requirements based on
23 that state of knowledge.

24 MR. DENNIG: Okay. Next slide, please.

25 MEMBER BANERJEE: If I interpret what

1 you said it means that you're willing to proceed
2 with less complete knowledge than you would have for
3 certain design basis accidents.

4 MR. MONNINGER: I think the staff does
5 do that. I think, you know, with the validation of
6 our severe accident codes, our models, the level of
7 completeness of our PRAs, our risk assessments, yes,
8 I do believe that's true. And that's, you know, an
9 accepted regulatory practice. Whether it's good or
10 not is different.

11 MEMBER BANERJEE: Yes. I mean you're
12 stating a fact.

13 MR. MONNINGER: Yes.

14 MR. DENNIG: Next slide, please. I want
15 slide 16. I've touched on this already. The
16 installation of filtered containment venting systems
17 has largely been in response to operating experience
18 from large accidents. You can see that it was done
19 after TMI is the earliest and that's Sweden and they
20 did the earliest after Chernobyl. And now after
21 Fukushima there are commitments to install filtered
22 containment venting systems.

23 The -- some plants, if you look into it,
24 the commitment is from the industry and voluntary to
25 the extent that we understand voluntary.

1 MEMBER ARMIJO: Strange word.

2 MR. DENNIG: One of the consistent
3 things though is that the way it usually proceeds is
4 that there's a decision that's been made that since
5 the containment has to be vented it has to be
6 filtered and that decision gets made, and then the
7 regulator works with industry to develop the
8 specifications and the approaches. So the decision
9 comes early and then the effort to come up with a
10 feasible solution follows.

11 Some countries have done this, put in
12 filters as part of their periodic backfit reviews.
13 But again, my sense is that it was driven by
14 operating experience, in response to operating
15 experience.

16 And at the time that these decisions are
17 made it is highly likely that severe accidents were
18 not part of the design basis, that they were going
19 beyond the design basis and later would incorporate
20 it, pull it into the design basis. But at the time
21 it was decided to have a filtered release that was
22 not the case. Next slide, please.

23 MEMBER ARMIJO: Before you do that, Bob,
24 are these systems that have been installed
25 seismically qualified?

1 MR. DENNIG: Yes.

2 MEMBER ARMIJO: And so, the last bullet
3 I'm trying to understand. Severe accidents were not
4 part of the design basis for the filter? I mean, or
5 --

6 MR. DENNIG: For the original plant.

7 MEMBER ARMIJO: For the original plant.

8 MR. DENNIG: Right. They had the same
9 thing as --

10 MEMBER ARMIJO: So as far as --

11 MR. DENNIG: -- design basis accidents,
12 you know, and successful if late recovery of ECCS
13 and stopping the accident process, the same thing as
14 we had.

15 MEMBER ARMIJO: Okay.

16 MR. DENNIG: Next slide, please. The
17 technical bases are to a great extent qualitative.
18 The regulators assert that it's -- FCVS is needed to
19 manage a severe accident with pressure challenges.

20 For example, the Finnish regulator,
21 their position is that a filtered containment
22 venting system is useful for anytime there are
23 fission products in the containment to manage the
24 accident.

25 Defense-in-depth to address

1 uncertainties associated with severe accidents.
2 This was the point that was emphasized to us by the
3 Swedish regulator.

4 And then obviously it significantly
5 reduces offsite release and land contamination. And
6 they do -- except for Sweden who actually has a
7 criterion for that contamination.

8 The other countries have adopted an
9 achievable DF approach, available technology. They
10 specify that you have on the filter, for the filter
11 a DF of 1,000 for aerosols and 100 or so for iodine.
12 And that's where they pick it up. That's the
13 requirement. It's stipulated.

14 MEMBER CORRADINI: And then when they --
15 because I guess Dana's going to help answer this
16 one. When you give a specification like that it
17 must be some average by some test? In other words,
18 because it is particle-dependent and you do get a
19 minimum. I remember some slides that Dana sent to
20 all of us kind of ahead of time on this. So, how is
21 the DF computed? Is it the minimum DF or is it some
22 integrated that takes account of particle size?

23 MR. DENNIG: The general assumption is
24 that the filters that are installed at the moment,
25 the technology at the moment, the DF is not

1 sensitive to particle size to any great degree.

2 That is the representation.

3 MEMBER BANERJEE: Are these for the
4 Venturi scrubbers?

5 MR. DENNIG: Yes.

6 MEMBER BANERJEE: There is a minimum but
7 it's fairly flat.

8 MR. DENNIG: Well, you can -- well.

9 MEMBER CORRADINI: Well, I guess what I
10 was asking is when you said if, you know, you said
11 1,000 for particles and 100 for iodine. The
12 question that went through my mind is is that the
13 minimum? Is that some sort of computed average
14 based on a test?

15 MR. DENNIG: No, that's a minimum.
16 That's a greater than or equal to 1,000 for
17 aerosols. That's a minimum. I'm sorry, I
18 misunderstood.

19 MEMBER BANERJEE: So physically suppose
20 you had these Venturi scrubbers. How big are they?

21 MEMBER CORRADINI: They're big.

22 MEMBER SKILLMAN: They're huge.

23 MR. DENNIG: Did we bring the
24 comparative slide?

25 MR. BETTLE: Yes, there's some backup

1 slides.

2 MEMBER BANERJEE: You brought some
3 pictures?

4 MR. DENNIG: We'll show you that, yes.
5 We'll show you that. Do you want to put it up? We
6 have a slide.

7 MEMBER BANERJEE: Whatever you're
8 comfortable with.

9 MEMBER CORRADINI: Just tell us the
10 number and we'll look at it.

11 MR. DENNIG: It's in the backup slides.

12 MEMBER CORRADINI: Oh, it's not in this.
13 This is just the main slides, sorry.

14 MEMBER STETKAR: This is just a high-
15 level summary.

16 MR. BETTLE: This is Jerome Bettle. The
17 Barseback filter was a large seismic reinforced
18 concrete cylindrical structure about the size of
19 their primary containment is like 65 meters high.
20 The -- when they reduce the size down with the water
21 bath multi-Venturi filters those are about I believe
22 21 meters. And a lot of the current designs are 9
23 meters and less.

24 MR. DENNIG: So it's evolved over time.

25 MEMBER BANERJEE: I'm glad I asked that

1 question.

2 MR. DENNIG: Well, and there is a design
3 that's being put on the Chinese plants that splits
4 the scrubber section from the after-particle
5 removal, the metallic filter section. And they do
6 it in two pieces and it fits inside the reactor
7 building.

8 MR. BETTLE: For more constrained
9 installation locations.

10 MEMBER CORRADINI: What Chinese plants
11 are these?

12 MR. DENNIG: There are two PWRs that I
13 know of that have the AREVA filter installed on it,
14 and they're putting it on all their PWR forward
15 builds. And the last time --

16 MEMBER CORRADINI: Not on their
17 construction, on their planned.

18 MR. DENNIG: Under construction.
19 Planned and under construction. They're putting
20 that system on their PWRs.

21 MEMBER BANERJEE: The AREVA plants.

22 MR. DENNIG: No, this is Chinese,
23 China's plants. They're using the AREVA design.

24 MEMBER CORRADINI: So let's just make
25 sure I'm clear. They have four AP1000's going up.

1 Are they on the four AP1000's?

2 MR. DENNIG: I don't have any
3 information about that.

4 MEMBER CORRADINI: There's four -- I
5 mean, there's 26 plants in construction. When you
6 say they're on all the plants, that's an awful lot
7 of plants to put them on. So I just want to make
8 sure I'm clear on what they're doing.

9 MR. DENNIG: I can give you the list.
10 It does not include -- well, I don't know. I have
11 the list of names of PWRs.

12 MEMBER CORRADINI: I was figuring that
13 would be the answer I would eventually hear.

14 (Laughter)

15 MEMBER CORRADINI: Okay, fine. Thanks.

16 MEMBER BANERJEE: And are they
17 backfitting any or it's just going forward?

18 MR. DENNIG: The words are new builds.

19 MR. MONNINGER: Well, throughout the
20 world or within China?

21 MEMBER BANERJEE: Within China.

22 MR. DENNIG: I haven't heard backfit.
23 I've heard going forward.

24 Okay. Barseback was a one-of-a-kind and
25 it was obsolete pretty much by the time it was

1 installed. And the period of 1980-ish to 1986, the
2 filter MVSS was developed in Sweden. And that's the
3 eighties technology and at that time that was fairly
4 expensive and the cost has gone down.

5 The people we talked to considered the
6 cost low to modest. The idea is that -- best
7 expressed by there's a reasonable solution, a
8 reasonable cost that can be implemented in a
9 reasonable amount of time is pretty much the way
10 this has worked.

11 MEMBER BANERJEE: Do you have any idea
12 what the cost is?

13 MR. DENNIG: Yes.

14 MEMBER BANERJEE: Could they give you
15 some idea?

16 MR. DENNIG: Yes. We think it's about
17 \$15 million for the filter and the appurtenances.

18 MEMBER BANERJEE: That's installed cost?

19 MR. DENNIG: Yes.

20 MEMBER BANERJEE: And roughly how long
21 does it take to do it?

22 MR. DENNIG: The -- 2 years. It takes,
23 what, two outages. And you can do this without
24 stopping production. You can do it in a way that
25 doesn't impact production and tie it in during an

1 outage.

2 MEMBER SIEBER: And this is big enough
3 to actually perform its function?

4 MR. DENNIG: Everybody uses 1 percent
5 license power as the beginning point of the size and
6 then the things about how much fission product
7 loading and so on and so forth. Those are worked
8 out in designing a system for a specific customer.

9 CHAIR SCHULTZ: Bob, it would be a two-
10 outage schedule following design?

11 MR. DENNIG: Yes. Having the design in
12 hand from -- between '86 and '88 Sweden installed
13 MVSS's on all of their plants. On 10 units.

14 MR. MONNINGER: So that would be the
15 foreign experience. Now, if the NRC was or wasn't
16 to do something doesn't necessarily mean that that
17 would be the schedule here.

18 CHAIR SCHULTZ: I understand. Thank
19 you.

20 MEMBER BLEY: Bob, when you said the
21 Barseback filter was obsolete shortly after it was
22 installed, commercially obsolete or functionally
23 obsolete?

24 MR. DENNIG: Both. Thank you.

25 MEMBER BLEY: How far functionally

1 obsolete?

2 MR. DENNIG: It was designed and tested
3 to achieve 1,000 I think was the spec for that, and
4 it could -- I'm sure it could continue to achieve
5 that. It was in large part that size for heat
6 capacity considerations.

7 MEMBER BANERJEE: Was this that gravel
8 bed or something?

9 MR. DENNIG: Yes. This is just a huge,
10 huge, huge, huge building of gravel.

11 MEMBER BLEY: You didn't finish saying -
12 -

13 MR. DENNIG: Oh, it was just too
14 expensive and too large.

15 MEMBER BLEY: It would still do --

16 MR. DENNIG: Oh, it would still perform
17 its function.

18 MEMBER BLEY: It was functionally
19 obsolete, it was just -- it was commercial.

20 MR. DENNIG: Oh, no. Okay, yes. There
21 were better solutions.

22 MEMBER BLEY: Fair enough.

23 MEMBER REMPE: In addition to subsequent
24 filter -- or replacement filter costs, are there
25 like testing costs? Like when we have a HEPA

1 filtration system we do testing. And are those
2 things very expensive?

3 MR. DENNIG: Yes. In other countries
4 these systems are -- they're not single-failure
5 proof but they are pretty much safety grade. They
6 have tech specs and they are tested periodically and
7 we do talk to the owners and operators about that
8 subject. And it's -- they characterize it as
9 minimal.

10 MR. MONNINGER: So, operational cost
11 once it's put in place?

12 MEMBER REMPE: They actually test how
13 good the filter is working at least with our system
14 in the lab and I just was wondering if that cost
15 very much.

16 MR. DENNIG: Oh, no, no, that's not
17 done.

18 MEMBER STETKAR: They do more like valve
19 cycling.

20 MR. DENNIG: Right, no, that's the way
21 it is.

22 And some of the -- well, they all have
23 chemistry, they all have iodine chemistry to one
24 degree or another so there's testing of that.
25 There's testing of the chemistry.

1 MEMBER BANERJEE: You mean they add
2 something to the water.

3 MR. DENNIG: Yes.

4 MEMBER BANERJEE: Like thiosulfate.

5 MR. BETTLE: And sodium hydroxide,
6 thiosulfate in the PSI system.

7 MR. DENNIG: Okay, next. As I mentioned
8 Sweden did develop subsequent to their decision to
9 put filters on their plants a land contamination
10 goal. And it is related to the dose received in the
11 first year from people returning to the site
12 following an accident assuming poor weather
13 conditions that concentrate the release in a small
14 area.

15 And the way they term it is that they
16 expect that with this filter they will have less
17 than 100 square kilometers of highly contaminated
18 property that would give somebody more than 5 rem in
19 the first year after they return to their homes.

20 MEMBER CORRADINI: I guess I didn't
21 appreciate how you said that. So maybe, can you say
22 it again? So they developed the goal after they had
23 the filter vent?

24 MR. DENNIG: They had decided to --
25 since the containment had to be vented and it had to

1 be filtered that much they knew. At that point they
2 worked out --

3 MEMBER CORRADINI: The effect on land
4 contamination.

5 MR. DENNIG: What -- yes. What was
6 achievable, what could be accomplished, and did that
7 meet their needs.

8 MEMBER CORRADINI: Okay. And the last
9 part, "meet their needs," means they have some sort
10 of performance goal about land contamination?

11 MR. DENNIG: The Swedish have -- no,
12 they don't have a contamination number, amount per
13 acre or square meter or anything like that. They
14 have this dose criterion that is going to be
15 calculated that pertains to the dose that would
16 return in public 1 year -- remaining in place 1 year
17 after the accident that they won't get more than 5
18 rem. They will get less than 5 rem in limited
19 areas.

20 MEMBER BLEY: Not to have this go on
21 forever but I'm a little confused by that because
22 from the way you stated it they've evacuated and now
23 they come back at some point in time and yet we
24 still have an area 100 kilometers square where they
25 get over 5 rem. So what determines that time

1 between the accident --

2 MEMBER CORRADINI: Less than.

3 MEMBER BLEY: No, he said there would be
4 an area --

5 MR. DENNIG: So, there's a limited area.
6 Yes, there are areas that you could return 100 --

7 MEMBER BLEY: Less than 100 kilometers -
8 -

9 MR. DENNIG: -- you would get less than
10 5 rem, yes, that's correct.

11 MEMBER BLEY: Over 5 rem.

12 MR. DENNIG: That's correct, yes. There
13 would be limited areas --

14 MEMBER BLEY: Why would you put them
15 back if --

16 MR. DENNIG: Well, that's -- they would
17 --

18 MEMBER BLEY: What is that delta time
19 that they use to apply that? I'm just curious.

20 MR. DENNIG: Oh, it's a couple of weeks.

21 MEMBER BLEY: So it's real fast. You're
22 returning them back pretty fast.

23 MR. DENNIG: Yes.

24 MEMBER BLEY: Okay. After the emergency
25 is over essentially.

1 MR. MONNINGER: A lot of the criteria
2 were driven by the need for no long-term
3 condemnation of the land. They wanted to ensure
4 that the populations could come back.

5 MEMBER ARMIJO: So it's temporary, a
6 very short period of evacuation for the bigger area
7 and no long-term condemnation for the more
8 contaminated area.

9 MR. MONNINGER: Right.

10 MEMBER ARMIJO: Okay.

11 MEMBER SIEBER: The driving nuclide for
12 the evacuation is iodine?

13 MR. MONNINGER: It's not my expertise
14 but I mean, it's all -- I think the rehabilitation
15 is the cesium within the soil for the long term.
16 But the actual evacuation --

17 MEMBER CORRADINI: I just wanted -- I
18 had a follow-up question. Since you used Sweden as
19 an example at least this kind of illustrates. So,
20 just to repeat what I thought you said is they
21 decided to do it, they did it. They estimated or
22 computed with the effect of it that connected to
23 their land contamination goal.

24 So, when this thing fails what do they
25 calculate to be the probability of failure of this

1 filtered vent in containment? Do they have a
2 performance goal for that?

3 MR. DENNIG: One chance in 1,000 is what
4 they said. If it was called upon to work it would
5 be 1 time in 1,000 that it wouldn't work.

6 MEMBER CORRADINI: So that is part of
7 their PSA analysis.

8 MR. DENNIG: Yes.

9 MR. MONNINGER: And they use passive
10 rupture disk in the line with manual valve bypasses.

11 MR. BETTLE: Yes, yes. First 24 hours
12 no operator intervention.

13 MR. DENNIG: The Swiss, and there's a
14 paper, they have looked at with the installation of
15 a scrubber that has the 1,000-100 combination, the
16 effect on emergency measures and zoning and so on
17 and so forth. And they have a system where they
18 postulate, one, you've got your standby gas
19 treatment system and that works and they give that
20 1,000 and 100. Then they've got it's worse than
21 that, you have to go to then venting containment,
22 controlling containment pressure. The filter gets
23 1,000 and 100. And then they have another scenario
24 where that fails. And so they analyze all that
25 stuff to help refine their evacuation strategies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: They can get -- what
2 factor do they get on the iodine with these
3 scrubbers?

4 MR. DENNIG: It's 100 is what's assumed.
5 Again, the testing that's presented that you can get
6 your hands on is higher than that, but as far as --

7 MEMBER BANERJEE: That has to assume
8 some organic iodides.

9 MR. DENNIG: This is elemental iodine.

10 MEMBER BANERJEE: Elemental.

11 MR. DENNIG: Right.

12 MEMBER BANERJEE: What happens if
13 there's a lot of organic iodides?

14 MR. DENNIG: I think that's where Paul
15 Scherrer's approach comes in. They feel that
16 they've taken care of the iodine question with the
17 chemistry to a great degree.

18 MEMBER BANERJEE: That would be
19 interesting to know.

20 MEMBER SIEBER: Could we postulate that
21 if somebody installs a containment filtered vent and
22 they have a severe accident and they use the vent
23 and it actually works, is the vent and all of its
24 appurtenances shielded sufficiently so that people
25 can still get around the plant to do emergency work?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. DENNIG: Yes. All the things that
2 would occur to you --

3 MEMBER SIEBER: What dose will the
4 operators get?

5 MR. DENNIG: -- in terms of the
6 practical engineering of the system have been done
7 and implemented. The shielding, the access, how you
8 drain the stuff out of the tank at the end.

9 MEMBER SIEBER: It would take a lot of
10 shielding because you basically moved a good part of
11 the radioactive part of the core into this filter.

12 MR. MONNINGER: Yes. Well, they utilize
13 existing plant structures. You know, you have walls
14 that are 4-feet reinforced concrete. You have --
15 and where it would be, let's say the pipe would run
16 past equipment that you might want to have access to
17 post accident, they put up shielding. So they --

18 MEMBER SIEBER: It would have to be
19 massive shielding.

20 MR. MONNINGER: Oh, yes. And as you see
21 on the original MVSS filter that the Swedish plants
22 have, you know, they started out with a reinforced
23 concrete vessel that has a liner in it so that
24 portion of it provides the shielding. And like what
25 Bob said, they have either the capability of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 filters located high enough they can, you know,
2 after the vent gets under control and you get
3 containment cooling back they can either gravity-
4 drain, open a valve and gravity-drain it back in the
5 containment or you can pump it back. You know, they
6 have installed pumps there behind, you know, some
7 pretty massive lead shielding bore areas. So,
8 they've considered the shielding needs.

9 MEMBER SIEBER: Thank you.

10 MR. DENNIG: Okay. I think I've covered
11 the points I wanted to make on this slide. Next
12 slide, please.

13 This is a preliminary rack-up of
14 installations outside of the U.S. The green is the
15 committed or installed, white is we're not quite
16 sure, red is we know they're not going to. And so
17 we're continuing to update this. We're interested
18 in Mark I's and Mark II's but that distinction is
19 not being made.

20 MEMBER CORRADINI: Maybe you said it and
21 we just didn't ask it. So, since Canada is so close
22 what's their regulatory basis for this?

23 MR. DENNIG: Okay. Back up to slide --

24 MEMBER CORRADINI: I mean, you don't
25 have to -- unless you --

1 MR. DENNIG: I'd like to.

2 MEMBER CORRADINI: What I'm noting is
3 what I remember from China is that only the heavy
4 water reactors there are vent. That was because
5 they essentially adopted them from the Canadian
6 design which all their reactors are.

7 MR. DENNIG: Right.

8 MEMBER CORRADINI: But there is a
9 regulatory difference in Canada is my memory.

10 MR. DENNIG: I do not know the Chinese
11 regulatory basis.

12 MEMBER BANERJEE: The regulatory
13 difference in Canada to some extent is they look at
14 impaired emergency cooling as part of their
15 regulatory basis.

16 MEMBER CORRADINI: Right.

17 MEMBER BANERJEE: They require it.

18 MEMBER CORRADINI: Essentially it's not
19 a single-failure criterion. They actually assume
20 failure of the --

21 MEMBER BANERJEE: Impairment of the --

22 MEMBER CORRADINI: -- core cooling.

23 MEMBER BANERJEE: Yes, emergency
24 cooling. It's required.

25 MR. DENNIG: This is a quote that

1 succinctly summarizes. This is for Point Lepreau
2 for the decision. They have installed a filtered
3 vent outside their containment and they put in some
4 walls to shield it. And so this is the best
5 statement that I've found of their regulatory basis,
6 just exactly what it says.

7 MEMBER BROWN: Did they actually cost
8 \$14 million?

9 MR. DENNIG: That is the number that I
10 was given by the plant people.

11 MEMBER BANERJEE: This is a 600.

12 MEMBER CORRADINI: This is a CANDU 6.
13 Is this -- I mean, just a little more detail. Is
14 this part of the vacuum building design? Or is the
15 newer one with a large dry containment over the --

16 MEMBER BANERJEE: Point Lepreau doesn't
17 have a vacuum. Bruce and Darlington do.

18 MEMBER CORRADINI: So this is an add-on
19 to their large dry.

20 MR. DENNIG: Yes.

21 MEMBER ARMIJO: Could you leave it up
22 just a little bit more? I just want to read that
23 last sentence.

24 MR. DENNIG: Well, we should provide the
25 backup slides that got used.

1 MEMBER ARMIJO: Yes, if we could have
2 the backup slides.

3 MEMBER CORRADINI: And last question
4 since -- did the Canadians do a PSA, some sort of
5 PRA in terms of the performance of this system?

6 MR. DENNIG: Yes.

7 MEMBER CORRADINI: Was it similar to
8 what you quoted for the Swedes? Or the Swiss. I
9 can't remember which one you said was 1 in 1,000. I
10 guess the only reason I'm focused --

11 MR. DENNIG: Yes, the reason why they
12 can say that it lines up well with SSG-3 and SSG-4
13 is that they did the level 2 PSA. And there are
14 guidelines in those guidance documents that they
15 stated that they met. I have another slide that has
16 the numerics on it I think. But it fits in well
17 with the criteria for large-release frequency and
18 the severe core damage frequency based on certain
19 plant damage states following the IAEA guidance.
20 And so they did that study and everybody was happy
21 with how that turned out.

22 MEMBER BANERJEE: Can you leave that on
23 for just a second?

24 MR. DENNIG: The Canadian one?

25 MEMBER BANERJEE: No, no. So with China

1 you're saying 13 are unknown status basically.

2 MR. DENNIG: Yes. That number is -- I'm
3 not quite sure where we got that number from that's
4 up there. I have to square that with my analyst,
5 get his laboratory to look at the Navy stuff. So
6 we'll clean that up. But since it was not BWR we
7 weren't particularly concerned about that aspect of
8 it.

9 MEMBER BANERJEE: Okay. Thank you.

10 MR. DENNIG: I think that's the end of
11 my -- thank you very much. Oh, I have one more?
12 Oh, okay. Here's the -- this is the distillation.
13 The boilers. And Mark I's and Mark II's, the lion's
14 share are here in Japan. The Mark I/Mark II no FCVS
15 decision, that is India and Mexico -- Mexico, yes.
16 The considering line, the Mark I is Spain and that
17 plant's shutting down in 2013. So I would guess
18 that they're not going to. And the Mark III is
19 still under scrutiny. And again that's Spain. But
20 they have PWRs and they have decided to put them on
21 PWRs.

22 But the regulatory authority's words
23 were they encourage everybody to have this. And the
24 PWRs apparently volunteered to do it. And there are
25 two BWRs that haven't. Like I said, one of them is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a Mark I that's being retired in 2013 and the other
2 one is -- it's a Mark III. I'm sorry, Mark III.

3 MR. MONNINGER: So approximately 90
4 percent of the boilers in the world either have them
5 or are committed to filters outside the U.S.

6 MEMBER ARMIJO: Could you go back to
7 that slide 19? The large number of PWRs that are
8 going to install them or have already installed
9 them, those include large dry containment systems.
10 So the issue of containment size wasn't -- really
11 wasn't central to their decision. They just said --
12 could you explain why -- what their reasoning was?

13 MR. MONNINGER: We believe the majority
14 of the decisions are based on land contamination,
15 evacuation, large population zones. So that's
16 generally the worldwide experience is based on what
17 happens to the land and to avoid any type of long-
18 term evacuation.

19 MR. DENNIG: Now, they do differentiate
20 in the accident progression between the one and the
21 other and the way the containment behaves. And the
22 acknowledgment is that the large dry, it's going to
23 be a long time and it's going to be laid over
24 pressure. And they acknowledge all of that.
25 Nonetheless --

1 MEMBER ARMIJO: They put in the same
2 size system to handle the --

3 MR. DENNIG: One percent.

4 MEMBER ARMIJO: Yes.

5 MR. DENNIG: One thousand.

6 MR. BETTLE: Some of them require
7 somewhat less. Because if they assume that because
8 it's going to handle the pressure for awhile it may
9 be 24-48 hours before you need the vent. So they
10 could have it sized for like one-half a percent. So
11 some of them are designed for lesser.

12 MEMBER SHACK: And the French ones
13 wouldn't be Venturi filters, right?

14 MR. BETTLE: The French are the sandbed.

15 MEMBER SHACK: They will be.

16 MR. BETTLE: They will be.

17 MR. DENNIG: They will be.

18 MEMBER SHACK: They're changing them?

19 MR. DENNIG: Yes. For a long time we've
20 been told that they were swapping out and going to a
21 scrubber system for a number of reasons. One of the
22 reasons is that the sandbeds are on tops of
23 buildings and are not seismic. So they're going to
24 have seismic scrubbers installed.

25 And I think EdF. EdF is putting --

1 they're putting a scrubber on the English plant, on
2 -- Sizewell.

3 MR. MONNINGER: So currently the staff,
4 our assessment is just limited to the Mark I's and
5 Mark II's. So once we come up with our
6 recommendations, whether it's no action or whether
7 it's something else, following that we would look at
8 other designs.

9 And right now we believe the focus
10 should be on the Mark I's and II's predominantly due
11 to the regulatory technical issues associated with
12 the Mark I and II containments.

13 MEMBER ARMIJO: But if the driver is
14 land contamination it really doesn't really matter
15 whether it's Mark I or BWR.

16 MR. MONNINGER: It could depend. It
17 could depend upon your decision, and the releases,
18 and the frequency of the releases and the
19 vulnerabilities in the particular containment
20 designs.

21 You know, we are -- the Commission may
22 decide wherever and whatever basis the Commission
23 would like to decide, up or down, left or right, but
24 the staff is looking at the technical aspects of the
25 design of the Mark I's and II's and how that plays

1 into potential offsite releases, et cetera. So we
2 believe there are technical issues associated with
3 the Mark I's and Mark II's and you could potentially
4 differentiate them from the rest of the fleet.

5 MR. DENNIG: There is a history of
6 concern especially about the Mark I's that led to
7 venting. And so the obvious question is, okay, how
8 about, you know, what do you want to do with
9 retaining fission products. And this, the
10 technology has advanced in the last 20-25 years to
11 the extent that you'll hear. And so it's time to,
12 you know, revisit that decision.

13 As I said, when it was first made here
14 the focus was on concepts that involved large
15 sandbeds, underground large sandbeds. And to my
16 knowledge we never did any particular research on
17 Venturi scrubbing. Although it was mentioned a
18 couple of times I'm not aware of anything that we've
19 done.

20 We participated in the ACE program
21 testing and there were Venturi scrubbers tested
22 there, but the vendors brought those in and --

23 MEMBER BANERJEE: Hyped them. Did they
24 hype them up?

25 MR. DENNIG: Oh, of course. Of course.

1 Sure.

2 MEMBER BANERJEE: That's really the
3 problem we face.

4 MR. DENNIG: Right, well sure.

5 MR. MONNINGER: It's not just the
6 vendors. I mean, any presentations we get from, you
7 know, not just the vendor filters but any
8 presentations. And we have to do the technical
9 question. Again, they've got to back it up with the
10 data and if they can't back it up --

11 MEMBER BANERJEE: Look at them with a
12 very cold eye I think, a lot of these claims.

13 MEMBER POWERS: That's strange, isn't
14 it?

15 MEMBER SIEBER: In the --

16 MEMBER POWERS: Well, let me interrupt
17 Jack to just reemphasize this. As far as I know I
18 have never seen a detailed wet Venturi scrubber
19 technology analyzed in a nuclear context. There
20 have been studies in connection with conventional
21 power plant dust removal things. But I've never
22 seen one in a nuclear context. That, you know, I
23 would say is at -- real academic study. The best
24 was done by the Swedes at SKI.

25 MEMBER SIEBER: I've not heard of any

1 modification of emergency planning tactics or
2 organization or warning devices or anything else
3 associated with whether you have a filtered vent
4 system. That will continue to be the case, right?
5 You'll still evacuate even though --

6 MR. DENNIG: Oh yes. Yes. That goes
7 over to the local authorities and whatever federal
8 authority oversees that process and that goes on.

9 MEMBER SIEBER: Right. Okay.

10 MR. BETTLE: They don't take the
11 position that, hey, we have filters so there's no
12 need to evacuate.

13 MEMBER SIEBER: Right.

14 MR. BETTLE: They're still going to all
15 evacuate.

16 MR. MONNINGER: But the Commission could
17 at any time reopen it. And there are other EP
18 issues associated with Tier 3. There's the issue
19 with expanded use of KI. There's also an issue out
20 there with expanded EPZ.

21 So when you look at some of these issues
22 and we've had discussions back in the past about how
23 could a filtered vent or severe accident capable
24 vent help address hydrogen issues. Could a filtered
25 vent potentially help address these other issues out

1 there? Potential EP issues.

2 MEMBER SIEBER: I think that it needs to
3 deal with the hydrogen issue to some extent, at
4 least be able to withstand it.

5 MR. DENNIG: Right. And what we've been
6 talking about has been designed to -- with the
7 hydrogen threat in mind. And in cases where the
8 containment is inerted then the system or filter
9 system is inerted prior to operation.

10 MEMBER SIEBER: Okay.

11 CHAIR SCHULTZ: I'd like to move to the
12 next presentation. Thank you, Bob, for yours.

13 We are behind our advertised schedule by
14 about 20 minutes. I'm not encouraging that we
15 complete the next presentation in a very short time,
16 but rather just draw attention to that. We will
17 have an opportunity to address the issues that I'm
18 sure continue to be on everyone's mind in subsequent
19 presentations and discussions.

20 Jerry, why don't you proceed.

21 MR. BETTLE: Okay. Yes, my name is
22 Jerome Bettle. I want to continue on. There's a
23 section there titled "Filtered Containment Vent
24 Systems in Severe Accident Management."

25 Just to get back to a little bit of the

1 nuts and bolts out at the power plants, we took a
2 look at some of the plant procedures, the emergency
3 operating procedures, severe accident management
4 guides and the extreme damage mitigation guides.

5 After 9/11 the order EA-02-6 for the
6 interim compensation measures had a Section B.5.b
7 discussed injection into the reactor pressure vessel
8 and drywell. The follow-on in 10 C.F.R.
9 50.54(hh)(2) puts at a high level, made a
10 requirement and then there was endorsement of some
11 NEI document.

12 And more recently along with the order
13 for the reliable hardened vent was the EA-12-049
14 order for mitigating strategies which also included
15 a requirement for injection capability.

16 Nothing in our discussions so far have
17 said that we didn't think that water injection into
18 the drywell into containment wasn't needed as a
19 companion severe accident mitigation action, that
20 somehow just venting alone was going to save the
21 day.

22 Most of the procedures, they started out
23 on venting. A lot of this is from the emergency
24 operating procedures. There's some level of
25 assumption that standby gas treatment is going to

1 work. You're going to vent out, and the first line
2 is you go out through your normal vent purge pathway
3 to the standby gas treatment filtration system, and
4 they'll operate. Since that's not rated for much of
5 a pressure, containment pressure, it has to be like
6 1 to 2 pounds or less.

7 The other pathways that they then drop
8 down to, some plants maintain a line out for
9 depressurizing from integrated leak rate tests.
10 They say we've got a pipe we can use for that.
11 There's a couple other pathways some plants use, but
12 a lot of those are going to wind up basically
13 venting into the reactor building, other than the
14 Mark I's with a hardened vent. And in their case
15 that would be the one that would be the first line
16 if containment pressure was high.

17 Most of the venting for the design basis
18 accidents considers for eliminating the hydrogen-
19 oxygen mixture that might develop from radiolysis,
20 you know, many days after a DBA LOCA.

21 And again with that, if you have an
22 unfiltered vent the procedures, you know, you
23 certainly don't want to vent out radioactive
24 material to the environment, to the plant, to the
25 reactor building. You know, so there's plenty of

1 cautions along that line, but then there's others.
2 You're not going to allow a structural failure of
3 containment. So it's kind of a back-and-forth.

4 MEMBER ARMIJO: So if -- I'm trying to
5 follow that. So if you have this vent capability,
6 filter capability, then you are not encouraged but -
7 - you're not discouraged from venting.

8 MR. BETTLE: There would be less
9 hesitation and less discouragement from going to a
10 vent, especially from going to a vent early. The
11 consequences are likely to be fairly minimal.

12 MEMBER STETKAR: Jerry?

13 MR. BETTLE: Yes.

14 MEMBER STETKAR: Bob gave us an overview
15 of the hardware experience looking at the foreign
16 plants.

17 MR. BETTLE: Yes.

18 MEMBER STETKAR: Did you look at all at
19 their experience in rewriting their severe accident
20 mitigation guidelines, because they have them in
21 Europe, and their emergency operating procedures to
22 see how their philosophy preventing it, if I can
23 call it that, has changed or will change?

24 MR. BETTLE: No, we didn't read into --

25 MEMBER STETKAR: Because that strikes

1 me, rather than looking at what our procedures look
2 like today with no filtered vents and trying to
3 divine what they might look like with a filtered
4 vent, it would be useful to look at people who have
5 installed them and see how their procedures are
6 changed. Recognizing that unfortunately a lot of
7 them were installed at the time, the ones that are
8 installed in Europe were installed at the time when
9 they were developing severe accident mitigation
10 guidelines. So they're developed in parallel.

11 However, the plants that are now
12 committing to install them will need to change their
13 severe accident mitigation guidelines appropriately
14 and one would presume that they're doing that. So
15 that would seem to be good experience to look at to
16 see how their philosophy is changing.

17 MR. DENNIG: We saw the time line at the
18 sites. Where in conjunction with installing the
19 filter did they revise their procedures.

20 MEMBER STETKAR: Right.

21 MR. DENNIG: But we never pulled the
22 string on that.

23 MR. BETTLE: And getting that, that's an
24 excellent suggestion. The only -- of those
25 documents that I saw on the table while we were over

1 in Europe weren't in English and I didn't think to
2 ask for translated copies. So maybe that's
3 something we can take a look at.

4 Going onto slide 23, the drywell --
5 using drywell sprays for contamination. The
6 existing spray hose were designed for DBA purposes,
7 pressure control and heat removal. For the BWRs
8 Mark I's and Mark II's the original design was
9 typically from like 2,500 to 10,000 gallons per
10 minute for drywell spray. And even with that the
11 estimation was DFs might not be much more than 10.

12 We did give some credit for the design
13 spray scrubbing at at least one plant for when they
14 did their alternative source term license amendment
15 request. And pretty much they calculated down that
16 they had to take only 50 percent of the flow rate as
17 far as the input for the scrubbing. And from header
18 to floor, a 61-foot drop, you know, they would only
19 get credit for 8 feet of that because there's just
20 so many interferences with the spray flow inside the
21 Mark I and Mark II containments.

22 The portable pumps that have been
23 discussed are in the low one hundreds. You hear
24 that the absolute minimum would probably be about
25 100 gallons per minute to achieve boil-off of decay

1 heat. Other flow rates, the one that you saw from
2 the B.5.b stemming from that is 300 unless you can
3 justify less. EPRI has done some study assuming a
4 portable pump flow rate of 500 gallons per minute.

5 On those plants that would have headers
6 and spray nozzles arrayed for 10,000 gallons per
7 minute it's thought that if you're down in that 500,
8 300 range --

9 (Laughter)

10 MEMBER ARMIJO: The spray is not going
11 to ignite.

12 MR. BETTLE: It's going to be more of a
13 number of garden hoses coming out in containment
14 effectively. Although it is --

15 MEMBER POWERS: I mean, some of the
16 plants -- I mean, the original designs on the Mark
17 I's had this 10,000 gallon per minute kind of flow
18 rate and so they chose a particular nozzle.

19 MR. BETTLE: Right.

20 MEMBER POWERS: Some of the plants have
21 gone to a nozzle that didn't give you the 10,000
22 gallons a minute but it ignites at very low flow
23 rates.

24 MR. BETTLE: Usually for a lot of them
25 you consider if you have even 50 percent of the

1 design flow rate they'll still be almost, you know -
2 -

3 MEMBER POWERS: All of them should work
4 at 50 percent.

5 MR. BETTLE: Right.

6 MEMBER POWERS: It's the 10 percent
7 that's going to be --

8 MR. BETTLE: They're down in the 5-10
9 percent range.

10 MEMBER POWERS: They just won't be a
11 spray. I mean, it'll be a --

12 MR. BETTLE: However, you know, there
13 would be a good line for flooding inside containment
14 because you're getting a distributed flow coming in.
15 A lot of it's going to come down from the outside.
16 On the Mark I's especially it's going to hit the --
17 a lot of it is going to drain down the outside to
18 the floor.

19 It's going to help you with keeping any
20 molten core that comes down from getting to the
21 drywell wall. So it's an excellent entry point for
22 the drywell injection. However, you know, we don't
23 think that you can really take a whole lot of credit
24 for decontaminating the atmosphere.

25 Slide 24. Suppression pool has been

1 talked about earlier. If you start out with 75
2 degree water and you're running down the T-
3 quenchers, you know, in 9, 10, 12 feet of
4 submergence in cold water you're probably getting a
5 DF of 1,000 or better. It's going to be excellent.
6 I think later on in our Office of Reactor Research
7 discussion they're going to talk about DFs of 100 to
8 300.

9 However, when the core comes out the
10 flow is going to be down the downcomer pipes. And
11 there's typically 80 to 100 of those and 20-24
12 inches of diameter so it's a very large area. The
13 injection of the water might be 4 or 5 feet. Then
14 if you flood up, you know, you might get 8 or 10
15 feet before you have to transfer to the drywell
16 vent. In that case if the water has come up to
17 about saturation your DFs with the downcomers is
18 probably no more than 10 either.

19 MEMBER POWERS: That's the
20 decontamination that you get in the pool itself?

21 MR. BETTLE: Yes. It's coming through
22 the pool.

23 MEMBER POWERS: When we looked at this
24 we got a lot of decontamination. When you come down
25 those big downcomer pipes the bubble comes out and

1 detaches and does its thing.

2 MR. BETTLE: Right.

3 MEMBER POWERS: The water surges back
4 up. And we got a lot of decontamination actually in
5 the pipe itself. You do this water surging back and
6 forth. I don't know that any of the codes actually
7 take account of that.

8 MR. BETTLE: Yes, that's probably some
9 element of uncertainty.

10 MEMBER POWERS: Well, you know, just how
11 you calculate it is kind of interesting. But it's a
12 classic moving boundary problem.

13 MR. BETTLE: Right.

14 MEMBER POWERS: Flow's coming down,
15 water's coming up and it's kind of a surging flow.
16 And you know, the DFs you're going to get are not
17 going to be heroic but 10 is going to be a very
18 feasible thing.

19 But I don't -- I don't actually know but
20 I don't think that the SPARK code or any of those
21 classic codes take into account that. And I know of
22 absolutely no experimental studies of big pipes
23 putting out bubbles and decontaminated.
24 Everything's been for the T-quenchers. Nothing's
25 been for, you know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I mean even pipes like this, I don't
2 think anybody's ever done them. I mean, the problem
3 is one of bubble dynamics.

4 MR. BETTLE: T-quencher flow, those
5 holes are generally about 1 centimeter.

6 MEMBER POWERS: Easy to work with.

7 MR. BETTLE: And you're going to get
8 considerable velocity of the flow coming into the
9 water whereas you're not going to get a very
10 energetic discharge when you have the, you know,
11 after the cores come out, coming down through all
12 those downcomers. It's not like an initial LOCA
13 blowdown situation.

14 MEMBER POWERS: It's a nice, gentle
15 flow. But it's fairly dynamic in those pipes. And
16 I don't know whether anybody's ever.

17 MR. BETTLE: Okay. Onto slide 25. EPRI
18 has provided us some briefing. They have a report
19 that's available on their website for public
20 consumption that details their investigation using
21 the computer codes they use.

22 They use a portable pump for flooding
23 the drywell cavity or some flow path or the spray
24 header. They run with 500 gallons a minute. That
25 helps, I don't know, in terms of the spray for

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 scrubbing effect. But that's considerably more than
2 you would need for decay heat to boil off so it
3 maintains -- really helps to maintain suppression
4 pool -- cooling to give you some pool DF.

5 They do control containment pressure
6 that's near the design value. It gives them fold-
7 up, settling, plate-out. Helps out with the spray
8 effect even though it's relatively small. If you
9 just let it sit there and continually spray the
10 environment that's in containment it's going to
11 extract a lot of the aerosol.

12 And you also get a high velocity
13 discharge into the suppression pool when you
14 depressurize. They'll run 40 to 60 pounds. It gets
15 to 60, they'll open the vent line, drop it to 40 and
16 close the vents.

17 So they have to maintain let's say a
18 good indication and more or less continuous on
19 containment pressure and containment water level.
20 Because at some point they have to make a swap from
21 the wetwell vent to the drywell vent because at 500
22 gallons per minute you're going to flood up the --
23 and seal off the wetwell vent line in somewhere
24 around 20 hours.

25 Slide 26. The EPRI report does mention

1 the fact that if you don't put water in the
2 containment it's going to heat up and temperature is
3 going to get up to 1,000 degrees and that's going to
4 compromise penetrations.

5 They really didn't have any discussion
6 that if you're maintaining the pressure with the
7 spray flows that you have coming in or the flooding
8 especially on the Mark I's up in the top of
9 containment, it's almost the cylindrical section.
10 Unless you have something with momentum forcing up
11 there it seems that the heating from the residual
12 hot stuff in the vessel is going to come out the top
13 of the vessel and keep the top of the containment a
14 lot hotter than down at the bottom where the water's
15 introduced.

16 MEMBER POWERS: And it gets very hot up
17 there.

18 MR. BETTLE: Yes. They didn't really
19 talk about the fact of the high reliance on
20 instrumentation procedures and the human
21 performance. And just taking a look at what they
22 had on the graphs of the pressure it appears that
23 the vent valves would be cycled between 15 and 22
24 times in a 72-hour period that they analyzed.

25 So that's quite a few cycles and you

1 know, there's I'd say a considerable dependence on
2 knowing exactly what the pressure and the
3 temperature is, and fairly accurately too. So
4 you're putting a lot of reliance on the
5 instrumentation there to gain a substantial
6 decontamination factor from containment.

7 They're showing values that if you use
8 the regime that they assume that you can get -- the
9 containment itself will give you an effective -- the
10 pool and the spray will give you an effective
11 decontamination of anywhere from one to three
12 thousand. However, if you drop off of that regime
13 you can quickly fall back to the low hundreds and
14 even more so.

15 One other thing I didn't mention.

16 MEMBER POWERS: One hundred is a lot, by
17 the way.

18 MR. BETTLE: Pardon?

19 MEMBER POWERS: One hundred is a lot.

20 MR. BETTLE: Yes, yes.

21 MR. MONNINGER: Some of that is based on
22 the venting through the wetwell. And there is a
23 potential concern with venting through the drywell
24 also.

25 MR. BETTLE: Right. As the procedures

1 would say if you need to vent you vent from the
2 wetwell, but if that's not available then you go to
3 the drywell vent. In that case there's, you know,
4 there's much -- that early in the event there's a
5 lot more that's going to come out if you have to
6 vent from the drywell.

7 One other thing they didn't talk about
8 that would seem to be a potential problem. They
9 didn't talk about inerting the vent line. If you're
10 going to cycle the vent line it's going to have a
11 large composition of steam most of the time. So if
12 you close the valves it's going to start cooling off
13 and you know, the air from outside is going to rush
14 back in and meet with the residual hydrogen that
15 might be in the pipes. So you may be repeatedly
16 giving yourself a combustible atmosphere inside that
17 pipe.

18 MEMBER POWERS: Do you have any ignition
19 source?

20 MR. BETTLE: No you don't, but coming up
21 near the top it doesn't take much to ignite a
22 hydrogen mixture. Just the static charges from a
23 flow of air will ignite them.

24 MEMBER BLEY: You used to get that in
25 the offgas system.

1 MEMBER STETKAR: I had a melted hard hat
2 trying to put one of them out.

3 MR. BETTLE: So yes, that is a
4 possibility. There's experience with it.

5 In developing this paper for the
6 Commission we're presenting a number of choices for
7 action or options. Of course option 1 is the no-
8 action option, the no-action action. That's to sit
9 with the -- at least for the time being with the
10 current order as far as reliable hardened vents, the
11 Order EA-12-50.

12 The second option would be to have an
13 increase where we -- the requirements we would have
14 to work it so that it was fully reliable and capable
15 for a severe accident environment.

16 The third option would be installing
17 that external filter on this vent line.

18 And the fourth option would be a
19 performance-based which we really haven't explored,
20 but that would get down to more of a plant-by-plant
21 evaluation.

22 Slide 28. Option 2, severe accident
23 capable vent. Some of the considerations there is
24 higher temperatures and pressures, especially if
25 you're going to have to vent off the drywell. The

1 temperatures up there could be considerably higher
2 than let's say containment design pressures.

3 If you're coming out -- a lot of these
4 hardened vents for the Mark I's tapped off -- one of
5 the inboard vent purge line valves. Typically they
6 have soft seats. I don't know what the containment
7 temperatures might be coming out of that line,
8 whether they would be suitable. You'd have to make
9 some changes in that hardware.

10 Again, the hydrogen issue that I was
11 talking about earlier, that you'd have to have -- if
12 you just open a vent and left it open, and you've
13 got the heat source in there and stuff's coming out
14 is there's a constant push going out that pipe. So
15 you're not going to have air and oxygen coming back
16 in that's going to maintain it inerted.

17 You know, whether it's your, you know,
18 hydrogen or carbon monoxide, as long as there's just
19 steam in there with it and no oxygen it's not a
20 problem. And when you vent it out the venting clear
21 of any building or any restriction to expansion
22 you'll have a small zone of combustible gas. You
23 know, you could have a flare going on there but it's
24 not going to impact anything.

25 Also, the shielding that you would need

1 in the current order, it's not anticipating a
2 significant source term or radioactivity coming off
3 this -- the vent line when it's in service. So, you
4 know, I guess it could essentially run almost
5 anywhere. As long as people didn't have to squeeze
6 past it, touch it and get burned it would be okay
7 for the current order.

8 If it is going to be severe it can't be
9 going anyplace that you're going to need access to,
10 you know, to try to mitigate the event, operator
11 recovering equipment locally or you're going to have
12 to put shielding up to enable that to occur.

13 One of the discussions about early
14 venting is to -- after the core damage starts to
15 occur in the vessel to vent a lot of the generated
16 hydrogen out before the core comes out of the bottom
17 of the vessel. That would allow you to maintain the
18 vent closed for a considerable period of time.

19 And one of the things about being able
20 to use the vent and maintain the low pressure is
21 that whatever developing or existing leakage that
22 you could have out of the containment into the
23 reactor building would be minimized to keep not only
24 the combustible gases from potentially leading to
25 burning or explosion but also the steam environment,

1 the contamination that would be there, the airborne
2 makes it extremely difficult for anybody to access
3 the building to do anything good, you know,
4 regarding terminating the event or stabilizing the
5 conditions inside containment.

6 In talking about a wetwell vent, only
7 the existing order can specify whether there's
8 wetwell and drywell. As long as you don't have a
9 damaged core that means you've been able to inject
10 water into the vessel which means that the discharge
11 is coming out the SRVs to the pool. It's getting
12 scrubbed. And even if you have a vent off the
13 drywell it would come back up through the vacuum
14 breakers and go out the vent. So you'd be getting
15 the scrub.

16 In post accident of course -- or severe
17 accident the core could be coming out of the bottom
18 in which case if you're flooding up you're going to
19 seal off your wetwell vent path eventually. And
20 when you go to the drywell you don't have any --
21 you're going to need to have a drywell path but it's
22 not going to -- not going to be nearly so good. So
23 the existing order didn't really consider the
24 venting location because drywell/wetwell doesn't
25 really make a difference until the core comes out of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the vessel.

2 Okay. Given the accident it's going to
3 be very uncertain how it progresses, you know,
4 whether you get some water injection, you slow it
5 down. Core damage starts, you arrest it, it starts
6 again. The suppression pool, the drywell sprays,
7 how much injection you have there, how much
8 subcooling you can maintain is all going to make for
9 a high -- let's say a considerable uncertainty as to
10 what actually is going to be able to get out of
11 containment, or how much you're going to be able to
12 reduce the radioactivity leaving containment.

13 And in consideration of where the pipes
14 that are currently routed it may be that rerouting
15 the pipe would turn out to be more of a concern than
16 with the -- just having the pre-severe accident.
17 You know, if you go out one side of the building or
18 if you run it out through the turbine building to
19 get to your elevated release point you may wind up
20 just reorienting the pipe and running out a
21 different side of the building up to the roof line.

22 MR. DENNIG: The point here was that
23 it's not entirely clear that you're incrementing
24 what you've already got from 89-16. That may not be
25 the best engineering solution or the least expensive

1 engineering solution.

2 MR. BETTLE: Okay. Option 3, the
3 filtered vent.

4 MEMBER ARMIJO: Just before we leave.
5 Now, would you have to do these same things, many of
6 the same things from option 2 to make option 3 work?

7 MR. BETTLE: Yes.

8 MEMBER ARMIJO: So option 3 includes
9 many of the elements in option 2.

10 MR. BETTLE: Yes.

11 MEMBER ARMIJO: Okay.

12 MEMBER STETKAR: In fact, the last
13 bullet on that option 2 slide, if you decide to put
14 a vent in that may have a bigger influence on the
15 routing of your pipe. That's what I've seen in
16 Europe. Just because of space for your filter or
17 structural capability, you know, to handle the
18 filter.

19 MR. BETTLE: That will dictate the
20 layout of the vent system.

21 Okay, option 3. We consider that to be
22 -- it would be a significant enhancement in severe
23 accident containment performance. You get the
24 capability of option 2 plus, you know, it kind of
25 extends the containment function and you preserve

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the defense-in-depth.

2 So far in discussing with the Europeans
3 and in looking through as much literature as we can
4 nobody has really identified a technical or safety
5 issue with putting filters in a vent system.

6 MR. DENNIG: It doesn't introduce any
7 new accidents or problems in coping with -- as long
8 as it doesn't interfere with the existing systems.
9 As long as it's not intertwined in some way with the
10 existing systems. If you do that things get a
11 little confused. But as long as you keep those
12 things fairly separate you can manage it.

13 MR. BETTLE: And for the most part the
14 Europeans have come out of separate penetration and
15 they keep it totally separated from any of the
16 systems. It's essentially a stand-alone. They
17 don't tie in with, you know, have just a valve
18 barrier to standby gas treatment or other
19 ventilation systems on the way out to the vent
20 point.

21 If you have a filter, however much you
22 have coming out it's going to be much smaller than
23 without a filter. And it's been implemented in a
24 number of countries. It's proven in the sense that
25 nobody's come up with a reasonable way it's a bad

1 idea. And it's certainly a technology that is
2 available.

3 You can construct this with brass from a
4 wetwell with normally closed valves. And this would
5 be coming out to a filter. It would give you the
6 maximum amount of belt and suspenders reduction in
7 anything being released. It would be more conducive
8 to early venting, reduce the stress or any delay in
9 consideration of the potential releases.

10 And you can have one of the European
11 designs, a vent line from the drywell with one
12 branch, one with a rupture disk and the other with a
13 normally closed valves that you can open it up.

14 What you see there on slide 33 is what
15 you would have on a Mark I with this full-feature
16 vent system coming up, both the wetwell and the
17 drywell.

18 Okay, the external filter system. I
19 guess the staff would develop some sort of a
20 technical basis for requiring a minimum DF. There's
21 been some discussion before, there will probably be
22 some discussion later today. The Europeans for the
23 most part had a requirement of a DF of 1,000 for
24 aerosols and 100 for iodine.

25 We would engage all the stakeholders to

1 develop appropriate performance criteria for the
2 filters if it was made a requirement. And other
3 features that would be under consideration, if you
4 do have a filter it makes more sense in terms of
5 having a passive actuation through let's say an open
6 or exposed rupture disk.

7 MEMBER SKILLMAN: Jerry, what is the
8 assumption relative to the fission product inventory
9 or to, if you will, origin run for the core under
10 consideration? How did -- 2,500 megawatt cores
11 around 15 "B" billion curies, fission products plus
12 actinides plus transuranics. In your earlier slides
13 I don't think you were being slick, I think you were
14 being accurate, but it sounded like slide 28, not
15 too hard to put this plumbing experiences. You get
16 any number of those curies, you've got thousands of
17 R per hour on the interior coating of the piping,
18 and approaching that piping is deadly.

19 MR. BETTLE: Yes.

20 MEMBER SKILLMAN: So I'm wondering on
21 your slide 32, what is the assumption regarding the
22 original isotopic inventory? Where do you start?

23 MR. MONNINGER: I think, you know, from
24 other countries and from our internal discussions,
25 you know, from the fission product at the end of

1 life it would decay some. But there's a general
2 thought that somewhere around 10 percent of the
3 source term would then be hitting the filter.

4 MEMBER SKILLMAN: Would leave
5 containment.

6 MR. MONNINGER: That would potentially
7 be the expectation, 10 percent of the source term
8 would be available to the filter and a
9 decontamination of approximately 1,000 is ballpark
10 of what has been considered internationally. So
11 it's not the entire core, it's probably a release
12 somewhere on the order of 10 percent or so. And we
13 would look at various calculations to see the amount
14 and quantity of core debris released to the
15 containment, and what happens with a body of water
16 on top of that, et cetera.

17 MEMBER SKILLMAN: We're talking about
18 severe accident management.

19 MR. MONNINGER: Yes.

20 MEMBER SKILLMAN: And that suggests to
21 me actions in maybe the 72-hour to 120-hour range,
22 not in the 30-day to 90-day range. This is
23 suggesting to me something that is unfolding and
24 individuals are taking action right now. And that
25 would say your isotopic burden is on the greater

1 side than 10 percent, it's up in the 50 percent, 60
2 percent, not at the 10 percent level.

3 MR. MONNINGER: We have done some of the
4 calculations in looking at what is available for
5 release within the drywell in particular.

6 MR. DENNIG: I think that question will
7 fit in well with the Research presentation on their
8 MELCOR runs.

9 MEMBER CORRADINI: They've passed it
10 down the chain.

11 MR. DENNIG: I mean, we can wing it here
12 or let them answer.

13 MEMBER SKILLMAN: I know what it looks
14 like when you're up close and personal and I know
15 what those levels look like.

16 MR. MONNINGER: So the other thing to
17 keep in mind is, you know, the concern potentially
18 with the filters and the plate-out of the fission
19 product and sources.

20 I think the other thing to keep in mind
21 is without the filters they are directed to vent the
22 exact same source term and you will have the same
23 plate-out within these pipings. And if you don't do
24 the venting there are also procedures for sprays and
25 recirc and pumping from the suppression pools to the

1 sprays.

2 So I think irregardless of the filters
3 there could be considerable source terms throughout
4 the entire reactor building. Whether it's just
5 shine through the reactor or whether it's the filter
6 in which they would do with the unfiltered vent, or
7 whether it's taken recirc from the suppression pool
8 of highly contaminated water throughout the reactor
9 building to inject into the spray.

10 So you know, I think we appreciate the
11 concern but we think there are also many other
12 scenarios that represent that same concern.

13 MEMBER SKILLMAN: Thank you.

14 MR. FULLER: This is Ed Fuller from the
15 Office of Research. You'll see later some
16 discussion of not only filtering or venting I should
17 say but also putting water on top of the core debris
18 that might exit the vessel.

19 And if you look at core melt progression
20 analyses you see that the preponderance of the
21 fission product releases that are coming out during
22 the period where the vent paths would actually be
23 effective, you would pretty much have the volatile
24 fission product inventory.

25 Any of the less volatile material would

1 be not tending to come out until you had core
2 debris-concrete interactions. And if you had such
3 core debris-concrete interactions the chances are
4 pretty high that you would have bypass pathways
5 develop and that would render the venting or
6 filtered vents ineffective, relatively ineffective.

7 So in terms of the inventory that one
8 would expect to go through the vent pathways I think
9 it's not 10 percent of the entire fission product
10 inventory in the core, it's a lot less than that.
11 Granted there's still a lot of decay heat that you
12 need to deal with, a lot of radioactive material
13 that you would need to deal with, which suggests to
14 me at least that you would need some sort of shields
15 around these pipes going to the -- toward the stack
16 or wherever.

17 MEMBER SKILLMAN: Thank you.

18 MR. BETTLE: Okay, onto option 4.

19 MEMBER ARMIJO: Jerry, before you leave
20 that. Just go back. If that same system had been
21 at Fukushima and those plants, I'm trying to think
22 faced with the same challenge how much better off
23 would we have been? It would have encouraged
24 earlier venting, at least I think it would, but if
25 the valves didn't have power, couldn't be opened.

1 MR. BETTLE: Then the rupture disk would
2 relieve and --

3 MEMBER ARMIJO: Set the rupture disk at
4 a low enough pressure.

5 MR. BETTLE: Yes. And there seems to be
6 some variance.

7 MEMBER ARMIJO: It would be totally
8 passive then.

9 MR. BETTLE: Yes. Anywhere from, what
10 do you say, containment design pressure to 120-140
11 percent is typically what a lot of them --

12 MEMBER ARMIJO: Set it to zero. Anyway,
13 you can go low pressure so it would just take care
14 of itself.

15 MR. BETTLE: Yes.

16 MEMBER ARMIJO: And you didn't need any
17 power.

18 MR. BETTLE: Right. And that's where
19 you get into the, you know, the rupture disk opens
20 and it just carries on for 24 hours without any
21 operator action.

22 MEMBER STETKAR: I mean, if you look at
23 the European designs they --

24 MEMBER ARMIJO: You don't have to do any
25 flow or any chemistry inside that tank, or anything

1 has to be activated?

2 MR. BETTLE: Not to that point. Beyond
3 that eventually because of the heat and the decay
4 products you're going to steam off a little bit more
5 of that water. Initially you'll start out cool,
6 you'll condense some of the steam coming in. The
7 level will rise a little bit and it'll start
8 essentially boiling off and the level will drop.

9 And you can size depending on how big
10 you want that tank to be, or you can stand it to be,
11 you get at least, typically at least 24 hours but
12 you could go longer. You'll have separate tanks on
13 the side that you can open a valve and replenish the
14 water that's been steamed down and also the
15 chemicals that were in there, kind of like recharge
16 it. And subsequent to that time it probably will be
17 good for several more days without further
18 intervention.

19 MR. DENNIG: A general criteria is that
20 it will be passively operable for 24 hours without
21 active --

22 MEMBER STETKAR: General criteria where?

23 MR. DENNIG: In the foreign reactor.

24 MEMBER STETKAR: Not necessarily all of
25 them. They have manually isolated, at least the

1 designs, some of the designs I've seen they keep the
2 rupture disk manually isolated. They have local
3 manual mechanical reach rods such that you don't
4 need either ac or dc power to operate the valves but
5 they have procedures about when to un-isolate the
6 rupture disk. Because it's not clear --

7 MR. DENNIG: Point Lepreau doesn't have
8 a rupture disk.

9 MEMBER STETKAR: That's --

10 MR. DENNIG: -- running with the valves
11 closed.

12 MEMBER STETKAR: But I mean you're --
13 the point is that they've designed the system so
14 that they don't require electric power. They can
15 be, you know, they're motor-operated valves but
16 they've put long reach rods out through the shield
17 so operators can actually get there and control the
18 release, you know, mechanically, manually.

19 MR. MONNINGER: If you look what the NRC
20 did for the ABWR, the advanced boiling water
21 reactor, there's a rupture disk there. There also
22 is a valve and that valve is normally open. And
23 it's designed to be operable to be closed following
24 severe accidents. So for what it's worth that's
25 what we did for the ABWR.

1 MEMBER ARMIJO: Yes. So my question was
2 really based, you know, don't give yourself credit
3 for the improvements that we're trying to put in
4 through the orders. With this system it's passive
5 enough that it would still have worked even with all
6 the things that didn't work at Fukushima. And I
7 guess it's the rupture disk and you don't have to do
8 anything actively to make the filter continue to
9 work for the duration that's important.

10 MR. MONNINGER: I think the notion is if
11 those two valves from the drywell were normally open
12 and then it's the rupture disk then yes.

13 MEMBER ARMIJO: And there's no rupture
14 disk on the wetwell vent?

15 MR. MONNINGER: No.

16 MEMBER ARMIJO: Just there.

17 MR. MONNINGER: Yes. But then you've
18 got, you know, if this did rupture you would have --
19 you've got your vacuum breakers that go back
20 through. You have a pathway from your suppression
21 pool --

22 MEMBER ARMIJO: But you get no scrubbing
23 in from the wetwell though.

24 MR. MONNINGER: Well, it would blow down
25 through the SRVs into your suppression pool, come up

1 and then this goes back to the vent pipe, right.
2 Your vacuum breakers allow the air to transfer back
3 from the suppression pool atmosphere to the drywell
4 and then you can go out through your rupture disk.

5 MR. BETTLE: Until the core comes out of
6 the bottom of the reactor.

7 MEMBER ARMIJO: Okay. So it would have
8 done some good had it been at this -- something like
9 this at Fukushima without any power would have done
10 some good.

11 MEMBER STETKAR: I think, yes,
12 mechanical reach rod depending on, you know.
13 Incentive to vent earlier, basically, I think is the
14 thing that it would have.

15 MR. MONNINGER: You could argue either
16 way. You could argue because you hear about some of
17 the political considerations in venting. Who knows,
18 maybe they would have gone in and tried to close one
19 of these valves. Who knows what they would have
20 done? You can argue it.

21 MEMBER STETKAR: Well, but that's what
22 I'm talking about in terms of the philosophy of once
23 you install one of these things how does the basic
24 accident management philosophy change, or does it?
25 Because if there's an overriding political

1 consideration that thou shalt not release a single
2 microcurie then it doesn't make any difference
3 because the operators will not do that.

4 MR. DENNIG: If you have an exposed
5 rupture disk pretty much everybody has come to terms
6 with the fact that that's the pre-approved relief
7 pressure. You know, everybody knows it's going to
8 go at that point.

9 MR. MONNINGER: There's also a notion
10 that the release through the filter is more or less
11 equivalent to what you would have from leakage
12 through penetration seals, et cetera.

13 MEMBER BANERJEE: This filter is just a
14 pool, right?

15 MR. BETTLE: It's a very engineered
16 pool. That's why you have the multi-Venturi or the
17 nozzle baffle plate, impingement plate system that's
18 supposed to be much more effective for removing the
19 --

20 MEMBER BANERJEE: But it just makes
21 smaller bubbles.

22 MR. BETTLE: Yes, higher velocity
23 smaller bubbles.

24 MR. MONNINGER: And tortuous pathways.

25 MR. DENNIG: There are two things that

1 happen in the Venturi as I understand it. Number
2 one, you use a rectangular throat in the Venturi,
3 that seems to be the best way to do things. You
4 have multiple levels of injection in the Venturi on
5 all sides. And what it does is -- and the other
6 thing that's important is the relative velocity of
7 the fluid into the gas as far as -- the idea is to
8 have something that will under most conditions
9 maintain that coverage of that throat while the gas
10 is going through.

11 And there's also a phenomenon that is in
12 the literature and is talked about by AREVA where
13 there are like films that break off. It forms
14 liquid films as opposed to a droplet for trapping
15 particles.

16 And then the last thing is that in both
17 the Paul Scherrer design and the AREVA design, the
18 AREVA design ends in like a ram's head. It comes up
19 and hits a surface and goes down, and in the PSI
20 design it has a series of plates like an impactor
21 for taking things out. So that's another part of
22 it. So that whole regime, that whole thing, that's
23 how it's supposed to work.

24 MEMBER BANERJEE: So the gas goes up
25 this baffle pathway.

1 MR. BETTLE: Yes. That way it allows
2 you to have a much more compact filter because the
3 bubble rise, a very -- so it makes sure all the
4 bubbles are small and they have a very tortuous path
5 up, to wend their way up through.

6 MEMBER BANERJEE: And the flow comes in
7 into a manifold with multiple Venturis on it?

8 MR. BETTLE: Yes.

9 MEMBER BANERJEE: This is an old
10 chemical plant design then?

11 MR. BETTLE: Yes, yes.

12 MEMBER BANERJEE: Okay. I know how it -
13 - yes. They use exactly these systems for emergency
14 release of chemical reactors.

15 MEMBER CORRADINI: That's what I was
16 going to say, it's a loss prevention design, right?
17 Off of a reactor.

18 MEMBER BANERJEE: I have a picture in my
19 book.

20 MR. MONNINGER: The thought would be
21 that the staff, if this was one of the
22 recommendations, we would not specify the particular
23 design. You would specify the performance
24 attributes and however the industry wanted to design
25 or meet those performance attributes, that would be

1 up to them to propose and demonstrate.

2 MEMBER BANERJEE: But you would --

3 MEMBER ARMIJO: Isn't there a philosophy
4 that goes with this equipment of early venting that
5 you would kind of push in the management guidelines?
6 That says -- that really makes people rely on that
7 thing.

8 MR. DENNIG: The virtue I guess, one way
9 to put it is that it is not very sequence-sensitive.
10 So whatever is happening, this is outside the
11 containment and it will do its thing. And you don't
12 have to worry about where you are even in terms of -
13 - if it's passive even in terms of the pressure.

14 MR. MONNINGER: Regarding early venting
15 there is a proposal in to the staff from the BWR
16 Owners Group to explicitly look at that, to look at
17 changes to the emergency operating procedures/the
18 SAMGs. If you look at the current EOPs, you know,
19 Rev 4 in the staff's evaluation, the notion of
20 venting is at a last-ditch resort. So it's, you
21 know, and the venting pressure shall be at the
22 highest, highest, highest possibly ever allowed. So
23 that is the mentality.

24 MEMBER ARMIJO: That's what worries me,
25 that whole mentality with this system.

1 MR. MONNINGER: Right, but you can
2 change the framework. Industry has proposed to
3 change that framework for early venting but the
4 filter isn't part of that currently.

5 MEMBER ARMIJO: Right. Okay.

6 MEMBER POWERS: When you think about
7 these designs, mitigate releases during a severe
8 accident such that we're thinking about here, do you
9 think about a heat load on that upper head still and
10 the failure of your seals for the upper drywell
11 head? Or maybe more generally just the whole
12 possibility of bypass through penetration in the
13 containment.

14 MR. MONNINGER: I think you would have
15 to. I think one of the things -- not to talk about
16 MAAP analysis but to talk about the MAAP analysis,
17 they would postulate the one containment failure,
18 then the second, then the third. You know, starting
19 with liner failure and eventually the upper seals
20 going away or penetrations, et cetera.

21 Dependent upon how you operated this
22 thing if it was open and kept open your forcing
23 function, your driving pressure would essentially be
24 limited to the head of water there versus a strategy
25 that is keeping your containment pressure between 40

1 and 60 pounds, you know, and the degradation of the
2 seals associated with that versus the head of water
3 there. I think it would be different.

4 MEMBER POWERS: I mean, I personally
5 have no idea what actually fails in the seals,
6 whether it's a dose embrittlement or actual
7 squeezing amount of pressure, something like that.
8 It strikes me that that's the tradeoff that you --
9 you kind of have a baseline release going on because
10 of those seals and the penetrations. Mark I's tend
11 to be very good. Mark III's tend to be very
12 horrible and things like that on those baseline
13 releases.

14 But I mean, Sam asked you how this was
15 going to behave in the Fukushima accident. I think
16 the seal would become problematic and in looking at
17 the Fukushima accidents really had this. That's one
18 of the great auxiliary benefits of drywell sprays is
19 that you can get cooling up in there and push things
20 down and stuff like that.

21 MR. DENNIG: That's one of the reasons
22 to have the drywell vent is because it's the
23 advantageous location to remove heat from the upper
24 vent area.

25 MEMBER POWERS: Yes, that's true.

1 MR. BETTLE: Once you're venting through
2 the top head of containment, you know, you're not at
3 the absolute best position for taking heat out of
4 containment. But you know, you could have points
5 that are at least mid or above the fuel zone in the
6 reactor. So you take that kind of heat off of a lot
7 of the penetrations in there. Maybe not the head
8 itself. You know, it would help, it would seem to
9 help.

10 Slide 34. Option 4, performance-based.
11 This would be each plant performing a site-specific
12 cost-benefit analysis. You come up with a defined
13 source term for the plant and a defined
14 decontamination factor and go through what their PRA
15 and event frequencies are and DF. It would all be
16 custom for each individual plant.

17 MEMBER CORRADINI: Would you have
18 requirements in terms of a diversity of approach?
19 In other words, the one you -- I was reading these
20 kind of ahead of time and the one you highlighted
21 was the third one. Would you consider then they
22 would have to define a large release and then also
23 some sort of frequency with it and a diverse
24 approach to handle it? I'm trying to understand
25 what this means.

1 MR. DENNIG: I think it would start from
2 the presumption of core damage. You wouldn't --

3 MEMBER CORRADINI: So given the
4 presumption of core damage. Then it would be what?
5 A definition of a large release over a cumulative
6 time period and some sort of reliability that -- or
7 some sort of demand you don't exceed it with some
8 frequency?

9 MR. MONNINGER: I don't think we've
10 fully worked it out. One of the potential outcomes
11 of this is, you know, if this was stylized according
12 to our current framework would you really come up
13 with any different result than your SAMA analysis.
14 I mean, essentially this is what your SAMA analysis
15 does, it look at the plant risk profiles. You cost
16 it out, it's site-specific, et cetera. Would this
17 result in anything different unless we went in with
18 some new type of deterministic criteria?

19 MEMBER CORRADINI: Like it must be
20 diverse.

21 MR. MONNINGER: Right. Or you know,
22 some criteria for defense-in-depth, some different
23 type of criteria for containment performance.

24 MEMBER CORRADINI: So, can I say it
25 differently? What you're saying is this sounds good

1 but once you defined it it would probably be status
2 quo. It would essentially degenerate to option 1.
3 That's what I heard you just say.

4 MR. MONNINGER: If you follow the
5 current regulatory process it could easily turn into
6 SAMA analysis option 1 status quo.

7 MEMBER CORRADINI: Should it be site-
8 dependent?

9 MR. MONNINGER: Well, the SAMA is site-
10 dependent to the extent that they do it for the wind
11 patterns, the people that live there, the source
12 terms, the release pathways, et cetera. You know,
13 we could potentially in this approach come up with
14 different types of metrics, et cetera, but then we
15 would be in that type of battle also.

16 MR. DENNIG: And this would be, in
17 talking about the EPRI insights report this would be
18 the place where you would entertain those sorts of
19 things as part of the mix.

20 MEMBER REMPE: You're thinking of using
21 the existing cost-benefit criteria? Are you
22 thinking of another one?

23 MR. MONNINGER: We use -- and this will
24 be a good discussion for this afternoon, the reg
25 analysis. We do use our existing tools, you know.

1 So until we change the tools we crank it through and
2 what comes out comes out. And it's not acceptable
3 to be using it in other regulatory applications. If
4 we think a different regulatory analysis approach is
5 needed here we should be using that in the other
6 approaches. So we would have to use our current
7 approaches. Unless we justify and the Commission
8 approves some other approach.

9 MR. DENNIG: But the variable is the --
10 what's the term. The other considerations that --

11 MR. MONNINGER: Qualitative arguments?

12 MR. DENNIG: Yes, that the Commission
13 has directed that you consider when doing the cost-
14 benefit analysis.

15 MR. MONNINGER: When we do our
16 regulatory analysis.

17 MR. DENNIG: Regulatory analysis.

18 MR. MONNINGER: And that will be
19 discussed this afternoon too, the qualitative part.

20 MEMBER STETKAR: Is there some subtlety
21 in option 4 that I'm missing? This strictly says
22 performance-based. I noticed it doesn't say risk-
23 informed performance-based. And you were careful to
24 say that you would presume core damage. So you're
25 presuming that option 4 has no information about

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 frequency or --

2 MEMBER SHACK: Makes the cost-benefit
3 analysis a lot easier.

4 MR. MONNINGER: I don't think we've gone
5 that far in our thinking on it. I think we would be
6 challenged, you know, to do that.

7 MEMBER POWERS: It looks to me like the
8 DFs selected for the foreign filtered vent systems,
9 1,000 for the aerosol and 100 for the iodine is
10 based on what you can do reasonably in engineering
11 the system. When you say plant meets a defined DF
12 or a defined source term is that what you're talking
13 about or would you be looking for something more
14 closely tied to the Part 100 kinds of thinking?

15 MR. MONNINGER: You know, and I wouldn't
16 say the group has consensus because we haven't had
17 that level of discussions. I don't think we would
18 necessarily tie it to Part 100. I think it would be
19 more on the lines of what is traditionally looked at
20 in PRAs risk assessments, severe accidents.

21 MR. DENNIG: The underlying idea is to
22 set up a target, talk about how you're going to meet
23 it. That's the basic concept. And we start with
24 specifying a decontamination factor and that would
25 apply to the -- presumably to the whole plant. And

1 the filter --

2 MEMBER POWERS: I mean, that aspect of
3 it I like.

4 MR. DENNIG: And we go from that.

5 MEMBER POWERS: I'm including applying
6 it -- treating the plant as kind of a black box and
7 saying this is the DF I want. I would say that's
8 more consistent with the Part 100 philosophy than
9 coming in and saying your filter has to get a DF of
10 1,000 on aerosols. Because you get into --

11 MR. DENNIG: Yes.

12 MEMBER POWERS: You put a constraint on
13 design and you disallow certain -- or disincentivize
14 certain activities that might be beneficial when you
15 do that.

16 I love Part 100 because it is really a
17 technology-neutral kind of regulation when the
18 regulators played the role of here's what I want. I
19 don't care how you get it, give me this. And in the
20 sense that you can get that idea. And certainly
21 saying I want a DF of this much for the plant and I
22 don't care what the individual parts are is
23 consistent with that.

24 MR. MONNINGER: So one of the thoughts,
25 if we've done 90 percent of the work in looking at

1 options 2 and 3, you know, it would be more on the
2 order of 10 percent for option 4. One of the
3 thoughts was it would be some type of rulemaking
4 activity, maybe some type of ANPR or proposed
5 rulemaking.

6 It's sort of a different type track that
7 we would pursue option 4 versus -- and you'll see it
8 within the reg analysis. We haven't tried to cost
9 out option 4 at all. It's if you want to do
10 something different, you're not comfortable today
11 making a decision for options 2 and 3, should we do
12 something at maybe a slower pace through rulemaking
13 and get, you know, consider plant-specific factors.
14 So it's not as comparable to options 2 or 3.

15 The thought is if options 2 or 3 were
16 potentially supported by the staff or the Commission
17 they would more likely be orders. Option 4 would,
18 if it was supported by the staff or the Commission
19 be more in line of a rulemaking.

20 MEMBER POWERS: Always in these filter
21 systems, I mean just knowing how people design
22 filter systems they get very focused on the system
23 itself and they forget that there are many slips
24 `twixt the release and the outlet there. And there
25 are lots of potentials for bypassing filter systems

1 and things like that. So a more comprehensive
2 examination embodied in a performance-based approach
3 always looks much more attractive to me than looking
4 at a pipe and a filter no matter how good I think
5 that filter is.

6 MR. DENNIG: Again, without introducing
7 some additional factor the subject of putting
8 filters on plants has come up before. And if the
9 technology and the cost doesn't factor into things
10 then we're doing, you know, we're back at looking at
11 concepts of internal mechanisms and external
12 mechanisms. So we're kind of back there in looking
13 at the whole picture.

14 MR. BETTLE: And when you look at the
15 plant-specific, you know, there's some other
16 factors. Is this something that's just a one-time
17 shot evaluation or over time if you're doubling the
18 population or the value of the property around the
19 plant, or you add another operating unit there, you
20 know, and you have to assume simultaneous severe
21 accidents is that going to change what you need to
22 have? Put a second unit there, that puts you over
23 the line and you've got to put filters on both of
24 them. Those would be some of the stuff that I think
25 you'd have to consider with a site-specific

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 analysis.

2 Okay. Slide 35. Office of Reactor
3 Research has performed some modeling. We need to
4 look at some representative cases to see what kind
5 of releases we get to evaluate the options. They
6 did a number of cases. We didn't look to explore,
7 you know, worst case or best case, just that we had
8 some representative scenarios. And also there were
9 some additional cases run as sensitivity to get a
10 little bit better understanding of what we were
11 getting for results.

12 We used MELCOR calculations. These were
13 used in SOARCA and they also have done some modeling
14 of the Fukushima situation to see how well it would
15 track with what the MELCOR would give you.

16 And then they did the MACCS calculations
17 for venting with and without a filter for what you'd
18 get offsite. So I guess at that point the Office of
19 Reactor Research will continue.

20 CHAIR SCHULTZ: Thank you, Jerry. At
21 this time I'm going to call a break for the meeting.
22 I would like to warn everyone that we are well over
23 schedule.

24 We had scheduled a long lunch break to
25 accommodate a separate meeting that the committee

1 has. I'm going to see if we can shorten up that
2 lunch break so that we can accommodate more for the
3 presentations in the next session because I don't
4 want to take away time that we've scheduled for
5 that.

6 Can we just hold the slide that we just
7 presented on the screen rather than this one during
8 the break? Because this is an excellent
9 introduction to the next phase.

10 With that I'll call a break. I'm going
11 to make the break until 10 past, 15 minutes because
12 it's been a long morning already but please be back.
13 We will start at 10 past 11.

14 (Whereupon, the foregoing matter went
15 off the record at 10:53 a.m. and went back on the
16 record at 11:11 a.m.)

17 CHAIR SCHULTZ: I'm calling the meeting
18 back to session. I did want to make one comment.
19 For the benefit of the recorder and for the benefit
20 of an accurate transcript the recorder would like to
21 let everyone know that we're having trouble with
22 people talking over each other and hearing that
23 properly so it can be properly transcribed. So
24 please pay attention to that over the next few
25 hours. We have many people in the room and in this

1 room voices carry and can conflict the transcript.
2 So please pay attention to that for the afternoon,
3 the rest of the morning and the afternoon.

4 With that I'll turn the discussion.
5 Bob, why don't you introduce this next session and
6 then Sud can begin.

7 MR. FRETZ: We have Sud Basu from the
8 Office of Research and Allen Notafrancesco. They
9 are to talk about the MELCOR analysis they
10 performed.

11 Again, as the slide shows or at least
12 what we tried to depict with the slide was the
13 MELCOR analysis was used to help us I guess begin
14 the process of informing our regulatory analysis.
15 And so Sud would like to talk about some of the
16 cases that they ran to help us in that aspect.

17 CHAIR SCHULTZ: Thank you. Next slide.

18 MR. BASU: Thank you, Bob, and thank
19 you, Mr. Chairman. In fact, if we can go back to
20 the slide that was projected I can cut back on a
21 couple of slides after that. That'll work, right?

22 So I want to show you MELCOR
23 calculations that were informed by SOARCA insight
24 and Fukushima insight. And these calculations
25 involve a number of prevention and mitigation

1 features and measures, a combination thereof that
2 are actually involving the options, the four options
3 that you had seen earlier in previous slides.

4 So with that I'm basically going to skip
5 to the -- skip to slide 38, talk about what analyses
6 we have performed and what -- a subset of which
7 we're going to show you here.

8 So filtered vent MELCOR analyses. We
9 looked at accident sequences that were informed by
10 SOARCA and Fukushima. Specifically we looked at the
11 long-term station blackout.

12 By the way, most of these slides are
13 repeat slides from the September 5th meeting so I'm
14 going to go through as quickly as I can. And if you
15 have questions by all means interrupt me and I will
16 respond.

17 MEMBER SHACK: Isn't the 16-hour battery
18 life a little generous?

19 MR. BASU: Yes, it might be thought that
20 way. Now, if you look at the SOARCA we used very
21 conservatively 4 hours battery life. In Peach
22 Bottom though the battery emission time is actually
23 8 hours.

24 We have reason to believe that with the
25 new mitigation measures and severe accident measures

1 that may be coming out it may be amenable to a
2 longer battery life, battery emission time. And 16
3 hours was picked by us as the best case but we
4 showed you in the September 5th meeting that the
5 RCIC sensitivity with 4 hours and 8 hours really,
6 you know, does not change the overall bottom line of
7 our calculation and insights therein.

8 MR. MONNINGER: This is John Monninger.
9 Maybe I could throw something in.

10 One of the things we are looking at is
11 the timing and what is necessarily more bounding.
12 Is it a shorter RCIC time or is it a longer RCIC
13 time? Or is it a longer time to core damage?

14 You know, one of the thoughts is if the
15 time to core damage, core ex vessel, et cetera, is
16 earlier the suppression pool maybe isn't at as high
17 of a temperature versus, you know, putting until you
18 drain the RWST and then you have 12 hours of decay
19 heat into the suppression pool and you have less
20 scrubbing by the time it hits it.

21 Other issues that impact for the long
22 term are the longer term your transient is out you
23 also have the potential that you have added more and
24 more water to your suppression pool. And as the
25 level goes up eventually you lose that wetwell

1 venting capacity. So it's not quite clear in terms
2 of looking at filtered vents, in terms of looking at
3 the potential impact on the environment or land
4 contamination whether it's better or worse to look
5 at early severe accident or a later severe accident.

6 MR. BASU: So we kind of bounded within
7 a range from 4 hours to 16 hours. We looked at
8 that. That's in terms of the battery time of the
9 RCIC.

10 We did look into other sensitivities
11 like the flow rate and timing and the wetwell versus
12 drywell. In fact, two cases that I'm going to show
13 you this time, they were not elaborated in the last
14 presentations of the drywell venting cases.

15 So, going into 39, giving you the punch
16 line. And I'll sort of show you some thoughts to
17 support these. Basically what it says is the water
18 on the drywell floor is needed to prevent liner
19 melt-through.

20 This is not a new finding. We have
21 actually concluded this back in the early nineties
22 in connection with the liner melt-through failure or
23 liner melt-through study. The MELCOR calculations
24 that we have presented and are going to present here
25 basically confirms this, that you need water on the

1 drywell floor to prevent liner melt-through.

2 And incidentally if you have water on
3 the floor it does scrub the fission products and
4 reduces the drywell temperature at the same time.
5 So there is some beneficial effect of that.

6 Venting on the other hand, this is the
7 other mitigation measure if you will. It prevents
8 overpressurization failure. And we're making a
9 statement here. And you'll see later on why this is
10 -- wetwell venting is preferable to drywell venting.
11 Wetwell venting of course gets the benefit of full
12 scrubbing whereas the drywell venting doesn't. So
13 that way it is more preferable.

14 However, you need a combination of both.
15 If you do not have venting you are going to then --
16 that's going to result in overpressure failure. If
17 you do not have water on the drywell floor it's
18 going to lead to melt-through. So you need a
19 combination of both and that's what basically we
20 concluded through our analysis.

21 So the nodalization, the MELCOR
22 nodalization that we have and you have seen this as
23 well, it comes from the Peach Bottom SOARCA study.
24 There's nothing new there. If you look at the
25 containment nodalization that shows you the various

1 flow paths, particularly for venting through drywell
2 and through wetwell.

3 I think there was a question in the last
4 session about what if we have different nodalization
5 and particularly in the reactor building
6 nodalization. If you look at the reactor building
7 nodalization these are high volumes so, you know,
8 I'm really not sure where the nodalization is going
9 to affect the overall outcome in an appreciable way.

10 So looking at the -- going to slide 41,
11 looking at the results. Again, these were shown in
12 the previous meeting. There's nothing new there on
13 slide 41.

14 I had an IOU from the last meeting about
15 why the venting cases are leading to early reactor
16 pressure vessel failure. And if you look at also
17 the hydrogen production in the next slide -- not the
18 next slide, slide 43 -- you'll see early venting
19 cases are producing also high quantity of hydrogen.

20 And these are related. What's happening
21 with the early venting, you are actually decreasing
22 the drywell pressure and that's going to impact the
23 accident progression in the vessel to increase
24 steaming. That's going to then lead to clad
25 oxidation and hydrogen production, higher melt

1 temperature and consequently the higher the vessel
2 temperature leading to earlier failure. So that's -
3 -

4 MEMBER CORRADINI: So that's a detail
5 that's important. Just so understand. So, the
6 communication between -- in the calculation, the
7 communication between the vessel and the drywell is
8 such that because of the venting you're lowering the
9 pressure.

10 So what's the flow path -- what is the
11 flow path out of the vessel? What is the -- I don't
12 want to say assumed. What is the model flow path
13 between the vessel and the drywell in that case?
14 It's not through the SRVs. It is? It is the SRV?

15 MR. BASU: Yes, that's correct. Okay,
16 so the two cases that I want to spend a little more
17 time on, these are the two cases that I did not
18 elaborate on in the last presentation, last meeting,
19 case 12 and case 13. Both are drywell venting
20 cases. Case 12 is only drywell venting whereas case
21 13 is the drywell venting with drywell spray.

22 The way we did these two calculations in
23 the MELCOR space is we actually disabled the SRV's
24 stack-open mechanisms so as not to route the flow
25 through the wetwell vent path. So that should have

1 led to main steam line rupture ahead of the vessel
2 failure. And this is what you will see in the --
3 I'm sort of going all the way to slide -- while I
4 don't have the slide number here printed I think
5 it's the second plot of drywell pressure. Okay.
6 No, next one, next one.

7 Okay, so you see for case 12 and 13
8 we're getting the main steam line creep rupture
9 ahead of the vessel failure. So that's the
10 difference between the two cases, the drywell
11 venting cases versus the wetwell venting cases.

12 Now, we could have actually simulated
13 the drywell venting cases in a manner similar to the
14 wetwell venting cases but that would have required a
15 much more involved workaround with MELCOR and some
16 of the models in MELCOR.

17 And again, at the end it would not have
18 made any difference in terms of the overall
19 findings. So, if I can go to the next slide that
20 shows you the -- and I'm talking cesium release as
21 just an indicator.

22 MEMBER CORRADINI: Sud, why don't I just
23 stop you because I'm trying to take your four tables
24 with your two figures. So can I just say it back to
25 you? I'm still back on your first observation, or

1 the question that was asked of you and you're
2 explaining which is hydrogen production goes up and
3 vessel failure time goes down.

4 MR. BASU: A couple of hours.

5 MEMBER CORRADINI: A bit.

6 MR. BASU: Yes.

7 MEMBER CORRADINI: Yes. And they --
8 hydrogen production is connected because you're
9 getting more steam flow out of the core through the
10 hot cladding. And one more time, the vessel -- I'm
11 still trying to understand why you get more steam
12 flow but that's my problem at this point.

13 And then the vessel failure is due to
14 what? You said it and I didn't catch it, I
15 apologize. The change --

16 MR. BASU: Early vessel failure --

17 MEMBER CORRADINI: Yes, earlier.

18 MR. BASU: -- is due to increased
19 oxidation of cladding raising the melt temperature
20 higher.

21 MEMBER CORRADINI: And then when it
22 slumps it slumps --

23 MR. BASU: It slumps and because the
24 vessel head failure is, you know, the creep rupture
25 failure so it depends on the temperature and

1 pressure.

2 MEMBER CORRADINI: Right. Thank you.

3 MEMBER REMPE: Why don't you explain
4 about the steam flow, that there's more steam flow
5 going through. What you said was why you have more
6 oxidation.

7 MR. BASU: Yes.

8 MEMBER REMPE: Could you -- is there --
9 is the pressure in the vessel still at full pressure
10 because you just are lifting the relief valve,
11 right?

12 MR. BASU: Yes.

13 MEMBER REMPE: So why is it --

14 MR. BASU: But it's the delta between
15 the drywell and the vessel.

16 MEMBER CORRADINI: But isn't it choke
17 flow? So it wouldn't matter what the downstream
18 pressure is for the flow rate.

19 MR. BASU: Why is it choke flow?

20 MEMBER CORRADINI: Well, because we're
21 at very high pressures inside the reactor vessel and
22 we're only about tens of psi.

23 MR. BASU: But you're tightly coupled.

24 MEMBER CORRADINI: Well, that's what I
25 was trying to get at. I was trying to understand

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 why they're tightly coupled versus I would think
2 they were uncoupled.

3 MR. BASU: In the Mark I configuration
4 your containment is tightly coupled with your
5 vessel, SRVs and others.

6 MEMBER CORRADINI: But we're still at
7 what pressure is inside the vessel. Very high
8 pressures, yes?

9 MR. BASU: It's at high pressure, yes.

10 MEMBER CORRADINI: So then it shouldn't
11 be affected by the downstream pressure. We're
12 around 1,000 psi in the vessel and only less than
13 100 psi in --

14 MR. BASU: In the drywell.

15 MEMBER CORRADINI: Right. That's above
16 a choke flow limit so it should be just the upstream
17 pressures determining the flow rate. That's what
18 I'm -- what I guess I'm asking is are the SRVs --
19 maybe I should ask the question. Are the SRVs
20 opening more frequently when you're venting than
21 when you're not venting?

22 MR. BASU: If SRV stack-open mechanism
23 is disabled.

24 MEMBER CORRADINI: So they're always
25 opening and closing, opening and closing. Right,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 I'll think about it some more. Thank you.

2 MEMBER ARMIJO: Sud, just before you --
3 could you go back to 44, slide 44?

4 MR. BASU: Forty-four, yes.

5 MEMBER ARMIJO: I'm trying to
6 understand. The case 15 is --

7 MR. BASU: Is a drywell spray, wetwell
8 venting.

9 MEMBER ARMIJO: Right and RCIC. So
10 that's about the best you can do, right? You're
11 doing everything right. You're spraying your
12 wetwell vent and everything.

13 Then case 14 you don't vent at all.

14 MR. BASU: Right.

15 MEMBER ARMIJO: But the head fails, or
16 the head flange fails. But yet you get much more
17 iodine release --

18 MR. BASU: And cesium release.

19 MEMBER ARMIJO: -- in the case 15. Am I
20 reading this wrong?

21 MR. BASU: Yes, and the question came
22 up.

23 MEMBER ARMIJO: Why is that? And the
24 benefit from cesium isn't that much better with a
25 wetwell vent.

1 MR. BASU: No.

2 MEMBER ARMIJO: A factor of 3.

3 MR. BASU: So what's happening is
4 remember the spray is coming on at 24 hours whereas
5 the head flange is opening before that. So, about
6 an hour or so before that in the case of --

7 MEMBER ARMIJO: So, but my question is
8 why don't we get a lot more release, both cesium and
9 iodine, in case 14 than in case 15.

10 MR. BASU: Okay, so if you go back to
11 slide 42. So for case 14 you do not have any
12 venting, correct?

13 MEMBER ARMIJO: Right.

14 MR. BASU: So, the head flange is going
15 to open up at about 26 hours. Right?

16 MEMBER ARMIJO: But it's still bottled
17 up.

18 MR. BASU: Yes, it's bottled up. And
19 you're getting a couple of hours' of benefit of
20 drywell spray there. Whereas in case 15 you are
21 actually opening the vent an hour before the drywell
22 spray is coming on. So you're not having the
23 benefit of any scrubbing for about an hour.

24 MEMBER ARMIJO: That may be true but it
25 sure does not satisfy. Okay, I understand what

1 you're saying.

2 MR. BASU: Okay? So if I can get the
3 cesium release to environment plot. Next one. So
4 these are the cesium release and you have seen
5 these. After 48 hours. And basically what it says
6 there, if you have a case where there's no venting,
7 no spray and that's case 2 with just RCIC it is
8 going to lead to liner melt-through and sort of
9 leading to pretty high cesium release to
10 environment, fairly high in relative terms, relative
11 to the other cases that are shown there. But it is
12 still on the order of, you know, between 1.2 to 1.4
13 percent.

14 CHAIR SCHULTZ: So Sud, did you --
15 you're not presenting case 13 here.

16 MR. BASU: No, that's the next slide.

17 CHAIR SCHULTZ: Okay. I'll wait. Thank
18 you.

19 MR. BASU: So we want to compress now
20 this here with the next slide.

21 MEMBER CORRADINI: Before you do that.

22 MR. BASU: Yes.

23 MEMBER CORRADINI: I'm sorry. So, was
24 this what Sam was asking? Maybe I was still on my
25 first question. So, for the figure you have up

1 there the purple is case 14 where I don't have a
2 drywell vent and yet the cesium release is low. Is
3 that what you were asking, Sam?

4 MEMBER ARMIJO: Yes, I didn't
5 understand.

6 MEMBER CORRADINI: I guess I'm slow to
7 pick up your question. I'm still scratching my head
8 on that one.

9 MEMBER ARMIJO: It may be true but it
10 sure isn't satisfying that the lowest release is
11 when you don't --

12 MEMBER CORRADINI: Is when it's bottled
13 up.

14 MEMBER ARMIJO: Yes, when it's bottled
15 up and you're putting the containment at risk. The
16 spray is helping.

17 MEMBER CORRADINI: But -- I agree with
18 you. But just since Dana is thinking what I was
19 thinking, I was comparing the purple guy to there --
20 where the hell is he.

21 MEMBER ARMIJO: To the best case is
22 black.

23 MEMBER CORRADINI: To the case 7 which
24 is a wetwell vent and spray in it.

25 MEMBER ARMIJO: Yes.

1 MEMBER CORRADINI: Is 7 the black?

2 MEMBER ARMIJO: Seven is case --

3 MR. BASU: Fourteen.

4 MEMBER CORRADINI: No, that's the
5 drywell vent. I'm looking at -- where I'm going
6 with this is in my mind the optimal case of all
7 would be eventually that I would vent through the
8 wetwell and I'd try to moisten up the drywell which
9 is essentially case --

10 MR. BASU: Fifteen.

11 MEMBER SHACK: Fifteen is a wetwell
12 vent.

13 MEMBER CORRADINI: I read that as a
14 drywell vent.

15 MR. BASU: No, no.

16 MEMBER CORRADINI: I'm sorry. Excuse
17 me. I'm sorry.

18 MR. BASU: I apologize. The vent, when
19 it says vent, that's wetwell vent.

20 MEMBER SHACK: But I think the price
21 you're paying for that lower release is that you're
22 pressurizing the drywell head. You're getting your
23 drywell head failure in 14. So you know, you're
24 trading off a release.

25 MEMBER CORRADINI: In 14 you're not

1 venting at all.

2 MEMBER SHACK: That's why you're losing
3 the drywell.

4 MR. BASU: That's why you're losing the
5 drywell head.

6 MEMBER CORRADINI: I understand. So
7 you're making a trade here. So then, just so we're
8 clear, so why is the black higher than the purple?

9 MEMBER ARMIJO: Exactly.

10 MEMBER STETKAR: Is there no release
11 through the --

12 MEMBER ARMIJO: The drywell head has to
13 release.

14 MEMBER POWERS: My understanding is that
15 --

16 MEMBER CORRADINI: We're picking on you
17 because we can't get the Sandia people in front of
18 us.

19 MEMBER POWERS: My understanding is that
20 they're venting prior to spraying for an hour.

21 MEMBER CORRADINI: Okay.

22 MEMBER BLEY: So really we need all
23 these scenarios laid out.

24 MEMBER REMPE: Yes.

25 MEMBER STETKAR: Would anybody actually

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 do that if they had sprays available?

2 MEMBER POWERS: Would anybody allow the
3 drywell pressure to go over the ultimate before they
4 opened up the wetwell vent? Yes.

5 (Laughter)

6 MEMBER ARMIJO: I think it's been done.

7 MEMBER CORRADINI: So then, that's fine.
8 Dana alerted me to my lack of memory.

9 So now I'm opening up the vent early. I
10 have the drywell spray. And therefore the reason
11 I'm not getting more decontamination through the
12 wetwell is simply this pressure well by that time is
13 saturated?

14 MR. BASU: No, you are actually venting
15 without the benefit of drywell spray for about an
16 hour.

17 MEMBER CORRADINI: Okay. And that's why
18 I'm getting most of the black. Okay. Okay, I'll
19 stop for now. Sorry.

20 MR. BASU: So what we want to do is
21 contrast that with the cesium release for the two
22 cases that are here this time to the drywell venting
23 cases, case 12 and case 13 which is in the next --

24 MR. FRETZ: There's an updated slide in
25 your packets.

1 MR. BASU: So I think --

2 MEMBER ARMIJO: That's the one in this
3 little supplement?

4 MEMBER BLEY: Two updated tables.

5 MR. BETTLE: This is Jerry Bettle. As a
6 point of clarification. When you show this as being
7 a release to the environment that's outside the
8 reactor building, right?

9 MR. BASU: Yes.

10 MR. BETTLE: So when they talk about the
11 releases are lower, you're just loading up the
12 reactor building with the release if it's coming out
13 the head. Is that a correct statement?

14 MR. BASU: Say that again?

15 MR. BETTLE: That when you're showing
16 releases to the environment that means outside the
17 reactor building.

18 MR. BASU: Outside the reactor building,
19 that's correct.

20 MR. BETTLE: So when you have a low
21 release coming out of the head you'd be loading up
22 into the reactor building and should that
23 disintegrate later then you'll get the release at
24 that point.

25 MR. BASU: Yes, but any release numbers

1 that you see here are releases to the environment.

2 MR. BETTLE: Right, which is external of
3 the reactor building.

4 MR. BASU: External of the reactor
5 building.

6 MEMBER STETKAR: So the reactor building
7 is perfectly tight.

8 MEMBER BROWN: No, this is outside the
9 reactor building.

10 MEMBER STETKAR: I'm still trying to
11 rationalize why a release from the head to the
12 reactor building isn't a release to the environment.

13 MEMBER BLEY: But what's in the model
14 about the reactor building?

15 MEMBER STETKAR: That's what I thought I
16 just heard him say.

17 MR. BASU: I'm saying that these
18 releases that you see here are releases outside.

19 MEMBER BROWN: Outside the reactor
20 building?

21 MR. BASU: Outside the reactor building.

22 MEMBER BROWN: So the reactor building
23 is open now, it's busted.

24 MR. FRETZ: If you go back to slide 40
25 you can see the flow path from the seals to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 control volume. Go back to slide 40. You see flow
2 path 903, the seals there. That's the flow path
3 through the seals to that control volume, and then
4 it'll migrate to the other control volumes, you
5 know, the spent fuel pool and then out the reactor
6 building.

7 I think what Jerry was trying to
8 highlight, if this is the release to the atmosphere
9 there's a significant source term and operator
10 action issue within the reactor building. Is that
11 the point of?

12 MR. BETTLE: Yes. Plus it's going to be
13 loading up in the reactor building --

14 MEMBER STETKAR: You have to come to the
15 microphone.

16 MR. BETTLE: Yes, if it's leaking out
17 into the reactor building it's going to be loading
18 up in the reactor building. If something happens to
19 the reactor building later that's when the release
20 to the environment will occur. And this graph
21 really doesn't show that.

22 MEMBER BROWN: So this, the graph is
23 representative of the reactor building not being
24 closed up.

25 MR. BETTLE: Exactly.

1 MEMBER BROWN: It's open. The roof blew
2 off or whatever.

3 MR. BETTLE: It's --

4 MEMBER BROWN: If it's outside how does
5 it get out?

6 MEMBER ARMIJO: I mean it's not tight in
7 a typical analysis --

8 MEMBER BROWN: Yes, but that's got to --
9 you've got to have some -- I mean, if it's not tight
10 that's different than having total access. I mean,
11 does that model the reactor building to get it out?
12 Is that what this does?

13 MEMBER POWERS: In a typical analysis
14 when you release that high in a Mark I you typically
15 get a DF of about 2 in the -- from what gets
16 released to what actually escapes into the
17 environment. Around number 2.

18 MEMBER BLEY: And that's sort of what
19 they're showing.

20 MEMBER POWERS: And if you go lower you
21 can get a much higher DF. But typically up around
22 the head at that level you come up with the
23 combination of interception and gravitational
24 deposition release and that gives you a DF of about
25 2. That is about half of what your release goes to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the environment.

2 MEMBER BLEY: So the reactor building is
3 treated like a filter.

4 MEMBER POWERS: It has a very
5 substantial leak rate and I can't remember. I mean,
6 I don't know what they did in these calculations at
7 all but typically I think the -- without blowing out
8 the blowout panels which clearly happened at Unit 1
9 at Fukushima. If you don't blow out the blowout
10 panels I think there's a circulation in there of
11 about 1 volume per hour. I think. But I don't know
12 what you did in these calculations.

13 MR. BASU: Well, it's the same set that
14 was used for Peach Bottom.

15 MEMBER POWERS: Peach Bottom has been
16 analyzed with every code and every approximation
17 since 1974.

18 MR. BASU: We're talking about Peach
19 Bottom --

20 MEMBER BLEY: At least from your results
21 a fair amount's leaking out.

22 MR. BASU: For these drywell venting
23 cases.

24 MEMBER BLEY: Yes.

25 MEMBER CORRADINI: Is there -- if I

1 might just ask since a bunch of us are still
2 unfortunately buried in the weeds. Is there a
3 backup document from Sandia that we can look at so
4 we don't have to keep on asking this stuff?

5 MR. BASU: We have a document that we're
6 --

7 MEMBER CORRADINI: Putting together?

8 MR. BASU: -- putting together.

9 MEMBER CORRADINI: Okay.

10 MR. BASU: It's not Sandia.

11 MEMBER REMPE: And it'll identify the
12 different scenarios and the assumptions?

13 MR. BASU: That's correct.

14 MEMBER REMPE: And present pressure
15 histories for the reactor.

16 MR. BASU: And I see we're putting
17 together a document which will form the attachment
18 to the SECY paper.

19 MEMBER CORRADINI: Okay, that's fine.

20 MR. BASU: That's something that we can
21 share with you.

22 MEMBER REMPE: We're having another
23 meeting, I forgot now, is it in a month or something
24 like that? And so can we have that document or a
25 draft of it before that meeting so that we don't go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 through this again?

2 MEMBER BLEY: Just for scheduling, we're
3 actually writing a letter on this in November?

4 CHAIR SCHULTZ: At the November meeting.

5 MEMBER BLEY: When are we going to see
6 this document? The November meeting?

7 MR. BASU: Before -- well, there is a
8 subcommittee meeting on October 31st I believe.

9 MEMBER BLEY: That's like a week before.

10 MEMBER STETKAR: That's like 2 days
11 before.

12 MEMBER BLEY: Oh, that's right, that's
13 that week.

14 MR. MONNINGER: The various -- there's
15 of course the Commission paper with a bunch of
16 different enclosures. The status of those various
17 documents is in different percentages. So, you
18 know, it's probably 80-90 percent or so. Some of
19 them are less.

20 To facilitate recommendation from the
21 ACRS letter-writing we would have all the intent to
22 give you, you know, the draft paper enclosures to
23 support the discussions --

24 MEMBER BLEY: A couple of days before
25 you want a letter.

1 MR. MONNINGER: Well, the question is
2 how far in advance. The question is how far in
3 advance.

4 MEMBER BLEY: How about now.

5 MR. MONNINGER: Well, today it's not
6 written. The steering committee hasn't even -- you
7 know, realistically the steering committee will have
8 the first version of this on October 16th. And we
9 have to reflect the views of the steering committee
10 prior to getting it to the ACRS. Then there will be
11 a second version that's given to the steering
12 committee. So hopefully the intent would be to give
13 the subcommittee the second draft that we would
14 present to the steering committee.

15 We have to make sure that the staff's
16 recommendation is supported because we're interested
17 not only in your views on the analysis but the
18 staff's recommendation. So we have to make sure we
19 have a pretty firm recommendation prior to giving
20 you that. And that, you know, is in the process of
21 being made now and will become more and more firm as
22 the steering committee sees our documentation and
23 analysis.

24 MEMBER ARMIJO: John, I think we're
25 talking about the Sandia report. It is not likely

1 to change as a result of a staff recommendation. A
2 report's a report.

3 MR. BASU: This is not going to be a
4 Sandia report. It's still an NRC report.

5 MEMBER BLEY: But isn't there a Sandia
6 report behind this that reports this analysis?

7 MR. BASU: No, there is no Sandia
8 report. Sandia has only done the calculations. We
9 are putting together the report.

10 MEMBER BLEY: What's kind of troubling
11 is if you look at the difference between old 48 that
12 we got electronically and new 48 that we got today
13 there's a substantial difference which means things
14 -- people are tweaking things in models that are in
15 a state of flux. And for us to write a letter in
16 November doesn't seem reasonable.

17 MR. MONNINGER: We did mention up front
18 that the analysis is ongoing and we're here to
19 present preliminary results. We could give to the
20 subcommittee documents, you know, enclosure 1 this
21 day, enclosure 2 that day, et cetera. And some of
22 them are much more ripe for the ACRS review steering
23 committee than the rest.

24 MR. RULAND: The staff of course is
25 under extreme schedule pressure to deliver this.

1 And first of all, we're doing our best.

2 Secondly is to remember when I opened my
3 opening remarks I said that the cost-benefit cases
4 were not made. And so the purpose of the MELCOR
5 calculations is to feed into the cost-benefit
6 analyses.

7 And what I would suggest is that
8 regardless of what the analysis shows it doesn't
9 demonstrate that the cost-benefit hurdle was
10 reached. So we are providing this because the
11 Commission in fact directed us to do this. And so
12 we're providing it and of course we need your
13 comments.

14 But ultimately we didn't demonstrate
15 that filters were cost-beneficial, that reached that
16 level. And in fact the qualitative arguments were
17 one of the things that we're going to talk about
18 today. And we're going to be particularly
19 interested in what your opinion is about our
20 qualitative argument.

21 MEMBER CORRADINI: Let me ask then --
22 let me reverse the question we're asking then. So
23 if you can go to slide, I don't know what slide.
24 It's the one with cesium release to environment.
25 After your tables. Back up.

1 So what I take out of this with fuzz
2 since all of this is fuzzy -- so any line I add or
3 subtract a factor of 2 at least -- is that, is kind
4 of what Dana said to me to explain it which is if I
5 don't vent it's going to leak out the top which is
6 un-good. If I do vent at an appropriate time scale
7 I make things better. If I spray and vent it makes
8 things better. And that purple thing out there
9 still gets me crazy. But except for that purple
10 line that succession of things makes sense to me.

11 So then to get to Bill's -- let me ask
12 Bill a question then. So what would have been the
13 person-rem averted have to be to make it cost-
14 beneficial? If 1 percent is not good enough or
15 three-tenths of a percent is not good enough to have
16 person-rem averted what would it have to have been
17 to make it cost-beneficial?

18 MR. MONNINGER: So and we'll go through
19 that some in the afternoon.

20 MEMBER CORRADINI: Okay. So you're
21 holding off.

22 MR. MONNINGER: A lot more would be the
23 potential next slide which would be the venting
24 through the drywell. And you can see, you know,
25 it's a -- you know, it's a factor of 100 greater,

1 the source term through the drywell. And that is
2 one of the concerns with regard to the current
3 procedures do preferentially have venting through
4 the wetwell. There is always the option there to go
5 venting through the drywell and you're directed to
6 vent irregardless of consequences. So if operator
7 access was not available or random failure in the
8 wetwell valves, et cetera.

9 The other scenario is, you know, what is
10 the particular time in the accident where the
11 suppression pool will be flooded up such that the
12 wetwell vent is no longer available and you'd have
13 to use the drywell. And we're not quite sure that
14 we can bound all these various scenarios in the
15 timing, whether the core melt is early, the
16 suppression pool is relatively cool, you have very
17 good scrubbing and you have plenty of room within
18 the suppression pool. You transfer the majority of
19 your source term to the suppression pool and then
20 you can ultimately go to the drywell. Whereas a
21 more bounding -- or realistic or bounding case,
22 whatever, a later scenario where the suppression
23 pool is more heated up, there's less scrubbing and
24 there's the potential that early in the transit you
25 lose the wetwell path.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, you know, there's a significant
2 difference in the releases between wetwell and
3 drywell. And our analysis, even though we ran 31
4 cases, you know, and some of this stuff, it sort of
5 took some of the good work that EPRI did is the
6 timing is about 10 or 12 hours for the flooding up
7 of the suppression pool.

8 Unfortunately we did not do the
9 integrated analysis. We assume one or the other.
10 We didn't, you know, now Monday morning we said wow,
11 if we had to do it again we would do some type of
12 integrated analysis over time that a certain portion
13 of the transient goes through the wetwell vent and
14 the rest of it goes through the drywell vent. You
15 know, we didn't do that.

16 You know, it's obvious to us that maybe
17 that would have been better to do now, but when you
18 do look at the numbers and all the uncertainty, you
19 know, in the end we did the analysis, we did the
20 regulatory analysis and we think what is very
21 important to us will be the qualitative arguments
22 that we will develop.

23 We're not hanging our hat on any one
24 scenario. We think there are scenarios that could
25 be a combination between wetwell and drywell, and if

1 we came in and we said well definitively we think
2 it's going to be 19 hours and it's all going out the
3 drywell we would be challenged. And that's -- it
4 won't be a success path to argue this accident
5 sequence versus that accident sequence versus that
6 accident sequence.

7 MEMBER ARMIJO: But -- I'm sorry, I
8 guess I'm really confused now. Case 3 looks pretty
9 good. That's just case 2 with a wetwell vent and
10 you leave the vent open. And you're saying that's
11 not a real case? I'm talking slide 48. That one.
12 So case 3 is the green line, lower right-hand
13 corner, and it's just the case 2 and leaving wetwell
14 vent open. What's wrong with that procedure?

15 MR. MONNINGER: There's nothing
16 necessarily wrong with it. The question is, you
17 know, if we were to take that accident sequence do
18 we believe that that would represent the majority of
19 the potential challenges to the plant.

20 MEMBER ARMIJO: Fair enough, that's fair
21 enough. You don't know enough yet to say one way or
22 the other whether that's -- but that's what I'm
23 looking for. What's the best we can do with what
24 we've got?

25 MEMBER STETKAR: Well, let me ask you,

1 is it a problem that you just simply don't have a
2 decent level 2 SPAR model for the Mark I
3 containment?

4 MR. MONNINGER: Right. I mean our
5 models are --

6 MEMBER STETKAR: Because we've heard a
7 lot about how much the PRAs are available and used
8 for SAMA analyses and how much they're used. If you
9 had an actual level 2 model you wouldn't be worried
10 about all of this integration or what fractions or
11 which ones might be worse or which ones. You'd have
12 the whole spectrum.

13 MR. MONNINGER: And even then, some of
14 the thought process goes when we do our PRAs, the
15 level 1, 2 or 3's, we're very much focused on the
16 early releases, the doses to the public. You know,
17 there's a general mentality that the earlier the
18 core damage occurs, the earlier release, the more
19 challenging it will be.

20 MEMBER STETKAR: -- release categories.

21 MR. MONNINGER: It's not necessarily
22 obvious that that would be the case for looking at
23 the filters and environmental releases because the
24 population has already been evacuated then. So then
25 you're looking at when is the most challenging time

1 for the filter, the challenging time for the
2 containment. Is it early on or is it later? Is it
3 these protracted Unit 2, Unit 3 scenarios that
4 happened at Fukushima? You know, is that --

5 MEMBER STETKAR: You'd still have
6 release categories.

7 MR. MONNINGER: So Marty Stutzke, and he
8 did do some modeling of containment event trees and
9 CCFPs and we will discuss that this afternoon. But
10 it is a limitation that we do have.

11 CHAIR SCHULTZ: Regardless of whether
12 you move forward with detailed evaluation of the
13 quantitative response it certainly appears that
14 there's some very important information with regard
15 to drywell vent, for example, that ought to be drawn
16 from the analyses that have been performed. Is that
17 going to be part of the documentation and when will
18 that portion be ready for review?

19 MR. MONNINGER: So, the MELCOR portion
20 of it is written. The MACCS portion is still being
21 written. What the staff globally thinks about those
22 two hasn't been pulled together yet. But we know we
23 need to provide that to the subcommittee.

24 CHAIR SCHULTZ: And will it include the
25 discussion, perhaps even more elaborate that you've

1 just provided which is the Monday morning decision-
2 making about how one would do a better analysis to
3 get more informed results about the performance and
4 perhaps severe accident management approaches?

5 MR. MONNINGER: Yes, we definitely could
6 weave that in there.

7 MEMBER BLEY: A very simple question.
8 Is there a slide 41 that has cases 2, 3, 6 and 7? I
9 got two slide 42's and no 41 in my package.

10 MEMBER CORRADINI: There is --
11 electronically there is a 41.

12 MEMBER BLEY: In the electronic one?
13 Okay. I didn't pull that up. Let me pull that up.

14 CHAIR SCHULTZ: Other comments then
15 related to this portion of the presentation? Thank
16 you very much. I appreciate it.

17 MR. BASU: Thank you.

18 MEMBER REMPE: I guess, can we ask again
19 about how soon we can get the report that's just the
20 MELCOR description? I mean, we talked about that
21 it's going to go to some sort of staff committee
22 review, senior whatever, but if it happens the 16th
23 are we going to get it like the 20th of the month?

24 MR. BASU: Okay, John?

25 CHAIR SCHULTZ: On our agenda we're

1 ready to move forward. I'm sorry.

2 MEMBER REMPE: But I had a question
3 again. I didn't get a firm answer of how soon we
4 could just get the MELCOR description report which
5 shouldn't change too much more I would think.

6 MR. BASU: Joy is asking how soon after
7 the steering committee --

8 MEMBER CORRADINI: Blesses it.

9 MR. BASU: -- blesses.

10 MR. MONNINGER: I think the MELCOR
11 report is, you know, it's factual. So there isn't
12 as much sensitivity to that. We do want to though
13 provide a high-quality document to the ACRS. And
14 all our documents of course are always high-quality.

15 (Laughter)

16 MR. MONNINGER: But with that said we
17 should be able to get back, you know, by end of
18 today or tomorrow to give you an ETA. I think it
19 would be more of a notion of release from the
20 particular offices than a blessing from the steering
21 committee for the MELCOR reports.

22 What's more sensitive to us is how we
23 use it, how it plays in our recommendation. You
24 know, the draft Commission paper is much more
25 sensitive to us.

1 MEMBER BLEY: I think we understand that
2 but --

3 MR. MONNINGER: But we should be able --
4 yes.

5 MEMBER BLEY: -- the analysis report so
6 we can see what's going on here.

7 MEMBER REMPE: And the assumptions in
8 the case.

9 MEMBER BLEY: Would really be helpful.

10 MEMBER REMPE: They could expedite that
11 and we could see it very close to after the 16th.

12 MEMBER BLEY: And if we get that too
13 close to the end we just won't have looked at it and
14 we'll have to say something like, well, the
15 qualitative stuff's all right if the analysis was
16 okay.

17 MEMBER REMPE: There were a lot of
18 questions that we couldn't figure out.

19 MR. MONNINGER: We should be able to get
20 an answer on the MELCOR report, you know, by today,
21 tomorrow.

22 MEMBER REMPE: That would be helpful.

23 MR. MONNINGER: Not providing it, just
24 when we would provide it.

25 MEMBER REMPE: Right, and asking them to

1 let you expedite that.

2 MR. MONNINGER: Right.

3 CHAIR SCHULTZ: All right. The next
4 presentation is going to begin. This is a
5 presentation of the MACCS analysis with Tina Ghosh
6 and Nathan Bixler.

7 With regard to this it has been
8 scheduled on the agenda as an hour. We want to
9 maintain the afternoon schedule approximately where
10 we had originally intended. If we need to break
11 this we'll make that -- the presentation before and
12 after lunch we'll make that determination as we go
13 through. We may have to do that. I'm hoping we
14 don't but let's see how it goes. Thank you.

15 MS. GHOSH: Okay, thank you. I'm Tina
16 Ghosh. We asked Nathan Bixler to join us from
17 Sandia. Nate is the -- kind of the MACCS lead for
18 the NRC. In fact, I think the overall lead for
19 MACCS at Sandia. So any code -- work and
20 applications Nate's kind of the lead on. And if we
21 can go to the next slide.

22 MEMBER POWERS: Tina, let me interrupt
23 you and just say that I do work for Sandia
24 Laboratories. I actually know this guy. I shall
25 refrain from comment on his work. Which is superb,

1 by the way.

2 (Laughter)

3 MS. GHOSH: We wanted to start with a
4 brief overview of what MACCS is and what it does.
5 And the reason is that, you know, there's been a lot
6 more attention on MACCS the code that we use for our
7 reg analysis in more recent times. Since Fukushima
8 people have become a lot more interested in level 3
9 consequence analysis-type information. So it's been
10 more recently that a wider audience has gotten
11 exposed to the tool and a lot of questions come up.

12 So we thought this might be a good
13 opportunity just to provide a brief overview of what
14 the code actually does. And Nate will do that and
15 after that I will provide a presentation of what our
16 preliminary MACCS analyses have shown. So if we go
17 to the next slide I'll turn it over to Nate for the
18 overview.

19 MR. BIXLER: Okay. So MACCS2 is also
20 referred to as the MELCOR Accidents Consequence Code
21 System and it's version 2 which is the -- where the
22 "2" comes from at the end. It was developed for the
23 NRC by Sandia as a PRA tool primarily with the idea
24 of being able to use it for analyses like the one
25 that we're doing now. It was used in SOARCA, in a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whole variety of other recent studies.

2 It was first released in '97 and stems
3 from a whole series of codes that were developed at
4 Sandia starting with CRAC, then CRAC2, MACCS, then
5 MACCS2. CRAC was originally developed for WASH-
6 1400. CRAC2 was used in what's called the Sandia
7 Siting Study that was published in 1982, also some
8 other early PRAs. MACCS, the original MACCS code
9 was used in NUREG-1150 and MACCS2 has been used
10 since roughly 1997.

11 The purpose of the code is to estimate
12 consequences generally in terms of health effects.
13 Before you get to health effects you have to
14 estimate doses. So it really does that as well.
15 And it estimates economic impacts in terms of land
16 areas and economic cost.

17 It is the code that's used by the
18 industry as well as by the NRC. There's no
19 alternative code currently available that's used in
20 the U.S. at least to compete with it. So it's used
21 both by the industry and the NRC for evaluations of
22 consequences.

23 Around 2001 we began developing an
24 interface code called WinMACCS that is intended to
25 make it easier to use the MACCS2 code. It assists

1 in creating inputs so it functions as a pre-
2 processor to MACCS2. It also functions as a post-
3 processor. And one of the main reasons for
4 developing it in the first place was to allow for
5 uncertainty, sampling of uncertain input variables
6 to determine how much effect they have on the
7 outcomes. And you may be familiar with the
8 uncertainty analysis that's being done for SOARCA is
9 being used in that mode there.

10 It was reviewed at the beginning of
11 SOARCA by an expert panel who evaluated the way that
12 we were intending to use it for SOARCA and also made
13 suggestions for improvements to the code. And many
14 of those improvements were actually implemented to
15 support the SOARCA study.

16 CHAIR SCHULTZ: What does that make the
17 timing of that peer review approximately?

18 MR. BIXLER: I'm going to guess 2005.
19 Something. Two thousand six maybe. Yes, right in
20 there.

21 MS. GHOSH: And the overall SOARCA study
22 was peer reviewed as well.

23 MR. BIXLER: Right, yes. So there was a
24 separate peer review at the beginning of the work to
25 give us comments on the directions we were planning

1 to take, and then a peer review that -- a group that
2 met and gave us comments along the way as we were
3 conducting the study.

4 Okay, slide 52, please. This is a
5 cartoon that we often use. It really depicts a
6 couple of things. It depicts the ways that MACCS2
7 models atmospheric transport, the mechanisms that
8 are used there. For example, it models plume rise
9 and dispersion and also dry and wet deposition. Wet
10 deposition occurs when it's raining.

11 The figure, the cartoon also shows the
12 dose pathways that are modeled. Those include
13 inhalation. Inhalation is both directly from the
14 cloud or the plume and from resuspension. It models
15 cloudshine, groundshine, deposition under the skin
16 for determining a dose to the skin and ingestion.
17 All of those pathways are modeled. Okay, next
18 slide, please..

19 MACCS2 is divided into three modules.
20 Earlier if you go back to the old MACCS code these
21 were actually three separate codes that were run
22 sequentially. One thing that MACCS2 did was to
23 integrate these three separate codes as three
24 modules so it's easier for the user to use now. You
25 just run one calculation instead of three separate

1 ones.

2 The three parts though are ATMOS which
3 does the atmospheric transport and deposition
4 portion of the calculation. It's not associated
5 with a particular phase as are the EARLY and CHRONC
6 parts of the code. EARLY does the emergency phase
7 which is allowed to last between 1 day and 1 week.
8 Typically for NRC applications we would use the full
9 week to define the emergency phase.

10 It calculates prompt and latent health
11 effects, and those are associated with doses that
12 are short-term and longer lifetime doses to
13 calculate those types of health effects.

14 It treats the types of actions that you
15 would expect to see during the emergency phase which
16 are sheltering, evacuation and relocation. I'll
17 talk more about each of these modules in the next
18 few slides so we'll come back to some of these
19 thoughts.

20 In the CHRONC module of the code we're
21 treating the longer term. Both what's called the
22 intermediate phase which can last up to a year and
23 the long-term phase which can last up to 10 to the
24 10th seconds which translates into about 317 years.
25 But typically we set the long-term phase to be on

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the order of 30 to 50 years. Fifty was used in
2 SOARCA and it's being used in this, the work that
3 we're presenting today.

4 MEMBER ARMIJO: In the SOARCA work, in
5 calculating health effects you used both the LNT
6 model and a threshold model.

7 MR. BIXLER: Yes.

8 MEMBER ARMIJO: Did you use both in this
9 analysis?

10 MR. BIXLER: So far we have only looked
11 at LNT in this analysis. And to support a cost-
12 benefit analysis what you really need are not
13 numbers of health effects or health effect risk
14 although we present those results. What you need
15 are population dose and the offsite economic costs
16 that MACCS2 predicts.

17 So those two pieces would be used in the
18 cost-benefit analysis and they're independent of any
19 dose threshold that you might implement. So I think
20 the thinking here was it wasn't so essential for the
21 purpose of this study to look at the threshold kinds
22 of calculations.

23 MEMBER SIEBER: Do you always assume
24 that there's an inversion layer?

25 MR. BIXLER: Yes, we always assume that

1 there's an inversion layer.

2 MEMBER SIEBER: And so that makes it
3 pretty conservative.

4 MR. BIXLER: Yes, it adds some
5 conservatism, definitely.

6 MEMBER SIEBER: Do you happen to know
7 the percentage of time roughly that there is an
8 inversion versus no inversion?

9 MR. BIXLER: At Peach Bottom in
10 particular? No, I don't know that. I haven't
11 looked into that.

12 MEMBER SIEBER: I used to fly every day
13 so I don't remember seeing that many inversions.

14 MR. BIXLER: Yes, okay. The CHRONC
15 calculation reports the effects of decontamination.
16 These are the types of actions that would be taken
17 during the long-term phase, decontamination,
18 introduction and condemnation. We'll talk about
19 each of those in a little bit more detail later as
20 well. Okay, next slide, please, 54.

21 So looking at the ATMOS model, the ATMOS
22 model again does the atmospheric transport with
23 dispersion, deposition. It's based on a Gaussian
24 plume segment model which is different than a
25 steady-state Gaussian plume model if you're familiar

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 with that distinction.

2 It has provisions for meander which is
3 an expansion of the plume in a horizontal cross-wind
4 dimension and also for surface roughness which
5 causes an expansion of the plume in the vertical
6 dimension.

7 It doesn't specifically treat some
8 things that would exist in reality like irregular
9 terrain, spatial variations in the wind field and
10 temporal variations in wind direction. Once a plume
11 begins to be released it travels in a straight line.
12 So it has that kind of quality to it, that after
13 beginning of release the direction doesn't change.
14 So in that regard it's a single weather tower sort
15 of calculation. It doesn't depend on multiple
16 weather towers. Yes.

17 MEMBER SIEBER: And so you don't
18 consider at all trapping in valleys?

19 MR. BIXLER: No.

20 MEMBER SIEBER: Where people live.

21 MR. BIXLER: No, we don't. That's not
22 part of the calculation.

23 MEMBER SIEBER: So this sort of
24 underestimates the health effect.

25 MR. BIXLER: It could in that situation,

1 yes.

2 MEMBER SIEBER: Right.

3 MR. BIXLER: Okay. There was a study
4 conducted I'm thinking about 5 years ago roughly
5 reported in NUREG/CR-6853 where we compared with two
6 Gaussian puff codes. Those are RASCAL and RATCHET.
7 RASCAL is used in the emergency response center
8 here. Both of those two codes are created by PNNL
9 and they're both based on Gaussian puff models.

10 We also compared with a Lagrangian
11 particle-tracking code from the NARAC group at
12 Lawrence Livermore called LODI which is considered
13 one of the state of the art codes in doing
14 atmospheric transport.

15 The comparison showed that MACCS2 on the
16 average, averaged over a year's worth of weather was
17 within a factor of 2 if averaged around the compass,
18 and within a factor of 3. Generally much better
19 than a factor of 3 but at the extreme factor of 3 at
20 a specific grid location.

21 And that study was done out to 100
22 miles. For the purposes of a lot of the studies
23 that are done with MACCS2 the distance is only out
24 to 50 miles. So that was a bit farther than perhaps
25 we needed to look.

1 Multiple plume segments are allowed in
2 the newest version of the code. We allow up to 200.
3 So you can -- the thinking behind that is to allow
4 the maximum use of the wind data that you have.
5 Usually we have the wind data on an hourly time
6 frame. We can carve up the overall release into
7 hour time segments and the MACCS2 code allows each
8 plume segment to travel in a different direction
9 depending on what direction the wind happens to be
10 blowing at the beginning of the release for that
11 plume segment. So you can in a simple way account
12 for the fact that not all of the plume goes off in
13 one direction and not -- the same group of people
14 don't receive the entire dose. It could travel.

15 MEMBER SHACK: The segment then
16 continues in that straight line through the whole
17 calc.

18 MR. BIXLER: Once it begins it continues
19 but then at the next hour the next plume segment may
20 travel in a different direction.

21 The ATMOS also accounts for plume rise
22 from the initial release height due to buoyancy of
23 the plume, the effects of the building wake in terms
24 of the initial size of the plume and also the
25 potential trapping of the plume in the building

1 wake. It accounts for dry and wet deposition, dry
2 deposition being a relatively slow process, wet
3 deposition being intermittent but a very rapid
4 process for depositing the plume.

5 And it accounts for radioactive decay
6 and ingrowth for up to 150 radionuclides in up to 6
7 generations. Usually we use about 50 to 60
8 radionuclides to do nuclear reactor accidents. So
9 that's more than enough. Next slide, 55, please.

10 Okay, continuing with the ATMOS module.
11 These days what we usually do at Sandia and the NRC
12 has done in the study that we're talking about now
13 is to use MELCOR to generate a source term. We have
14 an interface tool called MELMACCS that digests the
15 plot file produced by MELCOR and extracts all the
16 information you need to run MACCS2 to do a
17 consequence analysis. So it really automates the
18 treatment of the source term. It automates it and
19 is relatively foolproof so that you don't end up
20 with operator error from trying to hand-create the
21 inputs that you need.

22 The met data that are required by ATMOS
23 include wind speed and wind direction at least
24 hourly. And we have now capability to look at half-
25 hourly and every 15-minute time periods as well.

1 You also need Pasquill's stability
2 category. That's a derived quantity that's usually
3 derived from measuring temperature differences in
4 the atmosphere.

5 You need precipitation rate. All those
6 first three bullets are hourly information. The
7 last one is a seasonal, it's four times per year.
8 We use an a.m. and p.m. mixing height. Those are
9 minima and maxima in the mixing heights averaged
10 over a season of the year.

11 There are a number of sampling options
12 that the user can select. Several of them deal with
13 just single weather sequences to look at a specific
14 case. But most of the time we use multiple weather
15 sequences so that we can get statistics on what the
16 plume might do over the course of a year's worth of
17 data. The year's worth of data is intended to be
18 representative of -- it's archive data but it's
19 intended to be representative of the future as well.
20 And that's what we would normally do. Typically
21 these days we're doing about 1,000 weather samples,
22 weather trials to estimate the effect of 8,760 data
23 points that we have in our weather file which
24 represents 1 year, 365 times 24.

25 The outputs from ATMOS include basic

1 things like the dispersion parameters that go into
2 the Gaussian plume equation, χ over q which is a
3 dilution factor and the fraction of material
4 remaining in the plume accounting for radioactive
5 decay and deposition under the ground.

6 We can also get time-integrated error
7 concentrations and ground concentrations at various
8 points along the path of the plume.

9 MEMBER STETKAR: Nathan, are all your
10 meteorological data just sampled independently? The
11 precipitation.

12 MR. BIXLER: They're usually from a
13 single tower at the plant, at the site.

14 MEMBER STETKAR: No, I'm talking about
15 you had 8,760 data points for each of these. Some
16 of them would be correlated in the real world.

17 MR. BIXLER: Yes.

18 MEMBER STETKAR: The storms, for
19 example.

20 MR. BIXLER: Right. Well, these are
21 measuring the data points. So, if there's a real
22 correlation that should be observed in the data that
23 we're using.

24 MEMBER STETKAR: A single sample of all
25 four of those sub-bullets under number 2 or are they

1 four separate samples?

2 MR. BIXLER: Okay, I think I understand
3 the question. What we do is we start -- when we do
4 a weather trial we start at a particular time and
5 then we look at hour by hour what are the data in
6 the weather file. So we're not independently
7 sampling one hour and assuming that it stays that
8 way, we're looking at -- our sample really is
9 selecting an initial time point when the release
10 begins and then looking at the data in the weather
11 file hour by hour.

12 MEMBER STETKAR: But again, under that
13 second sub-bullet you have four different pieces of
14 data. You're saying you sample all four of them at
15 the time that they were reported.

16 MR. BIXLER: Yes.

17 MEMBER STETKAR: Thank you.

18 MR. BIXLER: Yes, exactly. Okay, next
19 slide, 56, please. Okay, now we'll look into the
20 EARLY module, the second module in MACCS2.

21 MEMBER CORRADINI: Just -- I'm sorry.
22 This is a side question. So as you went through
23 ATMOS the basic assumptions are very similar to
24 RASCAL. To a first approximation they're
25 essentially the same.

1 MR. BIXLER: I think that's right. The
2 difference would be RASCAL allows you to have
3 multiple weather towers instead of a single one.

4 MEMBER CORRADINI: I just wanted to make
5 sure because you were comparing it to something much
6 more sophisticated. Something that's in the open
7 for emergency planning that comes to my mind is
8 RASCAL but they're of a similar vintage and type.

9 MR. BIXLER: Yes.

10 MEMBER CORRADINI: Okay, that's fine.

11 MR. BIXLER: RASCAL is a Gaussian puff
12 model which means that you have -- the puff is
13 located by a single point at the center of the puff
14 and it can travel three-dimensionally around the --
15 through the grid as opposed to a Gaussian plume
16 model that is a straight line kind of model. So
17 that's the major difference between the two. Okay.

18 Okay, so EARLY is looking at the
19 emergency phase. And it calculates acute and
20 lifetime doses for each of the pathways that are
21 listed there. The only one that's missing is
22 ingestion. We don't consider ingestion during the
23 emergency phase. We only in fact consider it during
24 the long-term phase.

25 EARLY also calculates the health effects

1 that are associated with those doses which are early
2 injuries, early fatalities and latent health effects
3 both occurrences and fatalities from latent health
4 effects induced by a type of cancer.

5 The doses are subject to several actions
6 that can occur during this time, sheltering,
7 evacuation and relocation. The difference between
8 evacuation and relocation is really the way that
9 those two things are triggered. Evacuation is
10 generally implemented following the declaration of a
11 general emergency at the plant. Relocation is based
12 on exceeding a projected dose. So it would be
13 usually implemented at a later point in time, that
14 evacuation would have the higher priority and be
15 implemented more rapidly, relocation a bit on the
16 longer range of time.

17 MEMBER SKILLMAN: Nathan, how would
18 EARLY, results from EARLY differ for instance if it
19 were applied to Cooper Nuclear Station out in the
20 Midwest in a vast, very low-population area versus
21 Indian Point that is in close to a large urban
22 population?

23 MR. BIXLER: Okay. I haven't talked
24 about it up to this point, in fact, I don't think
25 it's in any of the slides, but part of the input to

1 MACCS2 is what's called a site file. The site file
2 contains the surrounding population on a grid-by-
3 grid basis, so a fairly good detail on where the
4 population are actually located. It also, the site
5 file also contains economic values for the land
6 surrounding the plant. So the value of property for
7 example would be contained in the site file.

8 So those two things, those two
9 categories of information would be very site-
10 specific. In addition, the met file would typically
11 be site-specific. So you'd look at a met file for
12 each of those locations separately.

13 MEMBER SKILLMAN: Thank you, Nathan.

14 MR. BIXLER: Yes. Okay. Outputs from
15 the EARLY module include doses, health effects, land
16 contamination areas and things of that nature. Next
17 slide, 57, please.

18 Now looking into the CHRONC module. The
19 CHRONC module includes the intermediate phase.
20 Typically for NRC applications up to this point in
21 time we have not treated the intermediate phase.
22 We've set the duration to zero and basically skipped
23 over the intermediate phase.

24 But if you include the intermediate
25 phase it's a fairly simple part of the calculation.

1 It's just looking at groundshine doses and
2 resuspension inhalation. Again, not including any
3 treatment of ingestion doses. And the only
4 protective action that's considered is continuing
5 relocation. The people may still be relocated away
6 from their homes if doses would warrant that.

7 The next phase is the long-term phase,
8 typically 50 years in most of the calculations we've
9 done recently. I've seen some SAMA analyses that
10 are based on 30 years so both of those are being
11 used.

12 The dose pathways include everything
13 that's still applicable at that point in time.
14 Groundshine resuspension from things that have
15 deposited and kicked back up into the air and
16 ingestion. So at this point we would pick up the
17 ingestion pathway.

18 The protective actions are based on two
19 criteria, habitability and farmability, habitability
20 being the more important of those two criteria. The
21 actions that would be taken based on those two
22 things are decontamination of land, interdiction of
23 land which would extend beyond decontamination.
24 Decontamination is considered a period of
25 interdiction, so it's the beginning of interdiction

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 but interdiction can follow and continue longer than
2 the decontamination period would take. And then the
3 final option if all else fails is condemnation.

4 Next slide, please.

5 MEMBER CORRADINI: Which you have a
6 payment associated with.

7 MR. BIXLER: Yes. Yes. The
8 condemnation you're saying?

9 MEMBER CORRADINI: Yes.

10 MR. BIXLER: Yes. We would tally the
11 value of the land, of the property that's being
12 condemned in that case, yes.

13 Okay, this is a logic tree or a decision
14 tree for the protective actions that would be taken
15 during the CHRONC module.

16 The first question is is the
17 habitability criterion met initially right after the
18 emergency phase. And if the answer is yes then no
19 actions are needed. People would return to their
20 homes at that point if they're not already at home.

21 MEMBER ARMIJO: What is that criterion?
22 Is it a single number or a number of different
23 things?

24 MR. BIXLER: It's a number in terms of a
25 dose. It's an organ which is usually effective, so

1 it's an effective dose. And it's a time period. So
2 for example, at Peach Bottom the state criterion for
3 habitability is 500 millirem in 1 year, in the first
4 year, and not more than that in subsequent years.
5 But usually the doses tail off in subsequent years.
6 So the way we enforce that is to check to see if
7 anyone would receive more than 500 millirem in the
8 first year after -- beginning at the beginning of
9 the long-term phase. Okay. So, that's what happens
10 if the habitability criterion is initially met.

11 If the answer to that first question is
12 no then the next question is asked and that's can we
13 decontaminate to a sufficient level to restore
14 habitability. And MACCS2 considers three
15 decontamination levels. So it would begin by asking
16 for the lowest level of decontamination is that good
17 enough. And if it is it would do that level of
18 decontamination, population would return afterwards
19 and that would be the end of it.

20 If the answer is no it would
21 sequentially consider higher levels of
22 decontamination up to the highest level that is in
23 the input. And if that's still -- if that's
24 sufficient then it would do that.

25 If not, it will ask the next question

1 which is can I restore habitability by
2 decontaminating plus an initial period of
3 interdiction. And if the answer to that is yes it
4 would first start out by performing the highest
5 level of decontamination and then it would interdict
6 for an additional period of time up to -- the
7 maximum that's allowed in the code is up to 30
8 years. So it would potentially go as far as 30
9 years, usually much less than that, but that's the
10 max allowable. And then after those two things are
11 performed the population would return home.

12 MEMBER CORRADINI: So is this -- are all
13 of these based on the protection action guidelines?
14 So that if I have a long-term dose of greater than -
15 - I can't remember the number, they can't come back?

16 MR. BIXLER: Yes. EPA has the -- EPA
17 PAG has 2 rem in the first year and one-half a rem
18 per year thereafter. And that's what most states
19 would adopt as their --

20 MEMBER CORRADINI: Some states are more
21 restrictive though.

22 MR. BIXLER: Pennsylvania is more
23 restrictive. I don't know if there are others but
24 there may be.

25 MEMBER CORRADINI: So 2 rem in the first

1 year and one-half a rem thereon.

2 MR. BIXLER: Yes.

3 MEMBER CORRADINI: And all these kind of
4 if/then/elses inside the computer thing just
5 basically says what got deposited, where does it sit
6 relative to those protection action guidelines.

7 MR. BIXLER: Yes. Okay, the last thing
8 that's considered if everything up to this point has
9 failed, and there are two ways that it can fail, is
10 -- the first way that it can fail is the
11 habitability can't be met by the highest level of
12 decontamination plus up to 30 years of interdiction.
13 You still can't meet the habitability criterion so
14 we condemn the property.

15 The second way that you can condemn
16 property is if it's not cost-effective. MACCS2
17 makes the decision purely based on economics. I
18 don't know if that's the rule situation or not but
19 that's the logic that's built in is the decision is
20 purely based on economics.

21 MEMBER REMPE: So the user has to then
22 input the worth of the property and then how much it
23 cost for labor?

24 MR. BIXLER: To do the decontamination,
25 yes.

1 MEMBER REMPE: And the user has to be
2 savvy enough to know the hours for the
3 decontamination and the cost of the labor.

4 MR. BIXLER: Yes. There's a period of
5 time needed to conduct the decontamination, a
6 decontamination factor and a cost associated with
7 that. A few other parameters as well but those are
8 probably the primary ones.

9 Okay, next slide, please.

10 MEMBER CORRADINI: But what about --
11 just out of curiosity because -- so if one wanted to
12 look at a sensitivity on the protection action
13 guidelines is there a flexibility to look at
14 different guidelines?

15 MR. BIXLER: These are all user input
16 values, so yes, they can.

17 MEMBER CORRADINI: Just curiosity.
18 Thank you.

19 MR. BIXLER: Yes. Okay, continuing with
20 the CHRONC module. The economic costs that are
21 reported include six items. Yes, I think this is
22 the right slide, 59. The six items are listed here.
23 There's a per diem and lost income cost for people
24 who are evacuated and relocated.

25 Over the longer term if people have to

1 be away from their homes for a longer term there's a
2 one-time moving expense that can include lost income
3 for some number of weeks or whatever it is that you
4 want to include with that.

5 The next category is decontamination
6 labor and materials. The next one is loss of use of
7 property. That's based on kind of an expected rate
8 of return on investment for property that you own.
9 The next one is condemnation of property which is
10 just the value of the property itself. And the last
11 one is in case the accident were to occur during the
12 farming season, the growing season, the value of the
13 crops or dairy products that are lost as a result of
14 the accident.

15 The outputs are doses -- was there a
16 question?

17 MEMBER STETKAR: What's the use of
18 property, for example, if property contained General
19 Motors for example. Is it simply the value of that
20 manufacturing facility and the real property that it
21 sits on, or is it loss of the entire production of
22 General Motors automobiles for some period of time?

23 MR. BIXLER: No, the current model just
24 accounts for the value of the property itself. It
25 doesn't account for any economic activity at that

1 property.

2 MEMBER STETKAR: Okay, thank you.

3 MR. BIXLER: Okay. So the outputs are
4 doses by pathway and organ, latent health effects,
5 and those are usually calculated for a variety of
6 organs and then summed up to get a total, and the
7 economic cost. And as we mentioned earlier you can
8 also get land contamination areas can be output as
9 well which is sometimes considered a subcategory of
10 economic cost.

11 MEMBER ARMIJO: In all of these economic
12 costs is there inflation adjustment in your model?

13 MR. BIXLER: There is not really an
14 inflation adjustment. There's an expected rate of
15 return and there's a loss of value of property due
16 to lack of maintenance. Both of those are a rate.
17 For example, during interdiction you don't maintain
18 property so there's a loss per year. Usually it's
19 20 percent is the assumed loss per year of the value
20 of property.

21 MS. GHOSH: In terms of the input values
22 if we have Census data -- the inflation is
23 different.

24 MR. BIXLER: Okay, yes. Tina makes a
25 good point. We usually would base the calculations

1 on a specific year, a target year, and we would
2 inflation-adjust if we have, for example, if we have
3 2002 economic data, that's what was used in SOARCA
4 and also used in this study, we would inflation-
5 adjust that to a target year when we assume that the
6 accident is going to occur. We would also do the
7 same thing with the population data. So in that
8 sense, yes, they are adjusted.

9 MEMBER ARMIJO: That's what I was
10 getting at.

11 MR. BIXLER: Okay.

12 MEMBER SHACK: But then you do --
13 everything is then expressed in terms of 2012
14 dollars.

15 MR. BIXLER: Yes, exactly. That's
16 right. Okay, next slide, number 60.

17 CHAIR SCHULTZ: Nathan, at this time I
18 think this is a good -- this slide's a good
19 introduction to what is going to follow which is
20 another section of the presentation. You've made a
21 very comprehensive presentation on the descriptive
22 features of the methodology so thank you for that.

23 With that I will call a recess for
24 lunch. And I'm going to ask so that we can start
25 the afternoon well for a sit-down time of 1:30. And

1 I'll bang the gavel at 1:35. Just so everyone knows
2 we will therefore begin at 1:35.

3 (Whereupon, the foregoing matter went
4 off the record at 12:34 p.m. and went back on the
5 record at 1:34 p.m.)

6 CHAIR SCHULTZ: Break is completed for
7 lunch and we're ready to resume the presentation.
8 We are in the middle of the presentation associated
9 with the MACCS code and the second piece associated
10 with that as well. So with that I'll turn the
11 presentation back over to you, Nathan, for this
12 slide.

13 MR. BIXLER: Okay. This is my last
14 slide before I turn it back over to Tina again. And
15 this is just describing some of the standard uses
16 for the MACCS2 code.

17 The first category there is for PRAs and
18 things that are kind of like a PRA, for example,
19 SOARCA we've used MACCS2 for. This type of study, a
20 reg analysis, is something that MACCS2 is very
21 useful for.

22 NEPA studies are used in licensing and
23 license extensions in terms of SAMA and SAMDA
24 analyses. Those are generally done with the MACCS2
25 code.

1 And the last category there is another -
2 - is not an NRC-type activity, it's a DOE activity
3 where MACCS2 is used pretty much throughout the
4 community of DOE facilities to do safety analyses
5 for authorization bases. These are often called
6 documented safety analyses.

7 And then the last bullet there is just
8 pointing out that there's an international usership
9 for MACCS2. I think we're up to 12 countries now
10 including the U.S., 11 international countries plus
11 the U.S. And I've kind of lost track of the number
12 of users but I think there are probably several
13 hundred at this point.

14 One thing I'd like to inject before I
15 turn it back over to Tina is that it was pointed out
16 earlier that there are some situations where MACCS2
17 would give you a conservative result or a non-
18 conservative result.

19 For example, the mixing layer height
20 issue or valleys and a variety of things like that.
21 There are situations where you may get a
22 conservative answer or you may get a non-
23 conservative answer.

24 For NRC applications we use MACCS2 in a
25 role where we're looking primarily at mean results

1 and those conservatisms or non-conservatisms tend to
2 average out, not entirely and not always but they
3 tend to do that. And so the means tend to lose most
4 of the effect of some of those conservatisms and
5 non-conservatisms.

6 Okay, I think with that, Tina?

7 MS. GHOSH: And we can skip this slide.
8 We added some references, that's just for your own
9 reference. We don't have to go through those. So
10 I'll talk now about the analysis which is in
11 progress but I'll talk about our preliminary
12 analyses for the filtered vents.

13 So, in terms of supporting the
14 regulatory analysis, the cost-benefit analysis
15 portion, we used MACCS2 to calculate the offsite
16 population doses which feeds directly into the reg
17 analysis as well as the economic cost.

18 And just a quick note that MACCS for the
19 offsite population doses, it's not only included the
20 public doses, doses to members of the public, but
21 also decontamination workers who are doing the
22 offsite decontamination. Those all get lumped into
23 the offsite population dose.

24 Then in addition to those two metrics
25 that we are feeding into the reg analysis we also

1 looked at a few additional metrics. One was the
2 population-weighted latent cancer fatality risk
3 which we've generally called individual latent
4 cancer fatality risk and the individual prompt
5 fatality risk, and land contamination. Which again
6 the other metrics are dependent on land
7 contamination but we looked at it as a separate
8 metric.

9 And the way we defined land
10 contamination for our purposes is to look at
11 different thresholds of cesium-137 concentration in
12 the soil. And when we get to the results you'll see
13 what that is. That's one way of defining land
14 contamination.

15 And we, for the purposes of reg analysis
16 we do everything out to 50 miles. So for most of
17 these metrics we looked out to a circle of 50 miles,
18 a radius around the plant.

19 The only exception to that is for the
20 land contamination numbers that we're reporting we
21 actually went out as far as we still found some land
22 contamination that exceeded the thresholds. In some
23 cases that's beyond 50 miles that we found exceeding
24 the threshold. So for land contamination the only
25 metric where the results are not limited to 50

1 miles. All the other results are for the 50-mile
2 circle.

3 MEMBER RYAN: What would drive that? I
4 guess the meteorological conditions?

5 MS. GHOSH: Yes, that's right. How much
6 the source term is and the meteorology.

7 MEMBER RYAN: That's fine. I just want
8 to understand what role -- thanks.

9 CHAIR SCHULTZ: And Tina, those are done
10 as Nathan indicated on a best estimate basis or not
11 getting into non-conservatisms associated with the
12 boundaries?

13 MS. GHOSH: Right, yes.

14 MR. BIXLER: For NRC applications we
15 tend to use MACCS2 in a best estimate mode. We try
16 to do the best job we can of matching what the real
17 conditions might be. For DOE analyses, on the other
18 hand, they tend to be very conservative. They're
19 looking at 95th percentile weather and things like
20 that. So those are two different ways of using
21 MACCS. You can use it in either mode, but for NRC
22 applications we tend to try to use it in a best
23 estimate mode.

24 MEMBER RYAN: It's interesting too.
25 Maybe you'll talk about this and if you will I'll

1 wait, but cesium, I understand why it's a marker,
2 it's fairly soluble, it's fairly prevalent and all
3 that and it's a nice marker. Strontium on the other
4 hand is insoluble but it's an important marker. On
5 that side of it there's lots of other individual
6 radionuclides that for one reason or another may
7 rise to prominence in a calculation or in a real-
8 world circumstance. Have you treated any other
9 nuclides or you're really just looking at cesium?

10 MS. GHOSH: Well you know, the analysis
11 itself certainly looked at all of the important
12 radionuclides. I think Nate mentioned typically
13 fifty-something.

14 The reason we focus on cesium is because
15 iodine of course is important. When you look at
16 prompt fatality risk you have to look at iodine. In
17 this case, and I'm getting partly to the --

18 MEMBER RYAN: If I'm getting ahead of
19 you, that's okay, I'll wait.

20 MS. GHOSH: Yes, for land contamination
21 we concentrate on cesium because that turns out to
22 be the most important.

23 MEMBER RYAN: I'm fine. All right,
24 that's good. Thanks.

25 MS. GHOSH: Okay.

1 MEMBER POWERS: Typically there's about
2 a factor of 10 difference in the release fractions
3 typically between strontium and cesium.

4 MS. GHOSH: So, the inputs we used for
5 the MACCS deck, we started with the SOARCA project
6 deck as was mentioned, the same with the MELCOR
7 folks. And there was a couple of key differences.
8 Obviously the source term would be different. We
9 took the source terms that were generated by the
10 MELCOR analysis to feed into MACCS. And in
11 addition, the ingestion pathway was actually turned
12 off for SOARCA and we turned it back on for this
13 analysis. So those are the two key differences.

14 The habitability criterion that we used,
15 that's when you allow people to come back, because
16 we're looking at Peach Bottom we based it on the
17 Pennsylvania state guideline which I think we
18 discussed this morning. It's a little bit more
19 stringent than the EPA guideline, it's 500 millirem
20 per year starting right at the first year.

21 And then --

22 MEMBER ARMIJO: Quick question. Do you
23 remember or know what the Japanese habitability
24 criterion is for return? Is it more conservative
25 than this, or the same, or higher?

1 MEMBER CORRADINI: As I understood it
2 the protection action guidelines are very similar to
3 this. They moved them out basically on 1 rem. But
4 the moving back in, there was a -- the staff
5 probably has it somewhere. There was a July 17th
6 date where they actually have regions where they're
7 moving them back in but I don't know what the dose
8 level is.

9 MEMBER ARMIJO: I have a number -- I
10 have a suspicion it's more conservative than the 500
11 but I'm not positive.

12 MEMBER CORRADINI: I think it is.

13 MEMBER POWERS: Somehow 50 millirem is
14 sticking in my mind.

15 MEMBER ARMIJO: Fifty?

16 MEMBER CORRADINI: Above background. A
17 delta, a very small delta.

18 MEMBER POWERS: But you know, why that's
19 sticking in my mind I don't know.

20 MR. NOSEK: Hi, my name is A.J. Nosek, I
21 work at the Office of Research.

22 I believe what the Japanese are using,
23 for habitability they're using a 2 rem threshold,
24 for return and habitability. And they plan to in
25 the future clean that down to 100 millirem past

1 habitability. That would be their cleanup standard.

2 MEMBER ARMIJO: That's the same as us,
3 same as EPA. That's what it sounds like.

4 MS. GHOSH: Okay, so the next point
5 actually Nate already covered in his overview. We
6 do do a statistical sampling of weather sequences
7 and in this case we used about 1,000 weather trials
8 because obviously we don't know when a hypothetical
9 future accident might occur. So we're taking into
10 account the uncertainty and the exact starting point
11 that the accident might occur.

12 And we limited our analysis to the
13 linear no-threshold dose-response model which is our
14 regulatory model still at this point. So unlike
15 SOARCA where we looked at the alternate dose
16 threshold models, in this case we only looked at the
17 LNT model. Next slide, please.

18 So just a quick overview. In the
19 emergency phase, you know, MACCS essentially models
20 people evacuating. And this is done by grouping the
21 population into groups of people who behave
22 similarly and we call those cohorts. So cohort 1 is
23 the zero- to 10-mile public, just the general public
24 that's in zero to 10 miles.

25 Cohort 2 is the 10- to 20-mile shadow

1 evacuation. So these are folks who haven't been
2 directed to evacuate but they hear that zero to 10
3 has been directed to evacuate and they voluntarily
4 choose to evacuate themselves.

5 Cohort 3 is a special category for the
6 zero to 10 schools. Generally the schools are
7 evacuated I believe in advance of the rest of the
8 population. They generally get an early evacuation.
9 And then similarly there may be others in the
10 general population, a zero to 10 shadow who evacuate
11 earlier than they're directed to do so.

12 Cohort 4 is the special facilities that
13 are within the EPZ and that's hospitals, prisons,
14 basically institutions that for example have good
15 shielding and need special evacuation provisions in
16 essence.

17 Cohort 5 is the zero to 10 tail. These
18 are the slow pokes, so they kind of are much slower
19 than the rest of the general population.

20 And then much like NUREG-1150 and other
21 studies, we also assume that there's some portion of
22 the population in the zero- to 10-mile region that
23 simply won't evacuate even though they're told to do
24 so. And in this case we assume that to be 0.5
25 percent of the population. Next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, I just wanted -- we wanted to make a
2 few notes on the decontamination factor of the
3 filters that we're assuming. So for the MACCS
4 portion of the analysis we essentially took all of
5 the MELCOR source terms --

6 MEMBER CORRADINI: Just one little
7 clarification.

8 MS. GHOSH: Yes.

9 MEMBER CORRADINI: I know that in
10 certain states you don't evacuate based on distance
11 as much as you evacuate based on an emergency
12 planning region that is approximately distance, like
13 county. Is that how that's done in these little
14 circles? You know what I'm saying?

15 MEMBER SIEBER: That's the way
16 Pennsylvania does it.

17 MEMBER CORRADINI: There's a name for
18 it. I can't remember the acronym.

19 MR. BIXLER: It's called a keyhole.

20 MEMBER CORRADINI: No. No, no, no.

21 MR. BIXLER: ERPA? You might be
22 thinking about ERPA?

23 MEMBER CORRADINI: Yes.

24 MR. BIXLER: Here we're evacuating the
25 entire 10-mile zone.

1 MEMBER CORRADINI: You're just going out
2 and --

3 MR. BIXLER: Yes, right. MACCS2
4 currently doesn't have the capability of just
5 evacuating a portion of the 10-mile EPZ. It does
6 the whole thing.

7 MEMBER CORRADINI: Or a keyhole.
8 Because one thing is just this, the other thing is
9 with the keyhole approach. But then on top of that
10 at least in Wisconsin they overlay that for any sort
11 of emergency and then say okay, within this fraction
12 of a county they have a siren. And it's not exactly
13 what it is, but that grouping is alerted and they go
14 out. Whether it's -- it's usually a little bit
15 larger than whatever any of these are.

16 MR. BIXLER: Yes, yes.

17 MEMBER CORRADINI: And that's not here.

18 MR. BIXLER: No, it's not here. We're
19 working on a keyhole evacuation model currently. In
20 fact, it's basically complete but not available for
21 use quite yet. It needs to be tested and so forth.
22 But not used in this study.

23 MEMBER CORRADINI: Okay, thank you.

24 MS. GHOSH: So, the decontamination
25 factor of the filters. So you'll see in the results

1 that are coming up on the next slides we took the
2 source terms from MELCOR and then we modeled both
3 the cases with and without filters.

4 And we just want to note that neither
5 MELCOR nor MACCS2 actually models mechanistically
6 the decontamination effect of the external filter.
7 So in essence we are just assigning a
8 decontamination factor value. It's a prescribed
9 value that we've assigned to the external filters.
10 And we've used several example values to see what
11 the differences might be.

12 And also the decontamination factor --
13 well, I guess this is an obvious point. But would
14 only be applied to the portion of the release that's
15 going through the pathway that's connected to the
16 venting, the filtered venting.

17 MEMBER POWERS: One of the things the
18 MACCS does is it calculates the deposition of
19 radionuclides in this plume as it moves along. That
20 deposition -- those deposition velocities are
21 functions of particle size. This decontaminated
22 material presumably has different particle sizes
23 than the non-decontaminated material. Do you
24 account for those in doing your deposition
25 calculations?

1 MR. BIXLER: The short answer is no. We
2 do account for what MELCOR tells us comes through
3 the suppression pool accounting for that
4 decontamination. But since we're just applying a
5 decontamination factor to the MELCOR flow that comes
6 out through what would be the filtered vent we're
7 just applying that DF across the board to all
8 aerosol sizes. We don't have a basis for selecting
9 which aerosol sizes get decontaminated differently
10 than others.

11 MEMBER POWERS: So you're just
12 attenuating the entire distribution by a factor and
13 not shifting the size distribution.

14 MR. BIXLER: That's right, yes.

15 MEMBER POWERS: So that has the effect
16 of accelerating your -- of increasing your particle
17 deposition relative to what it probably would be. I
18 mean, there's no -- there's the other problem of
19 course of agglomeration of those particles that may
20 shift them back into the larger distribution.

21 MS. GHOSH: Yes, that's true. I guess
22 based on discussions, and I wasn't part of all the
23 discussions, but based on internal discussions we've
24 had I guess there have been some vendor claims that
25 the latest filter technology is able to filter

1 particles down to lower sizes than one would
2 previously have thought.

3 I don't think we've done -- we haven't
4 done any independent studies on that but I guess
5 that was one thought, that perhaps this isn't that -
6 - if that were true then perhaps it's not that far
7 from what would actually happen. It may be an open
8 question.

9 And, right. So for the MACCS input then
10 the MELCOR source term only from the relevant flow
11 path, you know, where the filtered venting is
12 reduced by the decontamination factor that's
13 assigned to that filter. So if we can go to the
14 next slide.

15 The next two slides, there's a lot of
16 information here we've just summarized in two
17 tables. So these are the same eight cases that you
18 saw the MELCOR results were this morning and even
19 earlier.

20 And I just want to point out a couple of
21 things before I start. We're only presenting a
22 couple of the decontamination factor cases that
23 we've run. For the wetwell venting cases we also
24 ran a decontamination factor of 2 and 100. And
25 those results will be available in the draft SECY

1 enclosure that we are developing now. But anyway,
2 to give an idea of what difference the different
3 results produce we just are showing the
4 decontamination factor of 10 cases for the wetwell
5 venting.

6 The contaminated area which is the third
7 row in the tables, again we base this on a threshold
8 level of the cesium concentration, the aerial
9 concentration of cesium. And we picked -- we looked
10 at three or four different values. And these were
11 based on what IAEA were reporting following
12 Chernobyl.

13 And just so you know, the 15 microcuries
14 per meter squared in the case of Chernobyl
15 corresponded roughly to about an external dose about
16 800 millirem per year the first year, 1986, and then
17 dropped down to about 200 millirem per year for
18 several years after that. Just so you have some
19 idea at least for the Chernobyl case what that
20 contamination level corresponded to in terms of
21 external dose.

22 So we have here the population dose for
23 that 15-mile circle around the plant as a first
24 entry. The second is the individual latent cancer
25 fatality risk. The third is the land contamination

1 area and the fourth is the total economic cost.

2 MEMBER CORRADINI: And then if I might
3 just, just to remind myself. The last row is all
4 the things that you guys went through this morning.

5 MS. GHOSH: That's right.

6 MEMBER CORRADINI: So in theory this
7 should account for everything. In theory.

8 MR. BIXLER: If you were doing a SAMA
9 analysis you would add in the population dose times
10 \$2,000 per person rem. We're not doing that.

11 MEMBER CORRADINI: Okay, except for
12 that.

13 MS. GHOSH: And not the onsite cost
14 either.

15 MEMBER CORRADINI: Sure.

16 MS. GHOSH: So you'll see that later in
17 the reg analysis. So this is just the offsite
18 economic cost minus the population dose cost.

19 MEMBER CORRADINI: Got it. Right. So,
20 just the reason I asked that because my next
21 question is so, I benchmark this against what to get
22 a sense of reality? Or is it just a relative thing?
23 I should look at the base case divided into all the
24 others from a relative reduction. In other words,
25 should I believe the numbers or not believe the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 numbers?

2 MR. MONNINGER: For cost, for economic
3 cost we have on slide 78 some benchmarks that Marty
4 Stutzke will cover in detail.

5 MEMBER CORRADINI: Well, my next
6 question would be did you apply this analysis to one
7 of those base cases to see if you were within a
8 factor of 10, 2, or 10 percent.

9 MS. GHOSH: So, I think you asked this
10 question yesterday.

11 MEMBER CORRADINI: Yes, I did.

12 MS. GHOSH: I guess in a different
13 forum.

14 MEMBER CORRADINI: It's not a different
15 forum. It's highly connected.

16 MS. GHOSH: No, no, no, I know. The
17 topic of that discussion was different but of course
18 it's connected. In fact, this is one of the
19 activities that has to do with that SECY.

20 We haven't modeled Fukushima yet. In
21 fact, we think it's a little bit premature to do so
22 just because a lot of the -- we're still gathering
23 information. Even on just the source terms I've
24 seen quite a few different numbers coming out. And
25 certainly on the real economic cost. I mean, we've

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 seen some projections but we're still gathering
2 data. So we haven't done that type of benchmarking
3 yet.

4 I think there are a number of us who
5 think that it would be valuable to do at some point
6 but it's premature at this point. But I think what
7 you can see is so we're giving you a range of cases.

8 MEMBER CORRADINI: That's fine.

9 MS. GHOSH: And a range of numbers that
10 we've computed at least for the calculations we've
11 done. And you can kind of compare those against
12 some of the real-world costs that you'll see in the
13 slides later to kind of see where it falls, you
14 know, with respect to other real events.

15 MEMBER CORRADINI: Okay. I just kind of
16 anticipated you were going to tell me don't believe
17 any of this, just take column 2 and divide row 4
18 into the next set just to look at a relative change.
19 Because -- until you benchmark. While you
20 benchmark.

21 MS. GHOSH: Yes. Certainly the relative
22 numbers are maybe more valuable at this point than
23 the absolute numbers.

24 Okay, and so on that point in terms of
25 the relative numbers, you know, one of the things

1 that we're really trying to look at is how much
2 benefit do you get from applying a filter to
3 venting. So venting and then applying the filter to
4 the venting.

5 So, you'll see that there is inherently
6 a non-linear relationship between the
7 decontamination factor and what you get in terms of
8 a population dose and individual health risk as well
9 as the contaminated area and economic cost. And I
10 guess intuitively it makes sense, right? Because
11 the decontamination factor is only applied to one
12 pathway. So where you have a release coming from
13 multiple pathways you're not going to get the full
14 benefit of that decontamination factor. So that's
15 one intuitive point.

16 With the land contamination area you can
17 often see a super-linear effect and that's because
18 we're reporting contamination levels above a
19 particular threshold. So, if you don't reach that
20 threshold, if you're just under it you might lose a
21 big chunk of, you know, area. So that also makes
22 intuitive sense. So that explains some of the
23 inherent non-linearities.

24 The other thing is with the latent
25 cancer fatality risk for a lot of the numbers that

1 we've calculated the habitability criterion kind of
2 provides a backstop against how much risk you can
3 incur. Because you don't allow people to come back
4 and get long-term doses until you reach that
5 habitability criterion. So that can account for
6 some non-linearities as well.

7 MEMBER ARMIJO: But if you had used the
8 same threshold value on health effects as you used
9 in SOARCA for this calculation would there be any
10 difference among any of these cases for the latent
11 cancer fatality risk?

12 MS. GHOSH: Do you mean in terms of
13 trends between --

14 MEMBER ARMIJO: Yes, just there's a
15 threshold below which, you know, the number is --
16 latent cancer fatalities.

17 MS. GHOSH: Yes, I think much like the
18 land contamination area you probably -- you would
19 see a greater non-linear effect because in essence
20 you don't start counting until you reach a certain
21 threshold. So it would be a more pronounced effect
22 if you looked at the threshold dose models.

23 MEMBER ARMIJO: But the benefit of the
24 filter would be less.

25 MR. BIXLER: It would be less if you had

1 --

2 MEMBER STETKAR: But it might look like
3 the land contamination in that sense.

4 MS. GHOSH: It may be more, actually. I
5 think it may be more because with the LNT model you
6 may see bigger differences if you apply the dose
7 threshold.

8 MEMBER ARMIJO: Well, that's what has me
9 confused. So maybe offline I'll talk to somebody
10 else.

11 MEMBER CORRADINI: Just a follow-up to
12 Sam's question. Maybe I misunderstood. The third
13 row is the contaminated area -- maybe it isn't the
14 same. Is the third row anywhere related to the
15 protection action guidelines for rehabilitation? Is
16 this like an intermediate number?

17 MS. GHOSH: Yes, so that's what I was
18 mentioning before. In this case we're simply
19 reporting a threshold value for cesium aerial
20 contamination. So we can translate that to what it
21 was for Chernobyl. So in IAEA's calculations for
22 Chernobyl that translated to an 800 millirem per
23 year dose in the first year and about 200 millirem
24 per year for several years after that.

25 MEMBER CORRADINI: Okay, I missed that.

1 Okay, thank you. Thank you very much.

2 MS. GHOSH: Okay, so and the other thing
3 is I almost I had reproduced the MELCOR results
4 right before these tables because in order to
5 understand why you see the differences that you do
6 in the results you need to, you know, what I just
7 said about the non-linear effects but also you need
8 to see what's going on with the source term in the
9 release pathways in order to get the full
10 explanation.

11 So I guess -- well, we all have the hard
12 copy handouts. The key results to look at in
13 parallel are on pages 41 through 44 which basically
14 tell you what's happening with the source term
15 coming out that's feeding into the MACCS analysis.

16 MEMBER STETKAR: Tina?

17 MS. GHOSH: Yes?

18 MEMBER STETKAR: Can you go to the next
19 slide? Unless there's something pertinent
20 particularly on this one. Because we raised the
21 question a few hours ago about 15 versus 14.

22 MS. GHOSH: Right.

23 MEMBER STETKAR: And the MELCOR results
24 on slide 44 show higher releases in case 15 compared
25 to case 14 by about a factor of 3 roughly. These

1 results seem to indicate that with a filter case 15
2 is much better than case 14.

3 MEMBER BLEY: Which is where we came in
4 thinking --

5 MEMBER STETKAR: Which is where we came
6 in thinking it ought to be.

7 MR. MONNINGER: But the MELCOR doesn't
8 have the filter applied.

9 MEMBER STETKAR: Oh.

10 MR. MONNINGER: The MELCOR would be the
11 unfiltered red.

12 MEMBER STETKAR: Unfiltered versus 14.
13 Okay, never mind.

14 MR. MONNINGER: Tina threw the 10 on
15 hers.

16 MEMBER STETKAR: Never mind. You get
17 about the factor of 3 here so, sorry. Thank you.
18 It does hang together.

19 MS. GHOSH: Yes.

20 MEMBER STETKAR: MELCOR only had a vent.
21 It didn't have a filter. It sort of had a filter --

22 MEMBER BLEY: Even though it had a
23 wetwell vent you didn't take advantage of the wet.

24 MEMBER STETKAR: It sort of --

25 MR. MONNINGER: We took advantage of the

1 wetwell scrubbing but we didn't throw an extra --

2 MEMBER BLEY: An extra filter.

3 MEMBER CORRADINI: When they have
4 "unfiltered" here that means nothing external to the
5 --

6 MEMBER STETKAR: MELCOR model.

7 MEMBER BLEY: But it did go through the
8 wetwell.

9 MR. MONNINGER: Yes.

10 MEMBER BLEY: And back on the old one,
11 going through the wetwell didn't do what --

12 MEMBER STETKAR: And it had a de facto
13 reactor building filter on it, you know, factor of 2
14 or so.

15 CHAIR SCHULTZ: It appears it had a
16 benefit there, the wetwell did, and then as a result
17 it appears that the DF associated with the filter
18 for the wetwell vent is much lower than what it's
19 been proposed for the drywell.

20 MEMBER BLEY: Actually that's not so.
21 Back on 44, 43-44, the wetwell, going through the
22 wetwell made it worse.

23 CHAIR SCHULTZ: I'm talking about the
24 assumptions here though with regard to the DF for
25 the filter associated with drywell and wetwell.

1 MEMBER CORRADINI: Just the other thing
2 that -- because we had discussions at break about
3 this. Just to take case 14. Case 14 is what got
4 out by 48 hours, not what got out up to 30 days.
5 This is just the release up to 48 hours.

6 MS. GHOSH: Right, it's truncated at 48
7 hours.

8 MEMBER CORRADINI: That's probably a big
9 effect as to why -- I'm still looking at case 14.
10 It looks just strange and I think it's just got to
11 be because it was cut off.

12 MR. DENNIG: This is Bob Dennig. I'm
13 not sure that I need to say anything, but --

14 (Laughter)

15 MR. DENNIG: -- the 10 is not in any way
16 mechanistically or algorithmically or in any way
17 connected to what kind of a scrub you calculate in
18 MELCOR for the pool. The 10 is a 10. It was
19 arbitrarily assigned that value. It was a low value
20 as the minimum value which is what 90 percent for
21 all -- for small particles it would be 90 percent
22 removal for a factor of 10. And that's just in
23 there, that's just an input.

24 CHAIR SCHULTZ: Tina, each of the
25 categories that are selected there for a population

1 dose down to the economic cost over the 50-mile
2 radius. Each of those four have different stories
3 that they tell associated with the comparative
4 evaluation of each case. Are you telling that today
5 as to what findings or are we going to hear that
6 later? How is this going to be captured in the
7 quantitative and qualitative assessment features?

8 MS. GHOSH: Yes, we -- I mean today we
9 have just a very high-level summary of what came out
10 of the MACCS analysis. I think you'll hear a lot
11 more in the reg analysis and also Marty's
12 uncertainty analysis talks about it because they've
13 done additional sensitivity analyses and kind of put
14 together the story of what it all means.

15 I was going to offer just a couple of
16 very high-level thoughts. Certainly when you have
17 cases 12 and 13 where you have main steam line
18 rupture you can see that the overall consequences
19 are quite a bit greater because everything is going
20 to the drywell.

21 When you do put a filter, if you vent
22 and you put a filter on the vent you can see that
23 you attain a substantial reduction in all of the
24 consequences across the board. And certainly if
25 you're starting out with a decontamination factor of

1 1,000 and then looking at the comparison with 5,000,
2 the incremental benefit there is not very large.
3 You're getting a very large benefit from the DF of
4 1,000.

5 For cases 14 and 15 the drywell sprays
6 are effective and you don't get any containment
7 failure in case 15. That's just a note.

8 And if we can go back to the previous
9 slide, slide 66, we can see that essentially any
10 kind of wetwell venting is better than nothing at
11 all. So for these cases even when you have
12 unfiltered venting you're still better off than if
13 you don't vent at all. And you do get of course an
14 additional benefit when you put the filter on.

15 MEMBER POWERS: I guess I always have
16 trouble drawing that kind of conclusion from this
17 portrayal of the results. Because there are in fact
18 no descriptions of the distribution of the output
19 here. That if I look for instance at the difference
20 between 400,000 rem and 180,000 rem in me, but if I
21 found that looking at 1 sigma on either side of it,
22 the two numbers were in fact indistinguishable I
23 might draw a different conclusion than if in fact I
24 found that there was some differences in the 2 sigma
25 distribution there.

1 I'm wondering why you present things as
2 just the mean and don't provide -- since you
3 calculated I presume in MACCS some indication of
4 what the distribution of the results are.

5 MS. GHOSH: Yes, and you know, I guess
6 maybe we should clarify here. The distributions
7 that we're getting are based just on weather
8 uncertainty. So it's only on --

9 MEMBER POWERS: I think I understand
10 that.

11 MS. GHOSH: Yes. But there's also
12 epistemic uncertainty which we have not --

13 MEMBER POWERS: Well, I'm certain there
14 are, but even given the limitations in your code of
15 just having the weather which I think is unremovable
16 uncertainty, that no amount of research is going to
17 change the fact that the weather changes, it seems
18 to me that that's integral for drawing conclusions
19 from these results. Or am I missing something?

20 MS. GHOSH: I think that's certainly one
21 way to look at it. You know, I think the reason we
22 focused on the mean is just because it's kind of
23 been NRC policy to use the mean results and cost-
24 benefit analysis. But essentially we do have the
25 information on the distribution of results.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And as I mentioned, you know, I think
2 Aaron and Marty's going to go through the
3 sensitivity studies and uncertainty analyses that
4 they've done so we are going beyond just these mean
5 kind of point estimates almost in the overall
6 analysis. But we could also look at the range of
7 results from the weather uncertainty.

8 MEMBER POWERS: Just because you're
9 comparing two things. And especially where you have
10 a distribution in the result there's a pretty fair
11 probability that you get numbers that within the
12 range of variability of the weather you really can't
13 tell the difference between the two numbers in
14 actuality.

15 MEMBER STETKAR: You said you only run
16 1,000 samples out of your 8,760. Do you test -- is
17 it Monte Carlo sampling? Do you test for
18 convergence on the mean? I mean, if they test for
19 convergence --

20 MEMBER POWERS: Oh, well, convergence on
21 the mean is probably instantaneous. It's probably
22 10 that got convergence on the mean. Even for the 1
23 sigma level I would assume that 1,000 gets you more
24 than adequate convergence there.

25 MEMBER STETKAR: Yes, I would believe

1 so.

2 MEMBER POWERS: If you were asking about
3 the 99th percentile then it would be more dubious,
4 but --

5 MS. GHOSH: I suppose one thing I would
6 wonder is, you know, if the effects of the weather
7 uncertainty are about the same on the two cases,
8 while you may have some overlap if you look at the
9 total spread one would expect that you're going to
10 get the ranges to be different. And so maybe what
11 you're interested in is what percentage of the total
12 spreads are overlapping in some area. I think
13 that's an interesting question.

14 But I don't think we have any intuitive
15 reason to believe that the spreads would be that
16 different for one case versus another. So we could
17 look at the total range of the two but I think
18 comparing the means is still a meaningful metric
19 because the spreads would be around, you know, the
20 mean.

21 MEMBER CORRADINI: But just to get to
22 Dana's point though, it's fair to say that you've
23 got the data and you could look at it.

24 MS. GHOSH: Yes, that's fair.

25 CHAIR SCHULTZ: And I think that would

1 help in what I'm sure we could spend weeks on if not
2 the afternoon associated with comparing and asking
3 why are the differences here where we see between
4 case 3 and case 7, or the results from different
5 elements that are part of the output. How are they
6 connected or disconnected and how might we use the
7 results then in a regulatory analysis. What's the
8 appropriate way both quantitative and qualitatively.

9 MEMBER RYAN: Tina, have you done a lot
10 of either sensitivity studies or inter-case
11 comparison studies to see how they react to various
12 parameter values or changes in parameter value?

13 MS. GHOSH: Well, Marty is going to --

14 MEMBER RYAN: I guess I'm asking the
15 basic question what do you know and what don't you
16 know in these four cases.

17 MS. GHOSH: In terms of individual
18 inputs to the analysis for instance?

19 MEMBER RYAN: That's one aspect but the
20 other is how they behave once you start running the
21 calculation one to the other. We're making a lot of
22 comparisons and discussing a lot of parameters and
23 how they behave, but I'm not real sure -- I don't
24 have a hook in reality yet which one of these I
25 actually believe is fact and what's a calculated

1 estimate.

2 MS. GHOSH: Yes. I think, yes, I guess
3 this discussion today is not going to be completely
4 satisfying. I think our writeup is going to be
5 hopefully more satisfying because we go into more
6 detail about explaining why the different results
7 are what they are. I mean, I think we have
8 explanations for the differences, and again, it has
9 partly -- for these results has partly to do with
10 what's coming out of the MELCOR analysis and the
11 source term signature.

12 So it's which pathways, you know, how
13 long stuff is leaking out of the drywell head
14 flange, for instance, whether or not you have
15 drywell liner failure, whether you even have
16 containment failure, how effective the sprays are,
17 either core spray or containment spray when you do
18 have them.

19 It's a very -- it's a long story and we
20 don't have a satisfyingly succinct summary today but
21 I think when you do see the SECY enclosure hopefully
22 it'll get to more of that.

23 MEMBER RYAN: Okay. I guess when you
24 get to that point you'll be dealing with a little
25 bit more complex kind of human exposure

1 circumstance. I guess right now we're kind of
2 dealing with contamination and external doses. Have
3 you looked at intake pathways other than just
4 external exposure?

5 MS. GHOSH: Yes. Actually --

6 MEMBER RYAN: Direct gamma and crude and
7 all that other stuff sometimes can be much more
8 important than external gamma radiation.

9 MS. GHOSH: Yes and -- well, actually,
10 we can get to that in the -- we can go to slide 68.

11 MEMBER RYAN: Well, I don't want to rush
12 you out of order. If you're going to get to it
13 that's fine.

14 MS. GHOSH: Well, that's okay. I think
15 we could continue to have a very lengthy discussion
16 on this but I still don't know if it will be
17 completely satisfying.

18 MEMBER RYAN: That's fine.

19 MS. GHOSH: We should get to some to the
20 punch lines for at least the MACCS portion of the
21 analysis. And I don't think these will be
22 surprising but we did model all the pathways. This
23 kind of confirms what we've seen in other
24 applications.

25 In terms of the long-term radiation the

1 most important isotope is still cesium-137. And
2 this is accounting for everything. And the doses
3 are mostly coming from groundshine versus other
4 things. I believe that's because the residence time
5 in the body is pretty low for cesium-137. So
6 groundshine is the overwhelmingly dominant exposure
7 pathway. That's kind of why we have spent so much
8 time concentrating on the cesium-137.

9 In terms of the prompt fatality risk we
10 see essentially no prompt fatality risk. Even in
11 the cases 12 and 13 where we had much higher release
12 fractions, particularly of iodine if you go back to
13 the MELCOR tables we still don't see a prompt
14 fatality risk.

15 I think in one case there was a
16 conditional 1 in 1 billion chance, so conditional.
17 So then if you weight that by the frequency of how
18 likely that accident is to happen we are way down in
19 the weeds. And we're comfortable saying essentially
20 no prompt fatality risk. And the other ones, there
21 wasn't even a number that we could compute. So we
22 continue to focus on the latent cancer fatality
23 risk.

24 There are a couple of cases that were
25 very, very low absolute risk where the emergency

1 phase had a higher contribution. But for the most
2 part we're really talking about risk coming from
3 people coming back to their homes after the
4 habitability criterion has been met. So it's the
5 long-term phase of accumulating a lot of small doses
6 after you've come back to your property.

7 And then, the other thing as I mentioned
8 before, just inherently there is a non-linear
9 relationship between the decontamination factor that
10 you apply and both the land contamination area and
11 the health effects for the reasons I mentioned
12 before. So anyway, that's our very high-level
13 summary of what we're seeing new out of the MACCS
14 analysis.

15 But yes, I recognize for the discussion
16 of the tables we have to put together the story all
17 the way from the beginning of what's happening in
18 the reactor all the way through the offsite
19 consequences portion. So if there are any more
20 specific questions on the table entries, I mean we
21 can try to address those here but I don't know if
22 that would be valuable or not.

23 CHAIR SCHULTZ: Other questions from the
24 committee at this time?

25 MEMBER SHACK: The sensitivity studies

1 between say the 4-hour battery life and the 16-hour
2 battery life are going to be covered by somebody
3 else?

4 MS. GHOSH: Did anybody do that
5 sensitivity?

6 MEMBER CORRADINI: This morning we were
7 told that there was some sensitivity.

8 MR. MONNINGER: Yes, and that would --
9 the results would be in the MELCOR report. The
10 difference -- yes.

11 MR. BASU: In the MELCOR portion of the
12 report, MELCOR analysis?

13 MEMBER SHACK: Somewhere.

14 MR. BASU: Now, we haven't done the
15 MACCS analysis with all the sensitivities that we
16 did in the MELCOR area. So I don't think you're
17 going to --

18 MEMBER SHACK: Well, I'm just sort of
19 wondering how much of what we're seeing here is due
20 to the fact that you have a 16-hour battery life and
21 this is a very, very protracted extended accident
22 versus shorter battery life. That just seems to me
23 as sort of a basic case to look at. I could go back
24 and look at SOARCA except SOARCA didn't calculate
25 all these things.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: Or RCIC failing to
2 start.

3 MR. BASU: For MELCOR we're still going
4 to give you the release fractions of cesium and
5 iodine for 4-hour and then 12 hours. So that, you
6 can look at the proportion and see what sort of
7 effect MACCS will --

8 MEMBER SHACK: When it's non-linear I,
9 you know.

10 MR. BASU: Yes.

11 MS. GHOSH: I think, well we talked
12 about some of the preliminary SOARCA uncertainties
13 when we came in April, back in April. And the one
14 small --

15 MEMBER CORRADINI: You're assuming old
16 people can remember.

17 MS. GHOSH: You guys are not that old.
18 I don't take that -- not a good excuse. I think
19 that from there we went up to an 8-hour battery
20 life. So we didn't go all the way up to a 16-hour
21 battery life but what we found is it doesn't make
22 much difference for the 48-hour release. It doesn't
23 make that much of a difference.

24 But anyway, I'm sure the MELCOR writeup
25 will have the 16 versus 4. So it makes of course a

1 difference in the early hours but almost no
2 difference for the 48 hours which is -- actually, we
3 were surprised, frankly. We thought that it would
4 make more difference.

5 CHAIR SCHULTZ: Hearing no more
6 questions, thank you very much for your
7 presentations. We'd like to go right into the next
8 presentation on the agenda which is risk evaluation
9 by Marty Stutzke.

10 MR. STUTZKE: Being aware of the
11 schedule I thought I'd tell you a little anecdote.
12 I was preparing my presentation last night and my
13 10-year-old daughter came and asked me for help with
14 her homework problems. And she laid down about a
15 dozen 3-digit subtraction problems. I said this is
16 going to take a long time, and she goes well, it
17 will be a lot faster if you just watch and don't ask
18 any questions.

19 (Laughter)

20 MEMBER STETKAR: Are you trying to tell
21 us something?

22 MR. STUTZKE: I didn't think I could get
23 away with it.

24 MEMBER STETKAR: But it's a very good
25 story, thank you.

1 MR. STUTZKE: So, I'll reintroduce
2 myself. I'm the senior-level advisor for PRA
3 technologies in the Office of Research. We'll be
4 talking about the risk evaluation here with some
5 background.

6 First of all, the purpose of why we did
7 it, some background on CCFPs and some insights from
8 SAMA analyses. I'll summarize the tech report or
9 approach that I used, and the results and some crude
10 uncertainty work that I've done to try to give you
11 some insight. Next slide, please.

12 So, the purpose is to estimate the risk
13 reduction, the delta risk from installing severe
14 accident containment vent in the reg analysis. And
15 the metrics of importance are the change in the 50-
16 mile population dose, the change in the 50-mile
17 offsite cost, the change in the onsite worker dose
18 risk and the change in the onsite cost risk.

19 In addition, because the MACCS people
20 had calculated all these measures of land
21 contamination I decided it would be helpful to look
22 at the change in land contamination risk. Land
23 contamination as Tina told you, it's the area,
24 square kilometers, of land that's contaminated above
25 15 microcuries per square meter.

1 So if I do a normal risk calculation I
2 would take that metrics, square kilometers times the
3 accident sequence frequency and at least made a unit
4 of measure of square kilometers per reactor year
5 which I have no idea on Earth what that means.

6 MEMBER CORRADINI: Why not take the
7 ratio of the square kilometers to essentially what
8 the utility owns? So I would have essentially a
9 ratio of what is offsite to onsite.

10 MR. STUTZKE: That could work. What I
11 did was then take the risk and I divided it by the
12 sum of the release sequences. So what you get is a
13 frequency-weighted average area that's contaminated
14 above a certain level conditioned on the occurrence
15 of the accident. So it shows you units of --
16 changes of square kilometers and things like that.
17 It seemed to be a little bit more helpful to me.
18 But realize there's no regulatory guidance on
19 something that's acceptable like this. Okay. Next
20 slide, please.

21 Conditional containment failure
22 probabilities. These are -- for BWRs it's taken out
23 of the IPE results like this for Mark I's, II's and
24 III's containments. In general IPEs found that the
25 early containment failures were all due to liner

1 melt-throughs, large majority of them. And the late
2 containment failures are overpressurization failures
3 as well as basemat melt-throughs.

4 So you see similar results between the
5 Mark I's and Mark II's, and the Mark III's there's a
6 different distribution. If you flip over to the
7 next slide -- yes.

8 MEMBER CORRADINI: When you said early
9 and late you only were talking about Mark I, about
10 liner melt-through. There ain't no such animal
11 under Mark III.

12 MR. STUTZKE: Yes.

13 MEMBER CORRADINI: Okay. So what is the
14 early in the Mark III?

15 MR. STUTZKE: I'd have to look that up.

16 MEMBER CORRADINI: I don't remember
17 myself but I --

18 MR. STUTZKE: Yes, I'd have to look it
19 up. Since the focus here has been on Mark I's and
20 Mark II's.

21 MEMBER CORRADINI: Okay, that's fine,
22 that's fine.

23 MR. STUTZKE: The next slide shows the
24 results for the PWRs as well but I won't discuss
25 them.

1 MEMBER STETKAR: Marty, you didn't
2 mention containment isolation failure. Are those --
3 is that part of late?

4 MR. STUTZKE: That's part of the bypass.

5 MEMBER STETKAR: Part of bypass.

6 MR. STUTZKE: That's part of bypass.

7 MEMBER STETKAR: So that's not -- okay.

8 Thank you.

9 MR. STUTZKE: And there are issues with
10 reportability of segregating those out.

11 MEMBER STETKAR: Surprising where that
12 is then. Thank you.

13 MR. STUTZKE: Yes.

14 MEMBER SKILLMAN: Marty, what are the
15 early failures for the large dry and for the ice
16 condensers, please?

17 MR. STUTZKE: In terms of what --

18 MEMBER SKILLMAN: I presume bypass is
19 failure, late failures are overpressurization. What
20 is early failures for those two classes?

21 MR. STUTZKE: I'm going to have to look
22 those up.

23 MEMBER SKILLMAN: Just curiosity. Thank
24 you.

25 MR. MONNINGER: So we tried to put it in

1 here for our perspective but for the other
2 containment designs --

3 MEMBER SKILLMAN: You're doing peas
4 versus peas is what you're doing.

5 MR. MONNINGER: Yes.

6 MEMBER SKILLMAN: Okay, thank you.

7 MR. STUTZKE: The next source of
8 information comes from extending the intervals
9 between integrated leak rate tests that are required
10 by Appendix J in Part 50. And a number of licensees
11 have submitted and the staff has approved various
12 license amendments.

13 This is not a complete set. This is a
14 sampling of the information. But the methodology
15 provides information that lets one derive
16 conditional containment failure probability. In
17 fact, in some of these submittals they actually
18 report the numbers like this.

19 MEMBER CORRADINI: This is after they've
20 done all the tightening and all they've tried to do?
21 I don't understand what the final number means.
22 Because with an ILRT I thought they go through a lot
23 of -- to pass the test.

24 MR. STUTZKE: Right, but the idea here
25 is originally plants did ILRTs three times in 10

1 years. And now the idea is to extend the interval
2 to once in 10 years or once in every 15 years like
3 that -- like this. And what you find is the
4 following breakdown by the causes of conditional
5 containment failure probability.

6 You know, the ILRT is fixated on the
7 isolation failures, the liner leak-throughs and
8 things, things that would be detected by the test
9 and as a result because the contribution is small
10 you don't set much influence or sensitivity to the
11 interval between tests.

12 What I was interested in was the
13 contribution from accident phenomena that would
14 include things like liner melt-through, overpressure
15 failures, and I was trying to make a comparison
16 between this and the previous graphs I showed you to
17 see what have we learned since we did IPEs about the
18 likelihood of containment failure.

19 This accident phenomena column is the
20 ground on which we play here for filtered venting if
21 you want to look at it that way.

22 Okay. Then we went through a process --
23 next slide, please.

24 MEMBER CORRADINI: Marty, I'm sorry that
25 I'm slow. Since none of the numbers change do I

1 interpret that to mean I learn nothing or the test -
2 - I really don't understand what we're trying to get
3 out of this. I'm sorry.

4 MR. STUTZKE: Okay. The numbers that
5 change because of ILRT are the frequency of the
6 percent contributions of the isolation failures.

7 MEMBER CORRADINI: They kept going up
8 but don't really amount to anything.

9 MR. STUTZKE: Well, actually, they go --

10 MEMBER SIEBER: Well, look at the
11 conditional containment failure probability.

12 MEMBER REMPE: You're testing less
13 frequently.

14 MR. STUTZKE: Yes, you're testing less
15 frequently and you expect the contribution to go up
16 proportionally like this.

17 MEMBER SIEBER: What was the last
18 column? There's a pretty wide variation there.

19 MEMBER CORRADINI: But what I guess I
20 was -- now I see, I think I understand what Marty
21 was saying. The only column that really is changing
22 is the isolation failure.

23 MEMBER SIEBER: Yes, that's right.

24 MR. MONNINGER: For our purposes one of
25 the questions out there are what are the potential

1 accident sequences or scenarios in which a filter
2 may or may not be beneficial. And what we're trying
3 to say is that for some of this accident phenomena,
4 liner melt-through, overpressure, et cetera, the
5 boilers, the Mark I's and Mark II's have a high
6 probability of failure and could the filtered vents
7 play a beneficial role in there.

8 Could the filtered vents play a
9 beneficial role in this accident phenomena column?
10 They're not going to help isolation failures. So
11 licensees are reporting a high failure probability
12 for their own plants and this is where we believe
13 the filtered vent has value in potentially driving
14 these numbers down.

15 MEMBER STETKAR: John, is this -- or
16 Marty, is this different than the message that I --
17 kind of subtle message in the EPRI report which says
18 well, there are a whole bunch of other ways that the
19 containments fail so we're only going to focus on
20 this -- the message I got -- small fraction of the
21 events that a filter might help you? This says a
22 large fraction of the events a filter might help
23 you.

24 MR. STUTZKE: Potentially. The problem
25 here is it just says -- for the ILRT methodology it

1 just says accident phenomena. And you can't really
2 break out is it overpressure failure versus liner
3 melt-through. Some of the analyses, the submittals
4 actually give you that level of detail.

5 MR. MONNINGER: I think the other thing
6 they potentially say is a filter by itself is not
7 necessarily a solution. You need a package deal.

8 MEMBER STETKAR: Oh, I understand that.
9 There's a lot of introductory material in that EPRI
10 report where they go through winnowing down all of
11 the scenarios into the subset that they're really
12 going to look at. Okay, I guess I understand.
13 Thanks.

14 MR. STUTZKE: Okay, slide 75. We went
15 through every license renewal submittal up to
16 February of this year and looked at all of the
17 SAMAs.

18 And this is a breakdown by plant type of
19 which SAMAs had considered filtered containment
20 venting before, and if they had to what type of
21 analysis was done, so forth and so on.

22 So, if you look at the 23 BWR Mark I's
23 in 5 of the submittals the filtered vent doesn't
24 show up. It's simply not one of the SAMA options
25 that was evaluated. But it was evaluated in 16 of

1 the other ones, 11 through a screening analysis and
2 5 through a more detailed analysis.

3 When we say "screening analysis," the
4 way that that's done in SAMA is they take the
5 baseline risk of the plant and they monetize it.
6 And then one assumes that the fix, the plant
7 modification being considered completely eliminates
8 the risk. So the risk is now zero. If the cost of
9 the implementation is bigger than that maximum
10 possible monetized risk they screen it out.
11 Something like that. And so that's where the --

12 MEMBER STETKAR: Monetized risk at
13 \$1,000 per person-rem?

14 MR. STUTZKE: Two thousand.

15 MEMBER STETKAR: Two thousand.

16 MR. STUTZKE: Two thousand. Yes, and
17 there's an agreed-upon NEI methodology on how these
18 SAMAs are conducted like this.

19 MEMBER CORRADINI: So could you just
20 repeat that again please for the screening?

21 MR. STUTZKE: Okay, you take the total
22 risk. So in this case we're talking about offsite
23 risk, population dose risk, the offsite consequences
24 that are computed from MACCS by the licensees
25 through a level 2 type of PRA-type process, plus the

1 onsite risk which would include doses to the
2 workers, the onsite cleanup cost. In this case, in
3 SAMAs they include replacement power cost, et
4 cetera. And all of those risks are then monetized.
5 So they come out with some sort of a dollar amount.

6 MEMBER CORRADINI: And they compare it
7 to?

8 MR. STUTZKE: They compare it the cost
9 of implementing a proposed --

10 MEMBER SHACK: The maximum possible
11 benefit you could get from anything.

12 MR. STUTZKE: And so the point here is
13 when you get this sort of screening analysis you
14 don't get any detail about filtered venting and what
15 they assumed in the analysis like this. So I had a
16 look --

17 MEMBER CORRADINI: Just out of curiosity
18 since they did a comparison of dollars to dollars,
19 what were they using for the cost of the filtered
20 venting?

21 MR. STUTZKE: Well, it varies. Some of
22 them are at \$1 million. There's a lot of them at \$6
23 and then there's some at \$10.

24 MEMBER CORRADINI: So all lower than
25 what staff has been suggesting is the delivered --

1 MR. STUTZKE: You know, as you would
2 suspect. You know, there's basically one quote that
3 one utility made and everybody else copied it.

4 (Laughter)

5 MR. STUTZKE: Well, you know, in
6 fairness they do 100 SAMAs. There's 200 different
7 mods and they're looking for some efficient way to
8 zap through the analysis like that. But I drilled
9 down into some of the Mark I containments that
10 actually provided.

11 This is the sum total of information on
12 how those detailed analyses were actually done.
13 Those benefits are not times 1 million or anything,
14 that's just the actual benefit. Like this -- and
15 you can see what they're doing is to adjust the
16 accident progression source terms just by a factor
17 of 2.

18 And it raises all sorts of questions
19 because it's not clear that the venting to prevent
20 overpressurization failure is part of the analysis
21 here. It's not what we're really talking about
22 here. So, I'm left with somewhat of a suspicious
23 mind here that these things aren't maybe as
24 illuminative as I thought they would be --
25 illuminating, illustrative as I thought they would

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 be.

2 Okay, so while I was compiling tables --
3 don't worry, I'll start doing some analysis in a few
4 minutes. There's been this debate or discussion
5 within the staff on what the appropriate core damage
6 frequency is to use in this type of an analysis
7 because the severe accident event starts with the
8 occurrence, the assumption that core damage exists.
9 And so if one wants to calculate delta risk, those
10 delta risks are directly proportional to the CDF.
11 It's pretty simple. So, from NUREG-1150 a cdf --

12 MEMBER CORRADINI: Not in the real world
13 though, right?

14 MR. STUTZKE: No.

15 MEMBER CORRADINI: Okay, yes.

16 MR. STUTZKE: From 1150 the Peach Bottom
17 results using the Livermore seismic hazard curves
18 sums up about 10 to the -4. The staff has three
19 Mark I SPAR internal and external event models
20 combined. Those are patterned after licensees'
21 IPEs, we just adapted them over.

22 And you can see they're in the low 10 to
23 the -5 ranges like this. The range of core damage
24 frequencies from SAMA analyses from 2 to 6 times 10
25 to the -5. I should point out most SAMA analyses

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 only do internal events.

2 MEMBER BLEY: How about this SPAR -- oh,
3 the SPAR has the external vents in it.

4 MR. STUTZKE: There's a few. These are
5 the ones that I have that are relevant.

6 MEMBER BLEY: The external?

7 MR. STUTZKE: Yes, these are the real
8 external event, full set of fault trees, event
9 trees.

10 MEMBER STETKAR: Without seismic?

11 MR. STUTZKE: No, these are with
12 seismic.

13 MEMBER STETKAR: Those have seismic.

14 MR. STUTZKE: Yes.

15 MEMBER STETKAR: Oh, good.

16 MR. STUTZKE: But what I was saying was
17 most of the SAMA analyses don't even do external
18 events. What they do is put on an external event
19 multiplier onto the benefit and to scale it up by a
20 factor of 2 or 3 or 2.7 I've seen like this and it's
21 not helpful because I don't really know what the CDF
22 is coming out of it.

23 Then last and not least is what we've
24 termed the global statistical value. That's five
25 events, TMI, Chernobyl, three units at Fukushima

1 divided by 15,000 reactor years. Gives you a number
2 of 3 to the -4.

3 MEMBER CORRADINI: And that's close to
4 the upper bound, the report upper bound in WASH-
5 1400.

6 MR. STUTZKE: Right. Now, there is a
7 staff working group looking at this separately so
8 I'll set that aside.

9 Onto slide 78. I started to compile
10 some offsite economic consequences. And I may get
11 to your question of how do you know these numbers
12 are any good, but MACCS is computing out of here.

13 The first place is in the reg analysis
14 handbook. It says if you don't have information or
15 opportunity to do a consequence study assume \$3
16 billion for core damage and offsite consequences.

17 MEMBER CORRADINI: In 1990.

18 MR. STUTZKE: In 1990 dollars.

19 MEMBER CORRADINI: Wow.

20 MR. STUTZKE: Those actually came from
21 NUREG-1150. Those are actually out of NUREG-1150.
22 It's a little follow-on study that was done.

23 For the SAMA analyses, you know, they
24 range between six-tenths of \$1 billion up to \$30
25 billion like that. Peach Bottom is up at \$10

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 billion.

2 MEMBER BLEY: And those are whatever
3 dollars were used when they were calculated.

4 MR. STUTZKE: At the time of the SAMA.
5 So those are like 2005 up to the present time, stuff
6 like this -- like that.

7 Looking on the internet I discovered a
8 report that was issued by the Japan Center for
9 Economic Research that was issued last year. And
10 they estimated the total cost of the accident of
11 \$250 billion.

12 When you look at what they did they had
13 \$190 billion to clean up and replace the unit in
14 that. In our regulatory analysis that's a separate
15 thing, that's not part of the offsite cost. So I
16 subtracted it out. So you get this \$62 billion for
17 the three units.

18 And I tried to look into the assumptions
19 that were driving that and they said well, we'll
20 just assume all land within 20 kilometers is
21 condemned and we'll buy it. No cleanup, no
22 interdiction, it's gone. And we'll pay people for
23 10 years that lived in that region. So it gives you
24 a value.

25 Last and not least is the current cost

1 of the oil spill from the Deepwater Horizon
2 accident. It's roughly \$23 billion they paid out so
3 far in compensation. And I realize I threw that one
4 on there because it's an available number. I
5 actually learned it watching football the other
6 weekend. And the analogies are slippery -- pardon
7 the pun -- with the oil spill because, you know, an
8 oil spill is not like a reactor accident. But it's
9 some large industrial accident so it gives you some
10 ideas.

11 MR. MONNINGER: And maybe a marker for
12 what we've done for this would be base case 2 where
13 in today's dollars we calculated \$1.9 billion.

14 MR. STUTZKE: That's correct.

15 MR. MONNINGER: Is our base case. And
16 then we will then look at options.

17 MEMBER CORRADINI: Is there anything in
18 the chemical industry? I'm thinking of the
19 explosion in the plant in northern Italy that
20 essentially the land had to be -- I don't think
21 anybody's still living on it. I'm trying to think
22 of the name of the accident. It was in the
23 Dolomites. Do you know what I'm thinking of? It
24 was an explosion of a reactor essentially going out
25 of control and exploding. Loss of about 100 people.

1 MEMBER SIEBER: That was in India?

2 MEMBER CORRADINI: No, I'm not talking
3 Bhopal. I want to get to a country that worries
4 like we worry about it. So northern Italy. It was
5 about in the late nineteen seventies, '77, '78. I'm
6 pretty sure it was release of PCBs for dioxins.

7 MR. STUTZKE: I haven't looked at it in
8 detail. The thing about Bhopal with the cyanide
9 release is it all chemically combined and it went
10 away. Cleaned itself up. So you raise a good
11 point, I might be interested to collect some sort of
12 comparable industrial accidents that leave the same
13 lingering, long-term problem. Give us a benchmark.

14 Okay, slide 79. So, the decision was
15 made we're going to focus on BWR Mark I plants.
16 That's --

17 MEMBER CORRADINI: Seveso. S-E-V-E-S-O.

18 MEMBER BLEY: Thanks. That's been a few
19 years back.

20 MEMBER CORRADINI: But lost a number of
21 people in the general public and the land was
22 contaminated for a wide region.

23 MEMBER STETKAR: Marty, on the previous
24 slide, just a quick one. They're really interesting
25 dollar comparisons. Does it give you much pause

1 with the guidance that's in NUREG whatever the heck
2 it is, BR-0184 regarding valuations that are placed
3 on these things?

4 MR. STUTZKE: I'm not going to bite on
5 that question.

6 (Laughter)

7 MEMBER STETKAR: It was worth a shot.

8 MR. STUTZKE: No, I mean it's true.
9 First of all, these analyses that's in the handbook
10 are older. I mean they were done right after 1150
11 was done. And you know the plants are different
12 that way and of course the population, the
13 demographics have changed, et cetera, et cetera.

14 MEMBER STETKAR: Okay. Sorry. It was
15 worth a shot.

16 MR. STUTZKE: Okay, so as far as coming
17 up with a technical approach obviously if I were
18 king we would have banks of level 3 PRAs sitting up
19 in the Office of Research that I could go diddle
20 with and things like that. That's not going to
21 happen like that. We do have some simplified level
22 2 SPAR models but those are more proof of concept
23 that the Sapphire Software platform actually will
24 link things together like that.

25 MEMBER SIEBER: And they're just

1 internal events too, right?

2 MR. STUTZKE: Those are internal events.
3 And so there is some effort to expand the level 2's
4 into level 3's and into this -- to throw in the
5 external events as well. It's the ICM model,
6 integrated capabilities model. But those are still
7 in the future so I don't have, you know, fully
8 operational quantum loaded PRA so to speak to play
9 with here. So bear that in mind.

10 The other thing was that as the analyses
11 were progressing I kept getting different
12 sensitivity runs from the MACCS people and the
13 MELCOR people. We did this run, you know, no, we
14 did this one.

15 Okay, so what I did was I tried to
16 organize them into what I'll call candidate
17 modifications classified according to how does the
18 vent get open. Is it manual or is it passive
19 through some sort of a rupture disk because that
20 drives the frequency of the sequences.

21 The other two, where it's located. Is
22 it installed on the wetwell or on the drywell and is
23 it filtered or is it unfiltered. That affects the
24 consequence estimates. So I ended up with eight
25 modifications to the third power and ran those into

1 the PRA. And so what you'll actually see are the
2 delta risks with respect to what I call mod zero
3 which is the base case for each one of those. So
4 you can see, you know, the change in risk if I have
5 a passive drywell event without a filter. It's in
6 the pages.

7 The other thing that's necessary within
8 the event tree structure is to consider the fact
9 liner melt-through may be prevented by installation
10 of portable pumps or something like this. And we
11 wanted to credit that.

12 I think one of the things that bears
13 repeating is when we started the analysis it was
14 believed, and if you look at some of the old PRA
15 results we break down containment failure modes.
16 Oh, it's overpressure or it's a liner failure. And
17 we don't really talk about the fact you can have
18 both. It's an overpressure, oh, and then the liner
19 failed some hours later. We tend as PRA analysts to
20 group them and of course we all think mutually
21 exclusive and it ain't so in some cases. You can
22 have multiple things like this. And so you'll see
23 when I get into the structure I've tried to be very
24 clear about what I thought was going on here.

25 Some of the assumptions and the ground

1 rules here is we're using the existing guidance so
2 we're looking at a per-reactor basis. We're not
3 looking at multi-unit accidents yet.

4 We're not looking at spent fuel pool
5 accidents although my office director really wanted
6 me to go after that. The idea is well, without the
7 vent then you get Fukushima and maybe the spent fuel
8 pool gets damaged and there's this release. And I'm
9 going I don't know how to estimate the risk. There
10 are projects going on to be able to do that. So
11 it's set aside.

12 The other thing is that if you look at
13 the suite of MELCOR and MACCS runs -- and on a
14 personal note, I mean this has been a very
15 collaborative agreement between the Division of Risk
16 Analysis and DSA over in Research. We've worked
17 very closely. But unfortunately they can't run all
18 the sequences I can dream up.

19 It's like, well, what about LOCA
20 sequences or ATWS sequences, you know. Let's get to
21 some of the really sexy ones because all you guys
22 are doing are blowing the plant down and watching,
23 you know. Kind of boring. So everything I have is
24 station blackout sequences and from that I have to
25 infer well, does it apply to all types of sequences

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that I'm interested in.

2 MEMBER STETKAR: Marty, do you have a
3 sense of other high-pressure sequences, how well
4 station blackout does as a kind of/sort of surrogate
5 for those?

6 MR. STUTZKE: I really don't.

7 MEMBER STETKAR: You don't? Okay. I
8 was trying to think about that and I'm not sure
9 either.

10 MR. STUTZKE: I mean, one could argue,
11 you know, if I had a LOCA that voids the vessel then
12 maybe the sequence progression is roughly the same
13 as when I voided it with station blackout. That may
14 be true with respect to the core but probably not
15 with the containment conditions.

16 MEMBER STETKAR: Yes, that's what I'm
17 starting to think.

18 MEMBER CORRADINI: Is a loss of heat
19 sink considered a subset of a station blackout?

20 MR. STUTZKE: I think it would be, yes,
21 a subset of that. It's more benign. It's like I
22 say, this starts with the teapot full and it just
23 boils it down.

24 MEMBER RAY: Well, wait a minute, Mike.
25 Suppose you lost the heat sink due to a dam failure?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER CORRADINI: I simply asked --

2 MEMBER RAY: I understand. I understand
3 why you asked the question but I'm just trying to
4 say it doesn't seem to me like it's a subset of SBO.

5 MEMBER CORRADINI: But wouldn't it
6 progress in terms of the accident similar to it?
7 It's essentially an outside, it's an outside-in
8 event but you still would progress that you're all
9 bottled up.

10 MEMBER RAY: Very possibly but if the
11 dam failure was very likely and the SBO was very
12 unlikely it seems like the two things are unrelated.

13 MR. STUTZKE: Okay, we had the most
14 MELCOR and MACCS cases for the 16-hour RCIC time.
15 Yes. And so you know, the presumption is well, the
16 thing's going to run 16 hours. I used the smallest
17 decontamination factors when filtering was
18 considered, generally 10. Standard PRA assumption
19 about no credit for recovering offsite power if it's
20 an external event.

21 The last bullet turned out to be rather
22 important in the analysis, and it's the notion that
23 as John had said before, venting a containment is
24 only part of the fix. You need to cool the debris
25 bed.

1 And the assumption that I made in here
2 was, well, if you failed open a vent so now you --
3 we always talked about it as you're going to lift
4 the drywell head. Well, you might fail other parts
5 of the containment. And the point is that the
6 reactor building or the aux building would be
7 contaminated and it's certainly going to be full of
8 steam and things like that. And so the assumption I
9 made was once that happens if they don't have the
10 portable pump and running it's not going to happen.

11 And if you look at the timing of the
12 MELCOR sequences for all of these you're seeing core
13 damage, the onset of core damage is about 24 hours.
14 And the challenge to the containment is roughly at
15 25 hours. So with 1 hour after core damage you
16 begin to get this 80 pounds inside the drywell. So
17 it basically says then if the portable pump doesn't
18 get up and running in that 1 hour after core damage
19 it's not going to happen. And you'll see how that's
20 reflected in the tree logic.

21 So without further ado we came up with a
22 simple release tree. Let me walk you through it for
23 those that are not PRA analysts. Generally the up-
24 branches mean yes or success, the down-branches mean
25 no or failure. The tree progresses through a

1 partitioning process. So we take the total core
2 damage frequency and we divide it up. Some fraction
3 of it's due to internal events, loss of offsite
4 power, loss of grid, the LOCAs, things like this.
5 Some portion is due to external events, seismic,
6 tornados. Floods.

7 From that then we partition them into
8 sequence types. And the characteristic, the
9 defining characteristic here is one is what's going
10 on with offsite power because offsite power could be
11 recovered at some time. And the other thing is what
12 -- how much available time does the operator have to
13 respond. Some of these sequences like ATWS, the
14 operator would have very little time to get a manual
15 vent open. In other cases he's got time to do it.
16 So I tried to partition the sequences that way.

17 Then funny enough the "other" category
18 means it's not station blackout, it's not an
19 interfacing systems LOCA and it's not one of these
20 faster transients. It's all other. Same sort of
21 partition exists for the external events except
22 we've already assumed that offsite power is gone so
23 it collapses down to simply bypass or not bypass.

24 Then you see the venting, you vent in
25 there. The key assumption here is venting is always

1 required, every sequence. The only time it's not
2 required is if we're talking about bypass sequences,
3 interfacing LOCAs or the containment. External
4 event bypass means the containment is actually
5 opened up like some seismic event has ripped the
6 penetration loose from the steam line.

7 MEMBER STETKAR: How do you handle the
8 fraction of containment isolation failures?

9 MR. STUTZKE: Those would be in the
10 bypass. But you'll see it's --

11 MEMBER STETKAR: Okay. I just wanted to
12 make -- okay.

13 MR. STUTZKE: They're intended to be in
14 there and I understand.

15 MEMBER STETKAR: I mean, you know, a
16 reasonable fraction of scenarios are containment
17 isolation failure.

18 MR. STUTZKE: Right. Okay, then finally
19 given that venting succeeds we can consider the use
20 of the portable pump to provide either injection to
21 core spray or into drywell spray. If venting has
22 failed you see it goes directly to the end state.

23 The only subtlety here is if it is
24 station blackout and venting has failed there's
25 still a possibility to get water into the drywell.

1 If offsite power is recovered one could use
2 condensate, high-pressure servicewater, things like
3 this. So I included that in there.

4 Okay, so the 16 sequences then get
5 classified as to what I'll call the status of the
6 containment or the end state. And they're grouped
7 into four bins, either the containment is vented, or
8 it's suffered a liner melt-through, or it's suffered
9 an overpressure failure, or it's suffered an
10 overpressure failure and then a liner melt-through.

11 Now, quantification. Right now we
12 accept the values as shown in this table, and
13 there's some rationale behind them. The current
14 core damage frequency is at $2E-5$ which is out of the
15 SPAR external event models. As I said the staff is
16 debating this now. We did a sensitivity study at 3
17 times 10^{-4} and I think Karen will show you
18 some of those results.

19 The breakdowns, split fractions are
20 coming out of the SPAR models, whatever they are.
21 The one that I don't really have a good feel for is
22 this breakdown of external events that you bypass
23 the containment. NUREG-1150, that was one of the
24 major failure mechanisms where the assumption was
25 that the transient knocked the reactor vessel off

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 its pedestal and it pulled all the steam pipings
2 through and made this horrendous hole. And we no
3 longer that's as likely as it was.

4 Okay. As far as the treatment of this I
5 should -- the probability that the vent actually
6 fails. One of the things that I did rather cleverly
7 as a parenthetical comment is that I drew a single
8 event tree and designed it so that I could get all
9 of the cases by changing one number in the tree.
10 And that number is the probability the venting
11 fails. Everything else works.

12 So, for this mod zero, mod zero is the
13 current base case. You just set the probability a
14 venting fails to 1 and it's no credit for all it and
15 the tree works out. For these others who are slower
16 scenarios, station blackouts, 10 to the -3 comes out
17 of the SPAR-H manual. I bumped it up a little bit
18 for the faster transients to half. For the ones
19 where venting is done through the rupture disk, the
20 passive failure, I set it at 1 in 1,000. It seems a
21 good mechanical reliability number. We have good
22 offsite power recovery data for internal events from
23 NUREG/CR-6890.

24 And the probability that the portable
25 pump as installed is driven by SPAR-H. That one

1 actually is very consistent. We had Idaho Labs a
2 number of years ago do a study of the B.5.b
3 mitigative measures and these are numbers that they
4 derived.

5 MEMBER STETKAR: That includes the human
6 --

7 MR. STUTZKE: It's all human. The
8 hardware's not in there.

9 MEMBER STETKAR: A little better than
10 that.

11 MR. STUTZKE: Yes. And it's almost
12 implementation error but I won't even try to break
13 it into diagnostic versus something like that. But
14 yes, this is to account for the guys running around
15 the plant schlepping the pump where it needs to go,
16 running the hose where it needs to be installed,
17 these sorts of things. Okay.

18 Now, for the mystery table which makes
19 sense to me, but --

20 (Laughter)

21 MEMBER CORRADINI: So did you just skip
22 it or what?

23 MR. STUTZKE: It would be faster if you
24 just don't ask any questions.

25 (Laughter)

1 MR. STUTZKE: Okay, going across the top
2 up here it says "Release Sequence End States" and
3 hopefully you will recognize vented liner melt-
4 through, overpressure or overpressure and then liner
5 melt-through is that identifier. Those match up to
6 the end states on the event tree, okay?

7 And because you are having as much
8 problem as I do, you know, the MACCS people, the
9 MELCOR people, they know that case 7B non-filtered
10 means this and I don't know what that means. So I
11 had to write my little pneumonics. Oh, that means
12 it's vented. That means it was stuck on the
13 wetwell. Okay? And that's what these designators
14 are for.

15 So up here at the top when I say vented
16 it means the containment is vented and the drywell
17 is wet meaning there's no chance of liner melt-
18 through. Or it's vented but the drywell is dry so
19 there's no overpressure failure but liner melt-
20 through could occur. And so forth. And the
21 sequence numbers here that match each one of those
22 end states are summarized so you can sort that out.

23 The more difficult problem now is coming
24 down on it I have the description of the plant
25 modifications in terms of the vent location and the

1 filter. Remember what distinguishes a modification
2 is the location, filtering or non-filtering, and
3 actuation method, passive or manual.

4 As far as the consequences go I can lump
5 manual and passive together because that only
6 affects the frequency. So the way to read this
7 table is if I want to consider modification 1, well,
8 what is that modification? That is a wetwell vent
9 that has no filter but is manually actuated. That's
10 the definition of mod 1. And I wanted to know what
11 MELCOR case, MACCS case I should use to worry about
12 overpressure failure. And I would read over and say
13 oh, that's case 6.

14 So, the consequences then change
15 depending on which modification I have in the tree
16 which accomplishes the other thing. And so I do
17 this through a lookup function.

18 Another example is if I wanted to have
19 mod number 6. So that's a wetwell location, it's
20 filtered and it's passively actuated. And I wanted
21 to know what is the consequence of the vented
22 sequence I would use either case 7 or case 15.
23 Seven is the case of course spray, 15 is the case of
24 drywell spray. And in both cases it's the filtered
25 case. So that's the magic link between all of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MELCOR and MACCS runs that you've heard about and
2 the end states of the event tree.

3 Okay, results. First is contributions
4 to different types of containment failure modes.
5 Again, these are only affected by the probability of
6 actuation. So whether it's manually vented or
7 passively vented, doesn't matter what the
8 consequence is because we're dealing with frequency
9 contributions. And so you'll see the various
10 contributions lined up like that.

11 That total number is -- I'll call it,
12 it's analogous to conditional containment failure
13 probability. And the reason why I'll say that it's
14 analogous is, you know, is containment venting
15 actually a containment failure? Well, no. You've
16 tried to preserve the containment's function but in
17 fact the containment is not tight.

18 And so to avoid this word play with you,
19 if I said it was CCFP you'd go oh, it's a failure,
20 and I knew I couldn't win that argument. So I'll
21 call it analogous with that understanding.
22 Obviously if you had it in the containment venting
23 it goes to 100 percent because it has to go to one
24 of those categories. So that's the information.
25 But it's a notable reduction.

1 What actually happens is that as you add
2 the severe accident vent on here you move from one
3 end state to another. So you begin to avoid the
4 overpressure failures followed by liner melt-
5 throughs. They just become pure liner melt-
6 throughs. There's no overpressure failure so they
7 shut.

8 MEMBER CORRADINI: You talked about this
9 and I guess I now don't remember. How do I have the
10 overpressurization liner melt-through? Because
11 later on I dry out the drywell and then it proceeds
12 onto liner melt-through?

13 MR. STUTZKE: Right, right.

14 MEMBER CORRADINI: Okay. And then the
15 reason that that's so dramatically less in a passive
16 is because there's some sort of failure to manually
17 open it when you wanted to?

18 MR. STUTZKE: Right, and the passive is
19 very reliable.

20 MEMBER CORRADINI: Okay.

21 MR. STUTZKE: Rupture disk. Okay.
22 Slide 86 starts the baseline risk results. These
23 are the point estimate values. We'll talk about the
24 uncertainty in a little bit. And I've tried to put
25 this header on the top so you can easily distinguish

1 on the lefthand side are all the unfiltered cases
2 and the right-hand side are the filtered cases, this
3 location of a vent, wetwell versus drywell, and then
4 where it's manual or passive.

5 And these are the changes, the
6 reductions in risk with respect to mod 1. So green
7 means it's a reduction, red means it was actually a
8 risk increase. So the way to read this table would
9 say if I'm interested in a filtered wetwell vent
10 that has a rupture disk, it's passively actuated,
11 that's mod 6 and the point estimate, delta person-
12 rem per reactor year is 8.2. That number then gets
13 input to the reg analysis, monetized by \$2,000 a
14 person-rem, discounted over time, et cetera, and
15 Aaron Szabo will explain that.

16 MR. MONNINGER: So what's important is,
17 for example, he talked about mod 6 there. We're
18 comparing that back to mod zero or the base case.
19 And for our base case the failure was liner melt-
20 through and overpressurization. It didn't consider
21 what we talked about before, the potential for
22 drywell venting or wetwell venting.

23 So we're comparing all eight of these
24 cases to no venting capability at the site. Because
25 our first potential option would be to beef it up to

1 the severe accident capable and the next one would
2 be up to the filter. But we're not comparing these
3 cases against the potential for drywell venting.

4 MEMBER ARMIJO: So this overstates the
5 benefit because the base case has been defined very
6 conservatively.

7 MR. MONNINGER: The base case is
8 actually very minimal releases. The base case was -
9 -

10 MEMBER CORRADINI: Oh, the base case is
11 really containment failure.

12 MR. STUTZKE: It'll be a combination of
13 overpressure failure and overpressure followed by
14 liner melt-through failures. The base case says, as
15 John said, simply no venting is considered post
16 accident. So the phenomena evolves the way that
17 it's going to evolve and there's consequences to
18 that.

19 MR. MONNINGER: So it's way back there.
20 It's case 2 on page 41 and 43.

21 MR. STUTZKE: Like the MELCOR and MACCS
22 folks I actually have a writeup and you can see the
23 raw numbers for each modification. What I've shown
24 you here are the deltas relative to the mod zero.

25 The red bars for mod 3 and mod 4 should

1 not surprise you. That says I have an unfiltered
2 hole in the drywell. We all know that's bad.

3 (Laughter)

4 MR. STUTZKE: That's the reason why we
5 have containment.

6 MEMBER SIEBER: And why you have them in
7 red.

8 MR. STUTZKE: The next slide on 87 is
9 the change or the reduction in offsite cost risk.
10 And you see similar sorts of trends like this. You
11 can see that installing a severe accident vent on
12 the wetwell is better than on the drywell because of
13 the scrubbing effect a little bit like this.
14 Obviously filtering is beneficial and passive
15 actuation is better than manual as far as the
16 reliability goes.

17 MEMBER ARMIJO: Not a whole heck of a
18 lot.

19 MR. STUTZKE: Surprisingly not a whole
20 heck of a lot. And considering the uncertainties.

21 MEMBER POWERS: Those numbers are almost
22 identical.

23 MR. MONNINGER: But then it's -- we only
24 gave it a decontamination factor of 10 though for
25 the filter.

1 MEMBER POWERS: Probably all it
2 deserves.

3 MEMBER STETKAR: And this is only \$2,000
4 per person-rem.

5 MR. STUTZKE: Actually these numbers
6 don't defend on that monetization constant. These
7 are directly out of the MACCS output and so they
8 know the dollars --

9 MEMBER CORRADINI: So this is what MACCS
10 is computing with all its --

11 MR. STUTZKE: All of its horsepower and
12 assumptions, yes. The \$2,000 would be on the
13 previous slide on 86, a rough monetization.

14 Okay, we also have reductions in worker
15 dose risk and onsite cost risk. And the assumption
16 there on the consequences, those are not coming from
17 MACCS because MACCS can't calculate onsite
18 consequences. So in the regulatory analysis we used
19 a value that said well, if it is vented and it's
20 unfiltered the dose rate will be this. If it's
21 vented but it is filtered the dose rate will be
22 somewhat lower. And if it's a containment failure
23 the dose rate to the workers is some really big
24 number.

25 Same thing with the cost, cleanup cost.

1 You see on slide 89. That's why you don't see a
2 distinction between wetwell versus drywell in these
3 slides. The cost is the same.

4 What is interesting here is that some of
5 the earlier mods, mods 1 through 4, it's unfiltered
6 and yet there is a benefit to the worker. That's
7 because you've discharged it to the environment and
8 gotten it away from the worker. So it makes sense.

9 Last and not least on slide 90, remember
10 I talked to you before about the reduction in
11 conditional contaminated land area. And these are
12 the results.

13 So one way -- the way to interpret this
14 is let's consider -- let's pick a different mod now,
15 being mod number 2. So it's an unfiltered severe
16 accident vent attached to the wetwell passively
17 actuated. 224.8 fewer square kilometers that would
18 be contaminated above 15 microcuries. That's the
19 reduction in the land area that's contaminated above
20 15 microcuries per square meter.

21 And as you would expect these pattern-
22 wise match the population dose risk and they match
23 the offsite consequence risk. You see the red bars
24 are in the same place. I won't argue that they're
25 the same heights, but you see the same general

1 trend.

2 Okay. As part of the regulatory
3 analysis in addition to the point estimates you see
4 one needs some estimate of the high and the low
5 values. And thinking about it a little more and
6 thinking about the complexity of the event tree
7 structure it wasn't clear to me how to generate the
8 high value. Because if I say well, I increased the
9 probability that the vent fails to actuate, the risk
10 goes down a certain pathway. So it just seemed
11 easier to do some sort of an approximate Monte Carlo
12 approach to get a real feel for how this thing was
13 behaving like that.

14 This is under the type of analysis that
15 says the purpose of computing is insight, not
16 numbers. And so I realize it's not a real formal
17 analysis like that but it's trying to get a feel for
18 where the uncertainty slides. So I put
19 distributions not only on the numbers that affect
20 the sequence frequencies but also the consequences.

21 And we'll talk a little bit about how
22 that was done before I show you the results. CDF,
23 that was actually the easy one. It's log normal,
24 error factor of 10. People would debate whether
25 it's log normal or it's gamma but it's not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 unreasonable.

2 For all of the various split fractions
3 they're beta. The actual method is called
4 constrained non-informative power distributions.
5 That's why all of the parameters are set to one-half
6 and the other ones come out. I preserve the mean
7 value.

8 The technical insight is that when you
9 get to split fractions that have more than 2 and the
10 breakdown would be the sequence types for internal
11 hazards have four different categories. How do you
12 model that? Distribution. Generalized beta
13 distribution. So technically that was fun for me,
14 how to generate dose in Monte Carlo trial. Turns
15 out to be trivial, something like that.

16 Flipping over to the next slide, mod
17 zero were the event assumed to fail with probability
18 1's, not uncertain at all. The others follow on
19 these distributions.

20 Consequences. How do you put
21 uncertainty on the consequences in this type of a
22 form? Obviously you would want to know the aleatory
23 uncertainty because of the weather variations like
24 this, but there's also epistemic uncertainty
25 floating around like this.

1 Well, the SOARCA team has been working
2 on this and I can tell you, I've read the draft
3 uncertainty report and it is a tour de force of
4 modern uncertainty analysis. If you have insomnia -
5 -

6 (Laughter)

7 MR. STUTZKE: -- it will fix that. It's
8 actually, it's quite good. I shouldn't joke. I
9 mean, how to break out what's driving the
10 uncertainty in that type of an analysis is very,
11 very impressive and I learned a lot out of it.

12 But, being that way, the easy way to
13 generate the consequences is to assume that they are
14 totally correlated, they're totally dependent. That
15 means if the consequence in case 2 should be higher
16 so should it for all the other consequences, so
17 they're proportional. So I moved them up in lock-
18 step, just scaled them up.

19 And I said well, okay, so that
20 simplifies my computational issue too because it
21 means I only need to generate one random number and
22 I can calculate all the consequences because I'm
23 just scaling everything. And I said well, not
24 knowing any better, must be log normal with error
25 factor of 10. I had read once in IEEE transactions

1 on reliability about 25 years ago it says everything
2 looks log normal until you look.

3 MEMBER POWERS: That's exactly right.

4 MR. STUTZKE: You know?

5 MEMBER POWERS: Log normal fits
6 everything unless you look at it closely.

7 MR. STUTZKE: So I threw it on here and
8 then lo and behold I got the draft on SOARCA
9 uncertainty results. They gave me the 5th and the
10 95th and the median and so I got three points. And
11 I dutifully plotted them up on log normal
12 probability paper and it's almost a straight line.

13 (Laughter)

14 MR. STUTZKE: Like you said, don't look
15 very hard.

16 MEMBER STETKAR: And you were shocked to
17 learn that.

18 MR. STUTZKE: Yes, it turns out the
19 error factor is about 4 for latent cancer fatality.
20 And I'm going well, okay, so my 10 wasn't too far
21 off, and given the crudeness of this analysis. So
22 anyway, that's the spirit in which this is done, to
23 try to get some insight as to how bad -- how much
24 the numbers could be moving around.

25 So the next sets of viewgraphs show you

1 this. In all cases if you look at the ratio of the
2 95th to the mean values it's about three and a half
3 to four, four and a half. It doesn't seem to change
4 from mod to mod, it doesn't change from consequence
5 to consequence. And it doesn't surprise me because
6 what drives the uncertainty here is the uncertainty
7 on the core damage frequency and the uncertainty on
8 the consequence. All of the uncertainty on operator
9 reaction and whether the pump's going to be
10 installed seems to be irrelevant and that's not
11 surprising.

12 MEMBER CORRADINI: It seems to be what?
13 I'm sorry.

14 MR. STUTZKE: It's irrelevant. It's not
15 driving, it's not affecting these numbers.

16 MEMBER CORRADINI: Not dominant.

17 MR. STUTZKE: But you would expect that,
18 so. So we can flip through the last sets of slides.
19 I don't know that there's anything to point out
20 other than you don't see mods 3 and 4 in the
21 uncertainty analysis. After realizing they were not
22 beneficial I just kind of dropped them out of the
23 analysis. There's no reason they couldn't be done.

24 I think maybe to wrap up here, these
25 uncertainty results again, you know, the high and

1 low values needed in the reg analysis will be taken
2 as the 5th and the 95th values out of these types of
3 computations. It's probably a wide enough range to
4 demonstrate what the reg analysis needs to do.

5 If you all would care to comment on this
6 conditional contaminated land area risk metric I
7 would be very interested in that. Whether it's
8 useful. I think it's misleading. I thought about
9 it a great deal before I came up with this thing and
10 it's still not totally satisfying in some aspects.

11 Or not comment formally, drag me out in
12 the hallway.

13 CHAIR SCHULTZ: Comments for Marty on
14 this particular issue or other questions?

15 MEMBER ARMIJO: I have a question. On
16 your slide 90 I'm still trying to make sure I
17 understand. The case in which you have drywell
18 venting either manual or passive but no filtering,
19 there's an increase in the contaminated land area.

20 MR. STUTZKE: Yes.

21 MEMBER ARMIJO: But the base case has no
22 venting at all, no filtering and it fails at
23 containment somehow, somewhere along the line.

24 MR. STUTZKE: Right.

25 MEMBER ARMIJO: How can this be worse?

1 MR. STUTZKE: This way you gave it a
2 direct path outside the reactor building. There's
3 no holdup. There's nothing slowing it down in mods
4 3 or 4.

5 MEMBER POWERS: Plus you release when
6 you open up the vent and you do not get the benefit
7 of any agglomeration and deposition in the
8 containment.

9 MEMBER STETKAR: Okay, so you don't have
10 any holdup volumes.

11 MEMBER CORRADINI: And just so I -- I've
12 got to look back. In mods 3 and 4 -- I can't
13 remember what slide it is. Mod 3 and 4, there are
14 cases in there where the drywell has core sprays on
15 it? Sorry, but I don't remember now.

16 MR. STUTZKE: You're on slide 84?

17 MEMBER CORRADINI: Right. I'm trying to
18 understand mod 3 and 4 is manual passive in terms of
19 that, but within that cases there's case 214, 12 and
20 13 which means you have a wet -- I do have a wet
21 drywell.

22 MR. STUTZKE: Yes. That's what the
23 upper rows are for because I couldn't remember them
24 either.

25 MEMBER CORRADINI: Okay. I do have a

1 wet drywell but none of those are core sprays.

2 MR. STUTZKE: Well, if it says wet
3 drywell that means in your core spray or drywell
4 spray is on.

5 MEMBER CORRADINI: Okay. I'm sorry, I'm
6 sorry. I'm sorry.

7 MEMBER BLEY: And we always have RCIC
8 working?

9 MR. STUTZKE: Up to 16 hours until it
10 turns itself off.

11 MEMBER BLEY: Always works. It never
12 fails.

13 MR. STUTZKE: No, there's no RCIC fails
14 on demand.

15 MEMBER BLEY: Or over time.

16 MR. STUTZKE: I hear you. That may be,
17 you know, it goes back to that assumption.
18 Everything looks like an SBO until you look.

19 MEMBER STETKAR: Well, but if you looked
20 at one of your earliest slides 83 percent of the
21 internal event scenarios don't look like an SBO.

22 MEMBER CORRADINI: But that's not what
23 he's modeling. He's modeling the 12 percent.

24 MEMBER STETKAR: I understand that.
25 That's what we're saying.

1 MR. STUTZKE: Well, the 83 percent that
2 are not SBOs, the frequency is like it's what it is,
3 but the consequence is assumed to be just like an
4 SBO. Because we don't have MELCOR MACCS runs for
5 those non-SBO types of scenarios.

6 MEMBER STETKAR: But I mean, part of
7 that 83 percent is things like loss to feedwater and
8 RCIC fails to start.

9 MR. STUTZKE: All of these things.

10 MEMBER STETKAR: Which are high-pressure
11 melts.

12 CHAIR SCHULTZ: Other questions?

13 MEMBER BLEY: I have to study this
14 stuff.

15 MEMBER SKILLMAN: You asked about our
16 reaction to your contaminated land area.

17 MR. STUTZKE: Yes.

18 MEMBER SKILLMAN: I think it starts the
19 conversation. I'm not sure that the metric gives
20 exactly what it needs to be but I think it gets the
21 conversation going. So I think it's constructive,
22 it's useful.

23 MR. STUTZKE: I appreciate that because
24 there's so many different metrics MACCS2 could
25 actually produce. You know, they can talk about the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 number of people that are evacuated, they can talk
2 about the amount of land that is interdicted, the
3 amount of land that is condemned. And the
4 distinction being that MACCS2 is using a return
5 criteria which is expressed in terms of dose. This
6 is contamination per unit area which in my mind is a
7 different beast, it's a different animal.

8 MEMBER BLEY: I'm having a little
9 trouble with one thing. I'm trying to align your
10 mods with the cases. Mods 3 and 4 with the vented
11 drywell always look bad. But in some of those cases
12 you'd have drywell spray, right? Why don't we see
13 something that lets us -- between 3 and 4 when do we
14 have drywell spray? When we look at your results
15 with the red bars on them we just see 3 and 4 bad
16 and there's no distinguishing between those.

17 MR. STUTZKE: Yes. The question is
18 which sequences does it go to.

19 MEMBER BLEY: Yes.

20 MR. STUTZKE: And --

21 MEMBER CORRADINI: Because you have --
22 just so I say it, this is what I was confused about.
23 You have four sequences folded in, into any one of
24 the mods.

25 MEMBER BLEY: Yes. And they're not

1 equally --

2 MEMBER CORRADINI: Or not necessarily
3 four. You could have four or five.

4 MR. STUTZKE: Yes, the event tree
5 sequences apply to all mods, all 16 sequences
6 applies to every mod. And what you're changing is
7 the frequency, the proportion that goes there and
8 then the consequence that you multiply it towards.

9 MEMBER BLEY: So I can't see what I'm
10 looking for because they're --

11 MR. STUTZKE: I haven't given you the
12 level of detail --

13 MEMBER BLEY: -- probability weighted.

14 MR. STUTZKE: Yes.

15 MEMBER BLEY: Frequency weighted.

16 MR. STUTZKE: Right.

17 MEMBER BLEY: Yes.

18 MR. STUTZKE: In other words --

19 MEMBER BLEY: But some of those things
20 would make a big difference. I would think they
21 would make a big difference.

22 MR. STUTZKE: See, in other words if I
23 go to wetwell venting -- or excuse me, drywell
24 venting, that's the issue. Mods 3 and 4. Can we
25 flip back to slide 81 to look at the actual tree

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 structure?

2 MEMBER CORRADINI: But the way I
3 interpret your table is there are four sequences
4 that are within those two mods. Or is that an
5 incorrect interpretation?

6 MR. STUTZKE: I think that's an
7 incorrect interpretation. The way to interpret it
8 is there are five sequences that comprise this
9 vented status. Sequences number 1 and 4, 5, 10 and
10 13. Right? All of those are binned into this
11 vented scenario which then if I'm going to evaluate
12 modification number 3 I will apply MACCS case 13 to
13 get its consequences.

14 MEMBER BLEY: Now, just this particular
15 point I was hanging on. There will be differences
16 in the results of each of those sequences that sit
17 in there. We can't see that.

18 MR. STUTZKE: Not at this level of
19 detail.

20 MEMBER CORRADINI: Nor do we know which
21 one of those might dominate, of the five which one
22 might be a dominant one or they just all are --

23 MEMBER BLEY: We might be able to dope
24 that out if we look at them and think about it.

25 MEMBER STETKAR: Marty knows that.

1 MR. STUTZKE: It's in there but at the
2 same time --

3 MEMBER BLEY: But I mean, the problem we
4 were having, we were even talking about this. This
5 says venting the drywell looks terrible. But if
6 simultaneously you're spraying the drywell it
7 probably doesn't look as terrible. You just can't
8 see that in the way the results are summarized.

9 MR. STUTZKE: Right. Yes, I need to
10 give you the further breakdown.

11 MEMBER BLEY: There must be more things
12 like that that are kind of hidden because of the
13 categorization we did. Which means we might draw
14 some conclusions at this level that you might not
15 hold. Except they should be probabilistically
16 weighted such that they're probably okay.

17 MR. STUTZKE: Yes. I mean and that's
18 the intent.

19 MEMBER BLEY: I have to think about that
20 a bit more.

21 MEMBER CORRADINI: But can I -- I'm
22 sorry that I -- now that Dennis asked a question now
23 I'm -- so case 12 in terms of the MELCOR calculation
24 linking to the MACCS calculation drives all five of
25 these branch points, of these event tree branch

1 points.

2 MR. STUTZKE: End states.

3 MEMBER CORRADINI: Case 12 is drywell
4 vent at 24 hours.

5 MR. STUTZKE: Right.

6 MEMBER CORRADINI: Essentially modifying
7 case 2 which is the base case. And that has the
8 highest release fraction that MACCS then went and
9 sends out.

10 MR. STUTZKE: That's correct.

11 MEMBER CORRADINI: And it's higher than
12 everything. So unless one's looking at the MELCOR
13 calculation and says there's something inherently
14 conservative with that, that drives all five of the
15 cases.

16 CHAIR SCHULTZ: And so the integrated
17 response is fairly similar between each of these
18 presentations. For each of the metrics that were
19 chosen.

20 MEMBER CORRADINI: Yes. Because that's
21 the highest release fraction that would affect all
22 these key contributors, at least from what we heard
23 from the previous presenters.

24 CHAIR SCHULTZ: Where those previous
25 presenters were focusing in on particular event

1 sequences and the differences in results. Core vent
2 and no vent.

3 MR. STUTZKE: Yes, and what you see
4 there is probabilistically weighted. It's the sum
5 times the sequence frequency times the consequence
6 summed up. Classic risk definition.

7 MEMBER BLEY: When we get to the point
8 of figuring out whether your qualitative arguments
9 eventually make sense some of it's going to hinge on
10 the stuff that's tied up in this analysis in ways
11 that we've got to figure out a little bit to see if
12 those arguments really carry through. Maybe there
13 is a particular set of things within one of these
14 cases that would look very well if we pushed it in
15 that direction. This might not all be clear to
16 anybody, I'm just babbling a bit.

17 MEMBER CORRADINI: My reaction is if we
18 stopped at just what MELCOR says is released out of
19 containment it totally is dominated by that cesium
20 fraction. I mean, all the subsequent things are
21 totally dominated by what you released.

22 MEMBER SIEBER: That's right.

23 MEMBER BLEY: Which if we go back to
24 this case says -- that's case 12, right, that gets
25 us that one?

1 MEMBER CORRADINI: That's what I read it
2 to be, yes.

3 MEMBER BLEY: If that's right then
4 within mod 3 and 4 which look bad on the charts we
5 were looking at, actually it's just the LNT case
6 that's so bad. This stuff's heavily interrelated.
7 I don't know if you guys have had a chance to
8 distill it at this deeper level to really be sure
9 about what you've got. I'm sorry, Marty.

10 MR. STUTZKE: No, maybe another way to
11 do it is to flip back to slide 85 that showed you
12 the frequency contributions.

13 MEMBER BLEY: Back with the top cases.

14 MR. STUTZKE: Each one of those -- so
15 these are the contributions for overpressure, liner
16 melt-through or both. And by implication, for
17 example, if I look at the manual vent column what it
18 says is 46.8 percent are vented, right? It's 100
19 minus the 53.2 percent, right? And so ask yourself
20 then -- so I'm going to take 0.4 percent times the
21 consequences of the overpressure MELCOR case and
22 19.6 percent times the liner melt-through case, et
23 cetera.

24 And so the bottom one here when you look
25 at mods 3 and 4 that says I'm taking 46.8 percent

1 times the vented case for mods 3 and 4 which says
2 it's through the drywell, it's not filtered and the
3 consequences are big as you pointed out. And that's
4 why you get the big red bars.

5 MEMBER CORRADINI: That's why the red
6 bar for the passive is larger than the red bar for
7 the manual.

8 MR. STUTZKE: Yes, because you've made
9 that hole even more reliable.

10 (Laughter)

11 MEMBER STETKAR: Some of the earlier
12 stuff we said is you don't put a rupture disk on
13 there, it's actually worse.

14 MR. STUTZKE: The other way to interpret
15 it is if you were to look at slide 87 for this
16 monetization and you see the big red bars, that
17 means you should be willing to spend \$592,000 to
18 remove the system. It's that bad.

19 CHAIR SCHULTZ: And I think that was
20 coming out in some of the results that were shown
21 earlier from the MACCS study.

22 MR. STUTZKE: These are the reflections
23 of the MELCOR MACCS results, just frequency averaged
24 together.

25 MEMBER BLEY: Unless you can make sure

1 you don't get into that problem over here.

2 CHAIR SCHULTZ: That's correct.

3 MEMBER BLEY: You've got to do it in a
4 couple of pieces to get the argument. Interesting
5 stuff.

6 CHAIR SCHULTZ: Other questions?

7 MEMBER SKILLMAN: Yes, Marty, your
8 global statistical value on slide 77.

9 MR. STUTZKE: Yes.

10 MEMBER SKILLMAN: I've never seen that
11 before. Just how did you get the denominator,
12 please?

13 MR. STUTZKE: It's roughly 15,000
14 reactor years of worldwide operation.

15 MEMBER SKILLMAN: That's the calculated
16 value approximately today?

17 MR. STUTZKE: I saw that number reported
18 on the WANO website, World Association of Nuclear
19 Operators.

20 MEMBER SKILLMAN: Because I get a number
21 about half that. I was just curious. Thank you.

22 CHAIR SCHULTZ: We are ready for the
23 next topic before we have a break and the next topic
24 is regulatory analysis. Aaron Szabo is going to be
25 making that presentation. Bio break for 5 minutes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 (Whereupon, the foregoing matter went
2 off the record at 3:35 p.m. and went back on the
3 record at 3:44 p.m.)

4 CHAIR SCHULTZ: The next presentation is
5 associated with the regulatory analysis and
6 backfitting evaluation approach. Aaron Szabo is
7 going to make the presentation from the staff.

8 Aaron, please proceed. Thank you.

9 MR. SZABO: I'm Aaron Szabo, cost
10 analyst at NRR in the Rulemaking Branch. I work on
11 the regulatory analyses. Next slide.

12 This is just generally an outline I'm
13 going to go through. I'm just going to apologize
14 now for anyone who was here yesterday afternoon. A
15 lot of it might be similar. Hopefully maybe we've
16 got something new. But I'm going to go through just
17 the regulatory decision-making process, the
18 methodology for the regulatory analysis, kind of the
19 methodology for backfitting and then just go
20 specifically into the filtered vents regulatory
21 analysis. Next slide, please.

22 So, the first point I want to make about
23 regulatory analysis is it looks at all the costs and
24 all the benefits for any regulatory action. The
25 important thing to note is we've been talking in all

1 these past presentations of quantified analyses to
2 lead up to what eventually will go into the
3 regulatory analysis.

4 But really the quantification is only
5 one input to the regulatory analysis. For all those
6 costs and all the benefits we can't quantify we do
7 qualify them which the next presentation is going to
8 go into in more detail.

9 And also with the regulatory analysis
10 it's important for us to just outline all the
11 uncertainties with the analysis which you guys have
12 seen throughout today. In relation to just
13 backfitting for this situation it's based under 10
14 C.F.R. 50.109 which is the backfitting provision.
15 Next slide.

16 As you guys have heard before there's
17 four options in relation to when you see the
18 regulatory analysis. There's just a little bit of a
19 terminology difference. We call them alternatives
20 but it's essentially the same thing. We review all
21 four of these options through this.

22 And we are doing that using the current
23 framework which is NUREG/BR-0058 which is called the
24 Reg Analysis Guidelines, NUREG/BR-0184 which is the
25 Reg Analysis Technical Handbook and NUREG-1409 which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is the backfitting guidelines. If there are any
2 deviations that we make from the guidelines we just
3 provide them as a sensitivity analysis.

4 I also wanted to just reemphasize a
5 point about the technical handbook that Marty
6 brought up. Really a lot of the numbers were used
7 for examples. It was produced in 1997 based on
8 earlier reports. And the idea is you try and use
9 your MACCS code, your MELCOR and your MACCS when you
10 can. You really just fall back on these when you
11 don't have either the opportunity or the ability to
12 use those codes. Next slide, please.

13 Just when we perform a regulatory
14 analysis what we just do first is we identify the
15 problem and just look at what the alternatives are.
16 We determine if the action is a backfit which it
17 would clearly be in this situation. And then we go
18 through everything that we call attributes. Listed
19 there is everything what -- the attributes we looked
20 at for this regulatory action which include public
21 health and occupational health in case of an
22 accident, the offsite and onsite property as well as
23 the industry and NRC implementation operation costs.
24 As well as there's some other attributes like
25 regulatory efficiency as well as some other

1 situations like defense-in-depth that once again
2 will be talked about more later.

3 We then combine all those attributes
4 together, do a cost-benefit analysis and we develop
5 some recommendations for the Commission. Next
6 slide, please.

7 These recommendations are provided using
8 what we call the best estimate calculations per the
9 guidelines. As Marty pointed out their point
10 estimates for -- in this case. And this is just
11 kind of explaining what Marty's already done.

12 It's just -- we multiply all the
13 benefits and the costs times the probability. We
14 don't look at them without probability as clearly it
15 would just obscure things to the high end and might
16 give false impressions. And as stated before we
17 provide sensitivity analyses for the decision-
18 makers. Next slide, please.

19 On the backfitting, the first step in
20 backfit after you determine it is a backfit and
21 falls within the backfit rule is you look into
22 whether it falls under one of the exceptions.
23 Usually this would be adequate protection for these
24 cases. So the first review the staff would do would
25 be to look at whether any of these options would

1 fall under the adequate protection determination.

2 If it doesn't fall under the adequate
3 protection justification we then go into what's
4 commonly called the backfit analysis. It's also
5 called cost-justified substantial safety
6 enhancement.

7 This is a two-part analysis. The first
8 part is the substantial safety enhancement. The
9 second part is the cost justified.

10 And I just wanted to lay out here
11 something that the Commission stated back in 1993 in
12 an SRM. It really states that for the substantial
13 safety enhancement section they really want to keep
14 it as a flexible option with what they originally
15 intended. After the backfit rule the staff went
16 back to the Commission with some lookbacks kind of
17 on the backfit rule and this is what the Commission
18 came back with.

19 It states that for the substantial --
20 that includes both quantitative and qualitative
21 arguments. And the Commission would really like to
22 see things that -- even if it's not necessarily
23 considered what the staff might be substantial then
24 if it's still cost-justified they would like to see
25 it in front of them. And moving onto the next

1 slide.

2 So for the substantial safety
3 enhancement section the attributes that we would
4 look at within the backfit rule would be just the
5 public health and occupational health. So really
6 the substantial safety enhancement section only
7 looks at the averted person-rem and not at any of
8 the onsite or offsite property or any implementation
9 or operation costs. Next slide, please.

10 And then just moving onto the cost-
11 justified section. This is where we would add in
12 everything. And this is really, when you're looking
13 at the backfit analysis this is really going to be
14 almost exactly the same thing as the regulatory
15 analysis. That's why the person who does the
16 regulatory analysis usually just also does the
17 backfit analysis. It's just a lot of reference to
18 the regulatory analysis. And as you can see it's
19 all the attributes that I listed earlier. Next
20 slide, please.

21 As you saw during Marty's presentation
22 he mentioned that the onsite property and the
23 occupational workers came from the Technical
24 Handbook and not from the MELCOR/MACCS code. I just
25 wanted to provide within the Technical Handbook kind

1 of where these numbers came from.

2 For the onsite property, option 1, your
3 status quo is assumed was the upper bound of what
4 they said the onsite property costs would be which
5 were about \$2 billion in 1993. And escalating using
6 just a CPI, a consumer price index, to 2012 it's
7 about \$3.2 billion. Option 2 was what they
8 considered their middle or best estimate. We assume
9 that would be for just normal venting.

10 And option 3, the filtered vents we
11 thought would be close enough to TMI that the
12 options which were the low estimate or TMI for --
13 within the Technical Handbook would be similar to
14 having a filtered vent. So, for the onsite property
15 that was \$750 million back when -- in 1981, or \$1.9
16 billion today.

17 For occupational workers during the
18 accident we used the same kind of analysis. The
19 Technical Handbook had an upper, middle and lower or
20 TMI and we followed the same idea.

21 Just as a quick note, it does assume
22 there's 1,000 workers onsite working on this so
23 they're all getting low dose. And the occupational
24 workers does not include the decontamination cleanup
25 cost of offsite property. That was actually

1 subsumed within the MACCS2 public health, the
2 person-rem code. So any of the decontamination or
3 cleanup offsite was accounted for there. Next
4 slide.

5 MEMBER SKILLMAN: Aaron, those options
6 on page 109, slide 109 --

7 MR. SZABO: Yes.

8 MEMBER SKILLMAN: -- are the same
9 options as indicated on slide 102?

10 MR. SZABO: Yes.

11 MEMBER SKILLMAN: Thank you.

12 MEMBER ARMIJO: Aaron, these numbers
13 seem low to me. Let's take option 1. You -- or any
14 of them. You lose the reactor, right?

15 MR. SZABO: Yes.

16 MEMBER ARMIJO: In these events. And
17 replacement cost, is that included or not?

18 MR. SZABO: Sorry, just -- this is not
19 including replacement energy costs. Sorry.

20 MEMBER ARMIJO: I mean the reactor, the
21 investment.

22 MR. MONNINGER: It's just cleanup of the
23 site, decommissioning and cleanup is the onsite
24 property. It's not the replacement power --

25 MEMBER ARMIJO: Not considered --

1 MR. MONNINGER: -- or rebuilding it.

2 MR. SZABO: We do consider replacement
3 energy.

4 MEMBER ARMIJO: Just the energy.

5 MR. SZABO: Yes, but that is -- it is
6 part of the onsite property attribute but it is not
7 within this part of the onsite property. This is
8 just the property itself.

9 MEMBER SHACK: But again, if you're
10 looking at a cost to society why not the cost of the
11 replacement plant?

12 MR. SZABO: It will be -- it is included
13 in the regulatory analysis. This was just showing
14 these first couple of assumptions, these are
15 assumptions that we do make that I'll be showing
16 later.

17 However, for the plant itself because
18 we're assuming that we're at -- there's core damage,
19 there's severe accident, that unit itself is already
20 lost. So we wouldn't -- there's no delta
21 replacement energy from your status quo between your
22 options.

23 So I'll go into this -- well I can go
24 into this now. So your really only delta would be
25 if you have a multi-unit site. This would be the

1 difference between being able to work those other
2 units. That would be the only consideration we
3 would make within using the current framework as a
4 delta between.

5 MEMBER ARMIJO: Yes, I was off base
6 because if you lose a plant whether you have a
7 filtered vent or a non-filtered vent you've lost the
8 plant so it doesn't make any difference in the --
9 got it.

10 CHAIR SCHULTZ: But it is a good point
11 for a sister unit onsite.

12 MEMBER ARMIJO: If you would somehow
13 lose that you'd know it wasn't through
14 contamination.

15 CHAIR SCHULTZ: That's a possibility.

16 MR. SZABO: Next slide. Yes, I'm about
17 to go into -- go to the next slide.

18 So this goes into our current framework
19 as well as our sensitivity analyses. Just going
20 through the parameters so you can see there's about
21 five different parameters that we've run
22 sensitivities for. I'll just go through them one by
23 one.

24 The dollar per person-rem, as was
25 mentioned quite a bit yesterday as well as today.

1 NUREG-1530 is the dollar per person-rem. And it
2 says that currently it's \$2,000 per person-rem.
3 There's a currently and ongoing effort to update
4 that number.

5 Therefore, as just -- we believe as a
6 conservative sensitivity analysis we use the most
7 recent EPA valued statistical life which is \$7.3
8 million as well as the most recent ICRP number 103.
9 And this is using the same -- this is the same
10 analysis that we did for determining the \$2,000 per
11 person-rem. The \$2,000 per person-rem was just the
12 value of statistical life times a risk cancer factor
13 which was from ICRP number 60. This is just an
14 escalation of that to determine -- to come to the
15 \$4,000 which we provide as a sensitivity analysis.

16 Also, the discount rate, we currently
17 follow OMB Circular A-4 guidance which says that you
18 should net present value, all values at 3 percent
19 and 7 percent. The basis for these numbers, the 3
20 percent was your return on a government investment
21 and your 7 percent was your return on a private
22 investment. As we've seen --

23 (Laughter)

24 MEMBER STETKAR: Sure, you don't have to
25 retire in the next couple of years.

1 MEMBER ARMIJO: Better check those
2 numbers.

3 MR. SZABO: Those numbers, you know,
4 might not necessarily reflect the current market.
5 So as a sensitivity we're providing the undiscounted
6 discount rate. And this is also for both benefits
7 and the cost side because for your operation cost
8 you do have to do a net present value for that.

9 Then, as Marty was talking about, for
10 your CDF, for your initial event probability we used
11 the 2E to the -5th for our current framework as well
12 as the global statistical value just as a
13 sensitivity analysis.

14 Once again, kind of when Marty was
15 talking about his presentation he ran a Monte Carlo.
16 We used the point estimate as our best estimate.
17 However, we provide a low and a high of the 5th and
18 95th percentile.

19 And now onto replacement energy costs.
20 So in the current framework we follow the Technical
21 Handbook which was back in 1997 based on 1995 or
22 earlier numbers which said it was about \$15.4
23 million per year to replace energy.

24 Just to go into some background about
25 how we do the replacement energy costs. We assume

1 that every unit has a 10-year purchase power
2 agreement. So what we do is we assume that if you
3 have at least 10 years left in operation that you
4 wouldn't necessarily just multiply this 15.4 times
5 10 because you have to discount the numbers, but
6 it's similar to that. So, you losing a unit today
7 at an undiscounted rate would really cost \$154
8 million. The idea is that within 10 years they
9 would have established new energy sources to replace
10 that energy and would no longer be bound by that.

11 As stated, four, we assumed that the
12 other site would be lost if you are not able to do a
13 filtered vent. So we believe that there would be
14 enough radiation from either the status quo or just
15 venting without a filter that the other unit would
16 not be operational and thus you would need to
17 replace the purchase power.

18 Another ongoing effort is we have
19 provided -- we have developed new, updated,
20 regional-based replacement energy costs. And so
21 just a high and low from that as they are
22 sensitivity analysis is just -- it's either \$716,000
23 a year up to \$56.3 million. That's the lowest
24 regional -- the lowest low and the highest high. As
25 it's a sensitivity analysis we just wanted to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 provide the low and the high.

2 And generally for regulatory analyses
3 under the current framework we do not -- things that
4 are based on policy decisions are usually considered
5 to be too speculative for us to consider. However,
6 as we've seen from recent history the idea of a
7 policy decision to shut down all Mark I and Mark 2
8 reactors is not unreasonable so we've also decided
9 to provide that just as a sensitivity analysis.
10 Next slide, please.

11 Just as I mentioned before, the
12 recommendation, however, is based on the current
13 framework. With all these sensitivity analyses we
14 pretty much end up with 107 of them. So that kind
15 of gives you an idea of the general range of where
16 we're going, the highs and the lows. And there is
17 quite a range in that.

18 And there is no sensitivity provided for
19 the cost. However, we do provide a range for the
20 cost.

21 MEMBER ARMIJO: Aaron, would you go back
22 to that justification? What makes it reasonable to
23 consider that all the reactors, the Mark I and Mark
24 2 containments would be shut down by the Agency?

25 MR. SZABO: Well, we believe that it

1 wouldn't be an NRC decision. This would clearly be
2 a decision made by politicians as I don't think we
3 would necessarily -- I don't know if we would have
4 the right to.

5 MEMBER ARMIJO: Okay, so it wouldn't be
6 a regulatory. It would be some --

7 MR. SZABO: Yes. This would be a policy
8 decision above the NRC.

9 MEMBER POWERS: I guess what I don't
10 understand is how does that change with whether I
11 have a filter or not.

12 MR. SZABO: It would be considered a
13 benefit for either venting or -- the idea is that
14 all Mark I and Mark 2 reactors would be shut down if
15 there was a significant release from a severe
16 accident. So if they're able to mitigate the severe
17 accident that it would still ensure enough
18 confidence that the other reactors would still be
19 able to operate.

20 MEMBER POWERS: At least my recollection
21 of the results that were shown to us just previously
22 is the only ones of those cases that was different
23 was the one where you had an unfiltered drywell
24 vent. Otherwise they were about the same. And so
25 I'm still a little --

1 MR. SZABO: It would be the same benefit
2 for both, for both option 2 and option 3, both
3 venting -- having a severe accident capable vent and
4 having a filtered vent would provide the same
5 benefit in relation to that.

6 MEMBER ARMIJO: But you have the German
7 experience where they have filtered vents. They're
8 shutting down all their reactors. So, I mean how
9 does that -- why is that?

10 MEMBER STETKAR: PWRs and BWRs.

11 MEMBER ARMIJO: P's and B's and
12 everything. So, you know, it just seems --

13 MR. MONNINGER: That would argue to move
14 it from a sensitivity to the current framework
15 though, wouldn't it?

16 MEMBER ARMIJO: I don't know. I'm just
17 trying to find out is it right to -- or at all.

18 MR. RULAND: The purpose of doing the
19 sensitivity is just to provide information to the
20 decision-makers. And you know, you can agree or
21 disagree with the assumption but that's all, that's
22 the purpose of doing the sensitivity study.

23 MR. SZABO: So you can ignore it if you
24 don't believe any reactors would be shut down or,
25 you know.

1 MEMBER BLEY: So this is just a one-
2 liner. The sensitivity study would be how likely
3 would it be that this would happen given the four or
4 five scenarios we've got, or eight, I'm sorry.
5 Whatever the number.

6 What is a sensitivity study? What I
7 haven't understood is under this case what is the
8 sensitivity study? What will you actually do?
9 What's the sensitivity you'll be looking at? It's
10 not sensitivity to this, this is a result, right?

11 MR. SZABO: It's a sensitivity in
12 relation to its -- I guess outside our current
13 framework is another way you can frame this. I
14 mean, instead of a sensitivity it's just a -- I
15 guess alternative framework is what you can think of
16 it as.

17 CHAIR SCHULTZ: You have to presume that
18 in the event of an accident, because we are assuming
19 that the accident occurs, that the vent -- having a
20 vent would make a difference as to whether you shut
21 down all 30 units or not. It's just an economic
22 evaluation of how much it would entail to shut down
23 30 units versus not doing it in the event that that
24 would make a difference in public reaction.

25 There's other cases there of course.

1 One would be for an event to occur without a vent,
2 and then that would cause all vents to be added to
3 Mark I and Mark II's at that point in time.

4 In other words, there's a number of
5 scenarios that could be envisioned and this is the
6 worst one at least for the Mark I and II's.

7 MEMBER ARMIJO: Go ahead.

8 MR. SZABO: Those are the same four.
9 There's quite a bit of sensitivity cases that are
10 going to be -- we're currently working on, are going
11 to be provided. I guess we'll get onto the costs.

12 We're still going through -- these are
13 preliminary numbers. For option 2 the idea is that
14 these are total costs, by the way, for industry.
15 That would cost about \$60 million so about \$2
16 million per plant to install, to update the vents to
17 be severe accident capable. And with our NRC cost
18 as well it comes up to a total of about \$68 to \$72
19 million. Next slide.

20 So, here's the benefits for option 2
21 based only on the current framework. The ranges are
22 just based on the 3 and 7 percent discount rates.
23 So the public health, the total person-rem averted
24 is 112.

25 MEMBER CORRADINI: And where does that

1 come from? Just remind me where that comes from
2 then?

3 MR. SZABO: That's Marty's -- what Marty
4 had before based on reactor year. So he had I think
5 it was like 4 person-rem averted per reactor year
6 for wetwell.

7 MEMBER CORRADINI: That's why I was
8 going back to Marty's to find it.

9 MR. SZABO: Yes. So then you multiply
10 that by the 31 reactors per year and the average
11 life let is 25 years. So I'm not --

12 MEMBER CORRADINI: Marty had -- oh, I'm
13 sorry. You're right, four. Sorry.

14 MR. SZABO: So it's that times 31 times
15 25 gives you about your 112.

16 MEMBER BANERJEE: Is there any benefit
17 to the goodwill? Like companies say things are
18 worth \$1.5 billion goodwill. We have that. Like
19 Proctor & Gamble will say a branding.

20 MR. SZABO: No.

21 MEMBER BANERJEE: We have no benefit to
22 goodwill out of this?

23 MEMBER POWERS: Goodwill is a fudge
24 factor in accounting.

25 MEMBER BANERJEE: But that's more real

1 than most of these things. Does it give you any
2 benefit of public perception?

3 MR. MONNINGER: You could potentially
4 include it within the qualitative arguments if you
5 felt it's --

6 MEMBER BANERJEE: I don't know, I mean
7 these things are quantitative when it comes to
8 public companies. I mean people put values on them.

9 MEMBER BROWN: What about the public
10 confidence in the plants? I mean, there's no
11 benefit at all granted for that at all. And yet
12 based on the information, I mean the public
13 confidence in Japan now is zero.

14 MR. SZABO: Well that's getting into the
15 psychological benefits and there's questions as to
16 whether or not the NRC is allowed to consider
17 psychological benefits. I don't know if there's an
18 attorney here. I know at least some of them would
19 say you can't consider psychological costs or
20 benefits. And that's based on a TMI case from back
21 in the eighties.

22 MEMBER BROWN: So 30 years of not being
23 able to do anything. Real bad public confidence at
24 that time.

25 MEMBER BANERJEE: I think that's the

1 most important factor.

2 MR. SZABO: I guess it is a factor.

3 MEMBER BROWN: It's a big factor.

4 MEMBER SIEBER: It has to reflect itself
5 directly in money. And good public perception of
6 nuclear power will not increase sales. The plant is
7 100 percent. And so you may get a public benefit
8 out of it but it's not worth -- it does not have a
9 monetary value because it doesn't reflect itself in
10 your financial statement.

11 MR. SZABO: And in general, I know
12 you're talking about for the operator. It is -- the
13 regulatory analysis does look at it in a societal
14 framework. So really our only -- our delta benefit
15 would be any I guess happiness from the people being
16 more confident in it.

17 MEMBER CORRADINI: So I guess I'm -- I'm
18 listening to what Sanjoy said. I haven't gotten
19 past -- I still don't understand your 112. But
20 where's the stock price loss in all of this? If I
21 were a utility and I had one of these and I released
22 it offsite what would my stock do? Would it stay
23 where it is? I don't think so. So where's that
24 cost or the negative of that cost reflected in any
25 of this?

1 MR. SZABO: Well, I guess the -- my off-
2 the-cuff answer, other than it being very
3 speculative trying to come up with any number that,
4 you know, other than having a line stating that we
5 believe that the stock will drop.

6 MEMBER CORRADINI: You closed 30 BWRs
7 just a minute ago on your sensitivity so it's not
8 anymore nutty than that, excuse my English.

9 MR. RULAND: Aaron, you know, you don't
10 have to go here, you know.

11 (Laughter)

12 MR. RULAND: I mean, this is -- this is
13 very speculative as far as we're concerned.

14 MR. SZABO: Well, I just also wanted to
15 get into the idea of transfer of payments which is
16 what stocks essentially are. You know, someone has
17 to buy it, you know, to sell someone has to buy.
18 And it really comes -- we're looking at this as a
19 societal whole. So even if your stock's dropping
20 the idea that someone buys it is more of a transfer
21 of payment.

22 MEMBER CORRADINI: But I mean just --
23 I'll push it, then I'll shut up. The Seveso
24 accident in Italy, the chemical company went
25 bankrupt. Bhopal, there is no more Union Carbide,

1 okay? There is no more TEPCO. British Petroleum --
2 I mean, we can pick these accidents all over the
3 place and they don't have to be nuclear and I guess
4 I'm back to Sanjoy. Sanjoy's point said it in good
5 perception. But forget percpetion, let's just deal
6 with money. The company will suffer somehow.
7 That's what I think you're getting at.

8 MEMBER BANERJEE: Well, the industry
9 does. The Seveso accident led to the Seveso
10 directive.

11 MEMBER CORRADINI: Right.

12 MEMBER BANERJEE: Which had an enormous
13 impact.

14 MEMBER CORRADINI: On loss prevention
15 for the chemical industry.

16 MEMBER BANERJEE: Hundreds of billions.
17 So I think you have to be -- and then they had to
18 install emergency relief systems which would handle
19 two-phase flows, you know, treatment after that.
20 It's a big deal. They had to do it.

21 MR. RULAND: Aaron, while these are
22 interesting issues they aren't in our current
23 regulatory framework.

24 (Laughter)

25 MEMBER ARMIJO: Could you just flip back

1 one thing to the previous 112? The cost. Those
2 industry costs, are those the costs for the filtered
3 vent? These are just the costs of the accident.

4 MR. MONNINGER: This is beefing up the
5 valves for the existing order vent. We assume \$2
6 million per unit.

7 MEMBER ARMIJO: We're still on option 2
8 with upgraded hardware. Got it.

9 MR. SZABO: Let's go back to the
10 previous slide. So these are, as I was saying
11 before, they're kind of just pulled from Marty's
12 probability-weighted numbers and are extrapolated
13 out over all the reactor years and discounted.

14 And as you can see the offsite property
15 and onsite property provide a total benefit of about
16 \$16 and a half to \$24 and a half million. However,
17 as you can see the net value of option 2 is about
18 negative \$43 and a half to negative \$55 and a half
19 million for the industry total. Next slide, please.

20 Onto filtered vents. So here's --
21 filtered vent cost is, the assumption is about \$15
22 million per unit.

23 MEMBER CORRADINI: So, now I'll take the
24 other side of the coin. You guys have used that
25 number three times today. I can't believe it's that

1 cheap. I just cannot believe it's installed safety-
2 grade seismically qualified. That is, that's --

3 MR. DENNIG: Not safety-grade.

4 MEMBER CORRADINI: Not safety-grade.

5 MEMBER BLEY: But it's got to be
6 seismic.

7 MEMBER CORRADINI: It's got to be
8 seismic. Fifteen million seems like a bargain
9 basement price.

10 MR. DENNIG: That number is extrapolated
11 from talking to vendors and talking to licensees.
12 And that number includes in at least one case a
13 seismic installation, the \$14 million for Point
14 Lepreau is seismic. The extent to which you would
15 get a seismic installation here for that amount of
16 money, I don't know, but that's not currently one of
17 the things that's in the mix as part of the option
18 is to make it --

19 MEMBER CORRADINI: My only reaction is
20 that looks at least two to three times too cheap.

21 MEMBER ARMIJO: Yes, I agree with that.
22 Does that include the parts of option 2, the
23 upgrades in the option 2 to make this thing work?

24 MR. MONNINGER: No, this would be
25 costing this from a clean system. It's not the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 delta from option 2 to the current. It's costed out
2 on --

3 MEMBER ARMIJO: But if they actually did
4 it they'd have to make some plant modifications to
5 get this thing in. Anyway, the cost seems low.

6 MEMBER STETKAR: I don't know where you
7 got your cost information, you know, your actual
8 installed cost information. I'm familiar with a
9 couple of plants in Europe that perhaps buried some
10 of their cost because they were doing major upgrades
11 to other emergency facilities at the same time. So
12 how much they allocated perhaps to this particular
13 feature might not necessarily be all that clear.

14 MR. BETTLE: Yes, the cost is going to
15 vary considerably from plant to plant. In talking
16 about like upgrading to a filter, the filter vessel
17 itself is probably going to dictate the routing.
18 Some plants might have to pretty much just sacrifice
19 what they currently have and then be better off or a
20 net cheaper arrangement is to go from scratch. So
21 it's going to vary quite a bit if you just focus on
22 that particular number.

23 Others are probably going to be there.
24 Probably not a whole lot less, but probably in that
25 ballpark. This is basically where the amounts of

1 foreigners -- in foreign countries the licensees
2 were telling us what they spent and putting it in
3 U.S. dollars.

4 MEMBER STETKAR: Can I ask which
5 particular countries?

6 MR. BETTLE: Sweden, Switzerland and
7 Canada. Now --

8 MEMBER STETKAR: I know about
9 Switzerland. I don't want to share information,
10 but.

11 MR. BETTLE: Yes. The only guesstimate
12 as far as the actual filter vessel that we've
13 gotten, obviously these are a high-cost item and if
14 you want to get a firm quote you're going to have to
15 probably be ready to pony up money.

16 But you're looking at a ballpark of \$3
17 million for a vessel size to handle just the filter
18 itself, not the whole modification and piping system
19 and valving and so forth. But the filter itself
20 would be about \$3 million for 600 megawatts. It's
21 about \$6 million for a 1,200-megawatt unit. I say
22 that's not on the basis of a firm quote, so it's
23 just a --

24 MEMBER STETKAR: That's without the
25 massive reinforced concrete seismically categorized

1 structure to house this thing. If you don't have
2 one.

3 MR. SZABO: So that gives us the total
4 of about \$470 to \$480 million for the cost. Moving
5 onto the next slide.

6 So our benefits. Once again your
7 person-rem for the public is about 212 averted,
8 about 6 to 10 million, you know, slightly higher
9 than what you saw for the severe accident capable.

10 The onsite property costs are really
11 where you'll see a big delta here. And that's where
12 you have your sites where you are now no longer
13 losing the other unit because you're in pretty much
14 what we assume sort of a TMI-type situation where
15 it's only the one unit is really gone and you're
16 still able to operate the other one. And that
17 provides a total benefit from -- to about \$125 to
18 \$211 million.

19 And as stated earlier, you know, that's
20 not quantitatively cost-beneficial. About \$250 to
21 \$350 million in the negative I don't think surprises
22 anyone.

23 MEMBER BROWN: So offsite property is
24 only -- that's the contamination and everything else
25 that goes with it. Is that wrapped up in that? And

1 recovery of the land and all that type of stuff.
2 Only \$14 or \$15 million.

3 MR. SZABO: Yes, that's equivalent to
4 what the MACCS2 calls the economic consequences. We
5 just call it -- and that's, yes, frequency-weighted,
6 yes. And delta relative to what base would be.

7 MEMBER STETKAR: Remember the base is
8 really high. This is frequency-weighted delta,
9 right?

10 MR. SZABO: Yes.

11 MEMBER BROWN: Which means it really
12 costs \$30 billion but it's unlikely to happen so
13 it's only \$14 to \$20?

14 MR. SZABO: Delta.

15 MEMBER ARMIJO: If it happens it's going
16 to be a big number.

17 MR. SZABO: Yes, this is with 10 to the
18 -5 and the rest of Marty's probability tree.

19 MEMBER CORRADINI: So what was the
20 frequency used to weight this? I'm sorry.

21 MR. SZABO: Well, the initial CDF was
22 the 2E to the -5 and then it was -- yes, and then
23 Marty's. It's straight from Marty's earlier reactor
24 year.

25 MEMBER BANERJEE: So if you take the

1 frequency out what have you got?

2 MR. SZABO: It's what the MACCS code was
3 saying earlier.

4 MR. MONNINGER: Base case was \$1.9
5 billion in cost and the cost for the -- up to the
6 cost for the drywell venting which was about \$30
7 billion. That's the bottom lines on 66 and 67.

8 MR. SZABO: Your filters drive you into
9 the hundreds of millions if not -- a couple of
10 hundred million if not lower.

11 MEMBER BLEY: When you make these
12 decisions just doing it on an expected value basis
13 is deceptive sometimes. Every time. And to also
14 see the probability and the real answers, or the
15 probabilities and the real costs is very helpful
16 because when you look at expected number of deaths
17 in an accident and you see 0.0004 that looks like a
18 little number but it's a high probability of zero
19 and a low probability of maybe a lot. And that's a
20 very different picture than you get just seeing the
21 expected value. So, whoever has to make decisions
22 on these things really needs more information than
23 just the expected value. It's very deceptive.

24 MEMBER STETKAR: The 5 percent
25 probability that you'd lose 40 percent of your net

1 worth is a lot different than your expected value of
2 a slight increase in your net worth.

3 MEMBER BLEY: I would certainly want to
4 see that.

5 MEMBER STETKAR: You would certainly
6 want to see that, wouldn't you?

7 MEMBER BLEY: I just think it's -- I
8 mean, it isn't wrong, but it's deceptive. I think
9 you need both. Here's the expected value and here's
10 what goes into it. A very high probability of no
11 cost or benefits, whichever side we're working on,
12 and a very low probability of something pretty big.

13 MEMBER CORRADINI: I mean, just to make
14 sure you see where -- since I haven't forgotten the
15 stock price. If you're going to take the cost of
16 the plant, or the cost of the offsite damage and put
17 the expected then at least I'd put in the chance I'd
18 lose the worth of the company with some probability-
19 weighted thing. Because that's just as probable
20 with this thing occurring as onsite damages.

21 MEMBER ARMIJO: Well, it's happened. At
22 TMI you lost GPU, you lost B&We.

23 MEMBER STETKAR: And TEPCO.

24 MEMBER ARMIJO: I mean, whether or not
25 stuff was released into the environment or not.

1 MR. MONNINGER: To a certain extent I
2 think the staff tried to follow or followed the
3 regulatory analysis that we currently have. And you
4 know, as Bill mentioned we had expected the reg
5 analysis would not show it to be cost-beneficial.
6 So we could do things in here to increase the
7 numbers or decrease the numbers, but you know, given
8 the current way we do our analysis, our tools, et
9 cetera, we don't believe this is, you know, it would
10 significantly influence the numbers. So that's why
11 we think it's very important to have a good
12 discussion on the qualitative arguments that will be
13 influential in development of a recommendation.

14 MEMBER BLEY: I don't disagree with that
15 but I think you need -- even though the guidance
16 doesn't require it I think you need a quantitative
17 piece that puts into perspective these numbers.
18 What do they mean? Where did they come from? It
19 could be a high probability of \$300,000. You know,
20 it just doesn't communicate anything. You can call
21 that qualitative but don't put that quantitative
22 information in the qualitative discussion.

23 MEMBER BANERJEE: Suppose I was an
24 insurance company, you know, trying to insure these
25 things and this happens. Certainly I know the

1 chemical plant business pretty well. It's not
2 driven by lots of incidents which have very high
3 probability but low loss. The insurance is really
4 driven by low-probability events which have very
5 high loss. So, you know, it's not this averaging
6 sort of way to do it.

7 MEMBER SIEBER: That's why they put
8 limits on the policies.

9 MEMBER BANERJEE: Well, they put limits
10 on maybe nuclear policies but.

11 MEMBER SIEBER: All the policies have a
12 limit.

13 MEMBER BANERJEE: So yes. Maybe for --
14 but most of the time this is driven by very low
15 frequency but very high loss. Why don't we look at
16 things that way, more like an insurance company?
17 Suppose you were Zurich Re and had to insure this
18 plant. What would you do?

19 MR. MONNINGER: I mean, that's something
20 we can look into.

21 MR. RULAND: No doubt the committee who
22 is going to be writing a letter after our --

23 (Laughter)

24 MR. RULAND: -- you know, our final set
25 of -- you know, when we actually present the

1 recommendation. Clearly if you include this in a
2 letter the staff will seriously consider what we
3 need to do.

4 MEMBER RAY: Why don't you consider the
5 value of the product produced by the plant?

6 MR. MONNINGER: Well.

7 MEMBER RAY: What fraction of the total
8 power produced by all the plants that come up with
9 this net value is -- even assuming one were to use
10 these numbers, what percent of that value is this
11 net value loss here? No, the negative net value.
12 The bottom line.

13 MR. MONNINGER: Right. So, this is the
14 cost offsite from the replacement power.

15 MEMBER RAY: How many plants are we
16 talking about here in this net value at the bottom?

17 MR. MONNINGER: It's just -- this is the
18 fleet.

19 MEMBER RAY: That's right.

20 MR. MONNINGER: The fleet.

21 MEMBER RAY: All right. How much --
22 what is the value of the output of the fleet of
23 plants? Have you ever considered that on an annual
24 basis? I mean, this is trivial.

25 CHAIR SCHULTZ: Well, it comes into play

1 with the one sensitivity study that we discussed
2 earlier which is shutting down 30 plants.

3 MEMBER RAY: But just compare the net
4 value to whatever the heck it is that you're
5 producing with the assets that incur this cost
6 presumably. And you know, like I say, this is just
7 -- take a look at what you're talking about in terms
8 of the market value of the output of the plant
9 compared with the cost of making what Marty showed
10 to be some benefit assuming we're talking about the
11 benefit of the filter here in terms of improved
12 safety. Just this is --

13 MEMBER STETKAR: But Harold, in some
14 sense here replacement power is not a contributor to
15 that delta.

16 MEMBER RAY: Correct. I'm just talking
17 about what does the fleet of plants, what is the
18 value of their output compared with the cost of
19 imposing on them a requirement for a filter.

20 MEMBER STETKAR: Oh, okay, I see.

21 MEMBER RAY: That's all.

22 MEMBER STETKAR: I see what you mean.

23 CHAIR SCHULTZ: It's a different
24 question but it's worthy of consideration.

25 MEMBER RAY: Yes. I mean, that's the

1 way of, you know. Sanjoy is talking about
2 insurance. I mean, that's the way a business looks
3 at something like this. How much of the output that
4 I'm -- or the revenue that the plant output produces
5 is this costing me. It's a few minutes.

6 MEMBER BROWN: How many minutes of power
7 generation.

8 MEMBER RAY: It's ridiculous.

9 MEMBER BANERJEE: A power plant of 2.5
10 gigawatts is at least \$1 billion a year in power
11 roughly.

12 MEMBER RAY: Well, it's been awhile
13 since I -- I don't want to -- but I mean, it's a
14 simple calculation to make. And you know, the
15 revenue that the plant produces is way off the scale
16 compared with the cost, particularly if you put it
17 over -- you amortize the cost of the filter over how
18 many years. You pick a number, 10, 15, 20, 25.
19 It's nothing.

20 MEMBER ARMIJO: But Harold, none of
21 these options save the plant.

22 MEMBER RAY: Look, Sam, everybody can
23 have a perspective about whether it's warranted or
24 not from a safety standpoint. We're looking at
25 dollar numbers here and I'm only trying to put the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cost of the damn filter in perspective compared to
2 the output of the plant.

3 MEMBER ARMIJO: I understand, I
4 understand.

5 CHAIR SCHULTZ: One thing we're -- this
6 presentation does focus on the regulatory analysis.
7 And we're using the approaches that have been
8 established. The next presentation talks about
9 qualitative arguments some of which are quantitative
10 and may include this bullet.

11 MEMBER RAY: It's the only way I would
12 look at it I'll tell you. Because this is something
13 that may provide a benefit. You certainly don't
14 want to have it have a net negative safety benefit.
15 You know, in other words it needs to enhance the
16 safety of the plant. And if it's something that can
17 be done.

18 I mean, I think that's the way the
19 Europeans probably approached the problem is this is
20 something that we can do, it has arguably some
21 benefit, all of these calculations I don't think
22 amount to a hill of beans and it doesn't --

23 (Laughter)

24 MEMBER RAY: -- it doesn't amount to
25 more than a small percent of the value of the plant

1 output.

2 MR. RULAND: One of the things that the
3 staff considered when we were doing this analysis is
4 if the staff got too creative when we started doing
5 this analysis and deviated from our process that
6 we've already established the staff would be rightly
7 open for criticism of trying to game the system to
8 get an answer that we wanted.

9 MEMBER RAY: Yes, but our job is not to
10 look at it the way you are forced to look at it.

11 MR. RULAND: That's fine.

12 MEMBER RAY: Okay? I mean, that's why
13 we're her.

14 MR. RULAND: And I fully appreciate
15 that. And all I'm suggesting is the staff, that's
16 the reason we've done the analysis the way we have
17 done it.

18 MEMBER CORRADINI: I mean, what Harold's
19 asking I guess is you're just saying on an annual
20 basis what fraction of it it compares to and the
21 answer is a few percent.

22 MEMBER BROWN: It's not even that much.

23 MEMBER BANERJEE: No, no, it's point few
24 percent.

25 MEMBER BROWN: Point zero zero few

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 percent.

2 MEMBER BANERJEE: If you take it over 25
3 years it's nothing.

4 MEMBER SIEBER: It's pretty cheap
5 compared to the income of the plants.

6 MEMBER ARMIJO: If you look at it as a
7 businessman this is a cost for public goodwill or
8 something like that.

9 MEMBER RAY: I can do that. Let's get
10 on with it. Stop this hand-wringing.

11 MEMBER BANERJEE: Indian Point probably
12 spends more than that on publicity.

13 CHAIR SCHULTZ: I do feel we're going to
14 get to this when we get to the next presentation.

15 MEMBER SHACK: Better move on.

16 MR. SZABO: Next slide. Thank you. I
17 just stated before, option 4, we don't really have
18 any quantitative analysis so we're just kind of
19 provide qualitative arguments. And you know, it is
20 amenable to the site-specific approaches as kind of
21 mentioned previously. I don't want to hash out that
22 conversation again so we're going to skip to the
23 next slide.

24 (Laughter)

25 MR. SZABO: So once again, as stated,

1 the qualitative arguments that Tim's going to be
2 presenting next are going to be provided in the
3 regulatory analysis. And just provide some examples
4 of qualitative arguments that have historically been
5 included is the safety goal policy qualitative
6 goals, the defense-in-depth on uncertainties as well
7 as consistency with standards, as well as there are
8 other options as to -- in relation to qualitative
9 arguments. Onto the last slide.

10 As stated before, you know, option 2 and
11 option 3 do not appear to be cost-beneficial within
12 the current framework. There are sensitivity
13 analyses that may provide cases that are cost-
14 beneficial. You are changing the global statistical
15 value as a CDF 15 times greater as well as some of
16 the other sensitivities.

17 And just as a final note there may
18 require some qualitative arguments for just the
19 substantial safety enhancement part, especially with
20 filters in relation to determining that there is a
21 substantial safety enhancement.

22 I'm now open to any questions.

23 (Laughter)

24 CHAIR SCHULTZ: I have a question for
25 clarification. On option 4 are we not saying that

1 what option 4 does is postpone the regulatory
2 analysis on a site-specific basis to some different
3 evaluation? There's not a generic way or a combined
4 integral way to present it as a decision-making.
5 The decision is postponed to an individual site-
6 specific evaluation.

7 MR. MONNINGER: To a certain extent.
8 Hopefully when we have it developed I think it would
9 be an alternative. Option 1 is not -- then options
10 2 and 3 in order. Option 4 would be the staff would
11 look at doing some longer-term rulemaking and within
12 that actual rulemaking would be some type of
13 regulatory analysis based upon whatever we would be
14 requiring for the performance-based approach.

15 So it would be pushing it further down
16 the road as opposed to making a definitive decision
17 today is sort of how we're looking at option 4 to
18 address plant by plant by plant through some
19 performance-based approach. All the Mark I's and
20 II's plant by plant by plant performance-based
21 versus options 2, the severe accident capable vent
22 or filtered vent. We sort of looked at it on an
23 industry-wide approach and would come up with a
24 supporting regulatory analysis for that.

25 CHAIR SCHULTZ: Other comments or

1 questions particularly aimed at the regulatory
2 analysis approach? And you've already stated,
3 Aaron, that the qualitative is going to be
4 incorporated in that piece of evaluation which is
5 going to be presented.

6 MR. MONNINGER: Or the staff could stop
7 at the quantitative, you know, and provide it. But
8 we think it's very important.

9 CHAIR SCHULTZ: But you provide a
10 justification for incorporating it in the past.

11 MR. MONNINGER: Yes.

12 CHAIR SCHULTZ: And you may go forward
13 with what we're going to hear next.

14 MR. MONNINGER: Yes. That's Tim.

15 CHAIR SCHULTZ: Hearing none we'll move
16 to the next presentation which is the qualitative
17 arguments. Tim Collins is going to present. We
18 welcome you, Tim. Very timely that you're here for
19 this presentation.

20 MR. COLLINS: Thank you very much.

21 Well, my portion of the discussion is a summary of
22 the qualitative arguments for -- on the question of
23 filters for the containment venting systems.

24 As Aaron mentioned, these are
25 considerations that can be included in the

1 regulatory analysis in addition to the numbers that
2 are associated with the cost-benefit analysis. Next
3 slide, Bob.

4 Okay, this is just a summary of the
5 areas that I'm going to touch on. Most of these
6 have come up in the course of your questions in the
7 course of the day in one way or another but I'll
8 talk a little bit about them more in qualitative
9 terms than in quantitative terms. Next slide.

10 Okay, the first, probably the most
11 important consideration in the qualitative world is
12 enhancing defense-in-depth. A filtered vent
13 enhances defense-in-depth by improving the
14 containment. And the containment, it's the last
15 barrier to fission product release and it's
16 therefore important for treating uncertainties in
17 severe accident progression in the likelihood of a
18 severe accident, and it's important in keeping us
19 away from the uncertainties that are associated with
20 a large release.

21 It's important for health effects, it's
22 important for land contamination, environmental
23 consequences. And the containment is in fact the
24 last defense-in-depth measure for protection of the
25 environment.

1 Now, EP doesn't help the environment one
2 bit. EP is wonderful for health effects,
3 sheltering, relocation, that's fine, but it doesn't
4 do anything for things like land contamination and
5 the attendant consequences that go with land
6 contamination. So I want to talk about how
7 filtering improves the containment from a
8 qualitative perspective. Next slide.

9 Filtering improves the containment in
10 two ways, directly and indirectly. It directly
11 improves the containment performance clearly by
12 capturing the fission products that would otherwise
13 be released by an unfiltered venting process.

14 MEMBER POWERS: By that logic why
15 wouldn't you put two filters on the system?

16 MR. COLLINS: Why wouldn't you put two
17 filters on the system?

18 MEMBER POWERS: Yes. I mean, you're --
19 I vent from the wetwell. I will have some
20 radionuclides. They will go into your filter. Some
21 fraction of them will come out so why don't I put
22 two filters on that?

23 MR. COLLINS: You will have normal
24 containment leakage that at some time would dominate
25 over anything that's filtered out.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER POWERS: It may dominate over
2 having one filter. I'm asking him on his argument
3 why not two.

4 MR. COLLINS: I guess I really don't
5 understand the question. If you have a vent and
6 it's unfiltered --

7 MEMBER POWERS: It's always filtered if
8 you go through the wetwell.

9 MR. COLLINS: Okay, well let's say you
10 go through the drywell then.

11 MEMBER POWERS: And if it's sprayed then
12 it's also filtered.

13 MR. COLLINS: Okay. And in defense-in-
14 depth we try to approach things from protection in
15 the event of failures. What if it is a drywell
16 vent? What if we're venting from the drywell?

17 MEMBER POWERS: And you sprayed.

18 MR. COLLINS: No, I'm saying sprays have
19 failed at this point.

20 MEMBER POWERS: Okay. So I again ask
21 you why not two. If he's going to put one filter on
22 because it would capture some of the radionuclides
23 why not two or three until we hit your natural
24 leakage, wherever that may be. And I'll agree with
25 you that's an excellent place to decide stopping.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 But why not go till we get John's limit which is a
2 good -- I mean, it's a good natural limit, I agree
3 with that.

4 MR. DENNIG: Tim, I think it goes back
5 to the uncertainty in the benefits that you're going
6 to get from the spray, the uncertainty of the
7 benefit that you're going to get from the pool.

8 In 1150 those uncertainties were
9 estimated and they range from no scrubbing up to
10 1,000. And they also looked at pool scrubbing and
11 concrete-core interactions in some detail.

12 And so the issue is largely one of you
13 have processes inside the containment that are
14 driven by melting sequences and uncertainties in
15 core melt progression, and the conditions of the
16 wetwell and the availability of the spray and the
17 efficacy of the spray. And in the perspective of
18 those uncertainties does this provide compensation,
19 does this make things more certain. Is this sort of
20 like the big eraser. You make a lot of mistakes but
21 this would take care of a lot of the uncertainty.

22 So I think if you have the ideal
23 conditions in the wetwell and if you have the 3,000
24 or 4,000 gpm spray in a large containment then you
25 get a huge benefit, or a large benefit from those

1 mechanisms. But the analysis that we've done
2 before, and this is for 1150, doesn't show that that
3 in the mean -- the median that that benefit is very
4 large. So, in the face of that uncertainty is this
5 preferable.

6 The other thing is that I mentioned
7 earlier for the Mark II's part of the reason for not
8 putting a vent on a Mark II is because of the
9 concern about the pool bypass altogether. So
10 there's a question there for Mark II's. If we're
11 not -- if we don't have new analysis that takes away
12 that concern about the bypass by melting through
13 underneath the containment then it seems that our
14 previous analyses show that you have to have a
15 filter. That's what the CPIP said.

16 MR. COLLINS: I think the question deals
17 with the sufficiency of the filter. At what point
18 do you stop.

19 MEMBER SHACK: That's defense-in-depth
20 when do you stop is what he's really asking about.

21 MR. MONNINGER: We talk a lot about
22 defense-in-depth and there's been some efforts
23 within Reg Guide 1.14 to allow the staff some tools
24 for assessing the extent of the robustness of
25 defense-in-depth but it's a very difficult area.

1 There isn't much guidance out there to use to say
2 what is enough, what is sufficient. Can you really
3 quantify.

4 MEMBER POWERS: And that is exactly why
5 you have to resort to more quantitative risk
6 assessment methodologies because that's the vehicle
7 for capping defense-in-depth.

8 MEMBER SHACK: So sayeth the
9 structuralist.

10 MEMBER POWERS: So sayeth the
11 structuralist.

12 MEMBER CORRADINI: Can I ask it a
13 different way? What I heard in all the discussion
14 prior, primarily in Marty's case is that when he
15 talk the cumulative of all the things -- I'm not
16 going to talk about the money part -- is that for
17 health impacts this doesn't -- you can't find a way
18 to make the argument.

19 MR. COLLINS: That's right.

20 MEMBER CORRADINI: Are there other
21 things that you're going to make the argument, that
22 you might want to make the argument to do it for?
23 Because I don't sense it from a health impact
24 statement.

25 MR. COLLINS: Given the timing of the

1 potential release and evacuation the only health --
2 the majority of the health impacts are from the
3 repopulation when they come back, the re --

4 MEMBER RAY: Michael, what about the
5 last bullet up there? I mean, to me, you know,
6 having operated a plant the ability to lower the
7 pressure more readily because I have a filter than I
8 would feel otherwise I could do seems like a great
9 benefit. I mean, I ran a large dry containment
10 plant where you couldn't do it at all period.

11 MEMBER POWERS: I guess I don't know
12 enough about operations here so I look to you guys
13 that know much more. But to me from an offsite
14 standpoint if I said I'm essentially creating a
15 higher level of confidence, assurance that I don't
16 have to deal with offsite emergencies and I improve
17 onsite severe accident capabilities to manage the
18 accident that's a very big thing. You already have
19 a filter.

20 MEMBER RAY: That's correct. I'm just
21 saying it improves the confidence I would have as an
22 operator to open the vent on the basis that I don't
23 really know how the wetwell is going to work. I
24 have more confidence in this design than I do in the
25 wetwell albeit you know more about it than I do and

1 I defer to your judgment. But it would improve my
2 confidence to open the vent if I had a filter on the
3 end of the vent to get the pressure down if I
4 thought that was something I needed to do. It's as
5 simple as that.

6 MR. MONNINGER: We think there's a level
7 between the filtered vent for a decontamination or a
8 decontamination factor and the integral plant
9 systems. We believe there's a level of independence
10 there. The plant, what's held up within the core,
11 what's released, the timing, the core-concrete
12 interaction, the temperatures within the suppression
13 pool, the timings and all. You know, we don't
14 believe you have those issues, those uncertainties
15 in having to know the accident progression, the
16 release pathways, et cetera, with the filtered vent.
17 It provides a level of independence from the
18 accident progression. It may not be fully
19 independent but having it sit out there.

20 MEMBER STETKAR: You may be talking at
21 odds because as I understand your characterization
22 that's a purely passive containment function
23 filtered vent, is that correct?

24 MR. MONNINGER: You said purely.

25 MEMBER STETKAR: Purely passive.

1 Rupture disk type.

2 MR. MONNINGER: It could be but there's
3 a bypass around it that you could engage.

4 MEMBER STETKAR: Harold is thinking
5 about other functions in addition to that.

6 MEMBER RAY: That's right. I'm just
7 saying that containment pressure is high. I'd like
8 to be able to relieve it. I'm more -- I'm just
9 reading the words off the chart. I have more
10 confidence in doing that if I have a filter on the
11 end and I'm not having to rely on somebody's
12 speculation about how the wetwell is going to do the
13 filtering for me.

14 MEMBER STETKAR: And in essence it is
15 more integrated to accident progression than what's
16 going on.

17 MR. MONNINGER: Right. And it would
18 have both -- the thought is it may potentially have
19 both pathways.

20 MR. COLLINS: Actually, Mr. Ray's point
21 is what I was referring to as indirectly helping
22 containment because --

23 MEMBER RAY: No, I understand that.

24 MR. COLLINS: -- it frees the operator
25 to use the vent as a tool to help protect against

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 other challenges to the containment, challenges
2 other than overpressure challenges such as potential
3 hydrogen challenges or liner melt-through
4 challenges. I'll talk about both of those in a
5 couple of slides.

6 MEMBER POWERS: I guess I'm a bit
7 mystified on the hydrogen challenge.

8 MR. COLLINS: I'm going to have a slide
9 on that. It's about two down. Okay?

10 So as far as strengthening the
11 containment goes though I see you get the direct
12 effect of filtering what would otherwise be
13 unfiltered in the vent and then you get the freeing
14 of the operator to help other challenges to the
15 containment, okay?

16 There's also another -- before I get to
17 those, there is another defense-in-depth benefit
18 from filtering potentially which does touch on
19 health effects. Could you give me the next slide.

20 Filtering can also enhance defense-in-
21 depth for emergency planning implementation. This
22 would occur if we had an event where the earliest
23 challenge to the containment was an overpressure
24 challenge. In such a case if you had a filtered
25 vent that would provide protection against the

1 overpressure challenge, the early one, but another
2 challenge to containment may be right down the road
3 like a liner melt-through, right? But that would be
4 somewhat later in time. So, the time between the
5 second challenge and the first challenge is
6 additional margin for the completion of sheltering
7 and evacuation. So that's an additional defense-in-
8 depth benefit.

9 MEMBER ARMIJO: How much of an increase
10 is that?

11 MR. COLLINS: That would really be --
12 well, it would be event-dependent, it really would.
13 I mean, if you have an event where you get a little
14 bit of injection, injection gets knocked out and you
15 get another little bit of injection it could be a
16 substantial difference in time.

17 CHAIR SCHULTZ: That would have to tie
18 into a different emergency planning strategy
19 associated with --

20 MR. COLLINS: The start of emergency
21 planning wouldn't change. You start at the same
22 time. The question is how much time you have before
23 you have a real challenge to the people where
24 there's a real release. It would be longer. So
25 there's more margin to complete the emergency

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 actions. You wouldn't start them at any different
2 time.

3 CHAIR SCHULTZ: I understand.

4 MR. COLLINS: You're just putting off
5 the real challenge to the containment. You
6 eliminate the early challenge, gives you more time
7 before you get the next challenge.

8 MEMBER POWERS: Let me understand.

9 CHAIR SCHULTZ: I would pick at this
10 phrase in there, but I'll let Dana go ahead.

11 MEMBER POWERS: At my plant I'm
12 guaranteed to release heavier-than-air noble gases.
13 Your filter does nothing for that. That shine from
14 that release is guaranteed then to afflict your
15 evacuating population. If I didn't filter I don't
16 have that guarantee that they will be afflicted by a
17 release.

18 MR. COLLINS: No, you would vent anyway
19 when you get the overpressure challenge initially.
20 You would release more than just the noble gases.

21 MEMBER POWERS: Whenever that is
22 necessary or happens naturally.

23 MR. COLLINS: Yes.

24 MEMBER POWERS: But you're claiming
25 credit for margin where I'm guaranteed to put a

1 shine on those people.

2 MR. COLLINS: Okay, I guess you would
3 get a lesser effect by having the filters.

4 MEMBER POWERS: So I'm not sure what
5 I've gained here.

6 MR. COLLINS: Okay, you're saying you
7 haven't necessarily gained anything in EP space.
8 Okay, I understand what you're saying.

9 MEMBER POWERS: I'm just not clear what
10 you've gained here, especially when I look at the
11 consequence analyses that were presented earlier.
12 They seem that if I do a wetwell venting I don't
13 seem to see any distinguishable difference between
14 ordinary wetwell venting and venting through a
15 filter system.

16 MR. DENNIG: Yes, that's for that
17 sequence. For that set of circumstances, for that
18 sequence where you get the factor of 200 or 300 that
19 MELCOR calculated for the pool scrub. In a sequence
20 where you get 10 or less the core is outside the
21 vessel already and you're not getting the blowdown
22 through the T-quenchers and it's going through the
23 downcomers, the median is -- and the uncertainty
24 calculations is around 10 and the range is from, you
25 know, 1 to 1,000.

1 And so if you get a sequence that puts
2 you up in the high range you're in good shape. If
3 you get a sequence that puts you out of that range
4 where the temperatures and the hydraulic conditions
5 in the wetwell or the level in the wetwell have
6 changed then you don't get that. And so the
7 question is again, it's a hedge against or for
8 sequence independence if you will.

9 MEMBER SHACK: Which I guess isn't
10 captured in any of the analyses that you've done
11 because you've always assumed you have those kinds
12 of releases.

13 MR. DENNIG: The cases that were run,
14 there were 30 cases. In all of those cases --

15 MEMBER SHACK: The PRA feeds all events
16 through that back-end bin whereas in reality it
17 should be on a sequence-by-sequence basis and you
18 may get the effects you're talking about.

19 MR. DENNIG: Yes. What I've been
20 referring to is the uncertainty analysis that was
21 done in NUREG-1150 for all the sequences that were
22 modeled for Peach Bottom.

23 MR. COLLINS: Next slide. Okay, this is
24 where the operator's confidence in having a clean
25 release can help. And this is the hydrogen control

1 example I was talking about.

2 If the operator is confident that he can
3 vent without a significant offsite release then he
4 can intervene early to vent hydrogen and keep
5 containment pressure low. And if containment
6 pressure is maintained low that would reduce leakage
7 of hydrogen through penetration seals and decreased
8 leakage then reduces the threat of a hydrogen
9 explosion in the reactor building and any
10 consequences that go along with that explosion. And
11 it helps emergency responders who are probably
12 working in the reactor building to try to get some
13 water injected.

14 MEMBER POWERS: You're drawing a
15 distinction between the -- it is cleaner, you're
16 arguing, to go through an additional filter than
17 just going through the wetwell.

18 MR. COLLINS: Yes.

19 MEMBER POWERS: By roughly a factor of
20 10. But the noble gases are unaffected which would
21 have a most serious impact indeed upon your
22 emergency workers around the facility. They get
23 direct shine. It's pretty significant actually for
24 them. A few hundred million curies of xenon and
25 krypton that you will release.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER STETKAR: The other question is
2 if they don't release it what will the corresponding
3 doses be. You know.

4 CHAIR SCHULTZ: If the hydrogen is not
5 controlled.

6 MEMBER STETKAR: If the hydrogen is not
7 controlled.

8 MEMBER BLEY: Time delay, it will
9 eventually get --

10 MEMBER STETKAR: Yes, that's what I'm
11 saying. If indeed that time delay is long enough to
12 provide, you know, some sort of mitigation then it
13 can be a measurable delta.

14 MEMBER SIEBER: If you use that argument
15 though it seems to me that you need to have the vent
16 system capable of sustaining the hydrogen
17 deflagration or explosion. The condition to me, if
18 you want to use that argument, that you have to
19 design the vent system so that you won't get an
20 explosion or a deflagration which adds some cost to
21 it.

22 MEMBER SKILLMAN: What you've just
23 introduced in my mind is almost an entirely
24 different way of looking at this. Probably similar
25 to around the table I've been involved in bleeding

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 hydrogen from the pressurizer or from the makeup
2 tank to the gaseous waste holdup tank. I've done it
3 manually, know how to do it. That is an operations
4 action that an operator takes to change chemistry,
5 to change the dissolved hydrogen concentration or
6 maybe take preemptive action for a change that is
7 going to change the size of the bubble. That's
8 actually operating the reactor fueling system.

9 What you've introduced here is the idea
10 of operating the containment. That's what I
11 interpreted from what you just said. And there's
12 nothing wrong with that from my perspective except
13 that that is introducing a new set of operator
14 actions, a new set of operator behaviors and
15 intelligence as Dr. Powers said, a new path for what
16 could be significant quantities of xenon and
17 krypton.

18 When one decides to do this one is
19 making a decision to operate the containment.
20 That's different than having a passive membrane
21 first and release material to a filtered chamber.
22 So I think if we go down this path we need to be
23 thinking about a whole new set of training, a whole
24 new set of behaviorals that ensure that this is done
25 the way it is supposed to be done.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MONNINGER: So at risk for
2 potentially being wrong I'm pretty sure the current
3 EOPs for primary containment hydrogen control once
4 you reach 5 or 6 percent within the containment
5 direct you to vent currently. So, you know, those
6 noble gases, those impacts, et cetera, could -- and
7 I'll pull, you know, the EPGs, EOPs to make sure,
8 but I'm pretty confident. You don't just vent for
9 pressure control. You actually vent for hydrogen
10 control. And you can actually read into the primary
11 containment hydrogen control EOPs that would lead
12 one to believe that in the absence of indication of
13 hydrogen you could even potentially vent.

14 So what I'm trying to say is what we're
15 talking about here isn't potentially any worse than
16 the current state in which they would potentially be
17 releasing these noble gases along with the hydrogen
18 anyway. That's one point.

19 The second thing I would mention is
20 there is the current proposal in front of us from
21 the BWR Owners Group to proceed with a proposal for
22 early venting with the existing design of the plant.
23 So, I think to a certain extent it depends upon what
24 we're comparing this scenario to. I think a case
25 can be made that the scenario and the consequences

1 and the noble gases already exist. And what the
2 staff is potentially doing would be to make the
3 scenario better. Maybe not perfect, but better.
4 But we can check the --

5 MEMBER SKILLMAN: I accept your argument
6 and your logic. You're saying hey, maybe it's just
7 an extension of what exists today, perhaps with some
8 enhanced training or some enhanced intelligence.
9 All I'm saying is you're actually talking about
10 operating your containment perhaps differently than
11 what is presently envisioned by the emergency
12 procedures or other procedures that the plant uses.
13 It just strikes me this is different.

14 CHAIR SCHULTZ: John, in the scenario
15 you painted as you've indicated the advantage of
16 having a clean release for hydrogen control, it's
17 very qualitative.

18 MR. MONNINGER: Yes.

19 CHAIR SCHULTZ: In terms of whether it's
20 going to impact operator action or not. Because in
21 what you've just described the operator is directed
22 to perform the release. So in one sense one would
23 say you can't use that as an argument to put a
24 filter on it or not in terms of this increasing
25 confidence.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MONNINGER: Well, I guess --

2 CHAIR SCHULTZ: How you look at operator
3 action.

4 MR. COLLINS: Okay, next slide. This
5 goes along the same lines. If the operator is
6 confident of a reduced release then allows early
7 operator intervention to control pressure. And if
8 you can sustain low pressure you're facilitating
9 injection from any low-pressure source which may be
10 available. This increases your chances of early
11 melt arrest and protection of the liner.

12 Again, it would sustain lower pressure,
13 can reduce the leakage of fission products through
14 the penetration seals. This is the same question
15 that Dr. Powers just raised. If you're releasing
16 the noble gases though what are you trading off
17 there.

18 So maybe the last bullet is arguable.
19 It facilitates the use of all onsite resources. We
20 have to see. It seems to me if you have a filter on
21 there you've got a tool which you need to use as
22 best you can.

23 MEMBER POWERS: Well, the imponderable
24 in my mind is this question of am I more confident
25 with a filter or just with my pool. Now, I've done

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 experiments with pools and I'm enormously confident
2 in their ability to decontaminate. I become even
3 more confident, yet further confident if in fact I
4 use the wetwell sprays in conjunction with those
5 pools. So maybe I personally.

6 I don't know about operators or other
7 people. I don't know about the staff. If there's
8 some increment in their confidence that they have.
9 I mean, I don't know their psychology so I just
10 can't say. But what I do know is that pools are
11 enormously capable of removing aerosols and that
12 sprays are my darlings because they're just
13 wonderful in many, many ways. They -- especially
14 the drywell sprays because they do all kinds of
15 cooling functions in terrible things that are very
16 hot because you'd lost your drywell coolers at this
17 point in the accident. That's a half a megawatt of
18 heat removal that you really need in a very critical
19 location.

20 Now, what I don't know because I haven't
21 looked lately is in looking at the risk analyses how
22 often do we not have those spray systems. And maybe
23 there is a delta. But in all of the risk analyses
24 that have gone before nobody had highlighted that.

25 MEMBER STETKAR: I hear people mumbling

1 down there. I don't recall a lot of this. I
2 suspect a fair fraction of the core damage sequences
3 you may not have the normally installed sprays
4 available. If you think about power failures, dc
5 fires, seismic events, those types of things. You
6 know, it's been -- I don't have the models in front
7 of me. You certainly will have them available for
8 the high-pressure transients, you know, those kind
9 of things.

10 MEMBER POWERS: And that -- I mean, and
11 all of this may just simply argue that option 2 is
12 the way to go which is not the decision that's being
13 made here. It's developing qualitative arguments to
14 support option 3 right now. And I worry that we
15 heard developing arguments to support option 3 that
16 maybe we could develop arguments that say there are
17 downsides associated with option 3, or there are
18 options that achieve these things that I can do in
19 option 2.

20 MEMBER RAY: Well, as I said to you,
21 Dana, I'm more looking for what's the downside of
22 putting one of these things in.

23 MEMBER POWERS: Well, operational
24 complexity is the first thing that comes to mind.

25 MEMBER RAY: But the cost is not a

1 significant downside to me. But there may be other
2 downsides and I'm certainly open to hear what they
3 are.

4 MEMBER SIEBER: One of the things that
5 you point out here is you get early operator
6 intervention to control pressure. There are a lot
7 but -- there's not a lot, but some BWRs,
8 particularly ones with power upgrades that rely on
9 containment pressure to avoid cavitating their
10 pumps, particularly as a result of GSI-191. If I
11 was an operator I would probably think I have to
12 drive down a very skinny road now between too much
13 pressure and too little pressure in order to control
14 my -- what's going on in containment.

15 And I think that when you put that kind
16 of situation on an operator that's all he'll do. He
17 won't go and do other emergency duties. He'll
18 concentrate on that because that's a difficult task
19 and it's all done manually. And I have --

20 MEMBER RAY: We already confronted that
21 discussion. Without a severe accident we still have
22 to do that, don't we?

23 MR. DENNIG: The notion is that you
24 really don't know. In the situations that we're
25 talking about you don't know what your assets are

1 going to be basically. I mean that's the
2 presumption. You may have a lot of things, you may
3 have no things. What are your assets, how are you
4 going to work. We focused on the severe accident
5 management where you've gotten where you are because
6 you don't have anything. You don't have very much
7 to work with. You have to cobble something up.

8 So, all the features, the drywell spray,
9 the wetwell spray, core spray, all those things are
10 dependent on ac power, emergency ac power, and you
11 may not those. We're going to be damaged in some
12 way. So, the context is what do I know about my
13 assets, what am I going to have, what can I discern
14 of the conditions inside the containment and in
15 light of the information I have and the assets I
16 have what do I do.

17 MEMBER BANERJEE: What does early mean
18 here? How early?

19 MR. COLLINS: He could vent before he
20 reaches the containment design pressure or before he
21 reaches a rupture disk set point.

22 MEMBER SIEBER: Or before you get enough
23 hydrogen concentration to blow the reactor building
24 up.

25 MEMBER BANERJEE: So, let's take a

1 scenario.

2 MEMBER SIEBER: That to me is the
3 driving issue is hydrogen buildup.

4 MEMBER BANERJEE: Can you sort of take a
5 scenario what is the earliest time that this could
6 happen? Are we talking about hours, days?

7 MEMBER SIEBER: Depends on the accident.

8 MR. MONNINGER: I mean for this, if we
9 went to the MELCOR calculations, you know, you would
10 be 16-18, you know, probably --

11 MEMBER STETKAR: That's not the earliest
12 time.

13 MR. MONNINGER: For the MELCOR
14 calculations.

15 MEMBER STETKAR: But the MELCOR
16 calculations is not the earliest time in the real
17 world.

18 MR. MONNINGER: Right, right.

19 MEMBER BANERJEE: But what is the
20 earliest? Is it 12 hours, 15 hours?

21 MEMBER STETKAR: I don't do those
22 calculations, but the MELCOR calculations --

23 MEMBER SIEBER: Beyond the first shift
24 I'll bet you. When you first start considering.

25 MR. DENNIG: Between 10 and 12 hours.

1 MR. MONNINGER: I mean, you could take
2 the MAAP, the EPRI work and see, you know. But
3 there's even sequences that would be even earlier
4 than that. You're a boil-down sequence. I mean,
5 your LOCA if nothing else you're not boiling down.
6 You've got the pot of water there, you've got ATWS.

7 CHAIR SCHULTZ: In terms of timing think
8 of the progression at Fukushima.

9 MEMBER SIEBER: An active break in the
10 coolant system I think would bring you there pretty
11 fast.

12 MEMBER BANERJEE: So it's a few hours.

13 CHAIR SCHULTZ: There may things that
14 you plan to do earlier than that certainly.

15 MEMBER BANERJEE: You could stress the
16 operator.

17 CHAIR SCHULTZ: That's the question as
18 we talked on the previous slide. Is that a stressor
19 to the operator or is that an advantage to the
20 operator?

21 MEMBER SIEBER: Depends on the operator.
22 Different operators act different ways.

23 MEMBER BROWN: It could be more of a
24 stressor if he figures out he can't do anything at
25 all and the pressure is building up.

1 CHAIR SCHULTZ: Exactly.

2 MEMBER BROWN: So which way does the
3 stressor go depending on what the specific event is.

4 MEMBER BANERJEE: So in a sense you've
5 given the operator another tool in the repertoire of
6 whatever they can do.

7 CHAIR SCHULTZ: I think that's what Bob
8 was getting to, Bob Dennig was getting to with
9 respect to the operator options.

10 MEMBER STETKAR: But that's what I
11 mentioned earlier. I think it would be really
12 interesting to look at plants that have implemented
13 the filtered vents to see whether, first of all,
14 they've actually changed their operator guidance,
15 their philosophy for dealing with these accidents.
16 If they have it would be really interesting to see
17 how that's changed. Have they put higher priority
18 on venting earlier? Have they put lower priority on
19 trying to estimate what the offsite dose might be
20 before they make a decision to vent? And I don't
21 know the answer to those questions.

22 But I mean a lot of those things can
23 feed into some of these qualitative arguments just
24 from the experience of people who have done it. You
25 don't need to speculate because actual people in

1 Europe who have plants that look an awful lot like
2 our plants have done this.

3 MEMBER BANERJEE: They also require
4 containment overpressure?

5 MEMBER CORRADINI: Require or allow?

6 MEMBER BANERJEE: And allow.

7 MEMBER ARMIJO: Once you allow it, it's
8 required.

9 MEMBER SHACK: Well, I mean we focused
10 too on the early use of this but to me one of the
11 attractive features is that you always have a vent
12 available. I might lose the wetwell vent in the
13 number of sequences.

14 MEMBER SIEBER: Yes, or it may not do
15 you any good.

16 MEMBER SHACK: And here I would have it.

17 MEMBER ARMIJO: You'd have the drywell
18 vent.

19 MEMBER SHACK: Well, I mean -- but I
20 mean I would always have a filtered vent available.

21 MR. COLLINS: You just went to my next
22 slide.

23 MEMBER ARMIJO: But Dana said, okay, you
24 can spray for the drywell venting. And you're
25 saying okay but --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER SHACK: -- no ac power.

2 MEMBER ARMIJO: Well, you know, maybe
3 you'd better spend -- your money is better spent
4 putting \$30 million into assuring that you have
5 power for your sprays.

6 MEMBER SIEBER: So you buy another
7 diesel and it doesn't work.

8 MEMBER ARMIJO: Where are you going to
9 spend your money, on the existing equipment or a new
10 piece of equipment that's sort of like a panacea,
11 it's going to solve all your problems? Things never
12 quite work that way. It just seems to me we haven't
13 looked hard enough at how to make the best use of
14 existing equipment. That's where option 2 I guess
15 was going. Maybe broader.

16 MEMBER POWERS: One other question I
17 have more on philosophical basis for your study
18 because I don't know. I like confidence. I need a
19 filter. If I look at the risk profiles of our
20 plants I certainly see that seismic events are
21 commensurate with internal events as initiators.
22 And most of your sequences appear to be internal
23 event sequences. If I have a seismic initiator and
24 it's sufficient to disrupt my plant what does it do
25 to the filtration system? Or is that outside of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 scope?

2 MR. MONNINGER: I think we would have to
3 -- if the recommendation was to proceed with filters
4 we would have to explicitly say whether the staff
5 believes it is merited to withstand seismic
6 conditions or not.

7 I mean if we're banking on it to provide
8 that level of protection post seismic we would
9 provide some level of need for designing and
10 withstanding seismic events. But I don't think
11 we're at that point yet. I'm not sure if that
12 helped.

13 MEMBER SHACK: Well, you said earlier --
14 somebody said earlier in the meeting that the vent
15 and the -- presumably I carry that over into the
16 filter would be seismically qualified. It wouldn't
17 be something else but it would be seismically
18 qualified.

19 MR. MONNINGER: I think they might have
20 said the European.

21 MEMBER SHACK: It wouldn't be safety.

22 MR. MONNINGER: The Europeans were --
23 and Bob can talk.

24 MR. DENNIG: The European installations
25 are -- except for single-failure they are safety-

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 grade seismic the same as the plant. It's across
2 the board. It matches up that way except for the
3 single-failure notion.

4 One way to look at this is that given
5 that you have a containment that is of a size that
6 you know that it's too small and you have to vent
7 it, you're going to have to vent it, is it
8 beneficial to have that vent filtered or to just
9 take whatever release that you get under the
10 circumstances. But keeping it all inside the
11 containment isn't one of the options.

12 MR. COLLINS: Next slide.

13 CHAIR SCHULTZ: Let's see your next
14 slide.

15 MR. COLLINS: Which is what Dr. Shack
16 was just talking about. To have confidence again in
17 your filtration system and you can use the drywell
18 as a venting source as well as the wetwell.

19 And we also note that the current SAMGs
20 direct the operators to flood the drywell floor
21 which will eventually flood up the wetwell and block
22 off the wetwell vent. So the current strategies
23 would have them switch to a drywell vent. In this
24 case you'd have the same protection whether it was
25 coming off the wetwell or the drywell.

1 Also, if you have a filtered system I
2 think you'd be more confident putting a rupture disk
3 on the system because you have minimal consequences
4 of an inadvertent actuation. Okay, next slide.

5 MEMBER SIEBER: If you have a rupture
6 disk that means you have no containment overpressure
7 to provide MGSB from then on.

8 MEMBER RAY: You've got an isolation
9 valve, Jack, but you'd have to close it, that's for
10 sure.

11 MEMBER SIEBER: Right, manually.

12 MEMBER RAY: That's right.

13 MR. COLLINS: Now, the second-to-last
14 item is consequence uncertainties. Once fission
15 products escape from the containment land
16 contamination comes into play regardless of what EP
17 actions you've taken into account. And the amount
18 of land contamination to a large extent is dependent
19 upon the magnitude of the release and the weather.

20 And the consequences associated with
21 land contamination are dependent on other factors as
22 well. The longer term weather patterns affect it,
23 the local hydrology, whatever the land use is and
24 what the public response is. And so the total
25 consequences if we try to do total economic

1 consequences are really, really uncertain. Can I go
2 the next slide as well because there are more
3 consequence areas?

4 There's also the uncertainties in
5 consequences with regard to public response. I
6 mean, public anxiety can lead to things like impacts
7 on your energy supply chain. This is what happened
8 in Germany. They're closing down the nuclear power
9 stations. The Japanese are threatening to close
10 down their power stations.

11 I mean, when people get -- have to be
12 relocated for long periods of time, potentially
13 permanently, that has big socioeconomic impacts
14 which can affect things like the energy supply
15 chain. So a large release puts us in a condition
16 where we have little control over the potential non-
17 health effect consequences.

18 MEMBER ARMIJO: I think that holds for
19 any release. I think the German experience which
20 was shocking to me that even though they have all
21 the bells and whistles, they're still shutting down
22 all their plants. You know, that's fact.

23 MR. COLLINS: I wonder if -- what the
24 view of Fukushima would be if they hadn't had large
25 releases but they had melted down three cores. I

1 wonder if that would be viewed as a success or a
2 failure.

3 MEMBER ARMIJO: I think they'd still
4 shut down all the plants.

5 MR. COLLINS: I wonder. If there had
6 been no release from that event after the horrific
7 tsunami, right? You could say despite the fact that
8 we had this horrific event, melted the cores, the
9 people were protected, the land was protected.
10 Would we call that a successful failure?

11 MEMBER ARMIJO: Or when people were
12 protected at Fukushima they certainly evacuated and
13 were inconvenienced and frightened, but their health
14 and safety was protected. That didn't count for
15 beans.

16 MEMBER POWERS: That raises the question
17 of I wonder what the magnitude of release would have
18 been if we had done a wetwell vent following the
19 guidelines that we think we have in place at our
20 plants.

21 In fact, I think that we see in the
22 analyses that the suppression pools work pretty damn
23 well for limiting the radionuclide release. When
24 they were allowed to do so.

25 MR. DENNIG: The first 4 days at

1 Fukushima were wetwell vent releases. So you can
2 look at what the releases were during that period of
3 time if you want to get a sense of what value the
4 wetwell was.

5 MR. MONNINGER: I think there's a
6 question with regard to what happened to Unit 2.
7 And they talk about the potential preponderance of
8 the release or the land contamination coming from
9 Unit 2. I think there's a question out there as to
10 where that Unit 2 actually released from.

11 MEMBER POWERS: I think that's true.

12 MR. MONNINGER: For Unit 2.

13 MEMBER POWERS: And I certainly don't
14 know the answer. And I don't know of anybody that
15 does, but maybe there are people that do. But I
16 don't.

17 MR. COLLINS: There's also consideration
18 of our international practices. A requirement for
19 filtering the containment systems has been in place
20 at several European countries for many years, and
21 other countries are now adding the requirement.
22 Canada, Taiwan, Japan.

23 And if we went forward with a
24 requirement it would be directly responsive to a
25 recommendation from the recent meeting of members of

1 the Convention on Nuclear Safety where they
2 recommended measures to ensure containment integrity
3 and filtration strategies and hydrogen control. So
4 another consideration.

5 MEMBER POWERS: But aren't you already
6 in compliance with that? If I wetwell vent I have a
7 filtration strategy. If I inert I have a hydrogen
8 management for containment. So aren't you fully in
9 compliance with that?

10 MR. COLLINS: I don't know how the
11 judgment is made as to whether we're in compliance
12 with those practices or not. Certainly enhancing
13 the filtration capability and the hydrogen
14 management would be consistent with what they're
15 recommending.

16 MEMBER POWERS: Well, enhancing is not
17 required here. It says measures to ensure
18 containment integrity, filtration strategy and
19 hydrogen management for containment. It seems to me
20 like you have all of those already in these
21 particular plants.

22 MR. COLLINS: The recommendation is to
23 upgrade, right?

24 MEMBER ARMIJO: Your option 2 is in fact
25 an upgrade, isn't it?

1 MR. MONNINGER: Yes.

2 MEMBER ARMIJO: So that would be
3 consistent with that guidance. Maybe not the one
4 you want to do or you think is the best, but it
5 would be consistent.

6 MR. MONNINGER: We hadn't concluded on
7 any of the options yet.

8 MEMBER ARMIJO: Yes. Or what seems to
9 be the preferred.

10 MR. DENNIG: Option 2 does have the
11 downside of looking like you're saving the site,
12 protecting the site and dumping to the environment.
13 You are reliably able to open that vent to vent to
14 the environment, but it's not going to affect the
15 site of the reactor building or the response. So it
16 does have that downside.

17 MEMBER BANERJEE: Does that statement
18 only apply to BWRs or to PWRs as well?

19 MR. MONNINGER: It applies to PWRs as
20 well.

21 MEMBER BANERJEE: So, if I understand
22 it, most of the members are upgrading their PWRs as
23 well. Very few aren't.

24 MEMBER CORRADINI: France is. I'm not
25 sure others are.

1 MEMBER BANERJEE: Even the Chinese are.

2 MEMBER STETKAR: Yes, if you looked at
3 that chart.

4 MEMBER CORRADINI: The chart shows the
5 Chinese are doing their CANDUs. It's not showing
6 anything else from the chart.

7 MR. DENNIG: I'll get you the
8 information on the PWRs. They're doing forward
9 build on the PWRs. They're installing filters.

10 MEMBER CORRADINI: I guess I don't want
11 to be argumentative, but the current plants under
12 construction along the coast have no filtered vents.
13 The plants that are being planned inland will have
14 filtered vents, at least that's what they told me
15 when I was there 3 weeks ago. So it's different
16 because most of the plants in construction are along
17 the coast.

18 MR. DENNIG: Okay, I'll get you the list
19 that I have.

20 MEMBER BANERJEE: Well, whatever it is,
21 it applies really in general.

22 MEMBER CORRADINI: I guess I asked it
23 once earlier but I come back to it which is -- maybe
24 this is the wrong way of saying it, but it seems
25 staff is not looking at option 4 at all. You have

1 it there as -- I look at it as do nothing, 2, 3 and
2 some sort of performance-based. But it seems to me
3 the performance-based approach gives you flexibility
4 to come up with this performance standard and let
5 the industry be somewhat innovative on how they want
6 to approach it.

7 And you can designate the attributes you
8 want in that performance standard such that you can
9 demand diversity, you can demand a number of things
10 and still let the industry decide, and it would
11 probably be on a site basis, what they need to do
12 for some sort of goal to be determined. I'm not
13 going to tell you guys what your goal is because
14 that also fits into all your -- but I guess I'm not
15 sensing that option 4 --

16 MEMBER RAY: That's a two-edged sword,
17 Mike, from the industry standpoint.

18 MEMBER ARMIJO: Maybe.

19 MEMBER CORRADINI: I'm sure it is in
20 some sense. But it just seems to me, I sense
21 there's no appetite for option 4. It's always in
22 your slides but I just don't sense that there's a
23 lot of thrill there.

24 MEMBER REMPE: There's no health benefit
25 so it would be something for diversity? I mean,

1 what would be the --

2 MEMBER CORRADINI: Well, we were in
3 another subcommittee meeting last night, or
4 yesterday for a good 5 hours. I could come up with
5 a couple of reasons to do it.

6 MEMBER REMPE: The land contamination is
7 what you're thinking of?

8 MEMBER CORRADINI: Yes.

9 MR. MONNINGER: And you know, staff
10 appetite for it. I mentioned we're maybe 90 percent
11 looking at options 2 and 3. And you're right,
12 conceptually we're probably only 10 percent there on
13 option 4. We hadn't put the time and effort, but it
14 is, you know, something out there. We believe it
15 would still be within our paper. We're not wedded
16 to giving the Commission 1, 2, 3, or 4, but you
17 know, to the extent that we can develop it between
18 now and then we'll include it. We may come up with
19 two more options.

20 One thing I would mention, these
21 qualitative arguments, if you go back to our
22 quantitative analysis, neither option 2 or option 3
23 makes it on the cost-benefit. So, if the staff --
24 we would need qualitative arguments for option 2 or
25 option 3 if that was a recommendation. It may be a

1 little easier on option 2 because it's probably
2 closer to some type of line than it is for option 3
3 but we would need additional argument.

4 MEMBER SHACK: Well, you probably need
5 it for option 4 too I would suspect.

6 MR. MONNINGER: Yes.

7 MR. DENNIG: Once again I think we have
8 a different time line for Mark II's than we do for
9 Mark I's just because of the pool bypass that we've
10 identified earlier in the CPIP where we said that a
11 wetwell vent was not something to do because of that
12 probability of the pool bypass and the lack of a
13 scrub. So, to a certain extent that augurs for a
14 filter on Mark II's unless we have different
15 research that says that that's a different
16 situation.

17 MEMBER BANERJEE: Can't you make some of
18 these qualitative arguments quantitative?

19 MR. MONNINGER: We could potentially but
20 I guess --

21 MEMBER BANERJEE: They seem overwhelming
22 compared to the quantitative arguments.

23 MEMBER SIEBER: Yes, but there's no
24 point of proof. You have to -- the point of proof
25 has to come from the regulatory analysis and you

1 fail there.

2 MR. MONNINGER: I think one of the
3 things with the qualitative arguments that we're
4 sensitive to is we'll put them together and we want
5 to be as specific as possible for this. We don't
6 want to come up with qualitative arguments that can
7 be used for any staff flavor-of-the-day type
8 recommendations for improvement. So that's, you
9 know, it's difficult and there's, you know, once you
10 have a qualitative argument there's just so much you
11 can say. We don't --

12 MEMBER BANERJEE: That's why I'm
13 wondering whether you can make them more
14 quantitative.

15 MR. MONNINGER: And I'd have to look at
16 Marty and Sud and Research to see what we could
17 actually do. We can but do we have the tools, do we
18 have the complete level 3 PRAs. You know, a lot of
19 the focus on the traditional PRAs are in the early
20 time frame. But when it comes to land contamination
21 it's not just potentially that core damage accident
22 in the early time frame that you're worried about.
23 It could be the one at 12, 24, 36, or 48 hours.

24 MR. COLLINS: There's so much
25 uncertainty in the analysis we're doing already if

1 we try to make this quantitative it's going to just
2 be more uncertain.

3 MEMBER SIEBER: I don't think you can do
4 it.

5 MEMBER CORRADINI: But let me now -- now
6 that I said one thing let me turn around and say
7 something else. What's the rush to judgment on what
8 to do with this? I sense a rush. Is this because
9 it's defined as a Tier 1 activity and you must come
10 to a judgment soon? It seems to me this is a fairly
11 big change such that you want to do it right with
12 enough thinking that you might want to wait till
13 some sort of level 3 PRA results come in.

14 MR. MONNINGER: It's a Tier 1 item so we
15 owe recommendation to the Commission end of
16 November. That recommendation could be to do
17 nothing.

18 MR. RULAND: Not only was this a Tier 1
19 item, the staff actually requested a delay. So, the
20 staff believed they needed to delay this because we
21 had additional work to do. So I would argue the
22 staff has not been rushing this.

23 MR. MONNINGER: We've actually had two
24 delays because this was originally part of the Tier
25 1 in those orders that went to the Commission in

1 February and March. However, we said it's complex
2 and can we deliver it to you in July. And then we
3 didn't make July and we've requested a second
4 extension. So you could argue that this
5 recommendation was actually due back in February.

6 MEMBER CORRADINI: So you're late.

7 (Laughter)

8 MR. RULAND: No, we are on time.

9 MR. MONNINGER: With all our schedule
10 extensions we are on time.

11 MEMBER REMPE: Do you think you're ready
12 or do you need another extension?

13 MR. MONNINGER: Personally, you know,
14 personally I mean with all the work that's been done
15 over the years, what's been done internationally I
16 don't think if we studied it for 2 or 3 more years
17 we would be at a significantly different state in
18 developing our recommendation. I don't think that
19 our quantitative analysis would significantly change
20 over the next 2 to 3 years. That's my personal
21 opinion.

22 MEMBER SIEBER: You might make it more
23 precise but I don't think you're going to come up
24 with a different answer.

25 MR. RULAND: Yes, we believe that's the

1 case.

2 CHAIR SCHULTZ: Are there other
3 questions from the committee to Tim Collins on his
4 presentation? With that I'd like to thank you, Tim,
5 for the discussions that you've initiated.

6 One more piece on the agenda before we
7 move to public comment and that's, Bob, your
8 discussion associated with next steps.

9 MEMBER SIEBER: One slide.

10 MR. FRETZ: It's one slide. Again, as
11 we started out the whole presentation was that our
12 assessment continues. We really are not done yet so
13 we will hopefully take whatever insights we have
14 gained from today as well as some of the other
15 evaluations and develop the recommendations.

16 Our plans are to engage the steering
17 committee this month and to present our conclusions
18 later this month.

19 CHAIR SCHULTZ: There was more detail in
20 your earlier slide. We'll take this.

21 (Laughter)

22 CHAIR SCHULTZ: With that I'd like to
23 ask for public comments. First, from within the
24 room. We will be opening the phone line so that
25 those on the phone line could make comments if they

1 so desire. I'm looking for people within the room
2 that would like to make public comments. Seeing
3 none I'd like to open the phone line for public
4 comments.

5 MR. GUNTER: Paul Gunter.

6 CHAIR SCHULTZ: Paul, I thought you
7 might be on the phone.

8 MR. GUNTER: Thank you.

9 CHAIR SCHULTZ: Please go ahead.

10 MR. GUNTER: Thank you again for the
11 opportunity. My name is Paul Gunter. I'm with
12 Beyond Nuclear. We're out of Takoma Park, Maryland.

13 My question concerns option 1 and it's
14 directed to staff. My understanding is option 1
15 applies basically to -- for the Enforcement Action
16 2012-050. And I've been trying to understand that
17 the current order does not require for seismic-rated
18 changes to the hardened vent. And the interim staff
19 guidance speaks to what they call seismically
20 robust. And I'm wondering if staff can provide some
21 -- just a description of the differences between
22 seismically rated and seismically robust.

23 CHAIR SCHULTZ: Paul, two things. One,
24 I'm going to ask you to do two things. The first is
25 in the format for the subcommittee what you're

1 provided the opportunity for is a public comment,
2 not a question to the staff.

3 MR. GUNTER: Okay.

4 CHAIR SCHULTZ: So if you can first just
5 rephrase what you've stated as a comment we'd
6 certainly take it into consideration. And could you
7 please be sure you're speaking clearly as you can
8 into your phone. It's coming over a bit unclear.
9 So in terms of your diction and so forth.

10 MR. GUNTER: Yes, I'm on a cell phone.

11 CHAIR SCHULTZ: Okay, so take that into
12 consideration, please, and rephrase as a comment.
13 Thank you.

14 MR. GUNTER: Thank you. Again, my
15 concern regards the issue of seismic qualification.
16 And given, you know, sitting through this discussion
17 it seems as likely that, you know, the order that's
18 moving forward is what's going to stand. But the
19 current order does not -- it explicitly states that
20 the enhanced hardened vent will be seismically
21 robust. And it's my concern and it's the concern of
22 a number of members of the public that there is a
23 differentiation between seismically robust and
24 seismically qualified.

25 It was expressed earlier on in the

1 subcommittee meeting that there was clearly a need
2 for a seismically qualified hardened vent. But the
3 order that stands, the order that's moving forward
4 now and the order that the licensees are currently
5 basing their designs basically writes out
6 seismically qualified vent.

7 And you know, the concern is that we
8 don't really understand or see how seismically
9 robust is defined. And I think that that needs to
10 be publicly stated. Thank you.

11 CHAIR SCHULTZ: Thank you for your
12 comment. If you could put your phone on mute so
13 that other members of the public calling in can make
14 their comments we'd appreciate it. Thank you.
15 Thank you, Paul.

16 MR. LEYSE: Yes, this is Mark Leyse.

17 CHAIR SCHULTZ: Mark, could you hold on
18 just a moment? I know you've provided us a slide to
19 look at and that's coming up on the screen
20 momentarily. I'll take your comment next.

21 MR. LEYSE: Okay, thank you.

22 CHAIR SCHULTZ: Okay, the slide that you
23 provided is on the screen here and everyone in the
24 room can see it. So go ahead and proceed.

25 MR. LEYSE: Thank you. Okay. Yes. I

1 would like to thank the ACRS for giving me the
2 opportunity to speak, to fill in for Robert Leyse.

3 The slide which you have on the screen
4 are five questions which he had. And I think the
5 primary question is the fifth question talking about
6 what would the minimum diameter of the vent need to
7 be.

8 CHAIR SCHULTZ: Mark, excuse me. Can
9 you identify yourself?

10 MR. LEYSE: Sure.

11 CHAIR SCHULTZ: Thank you.

12 MR. LEYSE: Mark Leyse, L-E-Y-S-E.

13 CHAIR SCHULTZ: And proceed, thank you.

14 MR. LEYSE: You're welcome. Yes.

15 First, I want to point out that in the September
16 5th, 2012 ACRS meeting Dana Powers said that, quote,
17 "Neither MELCOR nor MACCS have a very firm
18 experimental base for modeling core degradation in
19 BWR accidents," end of quote.

20 And today I want to supplement that. I
21 would like to discuss the fact that the NRC's MELCOR
22 and EPRI's MAAP codes under-predict the rates of
23 hydrogen production that would occur in a severe
24 accident, especially the rates of hydrogen
25 production that would occur if there were a re-

1 flooding of an overheated core which did occur in
2 the Three Mile Island accident. There was a phase
3 where the overheated core was re-flooded. In such
4 case there's massive hydrogen generation.

5 Anyway, the MELCOR code uses the
6 Urbanic-Heidrick correlation to help predict
7 zirconium steam reaction rates. And that
8 correlation is used between the temperatures of 15,
9 20 and 2,880 degrees Fahrenheit. So that's a pretty
10 significant temperature range for a severe accident.

11 In a 2001 OECD Nuclear Energy Agency
12 report, the title is "In-Vessel and Ex-Vessel
13 Hydrogen Sources," it states that computer codes
14 using the available zircaloy steam oxidation
15 correlation such as the Urbanic-Heidrick correlation
16 under-predict hydrogen production in severe accident
17 scenarios in which there would be the re-flooding of
18 an overheated core.

19 So the NRC's calculations with MELCOR
20 using the Urbanic-Heidrick correlation under-
21 predicts hydrogen production rates in severe
22 accident scenarios in which there would be a re-
23 flooding of an overheated core. And the EPRI's MAAP
24 code would also under-predict hydrogen production
25 rates.

1 And there are plenty of other papers
2 that reiterate this same point. A 1999 paper
3 titled, "Current Knowledge on Core Degradation
4 Phenomena: A Review." That's from the Journal of
5 Nuclear Materials. That states, quote, "No models
6 are yet available to predict correctly the quenching
7 processes in the CORA and LOFT-LPFP2 tests. No
8 experiments have been conducted that are suitable
9 for calibrating the models. Since the increased
10 hydrogen production during quenching cannot be
11 determined on the basis of the available zircaloy
12 steam oxidation correlation new experiments are
13 necessary," end of quote.

14 Computer safety models also failed to
15 predict hydrogen production in the initial quench
16 facility experiments. A 1997 Oak Ridge National
17 Laboratory report explicitly states that, quote, "In
18 the initial quench facility experiments conducted at
19 Karlsruhe, Germany the hydrogen generation could not
20 be determined by available zircaloy steam oxidation
21 correlations," end of quote.

22 In a BWR severe accident hundreds of
23 kilograms of non-condensable hydrogen gas would be
24 produced up to over 3,000 kilograms at rates as high
25 as between 5 and 10 kilograms per second. That's if

1 there were the re-flooding of an overheated reactor
2 core.

3 So I want to just point out that a
4 reliable hardened vent piping would possibly need a
5 greater diameter in thickness than those of the
6 hardened vents that are presently installed in U.S.
7 BWR Mark I's which are typically 8 inches in
8 diameter. And the hardened vent needs to be
9 designed so it would perform well in scenarios in
10 which there would be a rapid containment pressure
11 increase, for example, in the scenarios in which
12 there would be the re-flooding of an overheated
13 reactor core.

14 Lastly, I want to say that the safety
15 analysis conducted by the NRC with MELCOR and EPRI
16 with MAAP regarding filtered vents for BWR Mark I's
17 and Mark II's need to be conservative, not non-
18 conservative. And it seems to me that the results
19 of the MELCOR calculations that the NRC has are non-
20 conservative, and that their results are misleading
21 because the code under-predicts the hydrogen
22 generation rates that would occur in an actual
23 severe accident.

24 Among other things, this would affect
25 the time that the containment would need to be

1 vented, especially in those scenarios in which there
2 was a rapid pressure increase in the primary
3 containment from rapid hydrogen generation.

4 So I would urge the staff and ACRS to
5 please keep in mind that these calculations are non-
6 conservative. Please keep that in mind when you
7 review the MELCOR results of your calculations.
8 Thank you.

9 CHAIR SCHULTZ: Mark, thank you for your
10 comments. We appreciate them and I appreciate you
11 sending the information before the meeting so that
12 we can see the questions that you wanted to present
13 to us today.

14 MR. LEYSE: Yes. May I just add that I
15 just threw a lot of information at -- you know, I
16 was stepping in for my father, Robert Leyse. And
17 some of the information that I've just cited, there
18 are actually references at the end of the transcript
19 for the July 11, 2012 ACRS meeting.

20 There are about three slides and it has
21 -- duplicates some of the information. And there's
22 also at the end of that transcript a short paper I
23 wrote for NRDC that's called "Post-Fukushima
24 Hardened Vents with High-Capacity Filters for BWR
25 Mark I's and Mark II's." That's also at the end of

1 the July 11 transcript. So that has some more of
2 the information.

3 CHAIR SCHULTZ: You just referenced that
4 on this transcript for us and so that will direct
5 whoever is interested back to that set of data. I
6 do recall that and we have incorporated that into
7 that transcript as you've identified. Thank you.

8 MR. LEYSE: Which I really appreciate.

9 CHAIR SCHULTZ: Okay. Are there other
10 members of the public that would like to make
11 comments at this time? It would be on the phone
12 line. So if you're on the phone line and would like
13 to make a comment please identify yourself.

14 Hearing none I'll close the public
15 comment section of the meeting and ask members of
16 the committee for comments that they would like to
17 add at this time. Jack, do you have any final
18 comments? Sanjoy?

19 MEMBER BANERJEE: No.

20 MEMBER SKILLMAN: No, thank you.

21 MEMBER BLEY: Other than thanking the
22 staff for a really good discussion today, nothing
23 additional.

24 CHAIR SCHULTZ: Dana?

25 MEMBER POWERS: I have provided you

1 comments as we went along but I would echo the
2 presentations were just really first rate. I may
3 not agree with everything but it was very clear what
4 you were saying.

5 (Laughter)

6 CHAIR SCHULTZ: Harold?

7 MEMBER RAY: No further comments, thank
8 you.

9 CHAIR SCHULTZ: Mike?

10 MEMBER CORRADINI: Nothing, just again
11 thank the staff. I think it was a very good day.
12 We learned a lot.

13 CHAIR SCHULTZ: Joy?

14 MEMBER REMPE: I'd like to thank the
15 staff also, but I also would like to remind them to
16 please expedite some of the documents before the
17 next meeting because we don't all take the Evelyn
18 Wood speed reading class. And it would be nice to
19 have a little more time to digest it.

20 MEMBER POWERS: Just be aware that
21 she'll ask a lot of questions as a result. So you
22 want to be careful about what you provide.

23 MEMBER REMPE: Never as many as you,
24 Dana.

25 MEMBER CORRADINI: Make sure you

1 optimize them.

2 MR. MONNINGER: We'll make sure we send
3 the research report so that's where all the
4 questions go.

5 CHAIR SCHULTZ: Charlie?

6 MEMBER BROWN: Just echo the credit. No
7 addition -- to the staff. And no other technical.
8 I made my piece.

9 CHAIR SCHULTZ: Bill?

10 MEMBER SHACK: No. Excellent
11 presentation, excellent discussion. I'm looking
12 forward to reading the paper. It should be a real
13 page-turner.

14 (Laughter)

15 CHAIR SCHULTZ: John?

16 MEMBER STETKAR: Nothing more, thanks.

17 MEMBER ARMIJO: Nothing more. A good,
18 good presentation, a lot to think about. Thank you.

19 CHAIR SCHULTZ: Well again I'd like to
20 just summarize in thanking the staff, all of the
21 staff who made presentations today consistently of
22 high quality. And I think, well, you realize more
23 than anyone how difficult those issues that you have
24 been directed to tackle have been. And in regard to
25 the presentation today as well as the work that has

1 been completed it was -- it is of very high quality.

2 Remaining as you can see from our
3 discussion and our questions and our considerations
4 there are still a lot of dynamics associated with
5 both the determination of the regulatory evaluation
6 and the decision-making that will follow.

7 One of the key areas that I think the
8 committee has stressed today is we've heard a lot
9 about the the upside benefit in terms of the
10 potentials that might move forward from a filtered
11 vent. We are equally as concerned about potential
12 downside risk associated with any change, whether it
13 be physical or operational in association with plant
14 modification or procedure modification.

15 That's not stating anything that we
16 don't already know but there are things on the
17 transcript that are certainly worthy of further
18 consideration by the group that is performing the
19 evaluation, documenting the work that has been done
20 and the steering committee that's going to be
21 helping to assess and evaluate what will be
22 presented to the Commission. So again, we look
23 forward to more information and we'll be also
24 providing further considerations. And we can talk
25 as we go forward.

1 So thank you very much again and we look
2 forward to information. With that I'll close the
3 meeting. Oh, excuse me.

4 MR. RULAND: Mr. Chairman, just one
5 final comment. On behalf of the staff I'd like to
6 acknowledge the recognition of the staff's effort.
7 I think it showed. This has been really a huge
8 effort.

9 And if you think about the NRC and all
10 the regulatory issues we've faced over the years I
11 would think that this is one of the most challenging
12 and probably one of the more significant actions
13 that the staff and the Commission has contemplated
14 over the last 5 to 10 years.

15 And I think you gave us a sufficient
16 amount of attention and clearly you see it too that
17 way. And so I'd just like to acknowledge that and
18 I'd just like to commend the staff from me
19 personally. Thank you.

20 CHAIR SCHULTZ: I appreciate you
21 providing that on the record. With that I'll thank
22 the staff once again and close the meeting.

23 (Whereupon, the foregoing matter went
24 off the record at 5:55 p.m.)
25



Filtered Containment Venting Systems

Bob Fretz, Senior Project Manager
Japan Lessons Learned Project Directorate
Office of Nuclear Reactor Regulation

Advisory Committee on Reactor Safeguards
Fukushima Subcommittee
October 3, 2012

Purpose

- To present the staff's preliminary regulatory analysis of the need for filtered venting systems in BWR Mark I and Mark II containments

Proposed Schedule

- 8:40 – 9:00 Introduction
- 9:00 – 9:45 Design and Regulatory History, and Foreign Experience
- 9:45 – 10:30 FCVS in Severe Accident Management
- 10:30 – 11:00 MELCOR Analysis
- 11:00 – 12:30 MACCS2 Analysis
- 12:30 – 1:30 Break
- 1:30 – 2:30 Risk Evaluation
- 2:30 – 3:30 Regulatory Analysis
- 3:30 – 4:30 Qualitative Arguments
- 4:30 – 5:00 Next Steps

Discussion Outline

- Project Plan
- SECY Paper
 1. Design and Regulatory History
 2. Foreign Experience
 3. Analysis of FCVS in Severe Accident Management
 4. Technical Analyses (MELCOR/MACCS/PRA)
 5. Stakeholder Interactions
 6. Evaluation of Options
- Next Steps

Project Plan - Highlights

- **November 30** **SECY Paper to Commission**
- November 20 SECY Paper to EDO
- November 1 ACRS Full Committee
- October 31 ACRS Subcommittee
- October 30 Draft Rev. 2 CP to SC
- October 16 Draft Rev. 1 CP to SC
- October 4 Public Meeting
- October 3 ACRS Subcommittee

SECY Paper Approach

- Purpose of Paper

“The purpose of this paper is to provide the U.S. Nuclear Regulatory Commission (NRC) with **information and recommendations** from the NRC staff regarding the **imposition of new requirements** related to containment venting systems for boiling water reactors (BWRs) with Mark I and Mark II containments.”

- Options

1. No Change
2. Severe Accident Capable Vent
3. Filtered Vent
4. Performance-Based Approach

SECY Paper Outline

- SECY Paper with Summaries of Enclosures, Options, and Recommendations
 - Enclosures
 1. Design and Regulatory History
 2. Foreign Experience
 3. Analysis of FCVS in Severe Accident Management
 4. Technical Analyses (MELCOR/MACCS/PRA)
 5. Stakeholder Interactions
 6. Evaluation of Options

Current Status

- Technical and policy assessments and evaluations ongoing
- Preliminary results being shared, subject to change
- Continuing to engage Steering Committee on path forward
- Staff recommendations will be made when technical evaluations and policy assessments are complete

Design and Regulatory History, and Foreign Experience

Bob Dennig

Office of Nuclear Reactor Regulation
Containment and Ventilation Branch

Design and Regulatory History

- Mark I Containments
 - WASH-1400 & NUREG-1150 found that Mark I containments could be severely challenged if a severe accident occurred
 - Relatively small volume
 - Gas and steam buildup affect pressure more dramatically
 - BWR cores have ~3 times the quantity of zirconium as PWRs
 - Potential for hydrogen gas and containment pressurization

Design and Regulatory History

- Mark I Containments
 - Containment Performance Improvement Program
 - Determine what actions, if any, should be taken to reduce the vulnerability to severe accidents
 - Staff recommended
 - Improve hardened vent
 - Improve RPV depressurization system
 - Provide alternate water supply to RPV and drywell sprays
 - Improve emergency procedures and training
 - Commission approved hardened vent
 - Other recommendations evaluated as part of IPE program

Design and Regulatory History

- Mark II Containments
 - Similar to Mark I, the most challenging severe accident sequences are station blackout and anticipated transients without scram
 - Risk profile dominated by early failure with a release that bypasses the suppression pool
 - Hardened venting was considered not beneficial because of unacceptable offsite consequences without an external filter like MVSS
 - Staff did not recommend generic backfit of hardened vent, but recommended a comprehensive evaluation as part of the IPE program

Design and Regulatory History

- Filtered Containment Vents
 - TMI Action Item – 10 CFR 50.34(f) “provide one or more dedicated containment penetrations, equivalent in size to a single 3-foot diameter opening, in order not to preclude future installation of systems to prevent containment failure, such as a filtered vented containment system”
 - Shoreham supplemental containment venting system
 - During the CPIP, possibility of filters for Mark I and Mark II containment vents was raised, but not pursued
 - Significant advancements in containment venting filter technology have occurred over the past 25 years

Design and Regulatory History

- What we have today...Order EA-12-050 requires
 - Reliable hardened vent capable of performing during a prolonged SBO (designed for use prior to the onset of core damage)
 - Severe accident conditions not considered
 - Designed to minimize operator actions
 - Discharges effluent to a release point above main plant structures

Foreign Experience

- Staff visited Sweden, Switzerland, and Canada
- Commission Paper will summarize FCVS regulatory and technical bases, and status of FCVS in other countries
- Insights from visits and public meetings consistent with previous findings
 - 1988 CSNI Report 156, Specialists' Meeting on Filtered Containment Venting Systems
- Together, FCVS and containment flooding scrub fission products from core debris and remove decay heat

Foreign Experience

- Government decree and/or regulator's order after TMI, Chernobyl, or Fukushima
 - Some plants installed or committed to install FCVS prior to requirement (e.g., Germany and Japan)
 - Regulator and industry develop guidance following regulatory decision (e.g., Sweden)
 - Some countries have periodic backfit reviews
 - Actual accidents more influential to decision (e.g., Switzerland)
 - Severe accidents were not part of the design basis when the decision was made

Foreign Experience

- Technical Bases Summary
 - Manage severe accident overpressure challenges
 - Defense-in-depth to address uncertainties associated with severe accidents
 - Significantly reduce offsite release and land contamination
- After Barsebäck filter was installed, subsequent filter costs considered low to modest

Foreign Experience

- Quantitative Bases Summary
 - Sweden land contamination goal
 - Require a Level 3 PSA
 - Level 1 frequencies low but not sufficient
 - After the decision, ensure equipment performance is acceptable generically and on plant-specific basis
 - Acceptable not judged quantitatively – “significantly reduce”, “almost eliminate”, etc.
 - Factored into emergency planning

Status of FCVS Internationally

Country	Boiling Water Reactors (BWR) by Containment Types						PWR	PWR/ VVER	PHWR	PHWR/ Candu	LWGR RBMK/ EGP
	GE Mark I	GE Mark II	ABB Mark II	GE Mark III	Other	ABWR					
Belgium							7				
Bulgaria								2			
Canada										18	
China							13			2	
Czech Republic							6				
Finland			2					2			
France							58				
Germany					2		11				
Hungary							4				
India	2								16		
Japan	8	7		3	4	3	24				
South Korea (ROK)							19		4		
Mexico		2									
Netherlands							1				
Romania									1	1	
Russia								17			15
Slovakia								4			
Slovenia							1				
South Africa							2				
Spain	1			1			6				
Sweden			4		3		3				
Switzerland	1			1			3				
Taiwan	2			2			2				
Ukraine								15			
United Kingdom							1				

#	FCVS installed and operational, or Committed to installing FCVS
#	Considering installing FCVS
#	No FCVS; has not committed to installing FCVS
#	FCVS Status Unknown

Foreign Experience

FCVS Status at Non-U.S. BWR Facilities

FCVS Status	GE Mark I	GE Mark II	ABB Mark II	GE Mark III	Other	ABWR	Totals	
FCVS Operational	1	0	6	1	5	0	13	30%
Committed	6	7	0	5	4	3	25	57%
Considering	1	0	0	1	0	0	2	5%
No FCVS	2	2	0	0	0	0	4	9%
Non-U.S. Totals	10	9	6	7	9	3	44	

FCVS in Severe Accident Management

Jerry Bettle

Office of Nuclear Reactor Regulation
Containment and Ventilation Branch

FCVS in Severe Accident Management

- Reviewed spectrum of plant procedures
- EOPs and SAMGs describe multiple containment vent pathways
- EDMGs provide portable pumps for RPV/DW injection
- Existing guidance provides for containment venting and injecting water to the reactor cavity
- EOPs focus on preventing core damage
- Decision to vent may be complicated with an unfiltered vent

FCVS in Severe Accident Management

- DW Sprays for Decontamination
 - Spray headers designed for DBA purposes (pressure control and heat removal) with flow rates of 1,000's GPM (provide estimated DFs around 10)
 - Portable pumps with flow rates in low 100's GPM result in spray nozzle dribble and DFs much less than full flow DFs
 - Good for cavity flooding
 - Not as effective for decontamination

FCVS in Severe Accident Management

- Suppression Pool for Decontamination
 - SRV discharge via T-quencher in bottom of subcooled suppression pool provides an aerosol DF of 100 to 300
 - Downcomer pipes which discharge higher in the suppression pool at or near saturation temperatures provide DFs of 10 or less

FCVS in Severe Accident Management

- EPRI Investigation of Strategies for Mitigating Radiological Releases in Severe Accidents
 - Employs a portable pump to flood drywell cavity and maintain suppression pool subcooling
 - Controls containment pressure near design value for holdup, settling, plate-out, spray effect, and high velocity discharge into suppression pool
 - Cycles containment vent valves to maintain containment pressure band (substantial reliance on instrumentation, valves/actuators, and operator actions)
 - Swap-over from WW to DW vent after 20 hours as containment floods up

FCVS in Severe Accident Management

- Staff preliminary assessment of EPRI investigation
 - Did not address potential increase in penetration leakage due to increased heat, radiation, and pressure
 - Did not address operation of valve, including instrumentation, procedures and human performance
 - Did not address water vapor condensation in vent line and potential for hydrogen buildup

Options Identified by Staff

- No Change (Option 1)
- Severe Accident Capable Vent (Option 2)
- Filtered Vent (Option 3)
- Performance-Based Approach (Option 4)

Option 2 - Severe Accident Capable Vent

- Upgraded reliable hardened vent for severe accident conditions and service
 - Higher temperatures and pressure
 - Hydrogen considerations in the vent line (inerting considerations)
 - Severe accident capable vent valves
 - Shielding for operator actions and personnel access to reactor building and/or remote manual operation of vent valves

Option 2 - Severe Accident Capable Vent

- Capable of safely handling hydrogen – Protect the reactor building and mitigate early hydrogen pressurization
- Capable of safely handling fission products – Maintain reactor building integrity for access to instrumentation and equipment, and facilitate operator actions
- Wetwell vent path only (did not consider consequences of swap-over to drywell vent)
- Protects containment by venting even after core damage
- Success depends on uncertain accident progression, decontamination in the suppression pool, and drywell sprays
- Upgrading existing Mark I vent path may require more work than expected for the reliable hardened vent

Option 3 - Filtered Vent

- Significant enhancement in severe accident containment performance
 - Benefits of Option 2 plus defense in depth enhancements
- No identified technical or safety problems
- Venting with a filter results in a much smaller release compared to without a filter
- Proven, feasible option that has been implemented in several countries

Option 3 - Filtered Vent


- External Filter System
 - Vent line branch from wetwell with normally closed valves are most compatible with early venting
 - May eventually be submerged and unusable due to drywell water injection
 - Vent line from drywell with two branches (one with rupture disk and normally open valve for passive venting, and the other with normally closed valves for early manual venting)
 - Supports drywell floodup and avoids shifting from wetwell to drywell venting and reliance on operator action to preserve containment function for 24+ hrs

Option 3 - Filtered Vent

- External Filter System
 - Staff would develop a technical basis to require a minimum DF or other performance requirement
 - e.g., $DF > 1,000$ aerosols (including submicron),
 - e.g., $DF > 100$ elemental Iodine
 - Engage stakeholders to develop appropriate performance criteria
 - May require active and passive features for prolonged SBO under severe accident conditions

Option 3 - Filtered Vent

- External Wet Filter System



Option 4 - Performance Based

- Potential approaches
 - Each plant meets a defined DF for a defined source term
 - Each plant meets criteria defined for combination of event frequencies and DF
 - Each plant performs a site-specific cost/benefit analysis
- Could potentially address forthcoming industry “filtering strategy” proposal (anticipating industry submittal)

Technical Analysis of Options 1, 2, & 3

- NRR identified a number of accident sequences (i.e., cases) to be evaluated by RES in support of conducting a Regulatory Analysis
 - Base cases were intended to be representative of options considered
 - Sensitivity cases also evaluated
- MELCOR calculations
 - Calculations informed by SOARCA and Fukushima
 - Various prevention and mitigation actions
- MACCS calculations
 - Venting with and without filter
- Event sequences and probabilities
- Consequence and frequency estimates

MELCOR Analysis

Sudhamay Basu and Allen Notafrancesco
Office of Nuclear Regulatory Research
Fuel and Source Term Code Development Branch

Insights on BWR Mark I Response

- SOARCA Peach Bottom Analysis
 - Base case SBO sequences with no sprays or venting
 - Primary containment vessel failure modes
 - DW liner shell melt-thru and over-pressure
 - Reactor building accident response
 - Blow-out panels open, local H₂ combustion, and roof failure
- Fukushima
 - Long term SBO with protracted RCIC operation
 - Primary containment vessel failure modes
 - Over-pressurization with leakage thru drywell head and containment penetrations?
 - Reactor building accident response
 - Significant combustion events


Filtered Vent MELCOR Analysis

- Based on SOARCA MELCOR modeling
- Accident sequences
 - Informed by SOARCA and Fukushima
 - Long-term SBO (base case 16 hr RCIC)
- Mitigation actions
 - B.5.b and/or FLEX provide core spray or drywell spray (300 gpm)
 - Containment venting
- Sensitivity analysis
 - Spray flow rate and timing, wetwell versus drywell venting, and RCIC duration


Insights from MELCOR Calculations

- Water on the drywell floor is needed to prevent liner melt-through
 - Also scrubs fission products and reduces drywell temperature
- Venting prevents over-pressurization failure
 - Wetwell venting is preferable to drywell venting
- Need combination of venting and drywell flooding
 - More reduction in fission product release
 - Maintain reactor building integrity

MELCOR BWR Nodalization



Reactor Building Nodalization



Containment Nodalization

Examples of MELCOR Results

Event Timing (hr.)	Case 2 RCIC only	Case 3 RCIC + wetwell vent	Case 6 RCIC + core spray	Case 7 RCIC + core spray + wetwell vent
Station blackout	0.0	0.0	0.0	0.0
RCIC flow terminates	17.9	17.9	17.9	18.0
Core uncover	22.9	22.9	22.9	22.9
Relocation of core debris to lower plenum	25.9	25.9	25.9	25.8
RPV lower head failure	37.3	34.3	36.7	33.8
Drywell pressure > 60 psig	22.8	22.8	23.3	23.2
Drywell head flange leakage (>80 psig)	25.5	---	25.4	---
Drywell liner melt-through	40.3	36.6	---	---
Calculation terminated	48	48	48	48

Examples of MELCOR Results

Event Timing (hr.)	Case 12 RCIC + drywell vent	Case 13 RCIC + drywell spray + drywell vent	Case 14 RCIC + drywell spray	Case 15 RCIC + drywell spray + wetwell vent
Station blackout	0.0	0.0	0.0	0.0
RCIC flow terminates	17.9	17.9	17.9	18.0
Core uncover	22.9	22.9	22.9	22.9
Relocation of core debris to lower plenum	28.3	28.7	25.7	25.6
RPV lower head failure	34.2	34.7	36.6	35.3
Drywell pressure > 60 psig	27.7	27.7	23.2	23.3
Drywell head flange leakage (>80 psig)	---	---	25.8	---
Drywell liner melt-through	34.8	---	---	---
Calculation terminated	48	48	48	48


Examples of MELCOR Results

Selected MELCOR Results	Case 2 RCIC only	Case 3 RCIC + vent	Case 6 RCIC + core spray	Case 7 RCIC + core spray + vent
Debris mass ejected (1000 kg)	286	270	255	302
In-vessel hydrogen generated (kg-mole)	525	600	500	600
Ex-vessel hydrogen generated (kg-mole)	461	708	276	333
Other non-condensable generated (kg-mole)	541	845	323	390
Cesium release fraction at 48 hrs.	1.32E-02	4.59E-03	3.76E-03	3.40E-03
Iodine release fraction at 48 hrs.	2.00E-02	2.81E-02	1.70E-02	2.37E-02


Examples of MELCOR Results

Selected MELCOR Results	Case 12 RCIC + drywell vent	Case 13 RCIC + drywell spray + drywell vent	Case 14 RCIC + drywell spray	Case 15 RCIC + drywell spray + wetwell vent
Debris mass ejected (1000 kg)	345	351	267	257
In-vessel hydrogen generated (kg-mole)	714	793	614	650
Ex-vessel hydrogen generated (kg-mole)	774	410	327	276
Other non-condensable generated (kg-mole)	922	485	383	270
Cesium release fraction at 48 hrs.	1.93E-01	1.86E-01	1.12E-03	3.01E-03
Iodine release fraction at 48 hrs.	4.90E-01	4.84E-01	5.41E-03	1.86E-02


Drywell Pressure




Drywell Pressure



Cs Release to Environment



Cs Release to Environment



MACCS2 Analyses Supporting Filtered Containment Venting Systems Commission Paper

Tina Ghosh

Office of Nuclear Regulatory Research

Nathan Bixler

Sandia National Laboratories

Outline


- Overview of MACCS2
 - MACCS2 Modules
 - ATMOS: Atmospheric Modeling
 - EARLY: Emergency Phase Modeling
 - CHRONC: Long Term Phase Modeling
 - MACCS2 Uses
 - References
- MACCS2 analysis for filtered containment venting systems
 - Scope of analysis
 - Inputs
 - Results of calculations, venting with and without filter

Overview of MACCS2

- MACCS2: MELCOR Accident Consequence Code System 2
 - Level-3 PRA tool to assess the risk and consequence associated with a hypothetical release of radioactive material into the atmosphere
 - First released in 1997
 - Evolved from series of codes: CRAC, CRAC2, MACCS, MACCS2
 - Estimates consequences
 - Health effects – numbers and risks
 - Economic impacts – land areas and costs
 - No equivalent industry code
- WinMACCS Graphical User Interface
 - Assist the user in creating MACCS2 inputs
 - Preprocessor for MACCS2 input
 - Postprocessor for MACCS2 output
 - Allow uncertainty mode sampling
- Use of MACCS2 in State-of-the-Art Reactor Consequences Analyses study peer-reviewed by independent panel of experts

Pathways to Receptors from Atmospheric Release

MACCS2 models the radioactive transport through the atmosphere (e.g. plume rise, dispersion, dry and wet deposition)



MACCS2 estimates the health effects from: inhalation, cloudshine, groundshine, skin deposition, and ingestion (e.g. water, milk, meat, crops)

MACCS2 Modules

- ATMOS
 - Not associated with a phase
 - Atmospheric transport and deposition
- EARLY (1 day to 1 week)
 - Emergency-phase
 - Prompt and latent health effects
 - Effects of sheltering, evacuation, and relocation
- CHRONC
 - Intermediate phase (0 to 1 year)
 - Long-term phase (0 to 317 years; 30-50 years typical)
 - Latent health effects
 - Effects of decontamination, interdiction, and condemnation

ATMOS Module

Atmospheric Transport and Dispersion (ATD) Estimates

- Dispersion based on Gaussian plume segment model
 - Provisions for meander and surface roughness effects
 - Phenomena not treated in detail in this model: irregular terrain, spatial variations in wind field, temporal variations in wind direction
 - A study (NUREG/CR-6853) comparing the MACCS2 ATD model with two Gaussian puff codes and a Lagrangian particle tracking code showed that the MACCS2 mean results (over weather) were within a factor of 2 for arc-averages and a factor of 3 at a specific grid location out to 100 miles from the point of release.
- Multiple Plume Segments (up to 200)
- Plume rise from initial release height
- Effects of building wake on initial plume size
- Dry and wet deposition
- Radioactive decay and ingrowth (150 radionuclides, 6 generations)

ATMOS Module (continued)

- MELCOR source term is input via MELMACCS
- Meteorological data required
 - Wind speed and direction
 - Pasquill stability category
 - Precipitation rate
 - Seasonal AM and PM mixing-layer height
- User selectable meteorology sampling options
 - Single weather sequence
 - Multiple weather sequences
 - Statistical sampling to represent uncertain conditions at the time of a hypothetical accident
- Outputs
 - Dispersion parameters, χ/Q , fraction remaining in plume
 - Air and ground concentrations

EARLY Module

- Emergency-phase consequences
 - Acute and lifetime doses for following dose pathways
 - Inhalation (direct and resuspension),
 - Cloudshine
 - Groundshine
 - Skin deposition
 - Associated health effects
 - Early injuries/fatalities from acute doses
 - Latent health effects from lifetime committed doses
- Doses are subject to effects of
 - Sheltering
 - Evacuation
 - Speed can vary by phase, location, precipitation
 - Relocation criteria for individuals
 - Based on projected dose
- Outputs
 - Doses, health effects, land contamination areas

CHRONC Module

- Intermediate Phase (optional, 0 to 1 year)
 - Dose pathways
 - Groundshine
 - Resuspension inhalation
 - Continued relocation is only protective action
- Long-Term Phase (up to 317 years, 30 to 50 typical)
 - Dose pathways
 - Groundshine
 - Resuspension inhalation
 - Ingestion
 - Protective actions
 - Based on habitability and farmability
 - Actions include
 - Decontamination
 - Interdiction
 - Condemnation

CHRONC Module (continued)

Decision logic for long-term protective actions

- Habitability criterion initially met?
 - No actions required
 - Population home at beginning of long-term phase
- Decontamination sufficient to restore habitability?
 - First-level decontamination performed if sufficient
 - Sequentially higher levels of decontamination performed if required
 - Population returns home following decontamination
- Decontamination plus interdiction sufficient to restore habitability?
 - Highest-level decontamination performed
 - Property is interdicted up to 30 years
 - Population returns home following decontamination plus interdiction
- Property is condemned when
 - Habitability cannot be restored within 30 years
 - Cost to restore habitability > value of property

CHRONC Module (continued)

- Economic costs
 - Per diem and lost income for evacuation/relocation
 - Moving expense lost income for interdicted property
 - Decontamination labor and materials
 - Loss of use of property
 - Condemned property
 - Contaminated crops and dairy
- Output
 - Doses by pathway and organ
 - Latent health effects
 - Economic costs

MACCS2 Uses

- PRAs and other severe accident studies (e.g., SOARCA)
 - Risks from operating a facility
 - Relative importance of the risk contributors
 - Insights on potential safety improvements
- NRC Regulatory Analyses
- NEPA Studies (National Environmental Policy Act) such as: License extension and new reactor applications
 - Environmental Impact Statements (EISs)
 - the results of the calculations are typically used to compare the accident risks posed by various alternatives
 - Severe Accident Mitigation Alternatives (SAMAs) and Design Alternative (SAMDAs) analyses required for license renewal and for new licenses
- DOE Applications: Authorization basis analyses performed for DBAs
 - the analyst is interested in conservatively calculated, bounding dose estimates for well-defined DBA and beyond-DBA accident scenarios. The results of this analysis are used to determine if the safety basis of the facility is adequate for operation (DOE 1989, 1992b)
- MACCS2 has an international usership (US plus over 10 other countries)

References

- Jow, H-N, J. L. Sprung, J. A. Rollstin, L. T. Ritchie, D. I. Chanin (1990), MELCOR Accident Consequence Code System (MACCS): Model Description, NUREG/CR-4691, Volume 2.
- Chanin, D., M. L. Young, J. Randall, K. Jamali (1998), Code Manual for MACCS2: Volume 1, User's Guide, NUREG/CR-6613.
- Chanin, D., M. L. Young, J. Randall, K. Jamali (1998), Code Manual for MACCS2: Volume 2, Preprocessor Codes COMIDA2, FGRDCF, IDCF2, NUREG/CR-6613.
- Young, M. L., D. Chanin (1997 draft), DOSFAC2 User's Guide, NUREG/CR-6547.
- Bixler, N. E., S. A. Shannon, C. W. Morrow, B. E. Meloche, and J. N. Ridgely (2003), SECPOP2000: Sector Population, Land Fraction, and Economic Estimation Program, NUREG/CR-6525 Rev. 1.
- C.R. Molenkamp, N.E. Bixler, C.W. Morrow, J.V. Ramsdell, Jr., J.A. Mitchell(2004), "Comparison of Average Transport and Dispersion Among a Gaussian, a Two-Dimensional, and a Three-Dimensional Model," NUREG/CR-6853.
- *Consolidated NUREG/CR Manual Under Development*

Scope of Analysis for Filtered Vents

MACCS2 used to calculate:

- Offsite population doses
 - Includes doses to public as well as off-site decontamination workers
- Individual latent cancer fatality risk and prompt fatality risk
- Land contamination
 - For different thresholds of Cs-137 concentration in soil (Ci/km²)
- Economic cost
- For 50-mile radius around plant

Inputs

- Work is based on the SOARCA project, which is documented in NUREG-1935 and NUREG/CR-7110 Volume 1
- Started with SOARCA inputs for Peach Bottom Atomic Power Station pilot plant (with exception of source term, and ingestion pathway modeled)
- Habitability (return) criterion used is 500 mrem/year, per Pennsylvania State guideline
- Statistical sampling of weather sequences used to represent uncertain conditions at the time of a hypothetical accident (~1,000 weather trials)
- Linear-no-threshold dose response model

Inputs – Six Emergency Phase Cohorts

- Cohort 1: 0 to 10 Public
- Cohort 2: 10 to 20 Shadow
- Cohort 3: 0 to 10 Schools and 0 to 10 Shadow
- Cohort 4: 0 to 10 Special Facilities
- Cohort 5: 0 to 10 Tail
- Cohort 6: Non-Evacuating Public (assumed to be 0.5%)

Inputs – Decontamination Factor of Filters

- Neither MELCOR nor MACCS2 models mechanistically the decontamination effect of an external filter
- A prescribed decontamination factor (DF) value is assigned for an external filter
- This DF is applied to only a portion of the total fractional release - the portion which is released through a flow path connected to venting
- For the MACCS2 input, the MELCOR source term from the relevant flow path was reduced by the DF

MACCS2 Results Per Event

Event	Base case Case 2	Base case with WW venting Case 3 Unfiltered Filtered DF = 10	Base case with core spray Case 6	Base case with WW venting and core spray Case 7 Unfiltered Filtered DF = 10
Population dose 50 mile radius <i>per event</i> (rem)	510,000	400,000 180,000	310,000	240,000 37,000
Population weighted latent cancer fatality (LCF) risk 50 mile radius <i>per event</i>	4.8E-05	3.3E-05 1.3E-05	2.5E-05	1.6E-05 2.2E-06
Contaminated area (km ²) with level exceeding 15 $\mu\text{Ci}/\text{m}^2$ <i>per event</i>	280	54 8	72	34 0.4
Total economic cost 50 mile radius <i>per event</i> (\$M)	1,900	1,700 270	850	480 18

MACCS2 Results Per Event (continued)

Event	Base case with drywell venting Case 12 Unfiltered Filtered 1 DF=1,000 Filtered 2 DF=5,000	Base case with DW venting and DW spray Case 13 Unfiltered Filtered DF=1,000	Base case with drywell spray Case 14	Base case with WW venting & drywell spray Case 15 Unfiltered Filtered DF = 10
Population dose 50 mile radius <i>per event</i> (rem)	3,800,000 230,000 210,000	3,900,000 60,000	86,000	280,000 43,000
Population weighted latent cancer fatality (LCF) risk 50 mile radius <i>per event</i>	3.2E-04 1.6E-05 1.4E-05	3.3E-04 3.7E-06	6.4E-06	2.1E-05 2.7E-06
Contaminated area (km ²) with level exceeding 15 µCi/m2 <i>per event</i>	9,200 28 25	8,800 2	10	28 0.3
Total economic cost 50 mile radius <i>per event</i> (\$M)	33,000 390 370	33,000 38	116	590 20

Insights from MACCS2 Calculations

- The health effect of interest is latent cancer fatality risk, which is controlled in part by the habitability (return) criterion
 - Essentially no prompt fatality risk
- In terms of long-term radiation, the most important isotope is Cs-137, and most of the doses are from ground shine
- There is a non-linear relationship between decontamination factor and both land contamination area and health effects

Severe Accident Containment Vent Risk Evaluation

Marty Stutzke

Office of Nuclear Regulatory Research


Outline

- Purpose
- Conditional Containment Failure Probability
- Insights from Severe Accident Mitigation Alternatives (SAMA) Analyses
- Technical Approach
- Results
- Uncertainties

Purpose


- To estimate the risk reduction resulting from installation of a severe accident containment vent for use in regulatory analysis
 - 50-mile population dose ($\Delta\text{person-rem/ry}$)
 - 50-mile offsite cost ($\Delta\$/\text{ry}$)
 - Onsite worker dose risk ($\Delta\text{person-rem/ry}$)
 - Onsite cost risk ($\Delta\$/\text{ry}$)
 - Land contamination ($\Delta\text{conditional contaminated land area}$)

Conditional Containment Failure Probability (BWR Individual Plant Examinations)



Source: NUREG-1560, Figure 12.3

Conditional Containment Failure Probability (PWR Individual Plant Examinations)



Source: NUREG-1560, Table 12.17

Conditional Containment Failure Probability (ILRT Extension License Amendments)

Plant	Type	ILRT Interval	Accident Phenomena	Bypass (ISLOCA)	Isolation Failures	Total CCFP
Cooper	Mark I	3 in 10y	94.6%	0.0%	1.0%	95.6%
		1 in 10y	94.6%	0.0%	1.0%	95.6%
		1 in 15y	94.6%	0.0%	1.0%	95.6%
Nine Mile Point 1	Mark I	3 in 10y	62.4%	2.7%	9.7%	74.8%
		1 in 10y	62.4%	2.7%	9.7%	74.9%
		1 in 15y	62.4%	2.7%	9.8%	74.9%
Peach Bottom	Mark I	3 in 10y	61.1%	2.4%	2.7%	66.2%
		1 in 10y	61.1%	2.4%	3.4%	67.0%
		1 in 15y	61.1%	2.4%	4.0%	67.5%
Pilgrim	Mark I	3 in 10y	97.7%	0.6%	0.0%	98.3%
		1 in 10y	97.7%	0.6%	0.1%	98.3%
		1 in 15y	97.7%	0.6%	0.1%	98.4%
Vermont Yankee	Mark I	1 in 10y	86.8%	1.1%	0.1%	88.0%
		1 in 15y	86.8%	1.1%	0.2%	88.1%
LaSalle	Mark II	3 in 10y	82.9%	2.4%	0.4%	85.7%
		1 in 10y	82.9%	2.4%	0.6%	85.9%
		1 in 15y	82.9%	2.4%	0.8%	86.1%
Limerick	Mark II	3 in 10y	62.4%	1.3%	0.7%	64.4%
		1 in 10y	62.4%	1.3%	1.5%	65.2%
		1 in 15y	62.4%	1.3%	2.0%	65.7%

Consideration of Filtered Containment Vents in SAMA Analyses

(As of February 2012)

Plant Type	Filtered Containment Vent Not Considered	FCV Considered (Screening Analysis)	FCV Considered (Detailed Analysis)	License Renewal Granted, but Limited SAMA	License Renewal Application Not Submitted	Total
BWR Mark I	5	11	5	1	1	23
BWR Mark II	1	3		2	2	8
BWR Mark III			1		3	4
PWR large dry containment	22	10	14		9	55
PWR subatmospheric containment			5			5
PWR ice condenser		2	4		3	9
Total	28	26	29	3	18	104

Screening Analysis: cost of implementation > plant-specific maximum possible monetized averted risk

Detailed SAMA Analyses of Filtered Containment Venting

Plant	Offsite Dose Reduction	Estimated Benefit	Notes
FitzPatrick	3.73%	\$4,090	Successful torus venting accident progression source terms were reduced by a factor of 2 to reflect the additional filtered capability
Pilgrim	0.00%	\$0	Successful torus venting accident progression source terms were reduced by a factor of 2 to reflect the additional filtered capability
Vermont Yankee	0.11%	\$200	Successful torus venting sequences were binned into the Low-Low release category to conservatively assess the benefit of this SAMA

Not clear if post-core-damage venting to prevent containment overpressurization failure was considered in these analyses

Core Damage Frequency

Source	CDF (/ry)
NUREG-1150 Peach Bottom (includes internal events, fires, and seismic events based on the LLNL hazard curves)	1E-4
SPAR Internal and External Event Models (BWR Mark I Plants) Duane Arnold Monticello Peach Bottom	1E-5 2E-5 2E-5
SAMA Analyses (Five BWR Mark I and Mark II plants with internal and external event PRAs)	2E-5 to 6E-5
Global Statistical Value	3E-4

Economic Consequences

Source	cost/event
Regulatory analysis handbook (NUREG/BR-0184, Table 5.6, Peach Bottom, 1990 dollars)	\$3B*
SAMA Analyses Peach Bottom Minimum for BWR Mark I and Mark II plants (Hatch) Maximum for BWR Mark I and Mark II plants (Hope Creek)	\$10B* \$0.6B* \$30B*
Estimated Fukushima offsite costs (3 Units) (Japan Center for Economic Research, June 2011, includes land condemnation for 20 km and compensation for 10 years)	\$62B
Deepwater Horizon oil spill	\$23B

*Frequency-weighted average of the point estimates for internal events


Designing a Technical Approach

- Focus on BWR Mark I plants
 - Risk modeling
 - No change in CDF
 - Need to use simplified Level 2/3 PRA
 - Not feasible to develop complete Level 3 PRA
 - SOARCA MELCOR and MACCS2 for Peach Bottom
 - Eight candidate plant modifications
 - Vent actuation: manual or passive
 - Vent location: wetwell or drywell
 - Filter: no or yes
 - Consideration of post-core-damage core spray or drywell spray to prevent liner melt-through
- Affects frequency estimation
- Affects consequence estimation

Assumptions and Groundrules

- Use existing regulatory analysis guidance
 - Risk evaluation developed on a “per-reactor” basis
 - Multi-unit accidents not addressed
 - Spent fuel pool accidents not addressed
- Release sequence consequences are reasonably approximated by determining the consequences of SBO sequences
- Battery life is 16 hours
- Filter decontamination factor of 10
- No credit for recovering offsite power if core-damage was caused by an external hazard (e.g., seismic, high winds)
- If a sequence involves failure to open the vent or containment bypass (e.g., ISLOCA), then use of a portable pump (B.5.b/FLEX) for core spray or drywell spray following core damage is precluded due to a harsh work environment (high dose rates, high temperatures, etc.)

Release Event Tree



Release Sequence Quantification Data Sources

Parameter	Value		Basis
Core-damage frequency	2E-5/ry		SPAR models
Fraction of total CDF due to external hazards	0.8		SPAR-EE models
Breakdown of sequence types for internal hazards	Other (not SBO, bypass, or fast)	0.83	SPAR models
	SBO	0.12	
	Bypass (ISLOCAs)	0.05	
	Fast (MLOCAs, LLOCAs, ATWS)	0.01	
Breakdown of sequence types for external hazards	Other (not bypass)	0.95	Engineering judgment
	Bypass	0.05	

Release Sequence

Quantification Data Sources

Parameter	Value		Basis
Probability that severe accident vent fails to open	Mod 0	1	Current situation (base case)
	Mods 1,3,5,7 – other or SBO	0.3	SPAR-H (manual vent, longer available time)
	Mods 1,3,5,7 - fast	0.5	SPAR-H (manual vent, shorter available time)
	Mods 2,4,6,8	0.001	Engineering judgment (passive vent)
Conditional probability that offsite power is not recovered by the time of lower head failure given not recovered at the time of core damage (internal hazards)	0.38		NUREG/CR-6890
Probability that portable pump for core spray or drywell spray fails	0.3		SPAR-H; consistent with B.5.b study done by INL

Mapping Release Sequence End States to MELCOR/MACCS2 Cases

Release Sequence End State				
Identifier	vented	LMT	OP	OP + LMT
Vented	yes	yes	no	no
Drywell Status	wet	dry	wet	dry
Sequences	1,4,5,10,13	2,6,11,14	7	3,8,9,12,15,16

Vent Location	Filter	Mod(s)	MELCOR/MACCS2 Case			
Wetwell	No	0 - none 1 - manual 2 - passive	Case 7 or 15 (no filter)	Case 3 (no filter)	Case 6	Case 2
Drywell	No	3 - manual 4 - passive	Case 13 (no filter)	Case 12 (no filter)	Case 14	Case 2
Wetwell	Yes	5 - manual 6 - passive	Case 7 or 15 (filter)	Case 3 (filter)	Case 6	Case 2
Drywell	Yes	7 - manual 8 - passive	Case 13 (filter)	Case 12 (filter)	Case 14	Case 2

Accident Sequence Frequency Contributions


Containment Failure Mode	Manual Vent Mods 1, 3, 5, 7	Passive Vent Mods 2, 4, 6, 8
Overpressurization (OP)	0.4%	0.0%
Liner Melt-Through (LMT)	19.6%	28.0%
Overpressurization and Liner Melt-Through (OP + LMT)	33.1%	5.1%
Total	53.2%	33.1%

Reduction in Population Dose Risk (Δ person-rem/reactor-year)

Unfiltered				Filtered			
Wetwell		Drywell		Wetwell		Drywell	
Manual	Passive	Manual	Passive	Manual	Passive	Manual	Passive
Mod 1	Mod 2	Mod 3	Mod 4	Mod 5	Mod 6	Mod 7	Mod 8




Reduction in Offsite Cost Risk (Δ \$/reactor-year)



Reduction in Worker Dose Risk (Δ person-rem/reactor-year)

Unfiltered				Filtered			
Wetwell		Drywell		Wetwell		Drywell	
Manual	Passive	Manual	Passive	Manual	Passive	Manual	Passive
Mod 1	Mod 2	Mod 3	Mod 4	Mod 5	Mod 6	Mod 7	Mod 8




Reduction in Onsite Cost Risk (Δ \$/reactor-year)

Unfiltered				Filtered			
Wetwell		Drywell		Wetwell		Drywell	
Manual	Passive	Manual	Passive	Manual	Passive	Manual	Passive
Mod 1	Mod 2	Mod 3	Mod 4	Mod 5	Mod 6	Mod 7	Mod 8



Reduction in Conditional Contaminated Land Area (Δ square kilometers)



Uncertainty Analysis

- Approximate Monte Carlo analysis performed to gain an appreciation of the uncertainties involved
 - Sequence frequencies
 - Sequence consequences


Uncertainty Parameters

Parameter	Mean		Parameters
Core-damage frequency	2E-5/ry		Log-normal; EF = 10
Fraction of total CDF due to external hazards	0.8		Beta; $\alpha = 0.5$, $\beta = 0.125$
Breakdown of sequence types for internal hazards	Other (not SBO, bypass, or fast)	0.83	Dirichlet $\alpha_1 = 41$ $\alpha_2 = 6$ $\alpha_3 = 2.5$ $\alpha_4 = 0.5$
	SBO	0.12	
	Bypass (ISLOCAs)	0.05	
	Fast (MLOCAs, LLOCAs, ATWS)	0.01	
Breakdown of sequence types for external hazards	Other (not bypass)	0.95	Beta; $\alpha = 0.5$, $\beta = 9.5$
	Bypass	0.05	


Uncertainty Parameters

Parameter	Mean		Parameters
Probability that severe accident vent fails to open	Mod 0	1	Not uncertain
	Mods 1,3,5,7 – other or SBO	0.3	Beta; $\alpha = 0.5$, $\beta = 1.167$
	Mods 1,3,5,7 - fast	0.5	Beta; $\alpha = 0.5$, $\beta = 0.5$
	Mods 2,4,6,8	0.001	Beta; $\alpha = 0.5$, $\beta = 499.5$
Conditional probability that offsite power is not recovered by the time of lower head failure given not recovered at the time of core damage (internal hazards)	0.38		Beta; $\alpha = 0.5$, $\beta = 0.816$
Probability that portable pump for core spray or drywell spray fails	0.3		Beta; $\alpha = 0.5$, $\beta = 1.167$
Consequences	Per MELCOR/MACCS2 results and regulatory analysis assumptions		Log-normal; EF = 10 (correlated)


Uncertainty in Population Dose Risk Reduction




Uncertainty in Offsite Cost Risk Reduction




Uncertainty in Onsite Worker Dose Risk Reduction



Uncertainty in Onsite Cost Risk Reduction



Uncertainty in Conditional Contaminated Land Area



Regulatory Analysis and Backfitting

Aaron Szabo

Office of Nuclear Reactor Regulation
Rulemaking Branch

Outline

- Regulatory Decision-Making Process
- Methodology for Regulatory Analysis
 - Task-specific information
 - Steps for a Regulatory Analysis
- Backfitting
 - Adequate Protection
 - Cost-Justified Substantial Safety Enhancement
- Filtered Vents Regulatory Analysis
 - Assumptions and Sensitivities
 - Quantitative Analysis
 - Current Framework
 - Sensitivity Analysis
 - Qualified Attributes
- Summary

Regulatory Decision-Making Process

- Regulatory Analysis looks at all the costs and all the benefits of the regulatory action to inform decision-makers
 - Quantified and qualified
 - Identify uncertainties with the analysis
- Backfitting determines if we can impose a requirement on licensees (10 CFR 50.109)

Methodology for Regulatory Analysis

- 4 Options
 - 1: No Change (Re-affirm EA-12-050)
 - 2: Severe Accident Capable Vent
 - 3: Filtered Vent
 - 4: Performance-Based Approach
- All attributes dispositioned using current framework
 - NUREG/BR-0058, NUREG/BR-0184, NUREG-1409
 - Any deviations are identified and provided as a sensitivity analysis

Methodology for Regulatory Analysis

- Steps to perform a Regulatory Analysis
 - Identify legitimate alternatives and options
 - Determine if the action is a backfit
 - Evaluate attributes
 - Public Health (Accident)
 - Offsite Property
 - Industry Implementation
 - NRC Implementation
 - Regulatory Efficiency
 - Occupational Health (Accident)
 - Onsite Property
 - Industry Operation
 - NRC Operation
 - Develop recommendations

How Information is Provided

- Recommendations are provided using the “best [point] estimate” calculations
- Benefits and costs are determined by multiplying the probability of the event by the change in consequences
 - (e.g. Probability of event times (Alt. 1 consequence – Alt. 2 consequence))
- Sensitivity analyses are provided for decision-makers

Backfitting

- Adequate Protection
 - Severe Accident Capable Vent
 - Filtered Vent
 - Performance-Based Approach

Backfitting - Cost-Justified Substantial Safety Enhancement

- 2 Part Analysis
 - Substantial Safety Enhancement
 - Cost-justified
- SRM-SECY-93-086, “Backfit Considerations”
 - The safety enhancement criterion should be administered with the degree of flexibility the Commission originally intended
 - The standard is not intended to be interpreted in a manner that would result in disapprovals of worthwhile safety or security improvements having costs that are justified in view of the increased protection that would be provided
 - Allows for both quantitative and qualitative arguments

Backfitting - Cost-Justified Substantial Safety Enhancement

- Substantial Safety Enhancement
 - Attributes included
 - Public Health (accident)
 - Occupational Health (accident)

Backfitting - Cost-Justified Substantial Safety Enhancement

- Cost-Justified
 - Attributes included
 - Public Health (accident)
 - Occupational Health (accident)
 - Industry Implementation and Operation
 - NRC Implementation and Operation
 - Offsite Property and Onsite Property
 - Regulatory Efficiency

Analysis Assumptions (NUREG/BR-0184)

- Onsite Property
 - Option 1 = Upper bound (\$2B (1993) or \$3.2B (2012))
 - Option 2 = Middle (\$1.5B (1993) or \$2.4B (2012))
 - Option 3 = TMI (\$750M (1981) or \$1.9B (2012))
- Occupational Workers (during accident)
 - Does not include decontamination and cleanup
 - Assumes at least 1,000 workers (small dose)
 - Option 1 = Upper bound (14,000 person-rem)
 - Option 2 = Middle (3,300 person-rem)
 - Option 3 = TMI (1,000 person-rem)

Sensitivity Analysis

Parameter	Current Framework	Sensitivity Analysis
Dollar per person-rem	\$2,000 (NUREG-1530)	\$4,000 (EPA and ICRP No. 103)
Discount Rate	3% and 7% (OMB Circular A-4)	Undiscounted (Current Market)
Initial Event Probability	2E-05 PRA based (SPAR Model)	3E-04 Global Statistical Value (Accidents/Operation)
Monte Carlo PRA	Point Estimate	5 th Percentile and 95 th Percentile
Replacement Energy Costs	\$15.4 million/year (NUREG/BR-0184)	\$56.3 million/year to \$716,000/year (Updated, regional based with high and low values)
	Other unit(s) at site shutdown	All Mark I and Mark II reactors shutdown (30 units)

Sensitivity Analysis

- Recommendation will be based on current framework
- Assessed 107 sensitivity cases based on the consequence results for each option, not including the discount values
 - No sensitivity cases for Industry and NRC Implementation and Operation costs

Quantitative Analysis – Option 2, SACV (Current Framework)

- Estimated Costs
 - Industry Costs: \$60M
 - NRC Costs: \$8M to \$12M
 - Total Costs: \$68M to \$72M

Quantitative Analysis – Option 2, SACV (Current Framework)

- Estimated Benefits (range based on discount factors)
 - Public Health: 112 person-rem averted
 - \$4M to \$5.7M
 - Occupational Health: 5 person-rem averted
 - \$100,000 to \$200,000
 - Offsite Property (Cost Offset)
 - \$8M to \$11M
 - Onsite Property (Cost Offset)
 - \$4.4M to \$7.5M
 - Total Benefit
 - \$16.5M to \$24.4M
- Net Value
 - (\$55.5M) to (\$43.6M)

Quantitative Analysis – Option 3, Filtered Vent (Current Framework)

- Estimated Costs
 - Industry Costs: \$465M (based on \$15M per unit)
 - NRC Costs: \$8M to \$12M
 - Total Costs: \$473M to \$477M

Quantitative Analysis – Option 3, Filtered Vent (Current Framework)

- Estimated Benefits (ranges based on discount factors)
 - Public Health: 212 person-rem averted
 - \$6.3M to \$9.3M
 - Occupational Health: 7 person-rem averted
 - \$300,000 to \$400,000
 - Offsite Property (Cost Offset)
 - \$14M to \$20M
 - Onsite Property (Cost Offset)
 - \$104M to \$181M
 - Total Benefit
 - \$125M to \$211M
- Net Value
 - (\$352M) to (\$262M)

Quantitative Analysis – Option 4, Performance-Based (Current Framework)

- No quantified costs or benefits
- Discussion provided qualitatively
- Amenable to site-specific approaches

Qualitative Arguments

- Will be included in the Regulatory Analysis
- Historically, they have considered safety goal policy qualitative goals, defense-in-depth, uncertainties, consistency with standards (regulatory efficiency), etc.

Summary

- Option 2 (SACV) and Option 3 (filtered vent) do not appear to be cost-beneficial quantitatively in the current framework
 - Sensitivity analysis may provide cases that are cost-beneficial
 - May require qualitative arguments for “substantial safety enhancement”

Qualitative Arguments for Filtered Vents (Option 3)

Tim Collins

Office of Nuclear Reactor Regulation

Division of Safety Systems

Qualitative Arguments

- Defense-in-Depth
- Severe Accident Management Decision Making
 - Operator Response
 - Hydrogen Control
- Consequence Uncertainties
- International Practice

Enhances Defense-in-Depth

- Containment is an essential element of DID
 - Protects against uncertainties in prevention of severe accidents and potential consequences of a large release
- Filtering compensates for the loss of the containment barrier due to venting
- Filtering improves confidence to depressurize containment to address other severe accident challenges

Enhances Defense-in-Depth

- Filtering extends time for emergency planning implementation
 - Adds margin for uncertainty in weather, public response, collateral damage, communications, etc.

Severe Accident Management Decision Making

- Improves operator confidence in a “clean” release for hydrogen control
 - Allows early operator intervention to vent hydrogen and control containment pressure
 - Sustained lower pressure reduces leakage of hydrogen thru penetration seals
 - Decreased leakage reduces threat from hydrogen explosion to reactor building, spent fuel pool, and emergency responders

Severe Accident Management Decision Making

- Facilitates arrest of in-vessel melt progression and ex-vessel challenge to drywell liner
 - Allows early operator intervention to control pressure
 - Sustained lower pressure facilitates injection from low pressure water sources
 - Increases chances of early melt arrest and protection of liner
 - Sustained lower pressure reduces leakage of fission products thru penetration seals
 - Facilitates operator access to reactor building for recovery
 - Facilitates use of all onsite resources

Severe Accident Management Decision Making

- Operator confidence in “clean” release facilitates use of vent as a mitigation tool
 - Supports use of drywell and/or wetwell as vent inlet
 - Alleviates concerns with wetwell floodup strategy
 - Supports passive actuation
 - Minimal consequences of inadvertent actuation

Consequence Uncertainties

- Improves protection against uncertainties associated with potential land contamination
 - Fission product release fractions
 - Weather patterns
 - Farm products/food chain impacts
 - Hydrology
 - Economic impacts

Consequence Uncertainties

- Reduces potential for significant social repercussions
 - Public anxiety
 - Impact on energy supply chain

International Practices

- Consistent with recommendation from Extraordinary Meeting of Members of Convention on Nuclear Safety to upgrade “measures to ensure containment integrity, and filtration strategies and hydrogen management for the containment”
- Consistent with decisions of most European countries, Canada, Taiwan, and Japan

Next Steps

- Continue staff assessment and develop recommendations
- Engage Steering Committee
- Present conclusions and recommendations to ACRS on October 31 and November 1



Filtered Containment Venting Systems

BACKUP SLIDES

Advisory Committee on Reactor Safeguards


Fukushima Subcommittee

October 3, 2012

Bob Dennig


Backup Slides

Comparison of Containment Volumes and Design Pressures




Zr Mass to Containment Free Volume (kg/cu. m)

Source: Nuclear Engineering and Design 162 (1996) 175-203



Uncertainty Distributions for Cesium
Decontamination Factors (DFs) used in NUREG-1150
Mark I Containment - Peach Bottom




Source: "Assessment of In-Containment Aerosol Removal Mechanisms," BNL Technical Report L-1535, 1992.

Particle Collection Efficiency in a Venturi Scrubber: Comparison of Experiments with Theory 1986


- Introduction
- Venturi scrubbers are used widely for removing particles from gases because of their many attractive features: they remove submicrometer particles efficiently; they are compact and simple to build, so that initial investment costs are small in comparison to other types of particle collection devices; and they function well in problematic situations such as hot or corrosive atmospheres and when sticky particles must be collected.

20th DOE/NRC Nuclear Air Cleaning Conference – August 1988

20th DOE/NRC NUCLEAR AIR CLEANING CONFERENCE



20th DOE/NRC Nuclear Air Cleaning Conference – August 1988



20th DOE/NRC Nuclear Air Cleaning Conference – August 1988





Figure 12 The Swedish MVSS Filter Concept

20th DOE/NRC Nuclear Air Cleaning Conference – August 1988



Sweden - FCVS DF Requirement

- No acute fatalities
- Limited area of first year dose from ground contamination (with rain) of greater than 50 mSv (5 Rem)
- Considered met if release of no more than 0.1% core inventory Cs-134, Cs-137, and Iodine of 1,800 MWth reactor, similar for other nuclides important to land contamination (Chernobyl 1%)
- Required demonstrated minimum DF >100; MVSS designed for >500, tested >> 1,000

Canada – FCVS Requirement

“ In 2007, the regulator and the utility discussed the installation of an FCVS similar to those on Swiss plants for severe accident management. The value of an FCVS was assessed by the licensee in a complete Level 2 PSA, including external events, in accordance with CNSC Regulatory Document S-294,. The analysis uses Severe Core Damage Frequency (SCDF), and large release frequency (>1% Cs-137 inventory) as decision metrics that align well with IAEA SSG-3 and SSG-4. The FCVS, costing approximately \$14 million Canadian, was found to be cost-beneficial when using the large release frequency metric. The stated purpose of the FCVS is “to prevent failure of containment integrity due to the increase of containment pressure beyond the failure pressure of approximately 220-230 kPa(g), or 31.9-33.4 psig.”

Finland - STUK

- “Containment filtered vent systems have been installed in Finland at the two operating BWRs, Olkiluoto 1 and 2. They were installed in 1990 at both units as a plant modification.”
- “The design purpose of the filtered vent is to decrease the containment pressure in a severe accident, if the pressure exceed a specified limit (see question 4). **The system is useful in all severe accident sequences, where energy and fission products are released into the containment**”

Required DFs for FCVS by Country

The following DFs are used

- Aerosols

– Sweden	BWR 100	PWR 500
– Germany	BWR 1000	PWR 1000
– Switzerland	BWR 1000	PWR 1000
– France	BWR NA	PWR 1000*
– Finland	BWR 1000	

- Elemental Iodine

– Sweden	BWR 100	PWR 500
– Germany	BWR None	PWR 100
– Switzerland	BWR 100	PWR 100
– France	BWR NA	PWR 10*
– Finland	BWR 100	



*Upgrade under consideration

Jerry Bettle

Backup Slides


FCVS in Severe Accident Management

IMI –PSI AMI System – Wet Filter with Nozzles and Impactor/Baffle Plates




FCVS in Severe Accident Management

Earlier Vintage Wet Filter with venturi nozzles
and NaOH for enhanced iodine retention.



Removal efficiencies
Aerosols
Elemental Iodine



$\geq 99.99\%$
 $\geq 99.5\%$



Operation of venturi nozzles
in submerged configuration

FCVS in Severe Accident Management

FILTRA-MVSS Multi-Venturi and Deep Pool



- A: Vent line from Rx Cnmt
- B: Venturi dist. system
- C: Venturis, incl. riser pipe
- D: Pool
- E: Moisture separator
- F: Release to atmosphere
- G: Pressure vessel
- H: Manhole
- I: Liner

FCVS in Severe Accident Management

Injecting Water Into the Drywell to Ensure Vent Benefit

50.54(hh)(2) currently requires capability for injecting water into the DW as well as into the RPV in BWRs, although for a minimum of 12 hours. Order EA-12-049 requires the capability for injecting water into the RPV, but not explicitly for injecting into the drywell. However, at the moment of RPV breach, RPV injection is drywell injection. The EA-12-049 capability requirement extends for an indefinite period, that is until the capability is no longer needed. Order EA-12-050, similar to EA-12-049, was developed for pre-severe accident (pre-core damage) conditions and thus without core breach of the RPV.

FCVS in Severe Accident Management

09/11/2001



Order EA-02-026, Interim Compensatory Measures (ICM) , Section B.5.b.



10 CFR 50.54 (hh)(2) ...shall develop and implement guidance and strategies intended to maintain or restore core cooling, containment, ... under the circumstances associated with loss of large areas of the plant due to explosions or fire, to include strategies ...to mitigate fuel damage...and actions to minimize radiological release.



FCVS in Severe Accident Management



License Conditions and Licensee Commitments to NEI 06-12, B.5.b
Phase 2 & 3 Submittal Guideline, Rev 2 dated December 2006



NEI 06-12, Rev 2, Section/Strategy 3.4.9, Provide cooling of the core debris and scrubbing of fission products...an AC-power-independent means to inject at least 300 gpm of water to the drywell for a period of 12 hours. The water injection can be directly to the drywell, or through lines connected to the RPV. This could utilize the Phase 2 portable pump or other existing sources.

FCVS in Severe Accident Management

03/11/2011




EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events. NEI 06-12, Rev 2 continues to provide an acceptable means of meeting the requirement to develop, implement and maintain guidance and strategies for that subset of beyond-design-basis external events. NEI 12-06, Rev 0, provides for development and implementation of mitigating strategies for beyond-design-basis external events to address those events not covered within the requirements of 10 CFR 50.54(hh)(2).



NEI 12-06, DIVERSE AND FLEXIBLE COPING STRATEGIES (FLEX) IMPLEMENTATION GUIDE, provides for RPV injection capability by portable pump. Equipment required for compliance with 50.54(hh)(2) may be used to support FLEX implementation. FLEX strategies are focused on the prevention of fuel damage and **would be** available to support accident mitigation efforts following fuel damage, but coordination of the FLEX equipment with Severe Accident Management Guidelines (SAMGs) is not addressed.

FCVS in Severe Accident Management

Uncertainty Distributions for Cesium
Decontamination Factors (DFs) used in NUREG-1150
Mark I Containment - Peach Bottom



Source: "Assessment of In-Containment Aerosol Removal Mechanisms," BNL Technical Report L-1535, 1992.

FCVS in Severe Accident Management

Table 2.1 Distributions for Suppression Pool Decontamination

<u>Conditions</u>	<u>Decontamination Factor (DF)</u>			
	<u>5th Percentile</u>	<u>Median</u>	<u>Mean</u>	<u>95th Percentile</u>
During In-vessel Release Phase (through T-Quenchers)				
Peach Bottom	2.3	81	14.5	1200
LaSalle & Grand Gulf	1.8	56	10.5	2500
During Ex-vessel Release Phase (through Vent Pipes)				
Peach Bottom	1.2	9.5	5.1	50
LaSalle & Grand Gulf	1.2	6.8	4.	72

SIZING A HARDENED VENT: Five Questions

1. What is the range of **compositions** of the **gases** that will be vented?
2. What is the range of **quantities** of **gases** that will be vented?
3. What is the range of **absolute pressures** at which the gases will be vented?
4. What is the range of the **rates** at which the gases will be vented?
5. What is the **minimum area** of a vent that will accommodate the most demanding combination of the above conditions?

A quote from the March 14, 2012, ACRS letter (ML12072A197):

Discussions with stakeholders regarding near-term actions for additional hydrogen control and mitigation measures in plants with Mark I and Mark II containments should be included in the staff's Tier 1 actions.