



**Nebraska Public Power District**

*Always there when you need us*

NLS2012118  
October 22, 2012

U.S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555-0001

**Subject:** Completion of License Renewal Commitment NLS2008071-04  
Cooper Nuclear Station, Docket No. 50-298, DPR-46

- References:**
1. Letter from Stewart B. Minahan, Nebraska Public Power District, to U.S. Nuclear Regulatory Commission, dated September 24, 2008, "License Renewal Application" (NLS2008071)
  2. NUREG-1944, "Safety Evaluation Report Related to the License Renewal of Cooper Nuclear Station," dated October 2010

Dear Sir or Madam:

The purpose of this letter is to inform the Nuclear Regulatory Commission (NRC) of the completion of License Renewal Commitment NLS2008071-04, as required by License Condition 2.F of the Cooper Nuclear Station (CNS) renewed Operating License.

In Reference 1, the Nebraska Public Power District made the following commitment:

Enhance the BWR Vessel Internals Program to include actions to replace the plugs in the core plate bypass holes based on their qualified life. [LRA Section B.1.9]

This commitment was acknowledged in Appendix A of Reference 2. In response, the Boiling Water Reactor (BWR) Vessel Internals Program has been enhanced to include actions to replace the core plate bypass plugs based on their qualified life. Accordingly, this commitment has been implemented at CNS. No additional commitments have been made with this submittal.

Should you have any questions regarding this submittal, please contact David Bremer, License Renewal Implementation Project Manager, at (402) 825-5673.

Sincerely,

David W. Van Der Kamp  
Licensing Manager

/wv

A136  
NRK

NLS2012118

Page 2 of 2

cc: Regional Administrator  
USNRC - Region IV

Cooper Project Manager  
USNRC - NRR Project Directorate IV-1

Senior Resident Inspector  
USNRC - CNS

NPG Distribution

CNS Records