



Entergy Nuclear Northeast  
Entergy Nuclear Operations, Inc.  
James A. FitzPatrick NPP  
P.O. Box 110  
Lycoming, NY 13094  
Tel 315-349-6024 Fax 315-349-6480

Michael J. Colomb  
Site Vice President

JAFP-12-0124  
October 29, 2012

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
11555 Rockville Pike  
Rockville, MD 20852

Subject: Initial Status Report in Response to March 12, 2012 Commission Order  
Modifying Licenses with Regard to Requirements for Mitigation  
Strategies for Beyond-Design-Basis External Events (Order Number EA-  
12-049)

James A. FitzPatrick Nuclear Power Plant  
Docket No. 50-333  
License No. DPR-59

Reference:

1. NRC Order Number EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events (ML 12054A735)
2. NRC Interim Staff Guidance JLD-ISG-2012-01, Compliance with Order EA-12-049, Order Modifying Licenses with Regard to Requirements for Mitigation Strategies for Beyond-Design-Basis External Events, Revision 0, dated August 29, 2012 (ML 12229A174)
3. Nuclear Energy Institute (NEI) Letter to NRC, Industry Initiative on Procurement of Equipment for the Diverse and Flexible Coping Strategy (FLEX), dated February 24, 2012
4. NEI 12-06, Diverse and Flexible Coping Strategies (FLEX) Implementation Guide, Revision 0, dated August 2012

Dear Sir or Madam:

On March 12, 2012, the Nuclear Regulatory Commission ("NRC" or "Commission") issued an order (Reference 1) to Entergy Nuclear Operations, Inc. Reference 1 was immediately effective and directs Entergy Nuclear Operations, Inc. to develop, implement, and maintain guidance and strategies to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities in the event of a beyond-design-basis external event. Specific requirements are outlined in Attachment 2 of Reference 1.

Reference 1 requires submission of an initial status report 60 days following issuance of the final interim staff guidance. The final interim staff guidance (Reference 2) was issued August 29, 2012. The purpose of this letter is to provide the initial status report pursuant to Section IV, Condition C.2, of Reference 1 within 60 days following issuance of Reference 2. This report confirms Entergy Nuclear Operations, Inc. for the James A. FitzPatrick Nuclear

Power Plant (JAF) has received Reference 2 and is in the process of evaluating the guidance for the purpose of establishing mitigation strategies to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities in the event of a beyond-design-basis external event as described in Attachment 2 of Reference 1.

Major activities that have been started or completed during this reporting period:

- Additional portable equipment was ordered prior to the issuance of Reference 2, as described in an NEI letter to the NRC (Reference 3).
- A site-specific evaluation is in progress to establish the coping capabilities as defined in NEI 12-06 (Reference 4).
- Resources are being identified and project plans initiated, including development of milestones, to assure compliance with Reference 1.

Planned activities for the next six months:

- Development and submittal of the overall integrated plan.

Technical difficulties encountered that could affect the ability to provide the licensee's February 28, 2013, submittal:

- None at this time

Project milestones schedule through completion of installation and testing:

- A project milestones schedule will be provided with the overall integrated plan.
- Implementation of the order will be completed for JAF prior to startup from Refueling Outage (RFO) 22 (Fall 2016).

This letter contains no new regulatory commitments.

If you have any questions regarding this report, please contact Mr. Chris Adner at (315) 349-6766.

I declare under penalty of perjury that the foregoing is true and correct.

Executed on the 29<sup>th</sup> day of October, 2012.

Sincerely,



Michael J. Colomb  
MJC/CA/kp

cc: Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
2100 Renaissance Boulevard, Suite 100  
King of Prussia, PA 19406-2713

U. S. Nuclear Regulatory Commission  
Attn: Director, Office of Nuclear Reactor Regulation  
One White Flint North  
11555 Rockville Pike  
Rockville, MD 20852

Resident Inspector's Office  
U. S. Nuclear Regulatory Commission  
James A. FitzPatrick Nuclear Power Plant  
P. O. Box 136  
Lycoming, NY 13093

Mr. Mohan Thadani, Senior Project Manager  
Plant Licensing Branch I-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Mail Stop O-8-C2A  
Washington, DC 20555-0001

Ms. Bridget Frymire  
New York State Department of Public Service  
3 Empire State Plaza, 10<sup>th</sup> Floor  
Albany, NY 12223

Mr. Francis J. Murray, JR, President  
NYSERDA  
17 Columbia Circle  
Albany, NY 12203-6399

---