

Official Transcript of Proceedings  
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards  
ABWR Subcommittee on STP COLA

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Tuesday, October 2, 2012

Work Order No.: NRC-1917

Pages 1-196

**NEAL R. GROSS AND CO., INC.**  
**Court Reporters and Transcribers**  
**1323 Rhode Island Avenue, N.W.**  
**Washington, D.C. 20005**  
**(202) 234-4433**

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS  
(ACRS)

+ + + + +

ABWR SUBCOMMITTEE ON STP COLA

+ + + + +

TUESDAY

OCTOBER 2, 2012

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear  
Regulatory Commission, Two White Flint North, Room T2B1,  
11545 Rockville Pike, at 8:30 a.m., Michael L.  
Corradini, Chairman, presiding.

SUBCOMMITTEE MEMBERS PRESENT:

- MICHAEL L. CORRADINI, Chairman
- J. SAM ARMIJO, Member
- SANJOY BANERJEE, Member
- DENNIS C. BLEY, Member
- CHARLES H. BROWN, JR. Member
- WILLIAM J. SHACK, Member
- JOHN W. STETKAR, Member

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS  
1323 RHODE ISLAND AVE., N.W.  
WASHINGTON, D.C. 20005-3701

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

ACRS CONSULTANTS PRESENT:

THOMAS S. KRESS

GRAHAM B. WALLIS

NRC STAFF PRESENT:

MAITRI BANERJEE, Designated Federal Official

A G E N D A

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

Opening Remarks .....4

NRO/NINA Staff Introductions .....6

Summary of Why Long-Term Core Cooling  
Is Acceptable .....7

Summary of ABWR Subcommittee Briefings  
on Long-Term Core Cooling and  
Issues Raised ..... 27

Break

ACRS Action Items 80 ..... 84

Summary of Staff Review Scope, Key Issues,  
and Why the Review Is Acceptable ..... 166

Public Comments ..... 193

Adjourn

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

## P R O C E E D I N G S

8:30 a.m.

CHAIRMAN CORRADINI: Okay. The meeting will come to order. This is a meeting of the Advanced Boiling Water Reactor Subcommittee of the ACRS. My name is Mike Corradini. I am the new chairman of the Subcommittee, so treat me nice.

The ACRS members in attendance today are Charlie Brown, Sam Armijo, Dennis Bley, soon to be Sanjoy Banerjee, Bill Shack, John Stetkar and our consultant, Graham Wallis, and other consultants in the audience, I seem to understand.

Ms. Maitri Banerjee is the Designated Federal Official for this meeting. As announced in the Federal Register on September 28th of 2012, the subject of today's briefing is long-term core cooling, and that aspect relative to the COL application submitted by Nuclear Innovation North America or NINA, for South Texas Projects 3 and 4, and resolution of remaining issues from previous briefings on the subject.

The issue was discussed in various ABWR Subcommittee meetings in the last two years, and NINA and the NRC staff will provide a summary to refresh our memory. Kind of off script, just to remind everybody, we haven't talked about this in a year, and many of us

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 haven't attended all five of the meetings. So I want  
2 to make sure that the staff and the Applicant have time  
3 to kind of refresh us on this.

4 The rules for participation in today's  
5 meeting were announced in the Federal Register notice  
6 for the open and closed meeting. Parts of this meeting  
7 may need to be closed to the public, to protect  
8 proprietary-related information. I'm asking the NRC  
9 staff and the Applicant to verify that only people with  
10 the required clearance and the need to know are present  
11 before we enter such a discussion.

12 So as we go through things, as we start a  
13 new subject, I'll just look to the Applicant and the  
14 staff to warn us, so that we can at least do a quick  
15 checkout. We have a telephone bridge line for the  
16 public and stakeholders to hear the deliberations.  
17 This line will not carry any signal from this end during  
18 the closed portion of the meeting.

19 Also, to minimize disturbances, the line  
20 will be kept in the listen-in only mode until the end  
21 of the meeting, when ten minutes are allocated for public  
22 comment. If we need more time, we'll give it if the  
23 public have comments.

24 At this time, any member of the public  
25 attending this meeting, or sorry. At that time, any

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 member of the public attending the meeting in person or  
2 through the bridge line can make a statement.

3 As the meeting is being transcribed, I  
4 request that participants in this meeting use  
5 microphones located through this room when addressing  
6 Subcommittee participants would first identify  
7 themselves and speak with clarity and volume, sufficient  
8 clarity and volume, so that they can be readily heard.  
9 Also, please make sure your cell phones are turned off  
10 or muted.

11 We will now proceed with the meeting. I  
12 will call upon George Wunder of NRO to begin the  
13 discussion and kind of lead us off.

14 George.

15 MR. WUNDER: Good morning, Mr. Chairman,  
16 and thank you very much. Thank you for that very  
17 thorough introduction. I see you covered all the points  
18 that I had on my sheet and I have nothing to add, other  
19 than to say that it is our hope that by the end of the  
20 day, we have provided the Subcommittee with the  
21 information it needs in order to respond to the  
22 Commission's SRM. Thank you.

23 CHAIRMAN CORRADINI: I would say though  
24 again, I mentioned it once, but just to remind everybody.  
25 Since they're kind of going to what I'll call give us

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 a refresher to kick this off, I'd ask that the Committee  
2 give everybody, let Applicant and staff kind of get us  
3 through the initial phase of this before we enter into  
4 the details, because I'm sure there will be details.

5 DR. WALLIS: If details appear on the  
6 slide, may we ask a question?

7 CHAIRMAN CORRADINI: You may, if it's  
8 clarification. No, I'm just joking. I think that we  
9 kind of pre-looked at the slides. I think their first  
10 ten or so slides is background. Then they're going to  
11 get into, I think, what some of the consultants and  
12 members are quite interested in.

13 So is Scott going to take -- George? Is  
14 that okay? I'm sorry, go ahead.

15 MR. HEAD: Thank you sir, and thank you for  
16 this opportunity to meet with you again. It has been  
17 over -- it's been over two years since our first meeting,  
18 and it's been literally a year since our last meeting  
19 on this topic. So we appreciate the opportunity to have  
20 this interaction today.

21 The point you were going to make or were  
22 making, one of the lessons learned we had from maybe  
23 the second or third meeting is we jumped right into  
24 closing follow-up actions, and we really didn't get a  
25 good review of where we were and the topic itself.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1           So our plan is today that I'm going to  
2 actually give a summary of everything we've done, both  
3 from a NINA perspective and our interaction with the  
4 staff and with ACRS. So I'm going to give that overview.

5           I'd like to get through it if I could,  
6 because I think it's important to have the big picture,  
7 because quite often we get into the details and I think  
8 it's important to understand the big picture of what a  
9 plant in our position has done with respect to this  
10 topic.

11           So that's how it's laid out. As you can see  
12 though, clearly we've brought our technical team here  
13 today to answer any questions that might still be there  
14 or new ones that might have evolved in the year since  
15 we have met. So we understand that that's an important  
16 part of where we are.

17           Here are the attendees that are with us  
18 today. I appreciate everyone joining us for this  
19 discussion. The agenda and quick introduction. I'm  
20 going to do the long-term fill in overview. I know they  
21 can raise some questions, but I would like to ask that  
22 if we can defer them to when we have a more appropriate  
23 point in the discussion, and some of them could be  
24 proprietary in nature.

25           Maybe the question's not, but we feel like

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 the answer may be. So there's, you know, a place later  
2 on in our discussion to cover that. Then we're going  
3 to -- Jim's going to go through the summary of key points  
4 from our four previous meetings, and we feel like that  
5 will obviously be an opportunity to address any acts or  
6 any questions that the ACRS might have.

7 Now sensibly we're here simply to close  
8 Follow-Up Item No. 80. That's the only, that's the last  
9 one that's been opened, and we have not closed, and we're  
10 certainly prepared to do that today.

11 CHAIRMAN CORRADINI: And if I might just  
12 interject, since Scott brought it up from a numbers  
13 standpoint, everybody knows from Maitri's status for  
14 the members that this is a separate requirement from the  
15 Commission, and because, excuse me, because the  
16 certification had already gone through, the  
17 Commission's requirement for long-term cooling  
18 verification then applies to the Applicant and for the  
19 COL. So that's why we're taking it up now.

20 MR. HEAD: Yes, sir, which my next slide  
21 speaks to. This is the, you know, why we're here, and  
22 I would note that the staff requirements memorandum came  
23 out nine months or so after we made our application for  
24 STP 3 and 4.

25 We've done a lot of work, both you know, from

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 an engineering perspective and a lot of work with respect  
2 to interactions with the staff and obviously with ACRS,  
3 to address the long-term cooling issue from a design  
4 basis perspective. So you know, you'll obviously see  
5 the results of that today.

6 In terms of an overview, the Advanced  
7 Boiling Water Reactor has a robust long-term cooling.  
8 There's numerous ECCS water sources for heat before it  
9 cools. Heat clad temperature during design basis LOCA  
10 is about half the limit. We have a very substantial  
11 ultimate heat sink, an adequate water supply for 30 days,  
12 as required. So that's the, you know, design basis  
13 aspect, if you will.

14 As part of the ABWR, as part of the work  
15 we've done, we've also addressed potential challenges  
16 to long-term cooling. You know, we've selected a  
17 strainer that will meet NPSH guidance, and it's a very  
18 large strainer, and it's based on a very conservative  
19 debris loading.

20 Let me back up. One of the things I forgot  
21 to mention is we're going to try to not introduce  
22 anything new in this discussion today. We've basically  
23 covered this all before, and you know, AC independent  
24 water addition, we've covered in other briefings.

25 But we felt at this point it's important in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 this one to note that it exists and it is a water source  
2 that is independent of the strainers. So it's something  
3 that we discussed in other, on other topics.

4 As part of, you know, as part of our effort,  
5 we've demonstrated that containment integrity is  
6 maintained, and due to the design features and the design  
7 process, ECCS gas accumulation will not be an issue, and  
8 I think one of the more important aspects and I think  
9 we've spent a lot of time on is the downstream fuel  
10 effects will be tested 18 months prior to operation.

11 And as we demonstrated in one of our  
12 meetings, that the long-term cooling will be met even  
13 with the fuel inlet blocked, and that's a defense indepth  
14 aspect that we've taken credit for.

15 CHAIRMAN CORRADINI: Okay, and Jim will go  
16 over these in more detail following your presentation.

17 MR. HEAD: Yes, sir. We'll --

18 CHAIRMAN CORRADINI: Okay, that's fine.

19 MR. HEAD: We're prepared to go, and so we  
20 have all the previous presentations with us today. So  
21 if there's an aspect of this we want to cover again, for  
22 example, that last item, we certainly can address that.

23 With respect to the downstream fuel test,  
24 the primary challenge of long-term cooling is does  
25 debris pass include the suction strainers and causing

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 downstream effects on the fuel? There are a number of  
2 features that ensure downstream fuel effects are  
3 mitigated.

4 DR. WALLIS: Can I ask you about that? Is  
5 this your assessment, or is this the regulatory  
6 assessment? Is it your engineering assessment, that  
7 this is the primary challenge, or is this the regulatory  
8 assessment?

9 MR. HEAD: It's our assessment.

10 DR. WALLIS: It is your assessment?

11 MR. HEAD: Yes, sir, and I believe the staff

12 --

13 (Simultaneous speaking.)

14 DR. WALLIS: And you're ready to back that  
15 up, that this is realistically the primary challenge?

16 MR. HEAD: Let me give my summary, and  
17 we'll --

18 DR. WALLIS: I just want to be clear, that  
19 it is your assessment?

20 MR. HEAD: Yes, sir.

21 DR. WALLIS: And if we ask you questions  
22 about it, you'll be prepared to --

23 CHAIRMAN CORRADINI: So Graham's setting  
24 you up, I'm sure you can see, because he's a very precise  
25 fellow. Can I ask this question a little differently?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 All the other challenges have been solved, and this is  
2 the last remaining challenge, or has it always been the  
3 primary challenge?

4 MR. TOMKINS: Well, it's certainly the  
5 primary challenge from the point of view of we spent the  
6 most time on it.

7 CHAIRMAN CORRADINI: Okay.

8 MR. TOMKINS: With the NRC and --

9 CHAIRMAN CORRADINI: Good. That's a way  
10 of answering it. Let's just keep on --

11 DR. WALLIS: No. Years ago, it was not a  
12 challenge at all, and now it's --

13 MR. TOMKINS: Right, I agree, and now it is.

14 DR. WALLIS: And now it's become the  
15 primary. It's the remaining challenge. Maybe that  
16 would be --

17 MR. HEAD: If it's the remaining, it's the  
18 primary at this point.

19 (Laughter.)

20 CHAIRMAN CORRADINI: That's fair, that's  
21 fair.

22 MR. HEAD: It is the remaining challenge.

23 CHAIRMAN CORRADINI: Okay. Keep on going.

24 MR. HEAD: Okay. There are design  
25 features that help ensure downstream fuel effects are

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 mitigated, are is that it's diverse water injection  
2 capability, the high pressure core flooder, you know,  
3 which comes in from above the core, and the AC  
4 independent water addition is also available.

5 We mentioned before we have state of the art  
6 suction strainers, as we'll talk about in more detail.  
7 We really don't take credit for those as part of the  
8 downstream effects, but they in fact are there.

9 I'll, you know, refer back to one of our previous  
10 meetings, when our engineering management and licensing  
11 were looking at this issue a couple of years ago.

12 Being from an operating plant, you know, we  
13 ask ourselves, you know, given where we are at this  
14 point in time, what decisions could we make now that  
15 would resolve what we believe many of the issues or many  
16 of the challenges with respect to the long-term cooling.

17 Or to put it in a different way, if we were  
18 an operating plant and you could say immediately what  
19 changes could I make right now and make some of the issues  
20 go away at an operating plant, what would we do?

21 That's been our philosophy as we've moved  
22 forward, and that's why it's easy to say there's no  
23 fiber, calcium silicate or aluminum primary  
24 containment. But those are significant decisions we  
25 made, to minimize the challenges that both from a fuel

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 perspective and, quite frankly, from a licensing  
2 perspective, to address those.

3 So we've made those decisions, that there  
4 will be no fiber or calcium silicate insulation, which  
5 you know, is a significant decision. We also respect  
6 aluminum primary containment. There's also minimal  
7 zinc in primary containment, and that's only in  
8 qualified coatings. Also a significant decision that  
9 we made to address this issue, and --

10 MEMBER SHACK: Will all your zinc coatings  
11 have an epoxy top coat?

12 MR. HEAD: Yes, sir, and then, like I said,  
13 introduced in about the second or third meeting was the  
14 design fuel assembly bypass flow, which is a defense  
15 indepth feature that we believe it important to  
16 acknowledge it exists.

17 CHAIRMAN CORRADINI: But, and you're going  
18 to -- just to clarify, but you don't take credit for it  
19 in the analysis, if I remember correctly, in reading it?

20 MR. HEAD: Correct, and that's part of a  
21 licensing strategy, if you will, that we believe we can  
22 address the issue head-on, with the changes we've made  
23 and the testing we're proposing, and then still have this  
24 as defense indepth. We think it's important.

25 CHAIRMAN CORRADINI: Okay, thank you.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Are you prepared to say what  
2 happens to the epoxy top coats --

3 MR. HEAD: Yes, sir, we are.

4 DR. WALLIS: Okay.

5 MR. HEAD: And then finally, there are  
6 strong programmatic controls over containment and  
7 suppression pool cleanliness, to ensure that latent  
8 debris amounts are low, and again, we looked at that from  
9 our perspective as an operating plant and the number of  
10 containment clean-ups that we've been involved with  
11 post-outage, closing up containment when you come out  
12 of an outage, and being aware of the controls that exist.

13 The oversight that's provided by the  
14 Nuclear Regulatory Commission as part of those  
15 containment closeouts, and in fact, you know, we have  
16 a corrective action program that identifies any issues,  
17 and you adjust your processes as you move forward.

18 We believe that's a very important part of  
19 the fact that latent debris will be low, as we -- when  
20 the plant is in operation. So we'll talk about in more  
21 detail the test programs but, you know, we believe we've  
22 done everything, will have done everything possible to  
23 ensure that latent debris are in fact very low.

24 There are a number of conservatisms in the  
25 downstream fuel test that we developed, because we

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 thought it was important to be able to have lots of margin  
2 in this discussion, and we, and feel like that was  
3 important. You know, they related to the debris  
4 assumptions, the analysis of the acceptance criteria and  
5 the test performance.

6 The chemical amounts assume no solubility  
7 of zinc or aluminum corrosion products in the one million  
8 gallon suppression pool, and then all chemical products  
9 form gelatinous precipitants. We discussed that in a  
10 previous meeting, so we're not going to discuss this more  
11 today.

12 So we believe that's a, you know, very, very  
13 conservative assumption. We discussed the next one in  
14 a number of, in probably at least two meetings, that no  
15 credit for settling debris in locations where it will  
16 not impact the strainers and fuel, such as the lower  
17 drywell, the bottom of the suppression pool and the lower  
18 plenum.

19 You know, we make assumptions in terms of  
20 what is going to exist, and we assume it all gets to the  
21 fuel, which in fact is not really what's going to happen  
22 in these situations, but it's appropriate conservatism  
23 and will be part of the test.

24 DR. WALLIS: Are you going to tell us what  
25 to assume about the sludge and the rust and that sort

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 of stuff?

2 MR. HEAD: Yes, sir.

3 DR. WALLIS: You're going to tell us?

4 MR. HEAD: What we can, yeah. Latent  
5 debris, latent fiber is all assumed to be 100 percent  
6 fiber fines with, as I mentioned before, 100 percent  
7 passing through the strainers. So the strainers in  
8 fact, with respect to the downstream impact, has no  
9 bearing.

10 Since fibrous material is prohibited, ~~axle~~  
11 latent fiber in the plant is assumed to be rags and ropes  
12 because, you know, we've made these other commitments  
13 with respect to fibrous material, and that sort of debris  
14 will obviously be taken up by the strainers and won't  
15 get to the fuel.

16 DR. WALLIS: Is there any sawdust or  
17 anything like that that get in there?

18 MR. HEAD: Sawdust?

19 DR. WALLIS: Sawdust left over from some  
20 operation.

21 MR. TOMKINS: That would be a part of the  
22 containment cleanliness. I can't imagine --

23 DR. WALLIS: You'd have to keep it out.

24 MR. HEAD: Well, there would be two things  
25 that would happen. I will just, as we get into it --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 (Simultaneous speaking.)

2 MR. HEAD: Okay. Now with respect to the  
3 analysis acceptance criteria, some very I think  
4 interesting and conservative assumptions we've made.

5 As decay heat is held constant at the value  
6 of five minutes after shutdown. This is long-term  
7 cooling, and we're challenging ourselves with a five  
8 minute heat load, and that's, I think, significant  
9 conservatism. It makes the analysis relatively easy,  
10 but it's not the actual challenge that we'll be seeing  
11 with respect not only to the fuel itself, but to the  
12 actual flow of debris.

13 The next bullet speaks to that. Debris  
14 particularly takes more than two hours to all reach the  
15 strainer the first time, and that is based on the actual  
16 suppression pool flow. It decayed about forty percent  
17 of value compared to the full five minutes.

18 And then, you know, an aspect of that with  
19 respect to long-term cooling is chemical precipitates  
20 such as zinc oxide, are predicted to take over 15 days  
21 to reach the values used in the test. So we  
22 instantaneously assume it all exists, and we relatively  
23 instantaneously assume it all gets there.

24 We challenge it with fuel that's going to  
25 stay at a heat level --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. WALLIS: How about those 15 days? It  
2 doesn't change its physical properties in any way?

3 MR. HEAD: We'll answer that one --

4 DR. WALLIS: Okay.

5 MR. HEAD: There's a factor of four margin  
6 of acceptance criteria, which is really a factor of two  
7 based on flow.

8 CHAIRMAN CORRADINI: What does that mean?  
9 I tried to look back in back documents, and I didn't --  
10 can you just briefly clarify that? Or if you're going  
11 to do it later.

12 MR. HEAD: That's really, that's wrapped up  
13 in the follow-up item.

14 CHAIRMAN CORRADINI: Okay, fine.

15 MR. HEAD: So it'll be discussed --

16 DR. WALLIS: It's decay factor, isn't it?

17 MR. TOMKINS: Right. It's on Action Item  
18 80.

19 MR. HEAD: Action Item 80, we'll cover all  
20 these details.

21 CHAIRMAN CORRADINI: Okay, okay. This  
22 will be explained. Thank you, thank you.

23 MR. HEAD: The void fraction of .95 in the  
24 hot assembly exit, which really is greater than twice  
25 the boiloff or flow rate, is another factor of two that's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 included in the acceptance criteria, and finally  
2 there's, as I mentioned before, the high pressure core  
3 flooder, no high pressure core flooder on fuel.

4 It's simply design bypass flow. It's  
5 credited, and each of those, by itself, is sufficient  
6 to provide adequate core cooling.

7 CHAIRMAN CORRADINI: And I wanted to ask  
8 there, I think I understand what that means. But again  
9 I'm new to this design discussion. Is that by  
10 calculation or by past testing, that the case is that  
11 each by itself is sufficient provide adequate cooling?

12 MR. HEAD: That's by calculation, and we'll  
13 be able to discuss that --

14 CHAIRMAN CORRADINI: Okay, later.

15 MR. HEAD: --in more detail.

16 MEMBER BROWN: When you say "each," what is  
17 meant by each? All the upper --

18 (Simultaneous speaking.)

19 MR. HEAD: No, just the two.

20 MEMBER BROWN: Just the HPCF ~~of~~ or the fuel  
21 assembly bypass?

22 MR. HEAD: Yes, those two.

23 MEMBER ARMIJO: Is there a reason why you  
24 don't credit the bypass flow?

25 MR. HEAD: Yes, sir.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1                   MEMBER ARMIJO:  It's a passive feature; you  
2 don't have to turn anything on or off.  It's just going  
3 to happen.

4                   MR. HEAD:  Yes, sir.

5                   MEMBER ARMIJO:  Why don't you credit it?

6                   MR. HEAD:  Well, we -- as we embarked upon  
7 this journey and we're making the decisions that we made  
8 with respect to this issue, we felt like we had addressed  
9 the issue with changes to containment, the actual  
10 inherent design of the ABWR.

11                   The programmatic processes that were placed  
12 that we've learned over the years.  So we believe we  
13 could take this and address this issue, you know, head  
14 on, without relying on this feature.

15                   In fact, this feature would then there be  
16 a defense in-depth.  So we asked ourselves that.  The  
17 staff asked us, why not maybe take this, you know, make  
18 this pivot, if you will.

19                   We just felt that it was not, you know, that  
20 it's not consistent with what the industry is doing, and  
21 we felt like it would not be appropriate, given where  
22 we believe the advanced boiling water reactor is, and  
23 the attributes it has and the attributes that STP has  
24 bought to the design.

25                   MEMBER ARMIJO:  I can see your position

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that it's not needed, but you know, if it's really a  
2 passive feature that's built in and that doesn't rely  
3 on any active systems to turn it on, turn it off, moderate  
4 it in any way, it seems excessive conservatism that --

5 MR. HEAD: Oh, it's there.

6 I mean it exists. It exists for really a  
7 separate reason. But it's there.

8 MEMBER ARMIJO: I understand, yeah.

9 MR. HEAD: And as a part of the licensing  
10 strategy, to be able to maybe answer that, or there's  
11 some question that there's some still unknown answer on,  
12 or some challenge that we felt that having this defense  
13 indepth would help us as part of the licensing process,  
14 and I'd say it was --

15 You know, that was our thought process, is  
16 that it would really be an inappropriate adjustment to  
17 what we believe was a very strong story.

18 DR. WALLIS: I was going over it, looking  
19 at your slides, and I'm wondering when is it I can ask  
20 detailed questions about this debris?

21 MR. HEAD: When Jim starts.

22 (Laughter.)

23 MR. HEAD: One more slide.

24 DR. WALLIS: Oh, only one more?

25 MR. HEAD: I think so, yes, sir.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: I told him to be  
2 polite to you, so he's --

3 MR. HEAD: It's incredible, sir. I  
4 appreciate it.

5 CHAIRMAN CORRADINI: He's ready.

6 (Simultaneous speaking.)

7 DR. WALLIS: I mean sometimes politeness is  
8 a veneer for something else. It's a very polite way of  
9 telling you things you don't want to know. It's the best  
10 way to do it.

11 MR. HEAD: I believe we want to know this,  
12 and I believe we're here to answer all questions that  
13 -- new questions or previously asked questions. So I've  
14 got no problem with that at all.

15 As I mentioned in my opening, though, I  
16 thought it was important to either overwhelm or bore you  
17 with everything that we've done on this project. So  
18 that's why I'm insisting on going through this.

19 Okay. With respect to the test  
20 performance, and we recognize some questions will come  
21 up with respect to this. But the debris is added in a  
22 manner that minimizes clumping, and it maximizes  
23 establishment of a filter bed and provides for the  
24 formation of the thin bed, all important aspects of a  
25 challenging test, and obviously Jim is here to address

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 any questions that might come up with respect to that.

2           Okay, and then this speaks a little bit to,  
3 you know, something we were talking about earlier. The  
4 conservatisms in the ~~downfield~~ downstream test  
5 translate to what we believe is a factor of eight in flow  
6 margin, the fuel, the blocking of the fuel.

7           The five minute decay heat, you know, is  
8 twice the decay heat expected, once the actual debris  
9 is deposited. As I mentioned before, the acceptance  
10 criteria on void fraction is, as I say, a factor of two  
11 with respect to the boiloff rate, and then we added  
12 additional conservatism acceptance criteria which --  
13 with respect to twice the required flow, and that's how  
14 we get to the factor of eight conservatively.

15           CHAIRMAN CORRADINI:           Just for  
16 clarification, the first bullet analysis based on is  
17 required by the ~~DVA~~ DBA assumption; is that correct? Or  
18 is that a judgment assumption --

19           MR. HEAD: It's a judgment assumption.

20           CHAIRMAN CORRADINI: It's a judgment on  
21 your part. It's not required by staff analysis.

22           MR. HEAD: It was one of those. Well,  
23 diesel starts, water flows. How soon could this kind  
24 of start, and we chose five minute.

25           CHAIRMAN CORRADINI: What is the required

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 set of assumptions? It's left to the Applicant.

2 MR. VAN HALTERN: The required set of  
3 assumptions is that you should use the ANS 5.1 decay heat  
4 curve.

5 CHAIRMAN CORRADINI: Okay. I thought that  
6 I couldn't -- I guess I was trying to determine was it  
7 your choice or was it the guidance by staff, regulatory  
8 guidance?

9 MR. VAN HALTERN: No. This is essentially  
10 just a simplification, to come up with a simple  
11 conservative acceptance criteria.

12 CHAIRMAN CORRADINI: Okay, thank you.

13 MR. HEAD: But we really didn't see debris  
14 could get there in any meaningful sooner than that. So  
15 if we started there and it was acceptable, then obviously  
16 we had an acceptable test program and acceptable  
17 results.

18 Okay. Now, let me just ask. Are there any  
19 questions with respect to that summary? If not, then  
20 I'm going to go ahead and turn it over to Jim. He's going  
21 to go through all the previous meetings at a high level.  
22 We have a slide on bookkeeping, which shows all the  
23 follow-up items that the ACRS has asked us to address  
24 and how we close those.

25 And then, as I mentioned before, as topics

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 come up, if there's any questions, we're certainly  
2 prepared here to answer any questions that we've either  
3 addressed before or new ones today. Appreciate that.  
4 Jim.

5 MR. TOMKINS: Okay. So as we've  
6 discussed, this is the fifth meeting on the subject, and  
7 this is just a list of the meetings we've already had.  
8 The first meeting was actually a meeting on Chapter 6  
9 of the COLA, where we presented the departure, because  
10 we had to make a departure to upgrade the strainers, the  
11 state-of-the-art strainers we have.

12 In that meeting, we talked about strainer  
13 design. We presented the sizing analysis that we did  
14 on the strainers, and that was the first meeting where  
15 we introduced the post-COL downstream ~~field~~ fuel test.  
16 So there was a lot of questions about the downstream test  
17 at that meeting.

18 On 3/8/11, we made a couple of  
19 clarifications from the initial meeting. We clarified  
20 that the downstream test would use one cubic foot of  
21 fiber. We had actually initially proposed ten percent  
22 of one cubic foot. We didn't think all of it would  
23 really get through, but we changed that assumption.

24 DR. WALLIS: May I ask you about that? I'm  
25 sorry to bring it up again. I told my wife that you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 didn't know how many fibers were there, so you assumed  
2 a cubic foot, and she expressed surprise in some other  
3 statements too.

4           Suppose that one cubic foot is okay, but two  
5 cubic foot is not? I mean I've done some calculations,  
6 and it looks as if you might be okay with one cubic foot,  
7 but you might not be okay with two cubic feet. It seems  
8 to me you have to give some justification for why it's  
9 okay to stop at one.

10           It's just a number, as far as I can see.  
11 It's just a number someone picked up, and there's got  
12 to be some technical justification for it.

13           MR. TOMKINS: Okay. Well first off, we  
14 have none in the plant. So the only fiber that's going  
15 to be in there will be fiber that's left in the  
16 containment. We have, we think, a really good  
17 containment cleanliness program. I've done those  
18 walkdowns. I mean literally, you're going through  
19 containment picking up little things.

20           DR. WALLIS: I understand that, I  
21 understand that.

22           MR. TOMKINS: So we think one foot is a  
23 large number, plus we think the assumption that the  
24 entire one foot is all little fines that are going to  
25 go through the strainers, is not really --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: So you say something about the  
2 length of these fibers too?

3 MR. TOMKINS: Well, we have Tim, who will  
4 talk to you about the length of them. But they're all,  
5 they're short.

6 (Simultaneous speaking.)

7 MR. TOMKINS: Correct. That's the plan.  
8 So they're fairly little; they will --

9 DR. WALLIS: So there's no justification,  
10 except that it seems okay?

11 MR. TOMKINS: We think it's a conservative  
12 number, that's correct.

13 MR. HEAD: But we had some Japanese  
14 experience.

15 MR. TOMKINS: And we had some Japanese  
16 experience.

17 DR. WALLIS: You see, if you tried to go --  
18 if you went before a public meeting and said it seemed  
19 okay, that wouldn't sound very technical.

20 MR. HEAD: We think it's very conservative.

21 DR. WALLIS: I know you think it's  
22 conservative.

23 MR. TOMKINS: We have experience from a  
24 Japanese plant and a Japanese --

25 DR. WALLIS: You do have some real basis --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 (Simultaneous speaking.)

2 DR. WALLIS: So you can justify it? And if  
3 it turned out that two was not acceptable, you wouldn't  
4 do that test?

5 CHAIRMAN CORRADINI: Can I ask Graham's  
6 question in a different way?

7 MR. HEAD: Sure.

8 CHAIRMAN CORRADINI: Because, I mean, I'm  
9 struggling with this. You guys have, it kind of  
10 connects to Sam's question, because you guys have made  
11 a series of assumptions, which I will, at least from my  
12 limited review of all this, since I'm not, haven't been  
13 in all these fun meetings, seems conservative, a series  
14 of assumptions.

15 So if you became more realistic, does one  
16 become ten before you're a problem? You know what I'm  
17 asking? I'm trying to judge this, compared to all the  
18 assumptions you made, which look at me like an order of  
19 magnitude, in terms of if I take this and assume that  
20 and I assume that and I assume that, you then say I'll  
21 take some assumed amount of volume of stuff that is bad,  
22 and I'm okay.

23 But if it's really ten times that volume of  
24 stuff, because of all the conservatisms I've got to get  
25 to this point, that gives me some -- me, maybe nobody

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 else on the Committee, gives me some feeling that you  
2 have an enormous margin. That's what I guess I'm --

3 MR. TOMKINS: We could take 100 cubic feet,  
4 because we can block the entire assembly and still cool  
5 it, based on our defense indepth is --

6 DR. WALLIS: You're not going to do the test  
7 with 100 cubic feet?

8 MR. TOMKINS: No, we're not going to do the  
9 test that way. But I'm saying --

10 MEMBER ARMIJO: Well, you know, I think --

11 MR. TOMKINS: --we can take more.

12 MEMBER ARMIJO: I'm on the same page as  
13 Mike. You might have answered Professor Wallis's  
14 question as we vacuumed up the Japanese ABWRs. We found  
15 a tenth of a cubic foot of stuff. We multiplied by ten  
16 and that's our margin.

17 But the basis for the one cubic foot is the  
18 question, I think, that Graham's asking.

19 DR. WALLIS: Right. If it turned out to be  
20 --

21 (Simultaneous speaking.)

22 CHAIRMAN CORRADINI: Gentlemen, please.

23 MEMBER ARMIJO: And you don't start with  
24 zero, because that's not real.

25 MR. HEAD: I'm going to ask Caroline to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 review our basis for the one.

2 MS. SCHLASEMAN: This is Caroline  
3 Schlaseman with MPR, and I'm representing TANE and  
4 Toshiba. When we were -- I started off with the strainer  
5 sizing. Obviously, we had to figure out what kind of  
6 debris there would be on the strainer, and I have with  
7 me with the design specifications, the ASME design  
8 specifications.

9 So I have the listing of all the details of  
10 what all the debris assumptions are for the entire  
11 suppression pool, everything that's going to be in the  
12 suppression pool. Obviously, it gets distributed to  
13 different strainers, and based on flow rates and all  
14 that, and we had covered that in previous meetings.

15 The basis for the fiber, our initial  
16 position was well, there is no fiber. But in going back  
17 and looking at the experience from Kashiwazaki-Kariwa  
18 Unit 6 and Kashiwazaki-Kariwa Unit 7, which were the two  
19 operating ABWRs in the world, and both of them have --  
20 one of them has been operating for a decade, and the other  
21 one is a little more recent.

22 But the older unit, the K-6 unit, we -- TEPCO  
23 provided the information to NINA. This is two and a half  
24 to three years ago, and the types of things that they  
25 found in their first suppression pool inspection, five

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 years after operation, included things like little teeny  
2 bits of rope, little teeny metal pieces, little parts.

3 I mean there was a collection of very small  
4 stuff, and out of that, the amount that was actually  
5 fibrous material was again, really small, like well  
6 under a cubic foot. So we were trying to figure out how  
7 to quantify that, and we chose a cubic foot as a bounding  
8 -- that sounded like a pretty big number, based on the  
9 specifics of the TEPCO report of what they found.

10 I would have to pull it off my laptop  
11 computer, but I could show you. You know, they sent a  
12 two or three page report that actually gave us itemized  
13 detail of little ring on top of can, you know, little  
14 bit of rope that was two centimeters long, little bit  
15 of rope that was five centimeters long.

16 It was those kinds of things, none of which  
17 are small enough, unless they somehow get destroyed  
18 during the break and get pulverized into fines, which  
19 is what we're assuming for passing through our  
20 strainers, is that our initial position was zero, and  
21 obviously with discussions with the staff, zero was not  
22 licensable.

23 So we chose the one cubic foot, and we still  
24 believe it's a very conservative number.

25 DR. WALLIS: But you had gave us something

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 hard here. Have you looked at the previous tests, such  
2 as the Owners Group test, to see how much fiber it would  
3 take to clog the craw? I mean that's a number -- I think  
4 you would have done that calculation.

5 Could you tell me what the weight of this  
6 one cubic foot is, because I'm -- calibrated in grams,  
7 and not in volume? Tim, what's the weight of that?

8 MR. ANDREYCHEK: 2.2 to 2.4 pounds per  
9 cubic foot.

10 DR. WALLIS: It's a bit heavier than that  
11 in the ANL test. Okay, okay. That's before it's  
12 squashed or something?

13 MR. ANDREYCHEK: That's the  
14 as-manufactured calculation.

15 DR. WALLIS: So you're going to put in 2.4  
16 pounds; is that what you're going to do?

17 MR. ANDREYCHEK: Yes.

18 DR. WALLIS: And how many assemblies do you  
19 have?

20 MR. VAN HALTERN: 872.

21 DR. WALLIS: 800 assemblies?

22 MR. VAN HALTERN: 872. So actually put in  
23 2.4 pounds, divided by 872, times the 70 percent penalty.

24 (Simultaneous speaking.)

25 DR. WALLIS: So the amount per assembly is

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 on you. You have 800 assemblies?

2 MR. VAN HALTERN: 872.

3 DR. WALLIS: So that's the sort of  
4 calculation I would like for you to have done, not sort  
5 of say it seems all right, and here's some sort of  
6 hearsay evidence. Do a technical calculation and show  
7 that there's two grams per assembly, and all your Owners  
8 Group tests show blah blah blah; therefore, this is a  
9 reasonable assumption, and we're a long way away from  
10 something.

11 But just to sort of say one looks reasonable  
12 isn't good enough. I think you should be more  
13 hard-nosed and technical about it, because otherwise,  
14 someone's going to say well suppose it were 1.1 or 1.2?  
15 Is that a problem?

16 Another way to do the test is to say we'll  
17 put fiber in to find out when we get a problem, and if  
18 there's no problem below 30 cubic feet, then forget it.  
19 But the one is sort of intangible and fuzzy.

20 MR. VAN HALTERN: But we think  
21 conservative, though.

22 DR. WALLIS: But you're going to do  
23 something more than just this qualitative argument?  
24 No? Because if you get up in front of a technical public  
25 meeting, people are going to say where are they coming

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 from? You can't discuss -- okay, I'm sorry. I've made  
2 my point, and I will put it in my report. But you've  
3 got 800 assemblies, 8-1/2 by 8?

4 (Simultaneous speaking.)

5 MR. VAN HALTERN: No. These are BWR  
6 assemblies.

7 DR. WALLIS: So what's --

8 MR. VAN HALTERN: It's about, if you -- the  
9 ratio, there's about the equivalent of three BWR  
10 assemblies --

11 DR. WALLIS: That's right. So I was  
12 thinking something like 200. I'm thinking of PWR.

13 MR. VAN HALTERN: Right. PWR is about --

14 DR. WALLIS: So I've to get this area.  
15 What's the area? We need to get the amount per unit area  
16 of debris at some level. You haven't calculated that?

17 (Simultaneous speaking.)

18 DR. WALLIS: These are things you can do in  
19 five minutes.

20 MR. TOMKINS: We can tell you, but not right  
21 now.

22 MR. VAN HALTERN: It's approximately 5 by  
23 5.

24 DR. WALLIS: How much?

25 MR. VAN HALTERN: 5 by 5.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: 5 by 5.

2 MR. TOMKINS: Approximately.

3 MR. VAN HALTERN: Five inches by five  
4 inches.

5 DR. WALLIS: But the overall core area is  
6 about the same as a PWR?

7 CHAIRMAN CORRADINI: Just multiply 872  
8 times 5 by 5.

9 MR. VAN HALTERN: It's bigger, because you  
10 have the gaps in between.

11 MR. TOMKINS: The gaps in between --

12 DR. WALLIS: It's bigger, it's bigger. So  
13 that helps.

14 MR. TOMKINS: You have all the gaps in  
15 between with control blades.

16 DR. WALLIS: That's good enough. Thank  
17 you.

18 MR. TOMKINS: Okay.

19 MEMBER ARMIJO: But basically you do have  
20 data? You do have fiber data from the Japanese plants.  
21 You could have said we found from the Japanese plants  
22 a tenth of a cubic foot of rope, rag, whatever it is,  
23 it's fibrous.

24 We multiply it by a big factor and we said  
25 one cubic foot's reasonable. But you can't start with

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 zero, and I think that's Graham's point.

2 DR. WALLIS: Well, I would be happier if you  
3 had determined, by analysis and experiment, that it  
4 takes 50 cubic feet of fiber to block these things, and  
5 we're never going to get anything like that in there.  
6 But you're going to take another view, okay.

7 MR. TOMKINS: Right. We're taking a  
8 different approach.

9 DR. WALLIS: You can do that.

10 MR. TOMKINS: The other thing we clarified  
11 at the 3/8/11 meeting was chemical precipitates. Our  
12 initial position was that we weren't going to have any  
13 significant chemicals, and we changed that position as  
14 well. We now are including some chemical precipitates.  
15 We can talk about that in a little bit.

16 DR. WALLIS: You're going to get to that.

17 MR. TOMKINS: Yeah.

18 DR. WALLIS: Are you going to talk about the  
19 sludge and the rust?

20 MR. TOMKINS: I wasn't, but we can.

21 DR. WALLIS: Because I think was it  
22 Barseback that had the event that started this whole  
23 business? Was it Barseback?

24 MR. TOMKINS: Barseback, yeah.

25 DR. WALLIS: What I think happened there,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 it's a long time ago, was that they were surprised that  
2 the pressure dropped, and the pressure drop was bigger  
3 than they expected, and this caused some interest. The  
4 cause seemed to be that the sludge filled in the holes  
5 --

6 MR. TOMKINS: I think it was fiber with the  
7 sludge.

8 DR. WALLIS: Sludge played a very big role  
9 in increasing the pressure drop. So how are you going  
10 to model this stuff, which we know was not irrelevant  
11 at Barseback?

12 CHAIRMAN CORRADINI: Can I ask, since I  
13 don't remember this, a little more background for me.  
14 But we switched from downstream effects to the  
15 strainers.

16 DR. WALLIS: Are we talking about  
17 downstream?

18 (Simultaneous speaking.)

19 CHAIRMAN CORRADINI: I know, but historic,  
20 the thing that you're quoting, though, is what happened  
21 with the strain screens?

22 DR. WALLIS: Mr. Chairman, you've got  
23 fibers and if sludge fills in the gaps and blocks them,  
24 it doesn't matter whether they're on the a strainer or  
25 a claw or on your coffee machine. I mean it's the same

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 physics.

2 CHAIRMAN CORRADINI: Right. But the only  
3 reason I'm asking is -- okay, fine.

4 MEMBER SHACK: He's just looking at a  
5 source of particulates.

6 CHAIRMAN CORRADINI: Fine.

7 DR. WALLIS: And how do you model these  
8 things, which turned out to play, as I understand, and  
9 we can check this out, an important role.

10 MR. ANDREYCHEK: We have four particulates  
11 that we're considering, right, and you can go through  
12 it with respect to dust and dirt?

13 DR. WALLIS: Are you modeling these things?

14 (Simultaneous speaking.)

15 MS. SCHLASEMAN: We have --

16 MR. TOMKINS: Go ahead.

17 DR. WALLIS: Are you modeling them though?  
18 How are do you -- I'm sorry.

19 MS. SCHLASEMAN: Based on the NUREG 6224,  
20 which is the strainer methodology, now I'm talking  
21 strainer sizing, the head loss for the strainer is  
22 determined based on several different debris types, and  
23 so for head loss calculations, I'm reading now out of  
24 the ASME code design specification for the strainers,  
25 that in the suppression pool, we have the one cubic foot

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 of fibrous insulation.

2 We do not have any calcium silicate, because  
3 it is specifically forbidden in our unit. We have over  
4 27,000 square feet of reflective metal insulation,  
5 metallic insulation, RMI. We have sludge, 195 pounds.

6 DR. WALLIS: 195 pounds?

7 MS. SCHLASEMAN: 195 pounds of sludge.

8 DR. WALLIS: That is a lot.

9 MS. SCHLASEMAN: It depends on --

10 (Simultaneous speaking.)

11 MS. SCHLASEMAN: Yes. For our plant, it is  
12 a lot, yeah. But it's, but that's the NUREG standard.

13 DR. WALLIS: How do you represent that in  
14 the test, so it can --

15 MS. SCHLASEMAN: That's going to be the --

16 DR. WALLIS: It seems to be more important  
17 than zinc oxide or any of these other things. I didn't  
18 see any description of how you're going to actually  
19 represent this stuff in a test.

20 MS. SCHLASEMAN: The sludge, the  
21 particulate, we'll be talking about the detail of what  
22 the surrogates are.

23 DR. WALLIS: From real sludge --

24 (Simultaneous speaking.)

25 MR. HEAD: No sir, we'll be using

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 surrogates.

2 DR. WALLIS: You've got to use the real  
3 stuff, because these surrogates can give you very  
4 unexpected effects.

5 MR. HEAD: We'll talk about that, you know.

6 DR. WALLIS: I think we need to talk to the  
7 staff about this too.

8 MS. SCHLASEMAN: That's not all of it.

9 DR. WALLIS: I mean you can't just put in  
10 something. You've got to put in something like the  
11 stuff you're going to get.

12 MS. SCHLASEMAN: There's more. So also,  
13 85 pounds of paint chips --

14 DR. WALLIS: That's right, and there's some  
15 assumption about them.

16 MS. SCHLASEMAN: That's the destroyed  
17 epoxy coating. That's within the zone of influence of  
18 the break, of the qualified coatings, and where it is  
19 an inorganic zinc primer and epoxy top coat that's  
20 qualified for drywell, for primary containment use, and  
21 then 50 pounds of rust flakes, and 150 pounds of dust  
22 or dirt. So that's the soup.

23 DR. WALLIS: Well, these are all  
24 interesting, and I'm really impressed by the amount.  
25 How are you going to represent them in the test?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 (Simultaneous speaking.)

2 CHAIRMAN CORRADINI: So I'm going to  
3 intervene at this point. Are you ready to do this later,  
4 so we can --

5 MR. HEAD: Oh no. I'm going to get to it.  
6 I'm just going to introduce, you know, or reintroduce,  
7 and we discussed this in this meeting.

8 CHAIRMAN CORRADINI: Okay.

9 MEMBER ARMIJO: But before you get to that,  
10 this 195 pounds of iron oxide and everything else. Now  
11 you, I thought you have stainless steel liners?

12 (Simultaneous speaking.)

13 MEMBER ARMIJO: It's going to be hard to  
14 generate that unless you're awful --

15 MR. TOMKINS: Sir, but it would be also hard  
16 to come up with a different number. So we agree that  
17 that will be the challenge that's in front of us, and  
18 instead of saying it's really 100 or more likely 10,  
19 because of the suppression pool cleanup system and the  
20 way we designed the plant, we felt like it was more  
21 appropriate just to stay at this expected test --

22 DR. WALLIS: But you've got to be careful,  
23 because if you do realistic tests with real sludge, you  
24 may find that this is a problem.

25 MR. TOMKINS: Well, we don't expect that,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 based on the calculations --

2 DR. WALLIS: Don't expect everything with  
3 regard to behavior of debris and sludge and stuff like  
4 that. Don't expect anything.

5 MR. TOMKINS: Well, we have to expect  
6 something, or we wouldn't --

7 DR. WALLIS: Well, I know, but it's a  
8 dangerous field to expect things in.

9 MR. TOMKINS: I recognize that, and I'm  
10 sure, as we'll talk about in a second, in terms of the  
11 surrogates that we're going to use, that there's --

12 DR. WALLIS: But that will be good. How  
13 are you going to represent the sludge?

14 MR. TOMKINS: Right now, we're going to  
15 discuss the surrogates that we're going to use for all  
16 these --

17 (Simultaneous speaking.)

18 DR. WALLIS: That's the question I'm after.  
19 How are you going to represent these?

20 CHAIRMAN CORRADINI: Okay, okay.

21 DR. WALLIS: That's the only question.

22 CHAIRMAN CORRADINI: Let's get out of a  
23 conversation mode. So let me just make sure that all  
24 the Committee heard, because you did it quickly. Of  
25 course, a cubic foot of powder or 200 pounds of sludge.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 How much paint chips? I apologize, from the guide?

2 MEMBER ARMIJO: Fifty-some.

3 MS. SCHLASEMAN: 85 pounds.

4 CHAIRMAN CORRADINI: Okay, and then there  
5 was one other dirt?

6 DR. WALLIS: 50 pounds rust flakes, 15  
7 pounds of dirt.

8 MS. SCHLASEMAN: No, 150 pounds.

9 MR. TOMKINS: Let me bring up the slide.

10 MR. HEAD: 150 pounds of dirt.

11 DR. WALLIS: 150 pounds. That's right.

12 MS. SCHLASEMAN: 150 pounds of dust and  
13 dirt.

14 DR. WALLIS: What is dirt?

15 MR. TOMKINS: Okay. So here's the --

16 MS. SCHLASEMAN: That's how it's defined in  
17 the NUREG.

18 CHAIRMAN CORRADINI: So have we missed  
19 anything from the list, before we go on to the  
20 surrogates?

21 MR. TOMKINS: Here's the list.

22 CHAIRMAN CORRADINI: Okay, thank you.

23 MR. TOMKINS: This is what we presented in  
24 3/8/11 meeting.

25 DR. WALLIS: Could we have that slide?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Could you give us that?

2 MR. TOMKINS: Yes. We gave it, you have  
3 it.

4 MR. HEAD: You have it. It's from that  
5 meeting. It's from the March 8th, 2011 meeting.

6 MR. TOMKINS: So we can go through the  
7 surrogates for each one of these.

8 DR. WALLIS: No. I just want to know that  
9 there are all of these things, that's all.

10 CHAIRMAN CORRADINI: Okay. Keep on going.

11 MS. SCHLASEMAN: It might make sense to  
12 clarify --

13 MR. HEAD: If you have questions like that,  
14 of a perspective, since you weren't involved, and as I  
15 mentioned before, we'll be able to pull up any previous  
16 discussions. We want you have them all, and so clearly,  
17 you know, we can make them available to you now or after  
18 the meeting.

19 CHAIRMAN CORRADINI: I'd rather you get  
20 back to what you planned to do, because I think the open  
21 discussion that Dr. Wallis is after is what do you plan  
22 to use for the surrogates. So you can talk about it now  
23 or later, but we get back to the surrogates.

24 MR. ANDREYCHEK: For the paint chips, we  
25 used paint chips. For particulates --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. WALLIS: You used paint chips?

2 MR. ANDREYCHEK: Pardon?

3 DR. WALLIS: Size spectrum of some sort or  
4 what?

5 MR. ANDREYCHEK: Well, we used -- we can  
6 create a size spectrum, based on creating a sheet of  
7 epoxy on top of plastic, and then you roll it in a --

8 DR. WALLIS: So you're going to use  
9 realistic paint chips?

10 MR. ANDREYCHEK: As best we know it, yes.

11 DR. WALLIS: Good, thank you.

12 MEMBER BLEY: You were about to tell us how  
13 you did it. You paint it on plastic and then you roll  
14 it up --

15 MR. ANDREYCHEK: No. You take the  
16 plastic, you put it -- there's a couple of ways you can  
17 make the chips. Take, you shake it up, plastic, put it  
18 into a large can on a mandrel, throw some ball bearings  
19 in and just roll it for a period of time, and that will  
20 create your chips. We've done that in a couple of  
21 different --

22 DR. WALLIS: And this is what happens in a  
23 LOCA?

24 MR. ANDREYCHEK: What happens in a LOCA is  
25 it blasts, you get a jet blast. But, you know, we're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 not going to necessarily create a LOCA to try to get paint  
2 chips --

3 DR. WALLIS: So there's an assumption here  
4 that ball bearings and LOCA produce the same kind of  
5 paint chips?

6 MR. ANDREYCHEK: About the same size chips.

7 MEMBER SHACK: Well, what is the size of  
8 chips? What does that distribution look like?

9 MR. ANDREYCHEK: Well, the distribution  
10 could be anywhere from about a quarter of an inch to  
11 something smaller than that.

12 DR. WALLIS: Something smaller? Did it  
13 get down to microns?

14 MR. ANDREYCHEK: Possibly. Might become  
15 epoxy dust.

16 MEMBER SHACK: I mean the FPL test with the  
17 pressurized water got down to like 50 microns.

18 MR. ANDREYCHEK: That's correct.

19 MEMBER SHACK: And so you aim it at  
20 something like that or --

21 MR. ANDREYCHEK: Come up with -- well  
22 again, if you look at what we're required to do, we're  
23 required to come up with chips that will either block  
24 the strainer, if that's what you're worried about, or  
25 pass through the strainer and create debris that you need

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 to consider downstream.

2 DR. WALLIS: What I read, and maybe I  
3 misread it, is that, I'm quoting now, "that the coating  
4 particles are assumed to be 10 microns spheres."

5 MR. ANDREYCHEK: That's for zinc.

6 DR. WALLIS: Isn't this part of the  
7 coating?

8 MR. ANDREYCHEK: That's the backside of it.  
9 That's the primer coat.

10 DR. WALLIS: Oh, that's behind. What  
11 you're talking about is what's in front?

12 MR. ANDREYCHEK: The epoxy, the epoxy coat,  
13 yes.

14 DR. WALLIS: Okay.

15 MR. ANDREYCHEK: And then for --

16 MEMBER SHACK: And then you're going to  
17 dissolve the inorganic zinc?

18 MR. ANDREYCHEK: The inorganic zinc  
19 doesn't necessarily dissolve. When you heat it up, it  
20 will become a little tacky. But it doesn't necessarily  
21 dissolve. If you have something along the lines of a  
22 polyurethane, that will dissolve, and actually even  
23 humidity will dissolve that. But epoxy coatings don't  
24 dissolve.

25 MEMBER SHACK: No. The inorganic zinc, it

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 dissolves.

2 MR. ANDREYCHEK: Inorganic zinc will not  
3 dissolve either. The inorganic zinc will oxidize and  
4 create a zinc oxide type of material over time, and as  
5 we said earlier, in one of the summary statements, it  
6 takes on the order of around 15 days. You're better to  
7 --

8 MEMBER SHACK: I thought you assumed that  
9 it dissolved and then precipitated in zinc oxide, or that  
10 you used 10 micron particles, which represent presumably  
11 less of things that get through the strainer?

12 MR. ANDREYCHEK: Exactly, exactly.

13 MR. TOMKINS: Remember, for the zinc, we're  
14 assuming aluminum hydroxide as --

15 (Simultaneous speaking.)

16 MEMBER SHACK: I mean yeah, the chemical  
17 precipitate, rather than a particulate. But again,  
18 you're using -- the 10 micron particles are basically  
19 what you think are going to get through the strainer,  
20 and come to the downstream effects?

21 MR. ANDREYCHEK: Correct, correct.

22 MEMBER SHACK: So I mean we can go through  
23 the whole discussion of all of your chips and all your  
24 sludge, but what you're using for the downstream test  
25 is essentially 10 micron particles.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. ANDREYCHEK: Correct.

2 MR. TOMKINS: But we're assuming all the  
3 zinc gets through.

4 MEMBER SHACK: That's right.

5 MR. TOMKINS: I mean none gets caught on the  
6 strainer.

7 MEMBER SHACK: Right.

8 MR. TOMKINS: It all gets into the --

9 MEMBER SHACK: It all gets through, for  
10 various reasons.

11 MR. ANDREYCHEK: Right, and the zinc, the  
12 formation -- all the zinc gets through, but we simulate  
13 it in the test as aluminum hydroxide.

14 DR. WALLIS: It gets through the strainer,  
15 but it won't get through the debris on the fuel?

16 MR. ANDREYCHEK: Correct.

17 DR. WALLIS: Why is it different? I mean  
18 if it's getting through a fiberglass debris, a  
19 fiberglass deposit on the strainer --

20 MR. ANDREYCHEK: It's a conservative  
21 approach.

22 DR. WALLIS: It won't get through the  
23 fiberglass that's on the --

24 MR. TOMKINS: Well, we'll test that and  
25 find out.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. ANDREYCHEK: It's a conservative  
2 approach, and unless you test it --

3 MEMBER SHACK: But I think with their one  
4 cubic feet, they're likely to have open areas on their  
5 strainers.

6 (Laughter.)

7 MEMBER SHACK: Even Graham might agree with  
8 that.

9 DR. WALLIS: Anything that's smaller than  
10 the hole in the strainer will get through.

11 MR. TOMKINS: Right, and the hole in the  
12 strainer is 2.1 millimeters.

13 DR. WALLIS: But it's fairly big, right?

14 MR. TOMKINS: Well, so all the particulate  
15 gets through, with the exception of the RMI shards.

16 MS. SCHLASEMAN: And the epoxy top coat.  
17 That's only 38 pounds for our epoxy top coat. That's  
18 the size distribution.

19 CHAIRMAN CORRADINI: Oh, can you -- I'm  
20 sorry. Could you just repeat? Jim said it, and then  
21 you kind of clarified. But what do you assume gets  
22 through out of this list? The epoxy is stopped. The  
23 RMI shards, I assume, are stopped.

24 MS. SCHLASEMAN: Right.

25 MR. TOMKINS: Not all of them. Some get

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 through.

2 CHAIRMAN CORRADINI: Some, because of  
3 their distribution.

4 MS. SCHLASEMAN: Right.

5 CHAIRMAN CORRADINI: But the assumption is  
6 other than those two, everything we see here is assumed  
7 to pass through the strainers?

8 MR. TOMKINS: Yep.

9 MS. SCHLASEMAN: That is correct.

10 CHAIRMAN CORRADINI: Okay.

11 MR. TOMKINS: And gets to the fuel.

12 MS. SCHLASEMAN: Part of them, because of  
13 the size distributions. There were 85 pounds for  
14 strainer head loss for epoxy coatings, and there were  
15 only 38 assumed to pass the strainer, based on the  
16 distributions.

17 CHAIRMAN CORRADINI: Okay, okay.

18 MR. HEAD: So that 38 is going to challenge  
19 the fuel?

20 MR. ANDREYCHEK: That's correct.

21 MS. SCHLASEMAN: It's assumed to pass the  
22 strainer, yes.

23 MR. HEAD: This is fuel.

24 MS. SCHLASEMAN: This is debris  
25 assumptions for the downstream effects.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Okay. That's what I  
2 wanted to make sure I understood.

3 MS. SCHLASEMAN: So that's what the first  
4 column is. So the first number, the epoxy coating of 38  
5 pounds, is less than the 85 pounds that I told you would  
6 be used for the strainer head loss calculation, and then  
7 the RMI shards, again that's much, much smaller than the,  
8 you know, 27,000 square feet of destroyed RMI. That's  
9 how much of size distribution would pass through the  
10 strainer.

11 CHAIRMAN CORRADINI: Okay. So let's just  
12 take us back to why we went to this slide. So Dr. Wallis  
13 asked about surrogates. So Tim started off by saying  
14 the epoxy is the epoxy. So what do you use for your fake  
15 sludge?

16 MR. ANDREYCHEK: Sludge, dust and dirt, and  
17 the -- we'll be looking right now at using silicon  
18 carbide, and the size distribution, we will be reviewing  
19 what the industry is doing and come up with the  
20 appropriate size distribution.

21 DR. WALLIS: So there won't be the 10 micron  
22 size? This doesn't say micron in the paper work?

23 MR. ANDREYCHEK: That's right.

24 DR. WALLIS: It won't be 10 micron size?

25 MR. ANDREYCHEK: But I also believe that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 that same paper work states that we'll be following the  
2 industry, what the industry is doing, and we will make  
3 modifications as necessary.

4 DR. WALLIS: Now didn't your Owners' Group  
5 test show you that 10 microns goes right through the  
6 fiberglass, most of them?

7 MR. ANDREYCHEK: Actually, no it didn't.

8 DR. WALLIS: It didn't?

9 MR. ANDREYCHEK: And what we found, I'm  
10 looking at the test and looking at when we pulled the  
11 assembly part to clean it, was that the fiber bed had  
12 debris throughout the fiber bed.

13 DR. WALLIS: Well, it had debris in it, but  
14 a lot of the product was run right through.

15 MR. ANDREYCHEK: I think what you'll find,  
16 and this depends on how much particulate you actually  
17 had, the fiber bed did in fact become saturated, and  
18 because of the nature of the design, the open lattice  
19 structure --

20 DR. WALLIS: I read your report, and it was  
21 clear that the particles went right through the bed, went  
22 around the loop about 30 times without being trapped.

23 MR. ANDREYCHEK: I think you'll find that  
24 in those particular tests, and I won't disagree with you  
25 that some of it did continue around, but you found --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 what we found was that the fiber bed became saturated  
2 with particulates, because we were using, in some tests,  
3 very, very large amounts.

4 The tests were very low, very close to a 1  
5 to 1 ratio. The water became very clean, because the  
6 fiber bed did in fact collect most of the --

7 DR. WALLIS: I think it's somewhere else,  
8 Tim. But if you used all those huge number of  
9 particulates, that if they had got trapped, I calculated  
10 you'd get pressure drops of hundreds or thousands of psi,  
11 which you never got.

12 So that's the kind of reasoning that led me  
13 to conclude, based on lot of other stuff, that a lot of  
14 these 10 micron particles went right through a fiber bed.  
15 I'm sure that a lot of the sludge isn't as small as 10  
16 microns. So it seems to me completely unrealistic to  
17 assume that all this stuff has a size of 10 microns.

18 You've got to put in realistic sizes, and  
19 some of these particles are going to be much bigger than  
20 that, because the holes in the strainer are 2  
21 millimeters, and this was like 2,000 microns?

22 MR. ANDREYCHEK: That statements said we  
23 will follow --

24 DR. WALLIS: What was the magnitude?

25 MR. ANDREYCHEK: We will follow what the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 industry's doing. We'll take a look at --

2 DR. WALLIS: I don't think you should  
3 follow what the industry's doing. You should follow  
4 what makes sense. If the industry isn't doing the right  
5 thing, you've got to do the right thing.

6 MR. HEAD: Let me address that, if I could,  
7 because I think that was a very important part of our  
8 previous meetings with respect to this discussion before  
9 us, is that the test protocol, including sizes, the  
10 concoction, how added, when added, temperature,  
11 everything is in an evolutionary state, both the BWRs  
12 and the Owners' Group, the BWRs.

13 We made the commitment on the docket, and  
14 it was not -- it was something we were already doing to  
15 follow the industry evolution, and if the protocol  
16 changes and as it changes, by the time we do the test,  
17 we will do the state of the art test at that point in  
18 time.

19 DR. WALLIS: You're very wise to say that,  
20 yeah.

21 CHAIRMAN CORRADINI: I don't know. I  
22 guess hearing that, I'm not sure what else they can say.

23 MR. HEAD: Well but it's important, because  
24 we need to agree on something that the staff would say  
25 was appropriate, that you would say is important, the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 industry says is important, and it's in a time of state  
2 of flux.

3 DR. WALLIS: Well, I would be happy if you  
4 really thought about it yourselves too, and said what  
5 you know. Sometimes what the staff says may not always  
6 be physically very sensible. May not always be. I'm  
7 not saying it isn't always, but sometimes it might not  
8 be. So you have to think about it yourself.

9 MR. HEAD: We do, and that's why picking,  
10 choosing what we think is a surrogate, including the  
11 aluminum hydroxide that we talked about is the most  
12 challenging, we believe, this has been part of our  
13 thinking all along. But we really felt like from a  
14 licensing perspective, an industry perspective and even  
15 an ACRS perspective, to concoct something that has no  
16 basis --

17 DR. WALLIS: Well, you just said aluminum  
18 hydroxide is very, very important?

19 MR. HEAD: We think in terms of  
20 challenging, in terms of the gelatinous mass. So we've  
21 thought about it.

22 DR. WALLIS: Well, but it turns out if you  
23 put in silicon carbide, it doesn't do anything.

24 MR. HEAD: And if that's what the industry  
25 and the staff concludes two or three years from now, when

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 you know, everyone it comes to say hey there is -- that's  
2 the appropriate challenge for sludge, and maybe here's  
3 a different challenge for dust, and here's what you ought  
4 to do for rust.

5 If that is the appropriate creation for the  
6 test, then that's what we'll use to close our license  
7 condition that's associated with --

8 DR. WALLIS: I think you also need to think  
9 yourselves, because if it turns out that this knowledge  
10 evolves, you've done the tests and then something comes  
11 up that says they weren't any good, you know. You've  
12 got to think ahead of time, that make darn sure you do  
13 the right test. Now the other thing --

14 CHAIRMAN CORRADINI: Hang on, Graham.  
15 Before you move on, I want to make sure we --

16 DR. WALLIS: I'll just say one other thing.

17 CHAIRMAN CORRADINI: But if I might.

18 DR. WALLIS: Yes.

19 CHAIRMAN CORRADINI: So we've addressed  
20 epoxy coating. I'm sorry. I'm linear about this.

21 (Simultaneous speaking.)

22 CHAIRMAN CORRADINI: I understand.  
23 You've answered the point about sludge in terms of  
24 inventory amount and essentially staying current to what  
25 the distribution was. Dust and dirt?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: Well, we used the same,  
2 silicon carbide.

3 CHAIRMAN CORRADINI: Okay. So for both  
4 sludge and dust and dirt, the surrogate is silicon  
5 carbide.

6 MR. ANDREYCHEK: As it stands right now  
7 today, yes.

8 CHAIRMAN CORRADINI: Okay, and the  
9 distribution, as Graham was asking relative to what it  
10 is, what you say it is right now, to what it may evolve  
11 to, is still in what we'll call you're going to follow  
12 what industry is doing?

13 MR. ANDREYCHEK: Correct.

14 CHAIRMAN CORRADINI: But I think --

15 DR. WALLIS: I noticed in the SER that the  
16 staff approved the use of 10 micron silicon carbide.  
17 That goes back to some EPRI thing and so on and so on.

18 MR. ANDREYCHEK: That's correct.

19 DR. WALLIS: So as of now, you would be  
20 within the regulations to say we'll use 10 micron silicon  
21 carbide?

22 MR. ANDREYCHEK: That's correct, right.  
23 But we have a commitment that we will send the NRC six  
24 months prior to doing the test, our truing up with  
25 industry experience with downstream tests. That's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 their --

2 DR. WALLIS: I think you should make a very  
3 sincere effort to properly represent the sludge, the  
4 dust and the dirt, and if you get results which are  
5 incompatible with the NRC assumption, you might well be  
6 right.

7 MR. HEAD: Yes, sir, but that would put us  
8 in an awkward position with respect to closing the  
9 license condition.

10 DR. WALLIS: That's right, that's right.

11 MR. HEAD: And so that's something that we  
12 will have to address at that point in time, and part of  
13 addressing that is staying involved with the industry.  
14 We do participate in the Owners' Group, okay. You know,  
15 we have a number of different people that participate  
16 with the BWR Owners Group. We obviously have PWR Owners  
17 Group affiliation, as part of this project.

18 So we're going to -- we're going to stay  
19 abreast of this evolution as it takes place, and when  
20 we do that test, we will know that it's like saying it's  
21 the state of the art, and we believe -- and we also  
22 believe it's an appropriate test at that point in time.

23 And I think most of that insight that we  
24 provide, though, will probably come as part of a member  
25 of the Owners Group, as opposed to us doing something

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 totally different. I think that would put us all in an  
2 unusual place, for us to --

3 CHAIRMAN CORRADINI: I think -- well, just  
4 so we continue to move on, I think what at least I hear  
5 Dr. Wallis is saying is that following the industry  
6 practice is fine, but you should follow it in an informed  
7 fashion.

8 MR. HEAD: Yes, sir.

9 CHAIRMAN CORRADINI: If you find something  
10 out that would modify the industry's --

11 MR. HEAD: And we'll have that option.  
12 When we submit our test protocols six months ahead of  
13 time, and if we say we're going to use, you know,  
14 something else as a surrogate, the staff can clearly at  
15 that point in time say yeah, we think that's a better  
16 way to go.

17 CHAIRMAN CORRADINI: Okay.

18 MR. HEAD: And we would head that way.

19 CHAIRMAN CORRADINI: Okay. So we're --

20 DR. WALLIS: --as much as possible not to  
21 use surrogates, because it is a complicated process, and  
22 you can do things that -- surrogates may have different  
23 properties that you don't know or aware of from the real  
24 stuff.

25 MR. HEAD: We take it. We understand.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Anything else in  
2 terms of we're down to rust flakes. How about rust  
3 flakes?

4 MR. ANDREYCHEK: Rust flakes would be iron  
5 oxide, the iron oxide, or again, we might use another  
6 surrogate for that. Current thinking right now. We  
7 could use iron oxide. RMI shards would be RMI shards.

8 CHAIRMAN CORRADINI: And latent fiber you  
9 had --

10 MR. ANDREYCHEK: Fiberglass, for practical  
11 purposes. In the aluminum, both precipitates, aluminum  
12 zinc will be aluminum oxyhydroxide.

13 CHAIRMAN CORRADINI: I'm not a chemical  
14 effects person, so I'll turn to the Committee if they  
15 have an issue.

16 MEMBER SHACK: No. We've accepted that  
17 essentially for all the testing and --

18 MR. ANDREYCHEK: There's been testing  
19 that's been demonstrated, found by NRC to demonstrate  
20 to aluminum oxyhydroxide, of the precipitates  
21 evaluated, is the worse for head loss on a fiber bed.

22 CHAIRMAN CORRADINI: Okay.

23 DR. WALLIS: This wasn't demonstrated, but  
24 it was sort of argued that nothing could be worse than  
25 oxyhydroxide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. HEAD: However, in the meantime, if  
2 something is discovered --

3 (Laughter.)

4 MR. HEAD: --and it works, okay, then that  
5 clearly would be something we would avail ourselves of,  
6 as part of closing the license condition.

7 CHAIRMAN CORRADINI: So let me ask a  
8 question that's not in the last four meetings, and I  
9 don't understand the connection. So I'm sure my  
10 colleagues will tell me I've got to be quiet. So the  
11 other part South Texas is trying to do a risk-informed  
12 approach on this.

13 MR. HEAD: Yes, sir.

14 CHAIRMAN CORRADINI: This just seems to be  
15 screaming to do something that's a bit more realistic  
16 than this, because this just looks like -- so my question  
17 is besides staying abreast of what the industry is doing  
18 from a deterministic standpoint, are you staying abreast  
19 with what South Texas was doing?

20 MR. HEAD: I was here as part of helping  
21 brief, and those are my colleagues for many years. You  
22 know, I know what they're doing. But they're doing a  
23 risk-informed approach for them and the industry for  
24 existing plants.

25 We've made most of the risks that they're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 talking about, and they're trying to model zero, we  
2 believe zero.

3 CHAIRMAN CORRADINI: So let me just ask the  
4 question differently. But to the extent that that's  
5 true, and they, whenever you do these tests; let's not  
6 try to guess an actual chronological date. It seems to  
7 me their methodology you could put your inventory  
8 through, and actually see the margin that you have, and  
9 see what seems to be an enormous margin.

10 Do you see what I'm getting at? In other  
11 words, they're developing a methodology. With that  
12 methodology, you can apply it to all of this. I would  
13 expect that where they have a worry of where the danger  
14 zone is, you're way below it.

15 It seems the demonstration of how big of a  
16 margin you've got, to me would be extremely important,  
17 so that all this in some sense dissipates, because you  
18 have, from a plant design standpoint, eliminated as --

19 DR. WALLIS: Well, you might continue to  
20 know where disaster is. You don't know what the margin  
21 is. So unless you do the tests up to the point where  
22 you find out you've actually clogged something, you then  
23 don't know how much of a margin you have from that  
24 clogging, unless you've done that test, do you? You get  
25 the point?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: I understand the  
2 point.

3 DR. WALLIS: You can be conservative.

4 MEMBER BLEY: But you do know up to the  
5 point at which you test it.

6 DR. WALLIS: You do --

7 MEMBER BLEY: There's many places where we  
8 can't test a failure or destruction. So we have to live  
9 with that.

10 CHAIRMAN CORRADINI: But what I guess I'm  
11 saying is, this maybe you can say it and I'll ask it,  
12 this is not a risk-informed approach. This is a  
13 deterministic approach that has built into it a series  
14 of conservative assumptions that, at least in my mind,  
15 are one piled on top of another, on top of another.

16 So I have, at least in my mind, have a hell  
17 of a time trying to figure out where the hell the problem  
18 is and where you're operating. It just seems -- so my  
19 first point, it's not a risk-informed approach clearly.

20 MR. HEAD: Well, in some ways maybe it  
21 doesn't look like that. But from my perspective, it is,  
22 because we're taking the risk off the table. I mean we  
23 are making some of the risks that STP 1 and 2 happen to  
24 deal with, which is a real number.

25 We're basically trying to make it zero, and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 then adding something to it, because we're actually  
2 challenging with stuff we're not thinking we're going  
3 to have.

4 MEMBER STETKAR: But I think, Scott, what  
5 you're hearing a little bit, forget about risk and sort  
6 of the traditional notion of risk. Think about risk in  
7 terms of evaluating uncertainties about parameters that  
8 you use in an analysis, distributions of sizes,  
9 distributions of the amount of material that would  
10 require to get to failure. Think of that in the context  
11 of the distribution for the frequency of, you know, the  
12 size of an earthquake or anything else.

13 In that sense, you're not doing a  
14 risk-informed analysis. You're not looking at those  
15 probability distributions or your uncertainties.  
16 You're doing what I would call a classic design basis  
17 analysis, that you pass a certain set of criteria and  
18 you've not evaluated things past that.

19 MEMBER BLEY: I think the weakness is what  
20 you're seeing. It's when you stack all of these  
21 supposed conservatisms on top of each other, when  
22 someone as Professor Wallis challenges you one of them,  
23 it's real hard to see how the others compensate for that  
24 one.

25 So you have to live with that in what you're

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 doing. So you're always vulnerable to what if you get  
2 one of these wrong, and you don't know how they interact.

3 MEMBER STETKAR: You don't have a  
4 quantitative assessment of --

5 MEMBER BLEY: Right.

6 MR. HEAD: Which is part of our defense  
7 indepth, is that we will never fail. We will always keep  
8 the core cooled, but we believe that even with respect  
9 to the risk-informed approach you're talking about, if  
10 there are some insights that come out of that which the  
11 industry is participating in, and the industry says  
12 "hey, that's a good distribution to apply to rust," based  
13 on the analysis they're doing, then that will  
14 ultimately, I think, evolve into the analysis for the  
15 test program that we'll do.

16 CHAIRMAN CORRADINI: Okay. That's a fair  
17 thing. Let's keep on going. I'm sorry.

18 MR. HEAD: So that was the bookkeeping  
19 discussion.

20 CHAIRMAN CORRADINI: And we'll get a copy  
21 of the bookkeeping slide, just in case some of us may  
22 have missed where it went.

23 MR. HEAD: Maitri has all of them.

24 MS. BANERJEE: Can I get a copy now?

25 CHAIRMAN CORRADINI: Maitri has it and will

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 get a copy to us, so we can lose it again. Keep on going.

2 (Laughter.)

3 MS. BANERJEE: I'll make a copy.

4 MR. TOMKINS: Okay. Got that first bullet  
5 wrapped up. That was easy. So the second point at the  
6 March meeting, we provided a comprehensive presentation  
7 on long-term cooling, and we went over the ECCS and the  
8 heat sink, and showed that they were more than adequate  
9 to provide cooling for 30 days.

10 We addressed the challenges. The  
11 challenges are debris impacts on NPSH of strainers,  
12 containment integrity, downstream effects on fuel,  
13 which is the one we spent the most time on, and ECCS gas  
14 accumulation. As we've said many times, we had a very  
15 detailed discussion in that 3/8/11 meeting on downstream  
16 fuel testing.

17 We also presented the defense indepth  
18 analyses, showing that high pressure core flooders from  
19 above the core, and fuel assembly bypass flow. Each of  
20 those, which by itself can provide adequate cooling for  
21 the core, even if the assembly were to plug completely.

22 So again, that's our bounding. We're going  
23 to do a test. We're confident we're going to pass the  
24 test, but even if those assemblies were to plug, we think  
25 we'll get cooling to the core and we're okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1           On 6/21/2011 and 10/4/2011, we addressed a  
2 series of follow-up items, and I'm going to present those  
3 next. So this is the -- this is probably the slide we  
4 can delve into detail. We've already gone into some,  
5 but if you look, this is all the action items.

6           There have been 19 follow-up items from  
7 ACRS. The "O" means that was the meeting they were open;  
8 the "C" is the meeting they were closed. So you can --  
9 there's a range. I mean there are, some were what was  
10 the boron concentration in the sodium pentaborate tank?  
11 One was give us a briefing on vacuum breakers, which we  
12 did.

13           CHAIRMAN CORRADINI: We like vacuum  
14 breakers.

15           MR. TOMKINS: Pardon?

16           CHAIRMAN CORRADINI: Nothing.

17           (Laughter.)

18           MR. TOMKINS: Yeah, and we take care of  
19 them. We're nice to them. Provide TOSHIBA with the  
20 technical reports. Then there were some more  
21 significant ones. Use of NUKON as a fiber surrogate,  
22 use of aluminum oxyhydroxide as a chemical surrogate.  
23 A lot of things we've already started discussing were  
24 covered in the 6/21/11 meeting.

25           You can see there's one that's still open,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 and that's Action Item 80, relating to the pressure drop  
2 versus flow exponent of 2.0 that we're just -- I plan  
3 to discuss that next.

4 Maitri, I think that agrees with your  
5 accounting?

6 MS. BANERJEE: That's correct, yes.

7 CHAIRMAN CORRADINI: She's the accountant,  
8 right. I'd go broke.

9 MR. TOMKINS: Okay. So you know, we talked  
10 about inlet flow distribution assumption. We did a  
11 parametric study of the results versus the assembly and  
12 K-factor. We had a discussion on modeling of the  
13 perforated strainer screen in holes. Caroline did  
14 that, and then there was a question on zinc oxide  
15 concentration.

16 So we can, you know, our belief is these are  
17 closed, but we can go back and delve into any of them,  
18 if you want to talk about them.

19 CHAIRMAN CORRADINI: Just so the Committee  
20 knows, the way they've structured this is they next want  
21 to talk about, I can't remember the number -- number 80,  
22 thank you, and there it is, number 80. So they're going  
23 to go into that in great detail. But I think before we  
24 go there, I want to make sure the Committee has the chance  
25 to ask them other detailed questions.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 (No response.)

2 CHAIRMAN CORRADINI: All right. We're  
3 dying for 80.

4 MR. TOMKINS: Before we go to 80, I just  
5 want to summarize. So from all the four meetings, for  
6 all the four meetings, here's, as Scott mentioned, our  
7 position has evolved in how we're going to do this task,  
8 and here's four things that we've changed so far.

9 We're going to include 100 percent of the  
10 one cubic foot in downstream fuel tests; we are going  
11 to include chemicals now in the downstream testing.  
12 We're going to perform multiple tests. We're actually  
13 going to test two separate flow rates, and then we're  
14 going to perform three to six tests at each of those flow  
15 rates, to make sure we understand uncertainties.

16 You know, I think everyone would agree, this  
17 process is somewhat random, in terms of how debris forms.  
18 Then the last one is the big one, which is we're going  
19 to review industry experience. We have membership on  
20 both the PWR and BWR Owners Groups. Milton Rejcek,  
21 sitting back there, is regularly attending the BWR  
22 Owners Group.

23 So we'll, anything we learn from them, we  
24 will put into our program, and that will be provided to  
25 the NRC six months before we do the test. So there's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 a commitment in the FSAR that we will do that. So it  
2 will be their opportunity to disagree with us, we didn't  
3 catch this, what about this.

4 And I think it's realistic that we probably  
5 will make some changes, changes on the tests.

6 MEMBER BLEY: In the beginning, you said  
7 you were going to do this, I forget what you told us,  
8 some time before --

9 MR. TOMKINS: Eighteen months.

10 MEMBER BLEY: Eighteen months, a year and  
11 a half.

12 MR. TOMKINS: That's required by license  
13 condition to be performed 18 months prior to operation.

14 CHAIRMAN CORRADINI: So the commitment on  
15 your side is to have them done and to the NRC for analysis  
16 or for review?

17 MR. TOMKINS: Right.

18 CHAIRMAN CORRADINI: Okay.

19 MR. TOMKINS: And then this other  
20 commitment is to give them the procedure six months  
21 before we --

22 CHAIRMAN CORRADINI: Before the -- thanks.

23 MR. HEAD: All of which is related to  
24 closing a license condition.

25 CHAIRMAN CORRADINI: Right.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TOMKINS: And I suspect the NRC will  
2 participate in the testing. I think that's very likely,  
3 when we actually do it.

4 (Simultaneous speaking.)

5 CHAIRMAN CORRADINI: So I guess the only  
6 thing I wanted to get back to, because I've written it  
7 down and I see where Dr. Wallis is coming from, is that,  
8 and let me ask it this way. So from your standpoint,  
9 you have provided the technical basis for the one cubic  
10 foot?

11 MR. TOMKINS: Yes, sir. We think so.

12 CHAIRMAN CORRADINI: Okay. So I guess I'd  
13 like to -- I think the Committee would like to see it,  
14 so we can reflect on it. That's another way of kind of  
15 getting to, I think, what Graham is asking.

16 And then from the standpoint of the  
17 inventory, which we now all have again, and some of us  
18 never had but now have for sure, you're doing assumptions  
19 on -- you know, you said it and I didn't write it down.  
20 Where would I go for the details of what you currently  
21 think is the, what I'll call, size distribution and  
22 surrogate composition for each of these, if you have  
23 decided to use a surrogate rather than the real thing?  
24 Can you remind me where I go look for that?

25 MR. ANDREYCHEK: Well, there's a couple of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 places that it would be. For example, we talk about the

2 --

3 CHAIRMAN CORRADINI: Well, I guess what I'm  
4 asking Tim is if the Committee wants to go back and just  
5 review where it is, given that it can evolve, but what  
6 you have committed to to this point, is it in your --  
7 what documentation would we go to, to look at -- besides  
8 inventory, but inventory, current list of materials,  
9 whether they be surrogate or real, and assume size  
10 distribution?

11 MR. ANDREYCHEK: I believe most of that  
12 information would be in the presentations that we gave  
13 over the course of responding to open items here.

14 CHAIRMAN CORRADINI: It doesn't sit, it  
15 doesn't reside in one place?

16 MR. ANDREYCHEK: I don't believe it does.

17 CHAIRMAN CORRADINI: Could we get -- I  
18 believe they're in tables. Can I get a table that it  
19 all resides on one place?

20 MR. ANDREYCHEK: Sure. I can do that.

21 CHAIRMAN CORRADINI: That would be very  
22 helpful.

23 MEMBER ARMIJO: It is. It's basically an  
24 expansion of this table.

25 CHAIRMAN CORRADINI: It's an expansion.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. ANDREYCHEK: We'll just add a column or  
2 two to that table, if that's what I'm hearing.

3 CHAIRMAN CORRADINI: That would be really  
4 good

5 MEMBER BLEY: You don't have anything like  
6 that now?

7 MR. ANDREYCHEK: Not currently, no.

8 CHAIRMAN CORRADINI: That would be a  
9 helpful guide to all. Is that, Dr. WALLIS?

10 MEMBER ARMIJO: It would help me.

11 CHAIRMAN CORRADINI: Okay.

12 DR. WALLIS: I'm still puzzled by what dirt  
13 is.

14 (Simultaneous speaking.)

15 CHAIRMAN CORRADINI: You clearly haven't  
16 been to my house.

17 MEMBER ARMIJO: But you know, along those  
18 lines, what is the official definition of sludge? The  
19 only thing I know that it isn't is silicon carbide. So  
20 what is, in a real power plant, I always envisioned  
21 sludge as an iron oxide goop that was at the bottom of  
22 the suppression pool. Is that what --

23 MR. ANDREYCHEK: Yes, yes.

24 MS. SCHLASEMAN: That's how it's defined in  
25 the NUREG 6224. 6224 defines --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER ARMIJO: So why not use iron oxide,  
2 getting back to Professor Wallis's --

3 MEMBER BLEY: Why in this case use a  
4 surrogate? I understand when you use surrogates for  
5 something that's very hazardous. But why use a  
6 surrogate for iron oxide?

7 MEMBER ARMIJO: Right, and why put so much  
8 iron oxide when you have stainless steel lined  
9 suppression pools? You know, I think -- I'm going to  
10 give my speech one last time. I think you guys are  
11 painting yourself into a corner with conservatisms  
12 upon conservatisms upon conservatisms, on a test that  
13 may turn out to give you problems to pass.

14 You think you're going to pass them, but  
15 then you're going to go to your bypass flow and other  
16 conservatisms and try to pencil whip your way out of a  
17 problem that you created yourselves. I just think  
18 you're painting yourselves into a corner by unrealistic  
19 assumptions and testing.

20 CHAIRMAN CORRADINI: So you have two  
21 questions here. The second part of it sounded more like  
22 a comment. But the first part was I guess I did want  
23 to hear from you guys. So you've chosen to use carbide  
24 as a surrogate.

25 Why not what you think is at least the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 majority composition of what sludge is? That's, I  
2 think, where you started.

3 MEMBER ARMIJO: Yeah.

4 CHAIRMAN CORRADINI: Could you comment on  
5 that from the --

6 MR. ANDREYCHEK: The thought process was  
7 it's silicon carbide is easily available. Make the  
8 sludge requires additional time, effort, in order to dig  
9 it out. I mean you've got to create the rust in order  
10 to create the sludge.

11 CHAIRMAN CORRADINI: Choosing to make  
12 rust.

13 DR. WALLIS: Take an old vehicle and  
14 scratch it.

15 (Simultaneous speaking.)

16 MR. ANDREYCHEK: --because they're going  
17 to be several tests that are going to be run. So I agree  
18 with you in concept. It's very easy. But that's --

19 MR. HEAD: But it's also one of those -- I  
20 mean there's an industry, an operating fleet that's  
21 dealing with this, and some sort of consistent test that  
22 we've agreed to, with some sort of a consistent protocol  
23 is important for the operating side.

24 CHAIRMAN CORRADINI: So here's a -- you  
25 don't get a chance this time. So here's a counter to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 that, because I don't disagree with that. You've got  
2 to stay with the industry, or else -- but an inventive  
3 experimenter might say okay, we're going to do all our  
4 tests with silicon carbide.

5 But we'll do two tests in two extremes with  
6 the real stuff, just to see if I see a difference.  
7 That's, I mean I know, I've been around Professor Wallis  
8 long enough that I have this sense that that's what one  
9 might do from a test program standpoint, is you do all  
10 of it with the industry-evolving standards. But then  
11 just in case, you do a couple to show that there's no  
12 difference with the --

13 DR. WALLIS: The risk is you do all your  
14 tests, and then some academic in some Midwestern  
15 university, because he's curious, does a test with the  
16 real stuff, and gee whiz, the pressure drops 100 times  
17 as much. That's the real danger you have, and it's not  
18 a good thing to face.

19 CHAIRMAN CORRADINI: We've made our point,  
20 I think.

21 MR. HEAD: Mr. Chairman, I think at this  
22 point in time, what I think I've heard is two follow-up  
23 items.

24 CHAIRMAN CORRADINI: Correct.

25 MR. HEAD: Okay, one is the basis on the one

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 cubic foot.

2 CHAIRMAN CORRADINI: Well, you have it.  
3 We would just like to see it, okay.

4 MR. HEAD: That seeing, is that in a  
5 meeting, or is that after the breakout or --

6 (Simultaneous speaking.)

7 MS. SCHLASEMAN: I need to download it.

8 CHAIRMAN CORRADINI: We'll let you guys --  
9 we trust you and we promise not to, I promise not to  
10 lose it. So if they lose it, they'll get it again. So  
11 it doesn't have to be in a meeting standpoint. It can  
12 be essentially a follow-up communication, all right.  
13 The second thing is just essentially expand your --

14 MR. HEAD: Okay, and is that in a follow-up?

15 CHAIRMAN CORRADINI: It can be a  
16 communication. We understand in both cases at least,  
17 and I'm going to speak for the Committee. We understand  
18 in both cases where you guys sit. You've given us a  
19 verbal technical basis. We'd like to see it, a  
20 communication.

21 You've told us by verbally going through the  
22 back and forth, what the inventory is and what you  
23 currently think is the distribution and the surrogate.  
24 I'd just like to see it summarized. So it doesn't have  
25 to -- we don't have to call you back in.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. WALLIS: Are you going to get it  
2 summarized so you can do the test?

3 CHAIRMAN CORRADINI: No. I just want it  
4 summarized, so I have it somewhere, okay.

5 MR. TOMKINS: So I can work with Maitri as  
6 to how we accomplish that?

7 CHAIRMAN CORRADINI: Sure, yep, yep.

8 MR. HEAD: Or the staff. We'll want to  
9 make sure the staff is involved in that interaction.  
10 But we certainly can submit something or provide it to  
11 Maitri, however is appropriate.

12 CHAIRMAN CORRADINI: Okay. We're ahead.  
13 Officially, we're doing Item 80 at 10:15. But can we  
14 take a break now, and read ahead and get ready for number  
15 80.

16 (Laughter.)

17 CHAIRMAN CORRADINI: All right. So I'd  
18 like you back at five after, at 10:05. We'll take a  
19 break.

20 (Whereupon, the above-entitled matter went  
21 off the record at 9:49 a.m. and resumed at 10:08 a.m.)

22 CHAIRMAN CORRADINI: Okay. We're back in  
23 session. Jim, you're going to take us through the  
24 follow-up item?

25 MR. TOMKINS: Uh-huh.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Right, okay.

2 MR. TOMKINS: So this is follow-up item 80,  
3 having to do with the basis for the test acceptance  
4 criteria that uses an exponent of --

5 CHAIRMAN CORRADINI: Jim, could you move  
6 your mic around a little bit, so it's closer, just so  
7 -- we also want the recorder to pick up everything.

8 MR. TOMKINS: Thanks.

9 CHAIRMAN CORRADINI: He really can't hear.  
10 He's just using the recorder as an excuse.

11 (Laughter.)

12 MR. TOMKINS: Okay. So this is the  
13 acceptance criteria. What it basically says is when you  
14 run the test, the final pressure drop over the initial  
15 pressure drop, that ratio has to be less than 1,200 times  
16 the ratio of the final flow over the initial flow  
17 squared.

18 And the two is the exponent we're talking  
19 about, and that is based on the Darcy equation, and  
20 that's what we used in the analysis.

21 DR. WALLIS: Darcy is one, isn't it? Darcy  
22 is also laminate, and it doesn't matter. I think Darcy  
23 is always one.

24 CHAIRMAN CORRADINI: I think turbulence is  
25 what they're -- yeah.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TOMKINS: Yes, we are. We think the  
2 exponent of two is a reasonable value for high debris  
3 loadings. So when we look at testing, when you get a  
4 lot of debris loaded onto the fuel assembly, it does  
5 follow the exponent of two.

6 But some have suggested that well maybe you  
7 should be using a different exponent. So we've done a  
8 sensitivity and we've looked at what it would look like  
9 if you use 1.5 or 1.2. That's sort of summarized on this  
10 colorful picture. Hopefully, that will jar everybody.

11 But this is -- so the Y axis is the ratio  
12 of pressure drop, and the X axis is the ratio of flow.  
13 Red is the zone where you'd have an unacceptable **test**  
14 ~~task~~. So every **test task** will define a single point on  
15 this curve.

16 So the equation we just talked about, with  
17 the 1,200 in it, is this line right here. Just going  
18 back to that, one thing I didn't mention is the analysis  
19 would actually support 4,800 being in there. So we  
20 reduced it by a factor of four in pressure drop, which  
21 becomes a factor of two in flow. So that was something  
22 we, you asked about, is what's that factor?

23 CHAIRMAN CORRADINI: You reduced the Y? I  
24 apologize.

25 MR. TOMKINS: Just for conservatism, for

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the fact that our understanding of this is imperfect,  
2 and we wanted to make sure if we get a result that it's  
3 a result we can rely on.

4 CHAIRMAN CORRADINI: So where does that  
5 factor of four fit into your colorful curve?

6 MR. TOMKINS: I'll show you. I'll show  
7 you. Okay. So 1,200 is this curve; 4,800 is this  
8 curve. So in other words, the green could actually go  
9 all the way up to here, if we just followed what the  
10 computer code said. We follow the acceptance criteria.  
11 So we decided to lower it, make it harder to pass the  
12 test.

13 Now if you put in exponents of 1.5 as this  
14 line and 1.2 as this line. So those variations in  
15 exponent are within the margin we have defined for the  
16 acceptance criteria, which is kind of exactly why we put  
17 it in there.

18 CHAIRMAN CORRADINI: I'm sorry. I don't  
19 mean to sound confused, but I'm confused. So you're  
20 telling me the delta P ratio equals constant delta P  
21 ratio squared, is that line there?

22 MR. TOMKINS: Right.

23 CHAIRMAN CORRADINI: That line.

24 MR. TOMKINS: Well, the previous curve,  
25 this curve right here, this equation right here is this

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 line.

2 CHAIRMAN CORRADINI: Okay. So you can't

3 --

4 MR. TOMKINS: If you put 4,800, you get that

5 line.

6 CHAIRMAN CORRADINI: Well then it can't be

7 1.2 or 1.5. It's got to be the reverse of that. What

8 am I missing?

9 MR. HEAD: I'll start with the 4,800 curve.

10 MR. TOMKINS: The 4,800 curve has an

11 exponent of two in it.

12 CHAIRMAN CORRADINI: Okay.

13 MR. TOMKINS: If you go back to this, it's

14 just this relationship, 4,800 there, ratio squared.

15 DR. KRESS: So if the 4,800 curve was 1.5,

16 that would be --

17 MR. TOMKINS: Right, yes. 4,800, 1.5

18 would be here; 4,800, 1.2 would be here. Still bounded

19 by what we've assumed.

20 MEMBER ARMIJO: And the bottom one is the

21 only one that uses a 1,200?

22 MR. HEAD: That's correct.

23 CHAIRMAN CORRADINI: Okay, thank you.

24 (Simultaneous speaking.)

25 DR. KRESS: So if you -- so here's the 1.5

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and --

2 CHAIRMAN CORRADINI: Welcome, Dr. Kress.

3 DR. KRESS: Yes, thank you, and the 1,200,  
4 then they would be down below the green that you have  
5 now?

6 MR. TOMKINS: No. Well yes, if we ratio it  
7 --

8 (Simultaneous speaking.)

9 DR. KRESS: That was the problem with the  
10 question in the first place.

11 MR. HEAD: But then we might not have  
12 selected to use the factor of two, the conservatism --

13 DR. KRESS: Yeah, that's an important  
14 concept.

15 MR. HEAD: You know, we've chosen those two  
16 curves. If it's something different, we might have  
17 concluded well okay, that's an inappropriate  
18 conservatism at that point in time. So --

19 (Simultaneous speaking.)

20 MR. HEAD: --something that looks like that  
21 bottom green.

22 MR. VAN HALTERN: If I can add just one  
23 thing. We were asked to come up with an acceptance  
24 criteria, in a simple form that could be used easily.  
25 We have not run the tests, and we're not -- I have not

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 been trying to predict how the test is going to perform  
2 for any amount of debris. We haven't run it.

3 We don't know what protocol we're going to  
4 use, you know. It could be for some, you know,  
5 completely different thing. But the code tells you what  
6 flow rate, what pressure drop will give you a flow rate  
7 that gives us our .95, which is about twice the boiloff  
8 rate. That's what the upper curve does, based on the  
9 code, using just a reduction of the inlet.

10 CHAIRMAN CORRADINI: It's essentially a K  
11 loss factor.

12 MR. VAN HALTERN: That's correct, that's  
13 correct.

14 CHAIRMAN CORRADINI: Okay.

15 MR. VAN HALTERN: We knew at the time that  
16 there could be variations in how debris accumulates or  
17 how that responds, particularly over a wide range of  
18 flow. That was one of the reasons why we put in this  
19 margin, the safety factor, a margin factor, because  
20 essentially we don't want to get to the point where we're  
21 right at the acceptance criteria limit. We want to make  
22 sure that there's margin, as part of the defense indepth.

23 DR. KRESS: There's been a lot of tests with  
24 just the filters themselves. They're generally run  
25 around two. Did you, is that your experience with it?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. VAN HALTERN: We have not run -- we have  
2 not run the BWR tests. But Tim -- say that one more time,  
3 to make sure I understand, Dr. Kress?

4 DR. KRESS: There's been a lot of test  
5 filters of this nature, without debris or without  
6 blockage.

7 MR. VAN HALTERN: Right.

8 DR. KRESS: And they generally run around  
9 two in the exponent.

10 MR. VAN HALTERN: That is correct.

11 DR. KRESS: Yes. I just wondered if that,  
12 I'm not quite familiar with these particular filters.  
13 But I just wondered if that was your experience with them  
14 when they're unblocked and clean.

15 MR. VAN HALTERN: When they're clean  
16 filters, there was clean assemblies, no debris  
17 whatsoever, they do match the Darcy equation, with the  
18 factor of two as an exponent.

19 DR. KRESS: Yes.

20 MEMBER ARMIJO: If you run a number of  
21 experiments, and you get data points falling in this  
22 cross-hatched margin region, what do you do then?

23 MR. TOMKINS: Oh, I think our expectation  
24 is that's not going to happen.

25 MEMBER ARMIJO: Right. So I'm sure that

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 you have that. I don't have a doubt about that. But  
2 I'm just saying what -- is there real margin or do you  
3 --

4 MR. VAN HALTERN: Several options. You  
5 have several options, right. One is that you change and  
6 it has to go through the licensing process. You have  
7 to change the debris assumptions. That's one option.

8 Another is to not use that as an acceptable  
9 fuel design, and have a different fuel design. The  
10 third would be to go back and justify a relaxation of  
11 some of this margin, based on the information that you've  
12 got. All of those would have to go through the  
13 Commission for approval.

14 So you don't know until you've done the  
15 test. I think that's Dr. Wallis's point all along.

16 MR. TOMKINS: But I think our expectation  
17 is that if we run four tests, that they should all be  
18 below the curve, and if they're not, then --

19 (Simultaneous speaking.)

20 DR. WALLIS: I understand what you're  
21 doing, and I thought there wasn't an issue at all when  
22 I looked at it, because you do a test. You measure a  
23 flow rate and a pressure drop. The computer has a K.

24 The only way you can take the test result  
25 and put it in the computer is to take that test, take

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the flow rate and the pressure drop, give it a K based  
2 on two, and put it in the computer.

3 The computer only deals with a K modeling  
4 two. So you can't, when there's no sense in  
5 representing power law if it were some other flow rate,  
6 because the test has one flow rate and one pressure drop,  
7 and it has a K. It has nothing to do with how we would  
8 vary if you changed the flow rate. So that's what you  
9 have to put in a computer is a K, and you get the K from  
10 the test.

11 MR. VAN HALTERN: So when you --

12 DR. WALLIS: K has nothing to do with how  
13 it varies with flow rate. K is simply flow rate.

14 (Simultaneous speaking.)

15 MR. VAN HALTERN: To come up with  
16 acceptance criteria like this, it's analytic-based.  
17 Basically, it is a pressure drop and a flow rate --

18 DR. WALLIS: But it has a K.

19 MR. VAN HALTERN: And so when you run the  
20 test, you may not get that same flow rate.

21 DR. WALLIS: You run a test, you get a flow  
22 rate representing reality.

23 MR. VAN HALTERN: Well, based on the test  
24 condition and the way you run the test, you'll get a flow  
25 rate which is different from that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. WALLIS: Well then you extrapolate to  
2 a different flow rate.

3 MR. VAN HALTERN: So then there's --  
4 essentially there's two things you do when you run the  
5 test. You have to, you want to normalize or the results  
6 to the test, a clean versus a fouled test. You want to  
7 correct that. You may do that by zeroing out your DP  
8 cells at a certain flow rate clean, or you may do that,  
9 in this case, by just normalizing, okay. So that you're  
10 measuring the change in conditions.

11 DR. WALLIS: So you're testing not the  
12 actual flow rate; you're testing some other flow rate  
13 than you expect in the reactor?

14 MR. VAN HALTERN: When you run, you will be,  
15 you will get a different flow rate. You can get a  
16 different flow rate, and you have to adjust back. In  
17 some of the other testing things, they used different  
18 relationships, and that's where a lot of those studies  
19 came, with the different exponents, to correct back to  
20 the test condition, to the acceptance criteria  
21 condition.

22 Here, I just -- we adjust the acceptance  
23 criteria to give you a range, so whatever flow rate  
24 you're at is consistent with the acceptance criteria.

25 CHAIRMAN CORRADINI: I'm listening to what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 he asked, and I'm listening to how you answered, but I'm,  
2 at least in my mind, I'm still fuzzy. So let me just  
3 make sure I get in this simple thing, that I got this  
4 right.

5 So the delta p of i and the mass flow rate,  
6 W of I, is when you kick off --

7 MR. VAN HALTERN: The reference condition.

8 CHAIRMAN CORRADINI: When you kick off the  
9 test with no added debris, that's what the loop  
10 resistance is for the test?

11 MR. VAN HALTERN: Correct.

12 CHAIRMAN CORRADINI: Now you start  
13 throwing in crap, highly organized and decided junk.  
14 But you throw in stuff, and now you get another delta  
15 P and another flow rate.

16 DR. WALLIS: So you've got another K,  
17 because it's, that's the way K is defined.

18 CHAIRMAN CORRADINI: Well, but as I  
19 understand, I'm just -- if I might. If I understand what  
20 you're saying is the ratio of the Ks should be 4,800,  
21 but you're assuming it's 1,200?

22 MR. VAN HALTERN: It's got to be less than  
23 1,200.

24 CHAIRMAN CORRADINI: But what Professor  
25 Wallis is saying, I think that's the way I was thinking

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 about this. Essentially, the test will give you the K  
2 ratio.

3 DR. WALLIS: Right, it does.

4 MR. TOMKINS: Okay, and we want to make sure  
5 the test results had a lower K ratio increase than the  
6 analysis showed us would cause a problem, with a void  
7 fraction of .95 at the top of the hot assembly. So  
8 that's the acceptance criteria. So in other words, you  
9 put the debris in; the amount of blockage and the amount  
10 of K increases better be less than what it was in the  
11 analysis.

12 (Simultaneous speaking.)

13 DR. WALLIS: --the model is K, because  
14 that's what it's based on.

15 MR. TOMKINS: They changed the area  
16 actually, but yes, that's effectively K.

17 CHAIRMAN CORRADINI: Okay, fine. So I  
18 guess we're on the same page, but let me just say it back  
19 so we're -- at least I'm there, is that this 1,200 is  
20 a -- what's driving me nuts is this 1,200 is a dimensional  
21 quantity.

22 It's essentially a square of an area is  
23 flying around in there, because that's what's causing  
24 it to go out. You're essentially squishing down, you're  
25 squishing down on the flow area by throwing in the junk,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 as well as potentially changing the flow regime or  
2 whatever it is so the K is different.

3 But it's that ratio that you're trying to  
4 estimate, and as Dr. Wallis is saying, you do the test,  
5 you get a K ratio, and that's what you have to live with.  
6 You're looking to see what that K ratio is relative to  
7 --

8 MR. TOMKINS: The analysis.

9 DR. WALLIS: To the analysis. Now when does the  
10 power level, power law come into it?

11 CHAIRMAN CORRADINI: It doesn't. They  
12 have to assume a power law to do the analysis.

13 DR. WALLIS: To do the computer, you have  
14 to put in a two.

15 CHAIRMAN CORRADINI: Or the Excel  
16 spreadsheet.

17 DR. WALLIS: -- from the experiment. I  
18 don't quite understand why you need to worry about if  
19 you had a different flow rate, how it would change. That  
20 was the way I looked at it. I just thought this index  
21 is irrelevant. But I don't quite know what you've done.

22 MR. VAN HALTERN: Well, I think the  
23 question was --

24 MR. TOMKINS: We were asked to do a  
25 sensitivity on it, if we used a exponent of 1.5 or 1.2

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 --

2 DR. WALLIS: If you had modeled with a power  
3 law of 1.5, you would have had a different kind of a K,  
4 yes, correct.

5 (Simultaneous speaking.)

6 DR. WALLIS: But that's not what the  
7 computer did. The computer modeled it with two. So in  
8 terms of the computer model, this is okay. You have  
9 1,200 margin. If the computer chooses to go back and  
10 model with 1.5, then you have a different --

11 MR. VAN HALTERN: And that's the -- those  
12 are the lines we plotted.

13 DR. WALLIS: But you didn't do that, did  
14 you?

15 MR. VAN HALTERN: Yes, we did, yes we did.

16 DR. WALLIS: You put this in the computer?

17 (Simultaneous speaking.)

18 DR. WALLIS: You put that in the computer  
19 when you modeled to this .95 and all that stuff, .95  
20 exponent?

21 MR. VAN HALTERN: It's the same, the same  
22 set of conditions if you use a 1.5 as your exponent, and  
23 you put that curve.

24 DR. WALLIS: So  $W_i$  and to the  $P_i$  will model  
25 with 1.5 as well?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. VAN HALTERN: Not the Wi.

2 DR. WALLIS: It has to be, because it's  
3 underneath. It's inside.

4 MR. VAN HALTERN: That's not what happens.

5 DR. WALLIS: It has to be.

6 MR. VAN HALTERN: You get a different  
7 relationship.

8 DR. WALLIS: Well, I don't understand what  
9 you've done.

10 CHAIRMAN CORRADINI: Can I take another  
11 stab at it, because I do want us to at least understand.  
12 So you've done a side calculation with, and I can't  
13 remember the tool.

14 MR. TOMKINS: GOBLIN.

15 CHAIRMAN CORRADINI: I'm sorry?

16 MR. TOMKINS: GOBLIN.

17 CHAIRMAN CORRADINI: GOBLIN, thank you. I  
18 was going to say there was all sorts of funny names, but  
19 so it with GOBLIN.

20 We're in the Halloween season, and you then  
21 said that at 95 percent void, you had defined that as  
22 a point. So at 95 percent void, the flow rate you need  
23 to essentially keep the core under those flow  
24 conditions, and then you then backed out the delta P,  
25 right?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. VAN HALTERN: That's correct, that's  
2 correct.

3 CHAIRMAN CORRADINI: And you have this  
4 relationship, which is everything below the solid line.  
5 Your analysis, and that's why I guess I want to make sure  
6 I got it right. The analysis at .95 is the 4,800 line  
7 or the 1,200 line?

8 MR. VAN HALTERN: 4,800.

9 CHAIRMAN CORRADINI: Okay. So the dash  
10 line at the very top is the one that would essentially  
11 provide you with a void fraction, such that you're well  
12 within the PCT and life is nice and cool?

13 MR. VAN HALTERN: Correct, very cool.

14 CHAIRMAN CORRADINI: Okay. Then you  
15 consciously decreased that by a factor of four as a  
16 margin, and stuck in the solid line, and everything below  
17 that is that. So in the model for GOBLIN, it assumes  
18 turbulent conditions, and therefore to Dr. Wallis's  
19 point, it only knows turbulent conditions, so its got  
20 two buried in it.

21 So once we're done with that, the computer  
22 is out of the picture, and it's simply a matter of just  
23 throwing where the data sits relative to the two lines?

24 MR. VAN HALTERN: Correct.

25 CHAIRMAN CORRADINI: Okay. Then I'm okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Well, I don't understand.  
2 The computer says that you'll be in trouble when you have  
3 a K of something, right. You do an experiment, you  
4 measure delta P and W squared and you've got a K, and  
5 that K is a thousand times smaller, so you're okay.  
6 Everything, that's okay.

7 CHAIRMAN CORRADINI: That's right.

8 DR. WALLIS: You don't have to ask how it  
9 would be if you happen to have a different flow rate.

10 CHAIRMAN CORRADINI: Well, I would say  
11 don't dwell on -- if I might, just a suggestion. Don't  
12 dwell on the 1.5 and the 1.2. Just dwell on the fact  
13 that the dash line and the solid line, and their point  
14 is their GOBLIN analysis says that they're well within  
15 accruable geometry when the dash line is met, and they've  
16 consciously taken it down by a factor of four, and they  
17 want to see that they sit within the green zone.

18 MR. HEAD: And we also felt this approach  
19 was appropriate for closing the license condition.

20 CHAIRMAN CORRADINI: Right. But I think  
21 Dr. WALLIS, and I'm kind of with him on this, the two  
22 lines in between are kind of red herrings, to pick  
23 another word for it.

24 (Simultaneous speaking.)

25 CHAIRMAN CORRADINI: I wasn't here, so I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 don't know. But all I know is that the two extremes make  
2 perfect sense, because your more sophisticated  
3 calculation gives you the dash line, your solid line  
4 essentially an assumption, and okay?

5 DR. WALLIS: Yes.

6 CHAIRMAN CORRADINI: Okay.

7 MR. HEAD: Thank you.

8 CHAIRMAN CORRADINI: I'm sorry, go ahead.

9 MR. TOMKINS: So that's really it. I mean  
10 the --

11 DR. WALLIS: I still don't know what you  
12 did. Are we going to be able to see what you did?

13 CHAIRMAN CORRADINI: Well, they haven't  
14 did anything yet.

15 DR. WALLIS: I don't think it matters, but  
16 I'm just curious of what on earth you did.

17 MR. VAN HALTERN: That is what we did.

18 DR. WALLIS: But you can't. You have to  
19 have a K. Everything is based on K. You can't fudge  
20 it and say it's something else.

21 CHAIRMAN CORRADINI: I think Graham, all  
22 they're saying is, if you go back to the curve, and then  
23 I'll stop. All they're saying is, is that based on their  
24 GOBLIN analysis, plus a factor of four reduction in their  
25 margin. So it's not .95 void; it's, I don't know,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 whatever the associated void is in the green zone.

2 DR. WALLIS: But they do the test. They do  
3 the test. The WF, is that the actual condition they  
4 expect, as predicted by the computer, isn't it?

5 CHAIRMAN CORRADINI: No,  $W_i$  is predicted by  
6 it. We do the test -- not necessarily.

7 DR. WALLIS: Now when you get this K where  
8 you're in the trouble --

9 CHAIRMAN CORRADINI: But can you answer his  
10 question, because I think that's where maybe he's  
11 confused.

12 DR. WALLIS: But you say you need a certain  
13 amount of water to cool the core, and it's double  
14 ~~blowdown~~ ~~boredown~~ condition, so we'll do the test at that  
15 flow rate. Don't you do that?

16 Don't you do the test at the flow rate that  
17 you need to cool the core? The only question then is  
18 what's the pressure drop, because the flow rate's fixed,  
19 and this defines the K, because the other  $p$  over  $w$  gives  
20 you a K.

21 MR. VAN HALTERN: Ask about is the flow  
22 rate, as you add debris will change, okay. So you start  
23 at some flow rate and you add the debris and it ends up  
24 at a different flow rate and the pressure drops.

25 CHAIRMAN CORRADINI: So let me interject.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 Then I think what he's asking is what flow rate do you  
2 start with, and that's the range of initial flow rates.

3 (Simultaneous speaking.)

4 DR. WALLIS: But they said we're going to  
5 get the flow rate we need to cool the core, and then we're  
6 going to see where pressure drop begins.

7 MR. VAN HALTERN: Correct. That's the  
8 way--

9 DR. WALLIS: You're going to do it the best  
10 way you --

11 MR. VAN HALTERN: We could do that as well.

12 DR. WALLIS: You've got in debris. How do  
13 you know what flow rate to use?

14 MR. TOMKINS: We start with a flow rate  
15 that's representative of post --

16 (Simultaneous speaking.)

17 DR. WALLIS: Conditions. Okay. So you  
18 find, okay. I see what you're doing.

19 CHAIRMAN CORRADINI: That's what I -- so I  
20 want to make sure you're clear about what flow, the W  
21 of I they start with.

22 DR. WALLIS: Oh, I know what  $W_i$  is --

23 (Simultaneous speaking.)

24 MR. TOMKINS: 16 gpm and 80 gpm are the two  
25 values that we have.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. VAN HALTERN: The questions that have  
2 come before us previously were don't you have to test  
3 the different flow rates, because you get debris bed  
4 formation differently. Well, so you start with a clean  
5 condition and you start at a flow rate, add your debris,  
6 and it will --

7 DR. WALLIS: And your --

8 MR. VAN HALTERN: And your flow rate will  
9 decrease and your pressure drop will increase.

10 DR. WALLIS: Flow rate is decreased  
11 according to the GOBLIN analysis, as the pressure drop  
12 builds up?

13 MR. VAN HALTERN: We control that in the  
14 test.

15 DR. WALLIS: You control that in the test,  
16 okay, okay. Is this written up somewhere so we can  
17 actually follow the logic? I mean this doesn't tell me  
18 what you really did.

19 MR. VAN HALTERN: I think it's in the COLA.

20 MR. TOMKINS: Yes. It's in, it's an RAI  
21 response.

22 MR. VAN HALTERN: It's in RAI response.

23 CHAIRMAN CORRADINI: There's an RAI  
24 response. We got a CD, and there's an RAI response in  
25 their test protocol, and that's where it would be.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Actually gives the math and  
2 the method?

3 CHAIRMAN CORRADINI: I would assume they  
4 have the test procedure.

5 MS. BANERJEE SCHLASEMAN: It's in the CD.

6 CHAIRMAN CORRADINI: It's described  
7 generally, but that may not be --

8 MS. SCHLASEMAN: I think it was one of the  
9 RAIs.

10 MR. TOMKINS: I can find the RAI.

11 CHAIRMAN CORRADINI: Would you please?

12 MR. TOMKINS: Yes, and that's something --

13 DR. WALLIS: When you do the test, your  
14 GOBLIN comes down.

15 MR. TOMKINS: Well, GOBLIN doesn't -- when  
16 we do the test. GOBLIN isn't doing it.

17 DR. WALLIS: But GOBLIN taught you how to  
18 control flow rate versus pressure drop, doesn't it?

19 MR. TOMKINS: No. GOBLIN just tells us --  
20 (Simultaneous speaking.)

21 DR. WALLIS: Well, how do you know how to  
22 do the test then? How do you know how to do the test?

23 CHAIRMAN CORRADINI: I think all that  
24 GOBLIN does, if I may just interject Graham, GOBLIN  
25 essentially gives them the dash line at top.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. TOMKINS: This line right here.

2 CHAIRMAN CORRADINI: That line. They then  
3 consciously add margin and take what GOBLIN predicts to  
4 be the loss coefficient and decrease it by a factor of  
5 four, and that's their line of acceptance.

6 DR. WALLIS: So how do you do -- how do you  
7 control the flow rate on the test? I thought that you  
8 were trying to model what happened in a real event, by  
9 letting the pressure drop increase across the core and  
10 then decreasing the flow rate correspondingly? Don't  
11 you do that?

12 MR. TOMKINS: Well, the pressure drop does  
13 increase, of course, when you start adding debris. So  
14 flow rate starts decreasing.

15 DR. WALLIS: Why does it go down?

16 MR. TOMKINS: Pardon?

17 DR. WALLIS: Why does it go down?

18 MR. TOMKINS: Because there's more  
19 resistance.

20 DR. WALLIS: But then your pump, you're  
21 following a pump characteristic. You're not following  
22 a core characteristic, the core in the pump. You're not  
23 trying to model the actual accident with the pump. Some  
24 people actually try and follow the accident and say as  
25 you build up pressure drop, the flow rate goes down.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TOMKINS: Right, right.

2 DR. WALLIS: You don't do that?

3 MR. VAN HALTERN: Our intent at this point  
4 was not, but we'll learn from the industry, see what  
5 makes sense.

6 MR. HEAD: This was a license condition  
7 that was, you know, simple, and if it accommodated the  
8 adjustment --

9 DR. WALLIS: But I thought we were  
10 following -- if you follow, try to follow the accident,  
11 so as the pressure drop builds up the flow rate goes down,  
12 then you're following essentially a GOBLIN model.

13 So when you get a certain point where you  
14 stop, you're actually on a certain point in the GOBLIN  
15 prediction, because you're following a GOBLIN curve.  
16 That's what I thought you were doing. If you're there,  
17 you have a K.

18 CHAIRMAN CORRADINI: Can I interject one  
19 more -- I don't think you have -- let me just ask. You  
20 don't have more to present?

21 MR. TOMKINS: No.

22 CHAIRMAN CORRADINI: So I think we've got  
23 to get it clear in our minds, and again, what I heard  
24 them say, I guess I interpreted it differently than what  
25 you just said. What they're saying is they've done the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealgross.com](http://www.nealgross.com)

1 GOBLIN calculation for reflood, and they basically asked  
2 themselves a question.

3 Parametrically, if I continually decrease  
4 the flow for reflood, or I should say long-term cooling,  
5 and I just invent some resistance and turbulent, assumed  
6 turbulent conditions, at what point do I get above 95  
7 percent void fraction, which is the surrogate for  
8 dryout? It's not dryout; it's the surrogate for dryout,  
9 and they get the dash curve.

10 MR. TOMKINS: Right, right.

11 CHAIRMAN CORRADINI: And then they then say  
12 well, there might be some uncertainty here, so we're  
13 going to take that down and increase the resistance  
14 further, and they take it down to the green region.

15 Then after that, the GOBLIN calculation is  
16 essentially not necessary anymore. Now they have a  
17 window. Now then they have a test protocol which you're  
18 after, as to how do they determine where they sit between  
19 green and red.

20 What I thought you said was they then take  
21 what they expect to be the W of i, start the test, and  
22 then add debris under some protocol.

23 MR. TOMKINS: Correct, and when we get  
24 steady state, we have a final pressure, we have initial  
25 pressure drop, final flow and we have the initial flow,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 and that's plugged into that.

2 DR. WALLIS: How do you control the pump  
3 characteristic, so that your responsive flow to pressure  
4 drop is realistic? You have to design the -- what are  
5 you trying to simulate in the test? You can design a  
6 pump which is always pumping the same flow rate, no  
7 matter what, to simply build up pressure drop.

8 MR. TOMKINS: Right.

9 DR. WALLIS: Or you could have a pump which  
10 decreases flow rate as the pressure drop builds up, and  
11 you can stop flow and you get a certain pressure drop.  
12 So that now which of those are you doing and how does  
13 that relate to GOBLIN?

14 I thought you were trying to follow a GOBLIN  
15 -- there's a GOBLIN curve of pressure drop and flow rate  
16 and there's a resistance curve and they meet, and that's  
17 where you are.

18 MR. VAN HALTERN: Correct, right.

19 DR. WALLIS: But you're not trying to do  
20 that?

21 MR. VAN HALTERN: Well, we would be  
22 approximating, and you can control that through --

23 DR. WALLIS: Approximately on the GOBLIN  
24 curve?

25 MR. VAN HALTERN: Yes. You would try to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 approximate that.

2 DR. WALLIS: Okay. So --

3 MR. VAN HALTERN: But the problem, you may  
4 not get to the GOBLIN final flow rate, because you  
5 wouldn't get to the debris resistance that you get for  
6 a 4,800 curve, right?

7 CHAIRMAN CORRADINI: Graham, are you okay?  
8 I want to make sure. We have the time to make sure you  
9 at least understand what they're saying.

10 DR. WALLIS: Not to the point where I fully  
11 understand what you're doing. But I'm not sure of  
12 either one.

13 MR. TOMKINS: I'd be willing to.

14 CHAIRMAN CORRADINI: Yes, Caroline.

15 MS. SCHLASEMAN: Well, I just want to  
16 understand. Are you talking about like the RHR pump,  
17 I mean as it -- I mean is it the loss? When you were  
18 talking about the strainer --

19 DR. WALLIS: No. I'm saying the reactor  
20 system has a certain characteristic. There's a  
21 certain flow rate versus pressure drop.

22 MR. VAN HALTERN: In the GOBLIN scenario,  
23 okay, you have a LOCA. You essentially fill the  
24 downcomer with a head of water. That head stays  
25 constant. You're in natural circ.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 DR. WALLIS: That's right.

2 MR. VAN HALTERN: And then as your  
3 resistance changes, what happens is you, more of the  
4 pressure drop is taken up by the resistance and the head  
5 of water in the fuel drops.

6 DR. WALLIS: That's right, and GOBLIN  
7 predicts the relationship within flow and pressure drop  
8 for the loop, apart from the blockage.

9 MR. VAN HALTERN: Yes, for that --

10 DR. WALLIS: Then you have a little curve  
11 coming up here. Where they meet is your operating  
12 point?

13 MR. VAN HALTERN: That's correct.

14 DR. WALLIS: I'm saying if you follow the  
15 GOBLIN curve, it doesn't really matter what, how you make  
16 the debris or anything. You're always on that curve,  
17 so you always have a K, because GOBLIN has a K.

18 MR. VAN HALTERN: No, I understand.

19 MR. TOMKINS: And so really what the test  
20 does is it says, you know, that increase in K, that in  
21 the analysis that led to the void fraction of .95, we'd  
22 better be less than that in the --

23 (Simultaneous speaking.)

24 DR. WALLIS: But the problem you have --

25 MR. TOMKINS: --and we put in a factor of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 four to make sure.

2 DR. WALLIS: The problem you have is if you  
3 do a test which has conditions so far away from the GOBLIN  
4 curve that you have to extrapolate a lot. That's where  
5 you get in trouble, and I don't know how far away you  
6 are.

7 MR. VAN HALTERN: I think we're reasonably  
8 close, in terms of both rates, the initial flow rate at  
9 least.

10 DR. WALLIS: I mean if GOBLIN is predicting  
11 flow rates of, I don't know, five gallons per minute per  
12 assembly or something at a certain pressure drop, and  
13 you're a way away far from that, then you may want to  
14 extrapolate in some way, to get those to meet.

15 But I don't -- until you show me that sort  
16 of analysis, I don't really understand what you're  
17 doing. I think I did it some time, to convince myself  
18 it was okay. But I don't see -- this doesn't tell me  
19 anything.

20 MR. VAN HALTERN: So your question is on the  
21 test protocol.

22 CHAIRMAN CORRADINI: Yes. I think what  
23 we're getting to is not the criterion; it's on the test  
24 protocol.

25 MR. VAN HALTERN: Protocol, correct.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. KRESS: Graham, I would be pleased if  
2 I knew that they were operating on the top curve, which  
3 is specific to the ECCS. If they're operating on the  
4 flat part, they never get down to the part where it  
5 decreases.

6 MR. TOMKINS: Remember, ECCS isn't in play  
7 per se here, because what's driving the flow is natural  
8 circ --

9 DR. WALLIS: Natural circulation.

10 DR. KRESS: This is natural circulation?

11 MR. TOMKINS: Yes, at this point, yes,  
12 because all the water that still goes in from ECCS  
13 spills out of the break --

14 DR. WALLIS: They're complicated.

15 MR. VAN HALTERN: Essentially you have a  
16 constant head of water, upstream of the assembly.

17 CHAIRMAN CORRADINI: Right.

18 MR. VAN HALTERN: Okay, and the flow will  
19 change as the resistance of that assembly changes.

20 DR. WALLIS: GOBLIN will predict the  
21 pressure drop?

22 MR. VAN HALTERN: Yes.

23 DR. WALLIS: Flow rate characteristic for  
24 the core and that stuff, and you have to match that with  
25 the other resistance from the debris. That's all.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 They've just two curves intersecting.

2 Now say if you do the test to really model  
3 reality, you will intersect at a realistic point, and  
4 that will have a K. You don't have to correct anything,  
5 because K is -- this curve has a K as a parameter.

6 MR. VAN HALTERN: So what you're suggesting  
7 is that we follow the flow versus time in GOBLIN, as we  
8 increase the resistance?

9 MR. TOMKINS: It's part of the test  
10 protocol, and we will make sure that the test protocol  
11 provides --

12 DR. WALLIS: You don't have to have time in  
13 there; you just have to have flow rate. GOBLIN predicts  
14 flow versus available pressure drop through the debris.

15 MR. TOMKINS: Right.

16 DR. WALLIS: The big stuff.

17 MR. TOMKINS: Right.

18 DR. WALLIS: So it predicts -- it has a K  
19 right away. If you're on that GOBLIN curve, you have  
20 a K. You don't have to correct anything. But if your  
21 test is way away from that reality, then you have to  
22 extrapolate. Maybe that's what you're doing here.

23 MR. TOMKINS: That's part of why we have  
24 that equation, is because the flow --

25 MR. VAN HALTERN: The K will change with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 debris.

2 MR. TOMKINS: So the flow might be a little  
3 different in the test. We're going to start at the same  
4 point.

5 DR. WALLIS: If it's a little different,  
6 it's not going to make much --

7 CHAIRMAN CORRADINI: So let me back us up  
8 a bit, because we're kind of -- I want to make sure we  
9 have time for the staff to address the Committee. So  
10 a thing that we should be reminded of is the RAI response,  
11 so we can look at the test protocol as you've responded  
12 to staff.

13 And what Dr. Wallis is asking, which I think  
14 I understand, is what is that test protocol versus at  
15 least what he expected it to be, since we -- let's just  
16 say we don't remember what we have somewhere in one of  
17 our hard drives, for the RAI response.

18 Then you also said there's a summary of the  
19 test protocol, but I can't remember where you said the  
20 summary was.

21 MR. VAN HALTERN: I think that was in 6C.

22 MR. TOMKINS: 6C has a summary of the  
23 protocol, but --

24 MS. SCHLASEMAN: I see it.

25 MR. TOMKINS: --it also has a summary of the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 analysis, validating the acceptance criteria.

2 MR. VAN HALTERN: A high level summary.

3 DR. WALLIS: But you are setting the flow  
4 rates that you're pumping through this debris to be  
5 pretty well what you're expecting --

6 MR. VAN HALTERN: Right.

7 DR. WALLIS: --when you get to this point  
8 where you don't cool the core.

9 MR. VAN HALTERN: Right.

10 DR. WALLIS: So you've got to be on that  
11 GOBLIN curve pretty realistically so you have a K. So  
12 I don't think there's a problem at all. I don't see how  
13 you could have such tremendous difference here.

14 CHAIRMAN CORRADINI: The tremendous  
15 difference is strictly an assumption.

16 MR. TOMKINS: Right. The factor of four is  
17 a tremendous difference. That's, yes.

18 DR. WALLIS: You're predicting a different  
19 curve there for --

20 CHAIRMAN CORRADINI: It's not their  
21 prediction. That's essentially their assumption. The  
22 dash line is what GOBLIN is saying is a set of conditions  
23 that will allow the core to stay cool. The solid line  
24 is what they assume.

25 DR. WALLIS: You can't change that.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. TOMKINS: The bottom line is what we use  
2 for the test and what we assume, and in essence, the test  
3 is doing what you say, because it is determining you've  
4 got a pressure drop and you've got a flow. So it's  
5 determining K.

6 DR. WALLIS: So it's determining a K.

7 MR. TOMKINS: So you're --

8 (Simultaneous speaking.)

9 DR. WALLIS: Absolutely, right. That's  
10 what we're trying to do.

11 MR. TOMKINS: So that's what that line is  
12 doing for us.

13 DR. WALLIS: Right. So why do you have to  
14 change it?

15 CHAIRMAN CORRADINI: Okay, all right.  
16 Anything else for the Committee, and Banerjee will catch  
17 up.

18 (Laughter.)

19 DR. WALLIS: If we can read the transcript.

20 CHAIRMAN CORRADINI: Go ahead.

21 (Simultaneous speaking.)

22 MR. TOMKINS: So in summary, we think we've  
23 addressed all the ACRS follow-up items. We understand  
24 we've got a couple of documents we're going to get to  
25 ACRS. We've written those down. There's three things

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 we're going to get to you. Scott will cover that.

2 We think there's adequate core cooling to  
3 meet long-term cooling. Both the ECCS and ultimate heat  
4 sink are more than adequate to provide the 30 days  
5 required, and as we've said before, the design basis LOCA  
6 peak clad temperature about half the limit. So we have  
7 a mild LOCA, if you will.

8 The challenge is that we've talked about  
9 containment integrity, ECCS gas accumulation and  
10 strainer NPSH were satisfactorily addressed in previous  
11 meetings. The primary challenge that we see, and  
12 certainly we -- certainly from the perspective of the  
13 amount of time we've spent on it was debris passing  
14 through the strainers and causing downstream effects.

15 We have a conservative downstream test.  
16 Acceptance criteria, you know, is a factor of four.  
17 There's a whole bunch of -- the .95 is conservative. So  
18 we think if we get a positive test in the downstream test,  
19 then we'll be very confident that debris would not  
20 compromise long-term cooling in the plant.

21 Furthermore, we have defense indepth, so  
22 that really even if the strainers plug completely,  
23 there's two other means. They have the high pressure  
24 core flooder, which a lot of plants don't have. They  
25 can inject water from the top, and we have bypass flow,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 which we've calculated and determined that that can  
2 provide sufficient cooling.

3 So we think we meet the regulatory  
4 requirements for long-term cooling.

5 DR. WALLIS: And you don't have any risk  
6 analysis of what happens if you do completely plug the  
7 bottom of the core. Maybe the risk is very small.

8 MR. TOMKINS: Well, our analysis shows that  
9 we can still cool it.

10 DR. WALLIS: No, but there's got to be a  
11 probability of that too, so you're within the PRA.

12 CHAIRMAN CORRADINI: So may I ask, again  
13 just for my personal reference, your last sub-bullet of  
14 "Furthermore," dot-dot-dot, where would I find the  
15 analysis that shows where the high pressure core flooders  
16 or the bypass of the assembly would essentially keep you  
17 within an acceptable --

18 MR. TOMKINS: It's described in various  
19 RAIs, and it's described in 6C also. But it's in a calc.  
20 I mean that's where really most of the details are. Is  
21 that correct Marty?

22 MR. VAN HALTERN: Yes.

23 CHAIRMAN CORRADINI: And I'll turn to  
24 Maitri to provide it to the Committee. But I just want  
25 to, since you made the point from a defense indepth

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 standpoint, that you have essentially two alternate  
2 means, I want to actually make sure we can get back to  
3 that. Thank you.

4 MR. HEAD: And at this point, I'd like to  
5 summarize what I think our actions are, at this point.  
6 One is that you wanted to understand the basis for the  
7 one cubic foot of debris, and we'll work with the staff  
8 on providing -- I think we'll get, you know, we'll docket  
9 something to provide that.

10 We probably won't provide the actual TEPCO  
11 report, but a derivative document or something that, and  
12 we'll --

13 MS. SCHLASEMAN: What I was going to say is  
14 I've just given Maitri a copy that we can show. It's  
15 a TEPCO proprietary document that's governed under STP's  
16 and NINA's relationship, and she has it, and we can show  
17 that, and we have shown that to the staff before. Rather  
18 than document --

19 MR. HEAD: You can't leave it, though,  
20 right?

21 MS. SCHLASEMAN: Right, we can't docket.

22 CHAIRMAN CORRADINI: Well, I'm not going to  
23 docket the report.

24 MS. SCHLASEMAN: But I'm just saying we can  
25 show that now.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. HEAD: Yes. We can show it and show its  
2 existence, but in terms of leaving it --

3 (Simultaneous speaking.)

4 MR. HEAD: We can't, because it -- we'll  
5 probably summarize that in this document we send you.  
6 We'll show you the report exists. NRC has seen the  
7 report.

8 MS. SCHLASEMAN: It's in the early RAIs  
9 also.

10 CHAIRMAN CORRADINI: Okay.

11 MR. HEAD: Right.

12 (Simultaneous speaking.)

13 CHAIRMAN CORRADINI: Okay, that was the  
14 first item.

15 MR. HEAD: We're not leaving the report.

16 MS. SCHLASEMAN: That's correct, we're  
17 not. It's TEPCO proprietary.

18 CHAIRMAN CORRADINI: Okay.

19 MR. HEAD: And the table that we talked  
20 about, in terms of the different sources of debris, which  
21 goes into what the surrogate is and some indication of  
22 the basis for that, you know, in terms of where in the  
23 industry that's been defined, we'll create that also and  
24 submit that to the staff for their, and then they'll  
25 provide that to ACRS.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1           So you'll have the entire picture of what  
2 we're planning to do right now. But as I would, I just,  
3 you know.

4           MEMBER ARMIJO: In that table, are you  
5 going to have a column on the size or size distribution?

6           MR. HEAD: Yes, yes. But then I probably  
7 won't do it, but they'll be a footnote or there could  
8 be a footnote that could say "subject to change as  
9 protocol evolves."

10           (Laughter.)

11           CHAIRMAN CORRADINI: Sure.

12           MR. HEAD: But that will be our current --

13           CHAIRMAN CORRADINI: I just think all the  
14 Committee is asking for is just a summary.

15           MR. HEAD: Okay.

16           DR. WALLIS: Could we get some real stuff  
17 from these Japanese containments? You said that there  
18 was sludge and rust and stuff in there. Could you  
19 actually provide some technical data about what that is  
20 like?

21           CHAIRMAN CORRADINI: To the extent they  
22 can, they will.

23           DR. WALLIS: Is it fibrous, what are the  
24 sizes?

25           MR. HEAD: Very little fiber.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MS. SCHLASEMAN: We have that information  
2 in the document, three-page document --

3 DR. WALLIS: You do have it?

4 MS. SCHLASEMAN: --that Maitri has, and we  
5 can send that to you. I think she has it.

6 CHAIRMAN CORRADINI: Okay, and then the  
7 last thing is, and I'll just repeat it, is that you've  
8 now pointed to a test protocol for the summaries in  
9 Appendix 6C, as is the defense indepth relative to the  
10 ~~core flooder flutter~~ and the bypass assembly. But there  
11 are RAIs that have calcs that we can look at, RAI  
12 responses on --

13 MR. HEAD: RAI responses with the calcs?

14 CHAIRMAN CORRADINI: No, no. I misspoke.  
15 RAI responses to those, both of those, the test protocol  
16 details, as well as the bypass assembly and core ~~flutter~~  
17 ~~flutter~~.

18 MR. VAN HALTERN: I don't remember any RAI  
19 responses to the test protocol.

20 CHAIRMAN CORRADINI: I just want a place  
21 where I can look to see where you've done the estimate  
22 that these defense indepth measures will essentially  
23 keep you acceptable.

24 MR. VAN HALTERN: Yes. That's written up  
25 into the 6C.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: Okay.

2 MR. TOMKINS: But it's also summarized in  
3 some RAI responses.

4 MR. VAN HALTERN: Yes, a little more  
5 detail, I think, in the RAI.

6 MR. TOMKINS: So we'll get that to Maitri.

7 MR. VAN HALTERN: I'll get that Maitri  
8 through Tom.

9 MS. BANERJEE: Well 6C, your FSAR 6C we  
10 have.

11 MR. TOMKINS: I understand.

12 MR. HEAD: And the RAI responses you have,  
13 but I think he's looking for more detail in terms of the  
14 bypass discussion, which 6C doesn't get into all that.

15 MEMBER ARMIJO: Yes, we need the RAI  
16 responses.

17 MS. BANERJEE: Okay. So you are going to  
18 give me the more detailed RAIs?

19 MR. TOMKINS: I'll communicate to you and  
20 yes, I'll just give you --

21 MR. HEAD: Bill. I was going to say Bill  
22 might be --

23 MR. MOONHOEK: I don't think that  
24 information is in that level of detail in the RAI  
25 responses. I think most of those calcs were looked at

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in an audit, and there might be -- I don't know how much  
2 detail would be in the audit report.

3 But I think all that you will see in the RAI  
4 responses and in 6 Charlie will be the summary level.

5 CHAIRMAN CORRADINI: That's fine, and  
6 we'll go to the staff and ask about the audit report.  
7 That's not your call.

8 MR. MOONHOEK: Okay.

9 MR. HEAD: Well, I guess I'm -- I'm going  
10 to make a submittal that covers these first two. If I  
11 could make some sort of an attachment that says here's  
12 what's in these calcs that we did, which I'm sure will  
13 look ~~bio~~biological to you. We might consider doing that.

14 CHAIRMAN CORRADINI: Okay.

15 MR. HEAD: You know what I mean? It's not,  
16 we can certainly still be proprietary, but we would --  
17 you know, it would not be, I think, that difficult to  
18 describe what we did. So we'll consider that.

19 CHAIRMAN CORRADINI: Okay.

20 MS. BANERJEE: That's on the last question.

21 MR. HEAD: Yes, on this defense indepth,  
22 you know, some more understanding of our basis for  
23 that.

24 CHAIRMAN CORRADINI: All right, good.

25 MEMBER BANERJEE: Mike, I have a question.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Is it --

2 CHAIRMAN CORRADINI: You're still in under  
3 the grace period, but go ahead.

4 MEMBER BANERJEE: I was looking at all this  
5 stuff, and you know, I only attended the first meeting.  
6 There's a lot of discussion about zinc versus aluminum  
7 hydroxide, and I remember going to Germany once and  
8 looking at the effect of zinc, and they had these, you  
9 know, galvanized things and stuff.

10 It looked like the effect was pretty large.  
11 Is there sort of certainty that aluminum hydroxide  
12 actually covers what you expect with zinc? Have you  
13 looked at the German experience?

14 MS. SCHLASEMAN: No. I was just going to  
15 say the --

16 MEMBER BANERJEE: I know this has been  
17 visited before, but looking at all of your minutes and  
18 your notes and stuff, it struck me.

19 MS. SCHLASEMAN: The German document that  
20 you were talking about was specifically talking about  
21 galvanized steel, and we've specifically said that we  
22 will not use galvanized steel in the drywell, in the  
23 primary containment. So we're left only with inorganic  
24 zinc primer for our your coatings.

25 It's the base for the -- it's inorganic

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 zinc, primer, epoxy top coated, qualified coatings. So  
2 after the break, the postulated break and zone of  
3 influence, we're left with, I think, 47 pounds of  
4 inorganic zinc primer, which gets into the suppression  
5 pool.

6 We've done a corrosion calc analysis, PWR  
7 Owners Group that Tim Andreychek of Westinghouse did,  
8 and so it expands a bit. It's 58 pounds total zinc, and  
9 so that 58 pounds of zinc corrosion products, that's it.  
10 I mean that is all we have, and we had proposed, I guess  
11 this is where I should pass it over to Tim, but that was  
12 the link with the German paper, with galvanized steel.

13 MEMBER BANERJEE: The German, with  
14 galvanized steel or iron, eventually the zinc gets into  
15 some form of corrosion product.

16 CHAIRMAN CORRADINI: Right, but I think --

17 MEMBER BANERJEE: And I wonder if it does.

18 CHAIRMAN CORRADINI: But I think she's  
19 saying all of that's precluded. It's not going to be  
20 in the primary containment.

21 MEMBER BANERJEE: I know. How much is it?

22 MR. ANDREYCHEK: 48 would be --

23 MEMBER BANERJEE: No, yours is 48. How  
24 much is the German?

25 MR. ANDREYCHEK: Off the head, I don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 know. I can't give you a number exactly.

2 MEMBER BANERJEE: Ultimately, the zinc  
3 ends up as corrosion products.

4 MR. ANDREYCHEK: It does, and we predict  
5 that it does occur, and it occurs over a 15-day period,  
6 based on the data that we had, that chose corrosion  
7 rates. So at 15 days, and that's a conservatively short  
8 period of time.

9 So the way we ran the calculations, we  
10 assumed the size of the zinc, constituent in the  
11 inorganic zinc primer, stays the same. So it has a  
12 maximum surface area.

13 MEMBER BANERJEE: Can you just summarize  
14 for me the German experience with that?

15 MR. ANDREYCHEK: No, I can't. I don't have  
16 that German experience at my fingertips.

17 MEMBER BANERJEE: Because I actually told  
18 it was quite a large effect, they told me.

19 MR. ANDREYCHEK: A large effect. I don't  
20 understand what you mean by "has a large effect." If  
21 you could let me understand what it means.

22 MEMBER BANERJEE: Well, on clogging, you  
23 know, the chemical effects. I'd have to look at the  
24 report. It's been a long time ago.

25 MR. ANDREYCHEK: And I don't recall the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 last time I looked at the German work, but our  
2 recollection was is that given what we were looking at,  
3 the aluminum hydroxide surrogate we're using gives us  
4 at least as bad if not worse pressure drop  
5 characteristics as the zinc products from the Germans.

6 And as a consequence, we chose to go with  
7 aluminum oxyhydroxide. Furthermore, even on the PWR  
8 side, you know, the amount of zinc compared to aluminum  
9 in PWRs was fairly small. Now we even assumed a  
10 relatively large amount of zinc for the corrosion  
11 product, and we're dealing now with something on the  
12 order of 47, 48 pounds, compared to hundreds of pounds  
13 in PWR. So it's really an order of magnitude lower, at  
14 least, what we think we have.

15 MEMBER BANERJEE: Do you have zinc  
16 treatment for radiation control?

17 MR. ANDREYCHEK: Zinc treatment. If  
18 you're talking about corrosion control in the plant,  
19 it's something that the plant is designed for. But it's  
20 not part of the current basis. So we don't have any more  
21 zinc, other than the inorganic zinc on the --

22 MEMBER BANERJEE: If you decided to use  
23 zinc, you'd have to go --

24 MR. ANDREYCHEK: Probably an evaluation  
25 under 5059, and we'd have to consider our previous

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 commitments and the analysis that supports that. So if  
2 we need to change it, we would have to go through the  
3 regulatory process.

4 MR. HEAD: Maybe I can just summarize this.  
5 Maybe we can't give you the details of the German  
6 experience, but we certainly have reacted to it. We  
7 have done everything we can to minimize zinc in  
8 containment, and we believe we've conservatively  
9 modeled its impact on the downstream ~~er~~ test. So we've  
10 been reacting to it for the last couple of years.

11 DR. WALLIS: I'd like to pick up on this.  
12 It's being said, Tim said it now, that aluminum  
13 oxyhydroxide had an enormous effect. It had an enormous  
14 effect in the ANL test. It shut down the whole thing,  
15 is what -- it just shut down the whole flow, became  
16 impermeable in that.

17 In the PWR ~~-- our~~ Owners Group tests, some  
18 of the tests you put in a huge amount of aluminum  
19 hydroxide according to the way it was specified to do  
20 it, and the pressure drop didn't rise at all, or it was  
21 very, very little.

22 So in those tests, those tests do not  
23 support the assertion that the aluminum hydroxide is so  
24 tremendous in its effect that nothing else could be so  
25 bad.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MR. ANDREYCHEK: May I respond?

2 DR. WALLIS: You certainly may.

3 MR. ANDREYCHEK: Thank you. I just want to  
4 make sure you're done, that's all, give you the courtesy  
5 of finishing. Those tests, and I don't disagree with  
6 you; you are correct. Those tests were tests where the  
7 --

8 CHAIRMAN CORRADINI: Which are those?  
9 Which those?

10 MR. ANDREYCHEK: The fuel tests, the PWR  
11 fuel debris capture tests.

12 DR. WALLIS: That we saw in May.

13 MR. ANDREYCHEK: That's correct. Many of  
14 those tests were under very high particulate to fiber  
15 ratios, and under those test conditions, based on what  
16 we observed and how we interpreted the data, the fiber  
17 bed was completely saturated with particulates. Bear  
18 with me please; let me finish.

19 And because you have an open lattice fuel  
20 assembly, which has gaps around the sides of the grid  
21 straps, we've had -- the fiber bed was fully saturated  
22 with both particulates, because the particulates  
23 couldn't be captured any more.

24 I mean we ran for a long period of time with  
25 the very high concentration of particulates, the silicon

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 carbide, and the water was still cloudy. We weren't  
2 capturing any more silicon carbide.

3 Then the chemical product was added, and the  
4 fiber bed again being fully saturated, gave us almost  
5 no change in pressure drop, and in some cases it actually  
6 went down a little bit, because we think that we got bore  
7 holes and it worked our way through the fiber bed.

8 DR. WALLIS: You don't know why it went  
9 down, but it went down.

10 MR. ANDREYCHEK: Yes. We don't know  
11 exactly why, but it went down. The question is, the  
12 fiber bed couldn't take the pressure drop --

13 DR. WALLIS: So the aluminum hydroxide had  
14 no effect?

15 MR. ANDREYCHEK: However, to address your  
16 point directly, when we start getting into low  
17 particulate to fiber ratios, if we established a fiber  
18 bed and we started getting smaller amounts of  
19 particulate to fiber, we added the aluminum  
20 oxyhydroxide.

21 We did see an immediate increase in pressure  
22 drop because again, based on our observations and our  
23 interpretation of the data, then the fiber bed was not  
24 fully saturated. You began to collect more of this  
25 aluminum oxyhydroxide, and you've got a pressure drop.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 DR. WALLIS: The pressure drop that you got  
2 when you added these chemicals, sometimes in a huge  
3 amount, was small. It was very small, compared with  
4 what has been found at Argonne, which was tens or more,  
5 so just shut down the whole loop.

6 You've got very small increments of  
7 pressure drop. So it's a myth that aluminum hydroxide  
8 always produces a very high pressure drop, and which is  
9 bigger than anything else you could produce.

10 MR. ANDREYCHEK: I'd take issue with that,  
11 from the standpoint of that it depends upon what you  
12 already have in the fiber bed. That's based on our  
13 experience.

14 DR. WALLIS: Yes, of course it does.  
15 Everything affects everything else.

16 MR. ANDREYCHEK: Right, and --

17 DR. WALLIS: But it does not produce a very  
18 high pressure drop.

19 MR. ANDREYCHEK: We have seen tests where  
20 we've had small amounts of fiber and particulate, we've  
21 added chemicals in it; it shut down our test also,  
22 because we did not have a fully saturated fiber bed.

23 As soon as you start getting chemicals on  
24 the fiber bed that's not saturated, we will get very high  
25 pressure drops.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: I don't understand your logic  
2 at all, that somehow putting the other particles in the  
3 fiber bed prevents the chemicals from having any effect.

4 MEMBER SHACK: Well, if the fiber bed is  
5 dead, essentially impervious, then making it more  
6 impervious --

7 (Simultaneous speaking.)

8 DR. WALLIS: The pressure drops modest even  
9 then.

10 MEMBER SHACK: But I think it's got enough  
11 openings.

12 CHAIRMAN CORRADINI: I guess, I'm  
13 listening to you guys go back and forth, and I think we  
14 have to let the staff come on. His interpretation is  
15 the reason is you've bypassed it.

16 MR. ANDREYCHEK: That's correct.

17 DR. WALLIS: Well Tim, you did a test where  
18 you measured the pressure drop when it's all bypass.  
19 None of your tests with chemicals ever approached that  
20 pressure drop.

21 MR. ANDREYCHEK: I'm sorry. So that one  
22 more time, please?

23 DR. WALLIS: You did tests where all the  
24 flow was bypassed. You actually blocked, blocked the  
25 fuel element and let the flow bypass, and you measured

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 pressure drop versus flow rate. I've seen that test.

2 The flow or pressure drop there was much  
3 bigger than anything that was ever recorded on any of  
4 the tests. So you cannot say that the test reached the  
5 situation where everything was bypassed. We can go  
6 through this in a different meeting, but it's a myth,  
7 it's a myth that aluminum hydroxide always produces a  
8 huge pressure drop.

9 MEMBER BANERJEE: I guess that was the  
10 basis of my question. We go back to the original  
11 question. I'd like to really -- this will never be  
12 completely satisfactorily demonstrated to me, that now  
13 in the PWRs, of course, you have so much aluminum  
14 hydroxide compared to zinc. That's probably not a big  
15 problem.

16 But when you have many zinc and no aluminum  
17 hydroxide, is that using an aluminum hydroxide surrogate  
18 actually conservative compared to using zinc?

19 MR. ANDREYCHEK: The answer is that's,  
20 based on what we know today, that's what we're going to  
21 use. Now, that's not to say that the BWR Owners Group  
22 is doing other work, and they might look at something.  
23 We're going to follow what the industry says, and we'll  
24 take a look at the German test one more time, to see what  
25 it says.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1           But given that we don't have additional  
2 information, and there's no reason to suspect that  
3 there's anything else different, our experience, based  
4 on what we have available, is the aluminum hydroxide,  
5 oxyhydroxide, is the avatar that gives us potentially  
6 the worse pressure drop that we have seen.

7           MEMBER BANERJEE: So since these tests are  
8 going to be done some time in the distant future --

9           MR. ANDREYCHEK: Uh-huh.

10          MEMBER BANERJEE: Really what you're  
11 saying is that you have an undertaking that you will look  
12 at any other industry experience that might point to  
13 having a different surrogate.

14          MR. ANDREYCHEK: That's correct.

15          MEMBER BANERJEE: That's fair enough.

16          MR. HEAD: We've covered that in previous  
17 meetings. We covered it again here.

18          CHAIRMAN CORRADINI: You missed that part.

19          MR. HEAD: We committed to in our, on the  
20 docket and --

21          MEMBER BANERJEE: I was on a plane.

22          MEMBER ARMIJO: Okay. I just wanted to  
23 make sure I have it straight.

24          MR. HEAD: Sir, I'm sorry. Sir, did that  
25 answer your question?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: Yes.

2 MR. HEAD: We really are going to stay  
3 involved with this. If something else comes up that's  
4 more of a challenge, as part of our submitting it to the  
5 NRC for their review, if we're still using aluminum  
6 hydroxide, and that's not the right, most challenging  
7 stuff at that point, clearly the staff would challenge  
8 us on it.

9 MEMBER BANERJEE: Well, I guess it depends  
10 on the taking you have with the NRC at the moment, that  
11 the test procedures and so on will be developed based  
12 on the best available knowledge.

13 MR. HEAD: It will be state of the art,  
14 based on our knowledge at that point in time.

15 CHAIRMAN CORRADINI: Okay.

16 MEMBER ARMIJO: In previous subcommittee  
17 meetings, I think I raised the question and other people  
18 raised similar questions on what form would -- what would  
19 happen with the zinc. The inorganic is basically  
20 metallic zinc in a carrier, and the question was could  
21 it form this kind of gelatinous oxyhydroxide, the same  
22 as aluminum? The question was we really don't know, but  
23 if it did, we're going to assume that it can. But it's  
24 more likely there will be zinc oxide particles, maybe  
25 even zinc metal particles, and some of it will even

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 dissolve, not even in the actual solution.

2 So your alternatives are either to treat it  
3 as something that is, does have a big affect on pressure  
4 drop, as this gelatinous material, and that's what  
5 you've chosen to do. But you could also just test it  
6 as particulate. Also, you can address it by experiment.

7 MR. ANDREYCHEK: The other thing that we've  
8 looked, we started looking at the corrosion products.  
9 Again, this is for PWRs. We used equilibrium chemistry  
10 codes to determine what kind of products we would get.

11 Granted, they're not -- they're in  
12 thermodynamic equilibrium, so we're not looking at  
13 transience. What we saw was that the aluminum  
14 oxyhydroxides tended to be the dominant form. We also  
15 had sodium aluminum silicate and sodium, I'm sorry,  
16 calcium phosphate as products that came out, based on  
17 the constituents that were in PWR containments.

18 And so that was the direction we went in,  
19 and based on additional work that NRC funded, the  
20 aluminum oxyhydroxide appeared to be the worse case  
21 actor for the cases that were studied, and that's the  
22 direction we went in.

23 MEMBER ARMIJO: Okay.

24 MR. HEAD: Let me ask a previous question,  
25 though, that you asked, is that, you know, we don't have

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 to wait until we run a test and go wow, that wasn't the  
2 right constituent. Between the time we get a COL, if  
3 the industry experience says hey, that's not the way to  
4 do something, we can always go back to the NRC and say  
5 we want to change, you know, our commitment and a more  
6 realistic test.

7 MEMBER ARMIJO: Yes. Instead of adding  
8 the zinc as the aluminum hydroxide, we'll add it as zinc  
9 oxide.

10 MR. HEAD: Yes. Future licensing managers  
11 are going to say who did that, but that was not the right  
12 thing to do, and we will want to approach NRC about a  
13 change. That would be a part of us using industry  
14 experience, as this thing evolves.

15 CHAIRMAN CORRADINI: Okay.

16 MR. HEAD: Okay.

17 DR. WALLIS: So back to the point I made  
18 before. The danger is that the industry adopts all  
19 these acceptable methods. Someone who does a realistic  
20 test and it turns out gives a bad result.

21 That reflects on the industry, NRC and  
22 everybody else, and someone has a quandary then. What  
23 are we going to do? When someone's done the more  
24 realistic test, and gee whiz, it's bad. That puts  
25 everyone in a very bad situation, including us. I don't

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 want that to happen.

2 MR. HEAD: I agree.

3 CHAIRMAN CORRADINI: Okay.

4 MS. BANERJEE: But did I hear that you're  
5 going to come back with the German test, take a look --

6 MR. HEAD: No ma'am.

7 CHAIRMAN CORRADINI: No, no, don't do that.

8 MS. BANERJEE: So we're wrapped up in the  
9 industry test experience commitment.

10 MR. HEAD: Yes.

11 MEMBER ARMIJO: Does the staff have that  
12 information on the German test? Let's ask that question  
13 when they come up.

14 CHAIRMAN CORRADINI: Okay. With that,  
15 I'll thank NINA and Associates, and we'll turn to the  
16 staff.

17 MS. BANERJEE: Can we take a little break,  
18 so that I can go and check German --

19 CHAIRMAN CORRADINI: The what?

20 MS. BANERJEE: Dr. Corradini, Dr.  
21 Corradini. Can I go and check this, to see if I have  
22 the TEPCO stuff in here or not?

23 (Simultaneous speaking.)

24 CHAIRMAN CORRADINI: Sure. Can we do it  
25 after the fact? We don't need to do it right now. Let's

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 do it after. Let's do it after. I want to make sure  
2 we get staff before we get too far behind.

3 (Simultaneous speaking.)

4 MR. TAI: Good morning. My name is Tom  
5 Tai. I'm the stand-in PA for Stacey Joseph, who's on  
6 maternity leave. But we are Jim Gilmer of Reactor  
7 System Branch and Greg Makar, who is the containment  
8 integrity and -- I mean containment and coordinate  
9 Mechanical and ~~Engineering Engine~~ Branch.

10 We are basically coming back in here to  
11 recap information that we reviewed and approved. So we  
12 do not have any new information since the last  
13 presentation. So if you have any new questions or old  
14 questions that you want us to revisit, that's why we're  
15 here, and then we have other reviewers in the audience  
16 that might help us. So Jim, with that.

17 MR. GILMER: Okay. Good morning. I'm Jim  
18 Gilmer. I happened to draw the short straw and  
19 presuming a long-term curve for the staff, that we have  
20 all of the appropriate reviewers to give more detail on  
21 any of the staff positions.

22 Most of the bullets you heard earlier from  
23 the Applicant this morning, so we apologize for any  
24 repeat. But feel free to stop me if you want further  
25 elaboration. Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN CORRADINI: I know where it is.  
2 I've got to see it, though. Here.

3 MR. GILMER: Thank you. Long-term core  
4 cooling for the ~~STP SCSA~~ BWR, as provided by RHR and the  
5 high pressure core ... ~~quadrant~~. RHR is pretty much a  
6 miniature of a BWR system. Long-term suppression ~~pool~~  
7 cooling temperatures can be maintained by operating the  
8 RHR in suppression ~~core~~ ~~pool~~ cooling mode.

9 The analysis for containment pressure shows  
10 that it's well below the design value, and the analysis  
11 for core cooling, also has a large margin, because the  
12 vessel water level is always maintained above the top  
13 of the active fuel. Next slide.

14 The staff review approach is consistent  
15 with other reviews, both for the operating plants and  
16 for the advanced reactors. The basic review, I'm sure  
17 that the long-term cooling rule, which is 10 CFR 50.46,  
18 subsection (b)(5), is satisfied, and this review  
19 includes the evaluation of the strainer performance.

20 Downstream effects, I would add, that's  
21 both ex-vessel and in-vessel downstream effects, and  
22 then the chemical effects.

23 DR. WALLIS: When do we get to ask you about  
24 those last two?

25 MR. GILMER: On the ex-vessel and

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 in-vessel?

2 DR. WALLIS: No, no. About downstream  
3 effects and chemicals.

4 MR. GILMER: Oh, downstream effects.  
5 Well, I guess at any time.

6 DR. WALLIS: I read the FSAR, and it said  
7 there that the staff approved the use of these 10 micron  
8 silicon carbide particles as a surrogate.

9 MR. GILMER: I'll defer that one to Greg as  
10 our chemical expert.

11 DR. WALLIS: Well, my understanding from  
12 the PWR Owners Group test is that most of those particles  
13 simply went right through there, the fiberglass, and  
14 were not a proper simulant of particles which would be  
15 bigger or have different effect.

16 The chemical effects, you're not going to  
17 hear this just now, but aluminum hydroxide is cited as  
18 being the worst possible chemical, but then the two BWR  
19 Owners Group, as Tim Andreychek himself said, sometimes  
20 it had a beneficial effect.

21 So the assertion that it's always the worst  
22 possible would seem to be put into question.

23 MR. MAKAR: Just to correct what Tom talks  
24 about in terms of division of engineering, so I'm working  
25 on chemicals and ~~coatings~~ ~~codings~~ for some downstream

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 ex-vessel effects. My understanding is a little  
2 different on a couple of things.

3 One, I'm not able to give a good summary now  
4 of what all that was done, but I know the NRR staff has  
5 looked, has spent a lot of time looking at how beds are  
6 developed and what happens to the particles, and my  
7 recollection is that they have seen a lot of particles  
8 trapped in the fibers, and they don't all -- those 10  
9 micron silicon carbide particles or 10 micron particles  
10 of other materials that have been used don't all pass  
11 through. But sometimes they do.

12 DR. WALLIS: Well, if you make a  
13 prediction, if you actually do the calculation according  
14 to the methods that are standard on the pressure drop  
15 you would get if the particles filled the bed. If you'd  
16 get hundreds of psi. So something must be not quite  
17 consistent.

18 MR. MAKAR: I haven't done any of those  
19 calculations. I'm just talking about their  
20 observations in testing.

21 DR. WALLIS: I think the problem is that  
22 we're learning as we go along, and on an extraordinarily  
23 slow learning curve, about what happens with different  
24 mixtures of stuff in these beds. And as we learn, I  
25 think that the, that new evidence seems to put in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 question some of the old conclusions. Maybe I'll simply  
2 send you a memo, and you can study that.

3 MR. MAKAR: Well, we have some -- with  
4 chemicals, we have some of that learning built into this  
5 for following what's going on with the BWR Owners Group,  
6 and the staff, and I don't think the Applicant either.  
7 But just speaking for the staff, we didn't assert that  
8 it was the worst possible chemical. It's the worst that  
9 we know of and we have observed, where it has had a --

10 DR. WALLIS: It's the worst on some tests,  
11 such as the Argonne tests. Some had an enormous effect  
12 in a small amount. But then there's this new evidence  
13 from the Owners Group test that sometimes it has a  
14 beneficial effect.

15 MR. MAKAR: But in those tests we don't --  
16 (Simultaneous speaking.)

17 DR. WALLIS: I would think that would be a  
18 red flag that's about as big as this building.

19 MR. MAKAR: Well, there's uncertainty, and  
20 if there had been another chemical for surrogate used  
21 in that test, whether it would have had a worst head loss  
22 than the aluminum oxyhydroxide.

23 DR. WALLIS: It's quite possible that I may  
24 deduce things one things one way and you guys may deduce  
25 another. You make a decision. I'm just going to tell

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealgross.com

1 you what I conclude from what I see.

2 MR. MAKAR: Right. But it's because of  
3 this uncertainty about the, about whether the zinc would  
4 actually form a precipitate, what form it would take,  
5 and how that precipitate would behave, that we number  
6 one went with the worst one we know of, and number two,  
7 had the expectation that the test plan will --

8 DR. WALLIS: But now you're not -- now it's  
9 put in question as to whether it is always the worst one,  
10 when you put --

11 MR. MAKAR: It's always been in question.

12 DR. WALLIS: --when you put in silicon  
13 carbide particles at 10 microns. It seems to have no  
14 effect at all. So it would seem that someone should  
15 actually investigate the reality and not guess. In fact  
16 --

17 MEMBER BANERJEE: well, we can separate two  
18 issues. One is the strainers and the other is  
19 downstream effects. In this case, if I understand it,  
20 we are requiring prototypical strainer tests for the  
21 PWRs, as you know. Every PWR has to do prototypical  
22 tests with the strainers, all operating plants, unless  
23 there's some extraordinary circumstance.

24 If I understand it, you're not requiring any  
25 prototypical tests here. You're going to take the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 experience from the German, I mean the Japanese ABWR  
2 test, right?

3 MR. MAKAR: And the BWR Owners Group, as  
4 well as the PWR.

5 MEMBER BANERJEE: Well, but the PWRs, every  
6 time you do something with an existing PWR, you've got  
7 to do a prototypical test, because no two PWRs -- I guess  
8 maybe that's too broad a statement, are still alike, you  
9 know, that you can take everything, you know.

10 We've been through this many, many times,  
11 the Reynolds numbers is that there are detailed  
12 differences. Since we can only depend on experiment,  
13 there is no theoretical basis, the NRR has adopted and  
14 we agree, a sort of set of proof testing, if you like,  
15 of each strainer concept, in prototypical conditions,  
16 with certain very clear guidelines as to how this should  
17 be done. It's to bound the sort of pressure losses.

18 Now maybe these tests that you're talking  
19 about are sufficiently applicable for the strainer, and  
20 there isn't that much debris in this system. Those are  
21 big strainers. So maybe as far as the strainer is  
22 concerned, you might be able to adopt it, and I presume  
23 you've looked at these previous tests and said they're  
24 sufficiently applicable, that we don't need to do any  
25 further testing. Is that the sort of position you've

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 taken with the strainers?

2 MR. WAGAGE: Well, the debris strainers  
3 they are there to hold other particulates, you have to  
4 have fiber. There's only one cubic foot of fiber, that  
5 it's so much easier to strain it. So there, what --

6 MEMBER BANERJEE: That's the reason you  
7 haven't.

8 MR. WAGAGE: Yes. They have also done that  
9 we'll call the Japanese ABWR. They have done testing  
10 using a vertical loop, which has more fiber and even  
11 calcium silicate, and it was a vertical loop. All the  
12 debris settled on the strainer. They calculated the  
13 initial, the head loss.

14 MEMBER BANERJEE: It was the same CDI  
15 strainers that they used?

16 MR. WAGAGE: Yes. Now they had fewer  
17 pockets of the strainer for the testing. But they found  
18 that they had head loss. They used the same head loss.  
19 Also, they don't have any fiber in this case to hold the  
20 debris. So we did not have an issue with --

21 MEMBER BANERJEE: Using those tests.

22 MR. WAGAGE: --debris strainer head loss.

23 MEMBER BANERJEE: You basically accepted  
24 the Japanese test as being bounding? I'm just trying  
25 to understand the logic.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WAGAGE: In this case, there is only one  
2 cubic foot of fiber to spread around so much. There's  
3 no way to argue so much head loss from the fiber and  
4 particulates, and the calculated head loss from RMI  
5 pieces by using (NUREG/CR-) 6808 ~~680E8~~ correlation, that  
6 gave us head loss.

7 So we did not have an issue with the debris  
8 strainer, because of there's minimum fiber monitor to  
9 give head loss, and also they use vertical test loop,  
10 which settle all the debris on the strainer. They  
11 calculated, measured head loss. They used the same head  
12 loss for this.

13 MEMBER BANERJEE: There was an issue, I'm  
14 just going back, because I haven't been here for the last  
15 four meetings. They kicked me off this Committee, okay.

16 There was an issue with void loss giving  
17 pressure waves, which for this particular type of  
18 strainer could put fairly large loads, and might be, you  
19 know, able to cause some problems that might allow RMI  
20 to go through. I sort of vaguely recall this, the sort  
21 of bubble collapse problem. Was that resolved, the  
22 pressure waves coming from that? Because these are very  
23 dense strainers.

24 DR. WALLIS: That was closed at one of our  
25 previous meetings.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 CHAIRMAN CORRADINI: That was closed.

2 MEMBER BANERJEE: If somebody could tell  
3 me.

4 CHAIRMAN CORRADINI: The only thing -- so  
5 let me interject, just so we can move on. Everything,  
6 as far as I know, since I'm a new chairman for this  
7 Committee, everything has been closed, save for the  
8 pressure loss, save for the pressure loss versus flow  
9 rate testing, and the associated test protocol.

10 MEMBER BANERJEE: Okay. So this pressure  
11 wave business was closed.

12 CHAIRMAN CORRADINI: We, the royal "we,"  
13 are okay.

14 DR. WALLIS: It was resolved in a rather  
15 peculiar way, by finding that the strainers behaved in  
16 a plastic way, and therefore they were okay. Now you  
17 mentioned something about --

18 CHAIRMAN CORRADINI: So before we go  
19 scattershot, you guys have about five or six slides.  
20 Why don't you, if you're done with strainers, let's move  
21 on, so we can get to what I think you're going to get  
22 as your myriad of questions, with your downstream  
23 effect. So let's stick with the program.

24 MR. GILMER: With the slide that's up now,  
25 I think pretty much we've, or the Applicant has covered

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 this already. Now in-vessel effects, I'm sure there  
2 will be plenty of discussion on it.

3 The .95 void fraction, you heard earlier  
4 this morning, and staff reviewed the calculation by  
5 audit on several occasions, and we have reasonable  
6 assurance that the calculation is acceptable.

7 MS. BANERJEE: I have some more.

8 MR. GILMER: I believe you asked for the  
9 audit report. We can make that available.

10 DR. WALLIS: Now the audit report is about  
11 the GOBLIN calculation, the K?

12 MR. GILMER: Yes, correct.

13 DR. WALLIS: I will accept that. If it's  
14 about the way that the loop behaves, the downcomer and  
15 the pressure drop through the core. It provides the  
16 pressure drop available through the debris. If it's  
17 about the GOBLIN stuff, I will accept that. That's  
18 okay. That's fine.

19 MR. GILMER: Yes, it is.

20 DR. WALLIS: That's what you audited. You  
21 didn't audit the debris stuff?

22 MR. GILMER: I did not. Did you --

23 CHAIRMAN CORRADINI: We're only talking  
24 about, I think, the criterion by which we determined what  
25 is good and not good.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MR. GILMER: And I believe there were some  
2 documents.

3 DR. WALLIS: K is acceptable. The K for  
4 acceptability is all right by me.

5 MR. GILMER: And staff feels it's a  
6 conservative bounding.

7 DR. WALLIS: It's a standard thing.

8 MR. GILMER: The peak calculated  
9 temperature is well below the fuel melting temperature  
10 that's in 50.46.

11 You heard already about the diverse  
12 injection assertions of ECCS, and multiple pass for  
13 getting water into their core.

14 DR. WALLIS: Do they have a high  
15 probability of success?

16 MR. GILMER: We feel that they do. We've  
17 not done a PRA specifically for this.

18 MS. BANERJEE: You have to go through a few  
19 more pages.

20 DR. WALLIS: Because one way it's showing  
21 that the blockage doesn't matter would be to do a PRA  
22 for these other injection sources, and show that the,  
23 you know, that what's left over is negligible.

24 MR. GILMER: Maybe part of what's been done  
25 in their plant PRA, I'm not familiar with that. So I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 can ask them, but that's a good point. A key in the  
2 safety evaluation is that the fuel test that will be  
3 performed essentially 18 months before fuel is allowed  
4 to be loaded, must satisfactorily demonstrate that.

5 DR. WALLIS: So this is a no-go, this last  
6 one? I mean suppose they do get blockage? They have  
7 to then go back and do something else?

8 MR. GILMER: Yes, that's --

9 DR. WALLIS: That's still a no-go, even  
10 though diverse injection sources and all that stuff?

11 MR. GILMER: It would be a no-go for fuel  
12 load. There are multiple options at that point. You  
13 either reduce the debris source term or --

14 CHAIRMAN CORRADINI: Jim, can you just  
15 repeat that? You answered Graham, but I want to make  
16 sure I'm clear. So can you repeat that kind of from the  
17 beginning.

18 MR. GILMER: Well the fuel tests, which are  
19 essentially part of the license condition, will be no-go  
20 hold point for loading fuel, if they fail to meet the  
21 acceptance criteria. Then we'll have to stop and figure  
22 out what needs to be done.

23 CHAIRMAN CORRADINI: Okay. But what could  
24 be done is they can essentially use other analyses for  
25 their other what we were told to be, which is bypass flows

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 and core ~~flooder flutter~~.

2 MR. GILMER: Yes. The GOBLIN analysis  
3 could be -- the conservatisms could be reduced. That's  
4 probably the cheapest option.

5 CHAIRMAN CORRADINI: Okay. Well, I don't  
6 care if it's cheap. I just want to know what the next  
7 step is, which is if they do these go/no-go tests based  
8 on these assumptions, and it turns out they don't pass,  
9 then they're going to have to deal with some sort of  
10 different analysis or testing.

11 MEMBER BLEY: Which would do the same  
12 thing, yes. It would show low impact on core flow.  
13 Yes, actual core flow, yes.

14 MR. GILMER: Or possibly even ECCS or fuel  
15 design changes. That's unlikely that they would --.

16 MEMBER ARMIJO: Okay, okay. I got it.  
17 I've got to get something on the record. This morning,  
18 the South Texas people reminded us of the March 2011  
19 meeting, and from their Slide 15 they presented a defense  
20 indepth analysis, showing that high pressure core  
21 ~~flooder flutter~~ flow from above the core and fuel  
22 assembly bypass flow each, by itself, can provide  
23 adequate cooling for the core in the event the inlet to  
24 the hot assembly were to plug completely. That's  
25 pretty, a very strong statement.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 DR. WALLIS: Yes.

2 MEMBER ARMIJO: My question is does the  
3 staff, has the staff reviewed or audited these analyses,  
4 and does the staff agree?

5 MR. GILMER: Yes, we have reviewed it, and  
6 we are satisfied this is the GOBLIN calculation that  
7 addresses --

8 MEMBER ARMIJO: Okay. So then if that's  
9 the case, whether the core blocks, whether it's 10 micron  
10 particulates or aluminum hydroxide, I mean basically  
11 Graham's question. If this is true, why does this test,  
12 to be done 18 months before fuel load, why is that even  
13 important? It's nice to do, but if these other things  
14 are reliable, why are we wasting time with all this  
15 stuff?

16 MR. McKIRGAN: If I could, this is John  
17 McKirgan from the staff.

18 MEMBER ARMIJO: Please do.

19 MR. McKIRGAN: In this instance we're  
20 looking at, this is really a licensing issue, and we're  
21 establishing the licensing basis of the plant. These  
22 other mechanisms are valuable information; they provide  
23 defense indepth and the staff is very comfortable with  
24 them.

25 But the licensing basis of the plant must

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 be satisfied before they can load fuel. The Applicant  
2 has proposed and the staff is on the verge of accepting  
3 the fact that this license condition and the curve is  
4 what is establishing the licensing basis, and absent  
5 that, they will not be allowed to load fuel.

6 MEMBER ARMIJO: Why isn't the licensing  
7 basis core coolability --

8 CHAIRMAN CORRADINI: That's their choice,  
9 though. That's the licensee's choice.

10 MEMBER ARMIJO: Okay. So they're taking a  
11 risk.

12 CHAIRMAN CORRADINI: Well, they've made a  
13 decision. They may have to change their decision, but  
14 they've made a decision currently.

15 MR. McKIRGAN: And we've discussed, and as  
16 Jim and the Applicant have both said, should they fail,  
17 there are options, all of which would have to come back  
18 to the staff for review.

19 MEMBER ARMIJO: Okay.

20 MR. GILMER: And essentially, it would  
21 amount to a delay in the initial start-up.

22 MEMBER ARMIJO: Yep.

23 MR. GILMER: And then --

24 MEMBER BANERJEE: How many months before  
25 the loading would these tests be done?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN CORRADINI: 18 months.

2 MR. GILMER: 18 months, and we will see the  
3 test protocol essentially 24 months before they --.

4 ~~MS. BANERJEE: I made a copy.~~

5 MR. GILMER: Okay. Regarding  
6 conservatisms in the ABWR design and the STP-specific  
7 analyses, some of these you heard already. The first  
8 is the reduced likelihood of latent debris generation.  
9 The reasons, in parenthesis, the restricted access to  
10 containment by administrative procedure. The  
11 suppression pool clean-up system and of course the  
12 stainless steel suppression pool, and the operational  
13 program for --

14 MEMBER BANERJEE: Do you agree that for  
15 these tests, latent debris should be all considered  
16 essentially NUKON, rather than hair and stuff like that?  
17 I mean we had an issue with this, with another advanced  
18 plant, where they did some experiments with hair.

19 MR. WAGAGE: Actually, we did that in a past  
20 meeting, the same, communicated the same issue and we  
21 brought up the results for testing for the other advanced  
22 plant. What we showed was that other types of like human  
23 hair and clothing did not matter.

24 MEMBER BANERJEE: It did.

25 MR. WAGAGE: It did, but this was -- what

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 happened with fiber was that you got earlier, but you  
2 got breakthroughs. With the hair, it continued to rise,  
3 and it went on and on and on.

4 MEMBER BANERJEE: So the characteristics  
5 were different. You did not get breakthroughs, you  
6 know, in the downstream effect, the in-vessel effects.  
7 I can show you the graphs.

8 MR. WAGAGE: But I compared the peak --

9 MEMBER BANERJEE: The peak was comparable,  
10 but the characteristics were very different and, you  
11 know, it depends on the type of fuel, because this is  
12 a classically ill-posed problem. If you get a slight  
13 change in conditions, you can get a big change in  
14 results.

15 But to make assurance, doubly-sure, I think  
16 you should probably look at a couple of experiments with  
17 hair, just you know.

18 DR. WALLIS: Well, Sanjoy, earlier we were  
19 told in the Japanese plants, they found ropes and things  
20 like that. There was no fiber in this plant. So  
21 modeling with fiber is a surrogate. What has been found  
22 is ropes, which are made of something else. But you  
23 don't have fiberglass ropes, as far as I know. So maybe  
24 you should look at that.

25 MEMBER BANERJEE: Well, the issue we had

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 before was that if you had cloth and stuff, it would not  
2 maybe degenerate to fibrous form that quickly. So the  
3 main latent debris would probably be, you know, fluff  
4 and hair and other stuff like that. But I mean --. But  
5 you know, with the previous thing, that was okay. I mean  
6 we had no issues ultimately. We agreed to whatever was  
7 presented. So but they did run a couple of experiments.

8 MS. BANERJEE: This is what they --.

9 MEMBER BANERJEE: Yes.

10 MS. BANERJEE: They had different kinds of  
11 tests.

12 CHAIRMAN CORRADINI: Keep on going.

13 MEMBER BANERJEE: Yes, I'm happy. Go  
14 ahead.

15 MR. GILMER: Okay. The next one is a key  
16 advantage for ABWR over conventional BWRs is the  
17 elimination of the large --

18 DR. WALLIS: I wanted to ask a question  
19 about this one cubic foot. I think if I were South  
20 Texas, and I were to come in and say there's no fiber,  
21 therefore there's no fiber, a supposition. For some  
22 reason, someone dreamed up this one cubic foot. Did  
23 that come from you folks or from them?

24 MR. GILMER: The original position, I  
25 believe, was no fiber.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. WALLIS: Why was that not acceptable?

2 MR. GILMER: Well, I think that came from  
3 our first meeting with the ACRS.

4 MR. WAGAGE: Actually, originally these  
5 approved BWR had so much fiber, and South Texas came up  
6 with their design, and they removed all the fiber, and  
7 they came up and said that we have zero fiber in the  
8 containment.

9 And we asked the question: What happen if  
10 you find some fiber in the containment later on? Then  
11 you are outside the licensing basis, and that would be  
12 a major issue. To avoid that major issue, they assumed  
13 one cubic foot of fiber to consider any amount of fiber  
14 they might find.

15 But they have containment clean-up, cleaning program --

16 DR. WALLIS: But why was it one and not two,  
17 or a half or .1 or something else?

18 MR. WAGAGE: Actually, the question might  
19 come. Even if they assume two, then we might have a  
20 question why not three?

21 (Laughter.)

22 DR. WALLIS: Well, it may well be. It may  
23 well be.

24 (Simultaneous speaking.)

25 DR. WALLIS: But three is bad.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. WAGAGE: The issue was that they did not  
2 have any fiber, but when they raised the question that  
3 how do you have any licensing issues later on, they  
4 assumed one could be good for fiber. We tested to our  
5 latent fiber --

6 MEMBER BANERJEE: That is latent fiber,  
7 isn't it? Is that latent fiber?

8 MR. WAGAGE: Yes, this is latent fiber,  
9 yes. Latent fiber --

10 MEMBER BANERJEE: That doesn't seem  
11 unreasonable.

12 MR. GILMER: So thank you.

13 (Laughter.)

14 CHAIRMAN CORRADINI: What is the "that"?  
15 The that that is zero, or that that is one?

16 MEMBER BROWN: One cubic foot.

17 MEMBER BANERJEE: I mean what is the  
18 experience in those Los Alamos swabs and all that? Do  
19 you remember?

20 MR. WAGAGE: You see, they had their  
21 different amount of fiber because for URG calculations,  
22 because they assumed the containment --

23 MEMBER BANERJEE: The latent, you know,  
24 those experiments that were done for latent fiber,  
25 remember? It wasn't a particularly clean containment,

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 but I'm trying to recall. Wasn't it --

2 DR. WALLIS: PWR?

3 MEMBER BANERJEE: Yes.

4 DR. WALLIS: In the PWR?

5 MEMBER BANERJEE: Yes, the PWRs, not BWRs.

6 MR. WAGAGE: Yes. I don't remember exact  
7 number. They assumed certain number on the fiber. But  
8 this containment is different, this has --

9 DR. WALLIS: Much smaller.

10 MR. WAGAGE: Smaller and containment  
11 cleanliness program. It has suppression pool  
12 cleanliness program. It has control of many fibers  
13 getting into the containment.

14 MEMBER BLEY: I seem to remember at an  
15 earlier meeting, it might not have been for this plant,  
16 that somebody on staff brought in a set of reports of  
17 inspections of containments, in which transient  
18 materials were found after the containment had been  
19 cleared, and used that as something of a basis for the  
20 thing. Do you guys remember that?

21 CHAIRMAN CORRADINI: But I think --

22 MEMBER BANERJEE: Those were PWRs.

23 CHAIRMAN CORRADINI: So let's just, let's  
24 just back up. I want to make sure we stay on track.  
25 Before you were here, we had this discussion with the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 STP folks.

2 MEMBER BANERJEE: Why do you ask me to come?

3 CHAIRMAN CORRADINI: Well, we anticipated  
4 your arrival with great expectation, but we proceeded  
5 anyway, and when STP discussed this, there was actual  
6 experience from KNK 6 and 7, where they've actually  
7 collected and analyzed what's there. That's what  
8 Graham referred to.

9 So we're going to get a document. One of  
10 the things that we agreed to from STP is we're going to  
11 get a summary document of what was seen there as the  
12 technical basis for the one, what would make up the one  
13 cubic foot.

14 MEMBER BANERJEE: Fair enough.

15 MR. GILMER: Okay.

16 DR. WALLIS: Well, I would just recall,  
17 Dick Skillman is not here. When he was here, he said  
18 that he actually ran reactors, that they found sawdust,  
19 for instance, in containment. Someone had cut  
20 something when they were doing something, and there was  
21 the sawdust.

22 CHAIRMAN CORRADINI: That's the Navy  
23 built. That isn't our experience.

24 DR. WALLIS: No, no, no. It was Texas.

25 (Simultaneous speaking.)

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: It's either a commercial ship  
2 or a commercial plant. That's where he's at.

3 DR. WALLIS: Well, the one cubic foot seems  
4 a little suspicious. If they'd been Europeans that have  
5 said .1 cubic meter or something, you know. It's just  
6 a number, and we asked this morning that they be more  
7 justifiable, that there be more justification for it,  
8 because just one looks like something, you know.

9 MEMBER BANERJEE: Well, it's probably .1,  
10 but they put it --

11 DR. WALLIS: If you can justify that it's  
12 never been measured above .1 and it's no longer, that  
13 would be --

14 MEMBER SHACK: Well, it just puts them at  
15 risk. If they find more than one, they're going to have  
16 a problem.

17 MEMBER STETKAR: That's right. That's all  
18 it is.

19 DR. WALLIS: That's all it is?

20 MEMBER STETKAR: They've shown that they  
21 can live with one. If they ever find more than one, they  
22 have a big problem in the licensing world.

23 DR. WALLIS: This more than is a real  
24 question, because BWR Owners Group test, it turned out  
25 that more particles was better. More particles

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 produced less flow, less pressure drop.

2 (Simultaneous speaking.)

3 MEMBER BANERJEE: But you know, if you  
4 really look at this, one cubic foot comes out to be a  
5 couple of grams for assembly.

6 DR. WALLIS: Something like seven grams for  
7 assembly or something like that.

8 MEMBER BANERJEE: Is it as much as seven?

9 DR. WALLIS: I'm thinking it's less than  
10 that, less than that. It's a very, very --

11 MEMBER BANERJEE: Yes.

12 MR. WAGAGE: About one.

13 MEMBER BANERJEE: So I mean I think they are  
14 quite far away from any boundaries, and they could  
15 probably relax this, and say you can have three.

16 CHAIRMAN CORRADINI: But I don't think we  
17 should tell -- I mean --

18 MEMBER BANERJEE: That's up to them.

19 CHAIRMAN CORRADINI: That's up to them.

20 MEMBER SHACK: We're not designing a licensing  
21 argument for them.

22 CHAIRMAN CORRADINI: No. That's their  
23 job.

24 MEMBER BANERJEE: A lot of conservatism  
25 there, yes. That's all I'm saying.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 CHAIRMAN CORRADINI: It's their strategy.  
2 They have to own it, not ours.

3 MR. GILMER: As I started saying, ABWR has  
4 a big advantage over operating BWRs, in that the large  
5 recirculation piping is eliminated by having internal  
6 pumps. Also by design, there are no breaks, or all  
7 breaks are above the top of the active fuel, so the core  
8 remains covered.

9 All corroded aluminum and zinc is assumed  
10 to precipitate in gelatinous form, and there are ABWR  
11 design features that minimize the transport of actual  
12 and generated debris. By that I mean like RHR takes a  
13 suction ~~section~~ from the suppression pool, which is a  
14 closed volume.

15 There are a couple of very torturous paths  
16 for like a steamline breakthrough that would require  
17 some flooding or cascading or gravity would get it into  
18 the suppression pool. The diversity of ECCS delivery  
19 locations, the various water systems and water sources,  
20 and most of those sources are also closed for core  
21 ~~flooder flutter~~, high pressure core ~~flooder clutter~~  
22 tank.

23 ~~Clutter~~ Flooder tank and piping, and you  
24 heard already many times about the factor for  
25 conservatism built into the GOBLIN analysis.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 CHAIRMAN CORRADINI: So let me ask a  
2 question here, and I'm not sure if I'm ahead of you in  
3 the slide. So if it's later, you can just postpone it.  
4 I think the question we ended up with STP was that we  
5 wanted to learn enough about the test protocol that we  
6 were comfortable with, to the extent that we understand  
7 what the limit is and how the limits folds into a line,  
8 and the line is decreased by a factor of four because  
9 of this and that.

10 What I think we were left with is we wanted  
11 to make sure the test protocol was acceptable, and  
12 detailed enough that you found it acceptable. So my  
13 question is what are the elements of the test protocol  
14 that were key to you that you found it acceptable?

15 Because I sense that Dr. Wallis is still  
16 unclear. So what made it clear for you, because I think  
17 in some sense we're still ruminating about the test  
18 protocol. That's why we're asking to look at some  
19 additional documents.

20 What were the sufficient conditions that  
21 allowed you to say that this was a good test protocol  
22 going forward at this point?

23 MR. GILMER: From my perspective on  
24 downstream --

25 CHAIRMAN CORRADINI: And if not now, if you

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 have it in a later slide, that's fine. But I just wanted  
2 to make sure we cover that.

3 MR. GILMER: All right. We can talk about  
4 it now. The GOBLIN calculation, I think used a natural  
5 circulation flow rate of about three feet per second,  
6 or a velocity of three feet per second, and that test  
7 protocol does essentially start with that.

8 DR. WALLIS: Three feet per second.

9 MR. GILMER: I'm trying to remember from  
10 two years ago, so I may be wrong. But Westinghouse can  
11 correct me, but that's my recollection.

12 MEMBER BANERJEE: It is a flat temperature  
13 limitation, like 800 degrees or something that they're  
14 trying to meet, or is it a quality criteria? What is  
15 the real thing there?

16 MR. GILMER: Well, the long-term **cooling**  
17 ~~fueling~~ regulation is related to the --

18 DR. WALLIS: The velocity in the PWR test  
19 is .2 feet per second. I think you are thinking about  
20 three gallons per minute or something like that.

21 MR. GILMER: I could be wrong on that.

22 MEMBER BANERJEE: But usually there is a  
23 criteria they're trying to meet, right?

24 DR. WALLIS: In the PWR, it's something  
25 like 304 gallons per minute per assembly. It's gallons

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 per minute, the way they express it, and it turns out  
2 to be I think about 0.2 feet per second.

3 MEMBER BANERJEE: It sounds reasonable,  
4 but that meets some criteria in terms of clad  
5 temperature, right?

6 DR. WALLIS: Boiloff.

7 MEMBER BANERJEE: 800 degrees? What is  
8 that?

9 DR. WALLIS: Boiloff, I think, is the --

10 MEMBER BANERJEE: No. It's --

11 MEMBER SHACK: In terms of quality, they  
12 were going to go from 0.95.

13 MEMBER BANERJEE: No. Before the APWR or  
14 whatever -- not the APWR; AP-1000, if I can say the word,  
15 we ended up with an outlet quality criteria which  
16 translated back to all sorts of things, right?

17 DR. WALLIS: And it started off as boiloff,  
18 and then it got backpacked to 0.95 quality or something.

19 MEMBER BANERJEE: 0.5, 0.5 quality, I think.  
20 0.95 void fraction.

21 So that was -- and that backed out to some  
22 clad temperature lack of wherever. So here, that's the  
23 question. Is it something equivalent to that that  
24 you're trying to achieve by these criteria?

25 I mean then you can back out the pressure

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 loss, which gives you this quality, you know, or if it  
2 can be traced back, and then the available head, wherever  
3 this pressure loss, should give you the slope. I'm just  
4 wondering how you establish it?

5 MR. GILMER: To some degree, it's part of  
6 the thermal properties of the crud buildup on the fuel  
7 rods, but I believe --

8 MR. MAKAR: Part of their in-vessel  
9 analysis is looking at the effect on peak clad  
10 temperature of depositing all of the debris that we  
11 discussed for this plant, including chemicals, on the  
12 fuel and seeing the physical dimensions of that and the  
13 temperature. That's part of the --

14 MEMBER BANERJEE: Yes, but part must also  
15 be that you don't want dryout, extended periods of  
16 dryout, right? So you have to have a certain quality.

17 CHAIRMAN CORRADINI: But that's why -- just  
18 to interject. That's why they've picked .95 as the void  
19 fraction. That is way below the point of dryout. So  
20 I mean --

21 MEMBER BANERJEE: Well, they must have  
22 justified that in some way.

23 CHAIRMAN CORRADINI: But I think my answer,  
24 as you asked the question, the step I answer back is they  
25 back out essentially what you're asking for, is given

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 .95, there's some sort of, with some margin, a bound to  
2 dryout. They look at essentially the flow rate that  
3 allows that.

4 MEMBER BANERJEE: It seems quite  
5 reasonable. But what I'm saying is have the staff  
6 looked at that, and agreed that this is an appropriate  
7 criteria, that whatever the outlet quality or void  
8 fraction is will guarantee that the fuel, you know,  
9 stays, if it's exposed for a long time to temperatures,  
10 which I don't know what they are. Is it 800 degrees?  
11 What is the temperature you're shooting for, for  
12 long-term dryout situation?

13 MR. MAKAR: I don't know what this  
14 Applicant used as a criteria for an upper temperature,  
15 but I don't think that was the main criteria for  
16 long-term cooling.

17 MR. GILMER: No, because it was well below  
18 even the 800. So we were not concerned.

19 MEMBER BANERJEE: So you just said we don't  
20 want dryout? What was the --

21 CHAIRMAN CORRADINI: I think they said .95  
22 was acceptable.

23 MEMBER BANERJEE: Huh?

24 CHAIRMAN CORRADINI: I think all they said  
25 was .95 is acceptable.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: But why?

2 CHAIRMAN CORRADINI: It's way below -- I'm  
3 not going to answer for them. I'm sorry.

4 MR. McKIRGAN: Could you go back one slide  
5 please, Tom? Could you go back to a previous slide for  
6 us? It's Slide 5. So Jim, perhaps maybe we went too  
7 quickly through this slide. But the first bullet there  
8 talks about the .95 void fraction. The next bullet  
9 talks about staying below the criteria of 50.46.

10 MEMBER BANERJEE: Yes, okay. But that is  
11 really -- and what is that? Can you remind me that  
12 criteria, 50.46? Is it 800?

13 CHAIRMAN CORRADINI: It's a 2,200 number.

14 MEMBER BANERJEE: It's a 2,200 number?

15 CHAIRMAN CORRADINI: Yes. They're  
16 nowhere close to it.

17 MEMBER BANERJEE: No, no. But that's not  
18 what other applicants have used.

19 MR. McKIRGAN: No. But I think we need to  
20 be mindful again, this is Jim McKirgan for the staff.  
21 Everyone is introducing significant conservatisms, to  
22 make sure they maintain margin for operability  
23 considerations.

24 So we will see a range of temperatures from  
25 a number of applicants, all of which have to stay, of

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 course, below the regulation of 2,200. So I don't  
2 recall and I don't know if the staff has exactly what  
3 this applicant is using, but they are all well removed  
4 from the limit.

5 MEMBER BANERJEE: Okay. So I mean 2,200,  
6 of course, is way high. But most applicants that I'm  
7 familiar with have, you know, for a prolonged exposure,  
8 they've accepted a much lower temperature, and but  
9 they're shooting for a much lower temperature.

10 That leads to a criteria like that .95,  
11 which may be equivalent to 50 percent quality or 30  
12 percent quality. I don't know; whatever that number is.

13 DR. WALLIS: I thought it was 800 degrees  
14 Fahrenheit.

15 MEMBER BANERJEE: It's usually 100  
16 degrees. That's what they shoot for. I mean --

17 CHAIRMAN CORRADINI: So I want to make sure  
18 we're on track. So are you asking the staff what was  
19 their basis to accept the .95, or are you asking STP?

20 MEMBER BANERJEE: I'm asking the staff why  
21 did they accept that?

22 MR. GILMER: Well, we'll look at the 2,200  
23 in the regulation.

24 MEMBER BANERJEE: That's very unusual. I  
25 mean for this long-term cooling, you accept 2,200

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 forever as the criteria?

2 MR. GILMER: Well, only because they were  
3 substantially below that, basically saturation.

4 MEMBER BANERJEE: Yes. But in previous,  
5 if you look back, in previous NRR or maybe even NRO, I  
6 thought that number was around 800.

7 MR. MAKAR: This, for the analysis that  
8 this applicant did for that issue, the temperature rise  
9 from depositing the material on tubes, I don't know what  
10 their criteria is. I can tell you it was a small  
11 incremental increase, and I don't know if it's  
12 proprietary for us to discuss the specific temperatures.

13 MEMBER BANERJEE: Oh, this is not closed at  
14 the moment?

15 CHAIRMAN CORRADINI: No.

16 MR. MAKAR: But they did an analysis like  
17 that, and it's much less than --

18 MEMBER BANERJEE: Yes, because the case  
19 that I'm talking about is very different from this case,  
20 because there is issues with boron depositions and all  
21 that that occur, and that's what limits the outlet  
22 quality. So maybe we can't speak of it freely here, but  
23 that's the reason.

24 MR. MAKAR: I don't have, from my area, a  
25 good understanding of that, the relationship between

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 that analysis of the deposition of the materials on the  
2 fuel and the temperature and --

3 MEMBER BANERJEE: Which is what limited the  
4 outlet quality. But it leads to a void fraction  
5 probably close to this or even higher than this. This  
6 could be just as limiting. So this is dictated by  
7 deposition on the fuel, this .95, or how did it come  
8 about?

9 MR. GILMER: Well, kind of indirectly, the  
10 thermal properties of the crud is included in the GOBLIN  
11 model. So it's being accounted for in the calculation.

12 MEMBER BANERJEE: So this is a prediction  
13 from GOBLIN, that you need to stay below .95?

14 MR. GILMER: Right.

15 MEMBER BANERJEE: And then your fuel  
16 remains at whatever temperature.

17 CHAIRMAN CORRADINI: Far below 2,200.

18 MEMBER BANERJEE: Far below.

19 (Simultaneous speaking.)

20 CHAIRMAN CORRADINI: Okay, let's move on.

21 DR. WALLIS: Can I ask you about the debris?  
22 We have a table here of 195 pounds of sludge, 150 pounds  
23 of dirt and so on. I think in the PWR Owners Group test,  
24 all this stuff was represented by 10 micron silicon  
25 carbide.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1                   Now I've gathered from the FSAR, that you  
2 guys were going to -- it says here that you were going  
3 to accept this silicon carbide as the surrogate for all  
4 the debris. Is that still your position?

5                   MR. MAKAR: It's not all the debris. It's  
6 all the particulate --

7                   DR. WALLIS: All the particulate debris is  
8 modeled as silicon carbide with 10 microns?

9                   I really question that surrogate being used  
10 in this way. I think the properties are just, of the  
11 real debris is quite different. It will interact  
12 differently with the fiberglass, and it would act  
13 differently with the chemicals.

14                   I think it's being accepted by some sort of  
15 historical precedent, that someone at some time in the  
16 remote past proposed this, and it wasn't really  
17 questioned. But then it looks, from my end anyway,  
18 looking at the BWR Owners Group data, as if it should  
19 be questioned.

20                   So I'm questioning it, and then asking the  
21 staff to look closely at it.

22                   CHAIRMAN CORRADINI: Does the staff have  
23 any comment back to Graham?

24                   MR. MAKAR: Well, I'll speak and Henry, if  
25 you want to add anything, please do. But yes, it's -- I

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 would say we're trying to be consistent with staff  
2 guidance on what's been accepted previously. You're  
3 right about that.

4 DR. WALLIS: It's an EPRI recommendation.  
5 The staff accepted it, and assuming it was conservative  
6 to use small particles, without thinking perhaps that  
7 small particles have an easier time going through the  
8 fiberglass than big particles, and there may be that new  
9 evidence needs to be considered in accepting this.

10 So I'm just asking you to do that before the  
11 18 month test gets started.

12 MEMBER ARMIJO: Well, that's a generic  
13 question, right?

14 DR. WALLIS: Well I know --

15 MEMBER ARMIJO: And that's not -- I think  
16 it will be looked at continually.

17 DR. WALLIS: Well, it's more frightening,  
18 perhaps, than the South Texas one.

19 CHAIRMAN CORRADINI: Well I mean Graham, I  
20 guess I'm kind of with Sam on this. What you're asking  
21 here kind of in some sense transcends STP. You're  
22 concerned about the use of surrogates generally, not  
23 just here.

24 DR. WALLIS: Yes, but in this context, it  
25 makes sense, because they have given us these large

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 numbers of debris, which are not silicon carbide  
2 particles.

3 MEMBER SHACK: Yes. I think one of the  
4 differences here is that they won't have much of a bed.  
5 There won't be much filtering. I mean you can make an  
6 argument in other cases, larger particles are likely to  
7 be filtered by the bed here.

8 CHAIRMAN CORRADINI: Filtered by the bed.

9 MEMBER SHACK: All of it, yes.

10 CHAIRMAN CORRADINI: On the strainer, you  
11 know. Filtered by the strainers themselves.

12 MEMBER SHACK: Filtered by the strainers.  
13 I mean here, everything is going to --

14 MEMBER ARMIJO: Go right through.

15 MEMBER SHACK: Come through. You know,  
16 there's not --

17 MEMBER BANERJEE: The fact is except to  
18 keep the RMI out, the strainer is not going to stop the  
19 fiber.

20 CHAIRMAN CORRADINI: That's true, but  
21 that's what they've assumed.

22 DR. WALLIS: They assume it all gets  
23 through?

24 CHAIRMAN CORRADINI: Right. So I'm  
25 struggling as to what, what are you asking the staff?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Your comment is you're concerned about the use of  
2 surrogates. But are you asking the staff to --

3 DR. WALLIS: But I'm specifically bothered  
4 by replacing all of the stuff. For instance, the sludge  
5 which I say, and rust was known to produce unexpected  
6 effects at Barseback, with silicon carbide, very small  
7 particles, which have different physical properties  
8 altogether. It seems as if in the Owners Group test,  
9 a lot of them simply went right through the fiberglass  
10 without being stopped at all.

11 MR. MAKAR: Well, we do have to use a  
12 surrogate. I mean it would be smart to use the rust  
13 sludge, but it can't be done. The material doesn't  
14 exist and may never. We don't know what we'll find when  
15 --

16 DR. WALLIS: Doesn't it exist in some type  
17 of --

18 MEMBER ARMIJO: Greg, you can make iron  
19 oxide real easy. Reactors do it every day.

20 MR. MAKAR: It may be under different,  
21 slightly different water chemistry. Is it -- does it  
22 have exactly the same properties as what they will really  
23 find?

24 MEMBER ARMIJO: I think its properties are  
25 better, more representative than silicon carbide, even

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 if it's a bad iron oxide, you know. It just seems to  
2 me that you try to be as prototypic as you can.

3 DR. WALLIS: I disagree with you entirely.  
4 You say it can't be done. There must be a basis for  
5 saying there is sludge there and there is dust there.  
6 So someone must have found sludge there, someone must  
7 have found dust there. Take that stuff and use it.

8 MR. MAKAR: And the rusty sludge is really,  
9 it is like a -- it's particles mixed with a lot of water.  
10 It's like when you take sand at the right consistency.  
11 You pick it up and it flows like --

12 DR. WALLIS: You have it, you have it. You  
13 don't need much of it for one assembly. I disagree with  
14 your statement you cannot use the right stuff.

15 MEMBER SHACK: Well, you certainly can use  
16 a distribution of sizes of particles, whether they're  
17 silicon carbide or not.

18 MR. MAKAR: Yes, yes, and we can --

19 DR. WALLIS: Yes. But it introduces a  
20 whole lot of new problems when you use a surrogate, and  
21 the fact that you know it's there means that it's there,  
22 and you can pick it up and use it.

23 MEMBER BANERJEE: How did we arrive --  
24 Bill, do you remember, at silicon carbide as a surrogate?

25 MEMBER SHACK: I think --

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MEMBER BANERJEE: There's a long history.

2 CHAIRMAN CORRADINI: I'll let the staff  
3 give their shot.

4 MEMBER BANERJEE: Yes.

5 MR. MAKAR: Well, it's not the only  
6 surrogate that's been accepted.

7 CHAIRMAN CORRADINI: Walnut dust.

8 MR. MAKAR: Walnut dust, tin powder,  
9 acrylic powders. It depends on the -- some licensees  
10 have used acrylic powders for coatings. Some have used  
11 other small particles, and the size range was just taking  
12 coatings, for example, looking at what's the range of  
13 chip sizes and what's the range of particles, the  
14 smallest constituents of that coating.

15 It's a little different for epoxies and  
16 inorganic things. So the staff has looked at the  
17 different materials and what different sizes they are,  
18 and what would be acceptable as a surrogate. So silicon  
19 carbide was one of the materials that, as Professor  
20 Wallis said, years ago that the staff --

21 MEMBER SHACK: You know, it doesn't  
22 dissolve and it's readily obtainable in a wide variety  
23 of sizes.

24 MEMBER ARMIJO: And it's inert, inert in  
25 that environment, right? So the particle sizes stay the

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 same.

2 MEMBER SHACK: But I think what the SC on  
3 the NEI document actually says is that you can use, the  
4 fine particles are assumed to be conservative if you have  
5 a fibrous bed. If you don't, then you're on a  
6 plant-specific basis, supposed to justify your choice  
7 of particles. Here, you could make the argument that  
8 they would have to do some sort of a justification of  
9 particle size at least, and particle characteristic.

10 DR. WALLIS: Well, rust flakes. I mean  
11 flakes presumably are not round things. They're more  
12 likely to get stuck, probably.

13 (Simultaneous speaking.)

14 CHAIRMAN CORRADINI: Other comments?

15 MEMBER BANERJEE: Your concern is with the  
16 in-vessel test.

17 CHAIRMAN CORRADINI: His concern is with  
18 what we're going to get as a summary of what will be the  
19 actual materials and inventories and sizes, and those  
20 that they choose to have surrogates, the justification  
21 for the surrogates. Not just inventory, but size  
22 distribution and surrogate composition.

23 MEMBER BANERJEE: For the in-vessel.

24 CHAIRMAN CORRADINI: For the in-vessel.

25 MEMBER BANERJEE: You're not worried about

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 the strainers.

2 CHAIRMAN CORRADINI: Nope, nope.

3 MEMBER BANERJEE: Or are you worried about  
4 the strainers?

5 DR. WALLIS: Those strainers are no longer  
6 part of the conversation.

7 CHAIRMAN CORRADINI: Were not part of the  
8 -- we're talking about downstream effects.

9 MEMBER BANERJEE: Downstream effects, all  
10 right.

11 MR. MAKAR: Right, and I would like to just,  
12 for the record, be clear that yes, we were looking at  
13 surrogate materials, to try to be -- we were, yes. We  
14 were accepting surrogate materials on ones that were  
15 consistent with existing staff guidance, rather than  
16 looking for real materials instead of surrogates.  
17 That is correct.

18 MEMBER BANERJEE: I guess the problem is  
19 that we haven't really done a lot on downstream effects  
20 in BWRs yet. We've looked at the BWRs, and we understand  
21 what's going on a little bit. But the materials are  
22 somewhat different.

23 As long as the idea is that whatever we  
24 learn, frankly incorporate into these tests, which will  
25 be happening some time in the future, that seems

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 reasonable, because we're going to have some testing for  
2 that, right?

3 CHAIRMAN CORRADINI: Other questions for  
4 the staff on this?

5 MR. GILMER: Okay. This next slide is an  
6 attempt to refresh your memory. As you heard  
7 previously, also for the benefit of the members that have  
8 not heard before, there is in the safety evaluation for  
9 FSAR Appendix 6C, a license condition that the staff felt  
10 it was needed, because well first, the STP COLA, the COL  
11 application, essentially incorporates the certified  
12 design by reference, that there are --

13 Well, there's one significant departure is  
14 the **casset**-type strainer, as opposed to the stacked disk  
15 conventional GE strainer design. So essentially then  
16 we had to address the GSI-191 because of that departure.

17 This license condition is intended to  
18 ensure that whatever fuel is loaded will perform  
19 satisfactorily with debris blockage. I should say that  
20 that blockage was never considered in the original  
21 certification, because the issue did not emerge for BWRs  
22 at the time of certification.

23 The proposed license condition includes  
24 test acceptance criteria, which you've heard already,  
25 that must be met for any type of fuel that's going to

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 be loaded for --

2 DR. WALLIS: When is this likely to happen?  
3 I mean we've got two years here. We've got six months  
4 prior to testing and then 18 months prior to load. When  
5 is load expected to happen?

6 CHAIRMAN CORRADINI: That's undetermined.

7 MR. GILMER: Yes, currently undetermined.

8 DR. WALLIS: Well if it's in three years,  
9 then we don't have much time to --

10 CHAIRMAN CORRADINI: It's undetermined.

11 MR. GILMER: For other reasons, it's  
12 undetermined.

13 DR. WALLIS: So it's not something that's  
14 around the corner?

15 CHAIRMAN CORRADINI: No.

16 MS. BANERJEE: Definitely not.

17 DR. WALLIS: So we can keep on not knowing  
18 much about debris for a few more years.

19 CHAIRMAN CORRADINI: The evolution may  
20 take -- there will be evolution in other fields faster.

21 MR. GILMER: I'm sure the Applicant hopes  
22 it will be this decade.

23 MEMBER ARMIJO: With this license  
24 condition, let's say the initial core fuel is put in  
25 there; it's tested. It meets the acceptance criteria.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 Then they want to put in a reload of a different fuel  
2 design. Would this license condition require them to  
3 repeat those tests?

4 MR. GILMER: Yes.

5 MEMBER ARMIJO: And meet the acceptance  
6 criteria of those tests. So they are forever more  
7 having to repeat those tests. Even --

8 CHAIRMAN CORRADINI: Well, let me just  
9 generalize it though, because I think Sam's point is  
10 correct. But that would be the case for any of the  
11 plants.

12 MEMBER ARMIJO: They'd have to pass a test?

13 CHAIRMAN CORRADINI: If they have a  
14 different fuel type, they will have to show long-term  
15 cooling capabilities. This is not just specific to the  
16 ABWR. The AP-1000, if they change the fuel type, they'd  
17 have to redo it.

18 MEMBER ARMIJO: Strange licensing  
19 conditions.

20 CHAIRMAN CORRADINI: The ESBWR, they'd  
21 have to do it. That's my interpretation, as I  
22 understand the --

23 MR. GILMER: And the staff agrees with  
24 that. We'd expect submittal of a topical report that  
25 would address this issue.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 MEMBER ARMIJO: Well, submitting a topical  
2 report is one thing. But having to do an acceptance test  
3 over and over and over, using unrealistic surrogates,  
4 using artificial conservatisms. It seems to me it's not  
5 performance-based. It's certainly not risk-informed,  
6 and it's just strange.

7 MS. BANERJEE: Can I add something?  
8 Didn't the Applicant commit to doing this, the analysis  
9 that they're going to send to you 24 months in advance,  
10 with the fuel that they're going to be loading in the  
11 first batch?

12 MR. GILMER: That's correct, and we've  
13 already received some of the topical reports, which I  
14 believe ACRS wants to have presentations on in the  
15 future.

16 MR. McKIRGAN: But Jim, if I could clarify.  
17 Those actions are not part of the current licensing  
18 action, what we're doing now.

19 MR. GILMER: That's correct.

20 MR. McKIRGAN: SER does not speak to this.

21 CHAIRMAN CORRADINI: This is different?

22 MR. McKIRGAN: That is a different  
23 licensing action that the Committee will have an  
24 opportunity to engage on.

25 CHAIRMAN CORRADINI: Okay.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 MR. GILMER: That's correct. That's  
2 basically to stay ahead of the game, on the schedule.

3 CHAIRMAN CORRADINI: Right, okay.

4 MR. GILMER: The two commitments that are  
5 now in the FSAR, you heard previously about the order  
6 kind of doesn't make sense now, because the first  
7 Commitment 61 was there in earlier revisions of the FSAR,  
8 and the second one was added, after discussion with  
9 staff, that we want to see the test protocol before the  
10 tests are started.

11 So it would make more sense to have them  
12 written in reverse order. But the current revision  
13 leave just the way it is. Okay. Next slide.

14 MEMBER BANERJEE: Are there any downstream  
15 effects tests being planned for the BWR Owners Group that  
16 you know of?

17 MR. GILMER: I believe the tests start in  
18 2013. Correct me if I'm wrong, Greg.

19 MR. GILMER: 2013-2014 time frame, and the  
20 proposed fuel for STP is one of the fuels that will be  
21 in that test area.

22 Okay. So in summary, the staff has  
23 reasonable assurance that adequate core cooling can be  
24 maintained, to meet long-term cooling requirements, and  
25 the containment pressure and temperature are maintained

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 below design value, and STP therefore meets 10 CFR 50.46,  
2 subsection (b) (5).

3 DR. WALLIS: If you have this conclusion,  
4 why do you need any tests?

5 MEMBER BANERJEE: Subject to --  
6 (Simultaneous speaking.)

7 MR. GILMER: There should be an asterisk.  
8 Subject to --

9 CHAIRMAN CORRADINI: It's subject to  
10 satisfactory performance of the tests.

11 MEMBER BANERJEE: Subject to the  
12 conditions, license conditions being met.

13 CHAIRMAN CORRADINI: Yes.

14 MR. GILMER: Any other questions or  
15 discussion?

16 CHAIRMAN CORRADINI: So let me -- two  
17 things for the Committee. So one, I want to make sure  
18 we get public comment, time for public comment, and two,  
19 there is another subcommittee meeting starting in this  
20 room in 50 minutes. So --

21 MEMBER BANERJEE: Which one is that?

22 CHAIRMAN CORRADINI: Well, that chairman  
23 will talk to you about that. But I just want to make  
24 sure of the time frame. So first, comments from the  
25 Committee to the staff. Otherwise, can we ask somebody

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1 in the control room to turn on the bridge line, see if  
2 there's comments from the public?

3 MS. BANERJEE: I'll make sure.

4 CHAIRMAN CORRADINI: Okay.

5 MS. BANERJEE: There were three members on  
6 the line.

7 CHAIRMAN CORRADINI: Okay.

8 So if anybody is out there --

9 Okay. Do we have members of the public that  
10 are out there, that want to make comments? Anybody out  
11 there? Is anybody out on the bridge line? Can you  
12 please at least acknowledge you're there?

13 (No response.)

14 CHAIRMAN CORRADINI: I don't hear anybody.  
15 So last comments from the Committee to staff or STP?

16 (No response.)

17 CHAIRMAN CORRADINI: All right. So let me  
18 just review what I heard -- where did staff go? He's  
19 behind me, okay. STP has agreed that they're going to  
20 get us a few things, just to finish this off. We're not  
21 going to have a meeting about it, but we will get things  
22 distributed to us from Maitri.

23 The technical basis, not necessarily the  
24 exact document, but a summary of the document on a  
25 technical basis for the one cubic foot is the limit.

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

[www.nealrgross.com](http://www.nealrgross.com)

1           We're going to get a table from STP that not  
2           only has the inventory of the material that would be or  
3           the inventory, what is expected to be the material making  
4           it to the core on a conservative basis, fiber, sludge,  
5           paint, dirt, rust, etcetera, but also the type of  
6           material and if it's a surrogate what the surrogate is,  
7           and distributions of sizes as they know it today, and  
8           that's all essentially backed with the asterisk or the  
9           proviso that things are still evolving.

10           But that will be at least what they know to  
11           this point. We've also been pointed to Appendix 6C for  
12           the -- 6C Rev 6, excuse me, for the test protocol, a  
13           summary of the test protocol, and also the high pressure  
14           core flooder and bypass assembly analysis, but those are  
15           summaries.

16           We've asked for the RAI or backup documents  
17           for both of those, and we'll get those so that the  
18           Committee has all that information, if we choose to go  
19           forward with a letter in the November time frame. Have  
20           I missed anything?

21           MR. HEAD: Mr. Chairman, we were also going  
22           to consider going back and looking at the bypass counts  
23           --

24           CHAIRMAN CORRADINI: Correct. I meant  
25           that, is that we were told that there's a summary in

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 Appendix 6C Rev 6 for both. But beyond --

2 MR. HEAD: Based on the nature of the  
3 questions today, I'm thinking you're probably not going  
4 to be reconciled to what you've seen.

5 CHAIRMAN CORRADINI: We always want more.

6 MEMBER STETKAR: I think that's a fair  
7 characterization.

8 CHAIRMAN CORRADINI: That's a fair  
9 characterization. So to the extent that you can provide  
10 it, we'd appreciate it.

11 MR. HEAD: Okay.

12 MS. BANERJEE: I understand this is  
13 something that staff had during their audit?

14 MR. HEAD: Yes, these have been looked at in  
15 audits.

16 MS. BANERJEE: There was a calculation base  
17 -

18 MR. HEAD: In terms of providing you some  
19 understanding.

20 CHAIRMAN CORRADINI: Okay. That's fine.  
21 Anything else from the Committee?

22 (No response.)

23 CHAIRMAN CORRADINI: Okay. In terms of  
24 future attractions, Mr. Chairman of the afternoon  
25 meeting, when are we supposed to be back here?

**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1 MEMBER STETKAR: One o'clock.

2 CHAIRMAN CORRADINI: And the subject is?

3 MEMBER STETKAR: The subject is land  
4 contamination, economic consequences, whatever you want  
5 to characterize that.

6 (Simultaneous speaking.)

7 CHAIRMAN CORRADINI: A pretty boring  
8 topic, but we'll be back. With that, we'll adjourn for  
9 lunch.

10 (Whereupon, the above-entitled matter went  
11 off the record at 12:14 p.m.)


**NEAL R. GROSS**

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

# South Texas Project Units 3&4 Presentation to ACRS Subcommittee Long Term Cooling Follow-up





# Attendees

Scott Head	NINA Manager, STP 3&4
Bill Mookhoek	NINA Licensing Supervisor, STP 3&4
James Tomkins	NINA Licensing, STP 3&4
Milton Rejcek	NINA Engineering, STP 3&4
Kenji Arai	Senior Fellow, Toshiba
Caroline Schlaseman	MPR/TANE
Martin Van Haltern	Westinghouse
Tim Andreychek	Westinghouse

# Agenda

- Introduction
- Long term cooling overview
- Summary of key points from previous meetings
- Follow-up item # 80
- Summary

# Introduction

- May 8, 2008 Staff Requirements Memorandum asked ACRS to advise Commission on adequacy of design-basis long term cooling approach for each reactor type
- Main focus was ability of safety systems to provide adequate core cooling for extended periods of time when the ECCS recirculation mode is activated during a design basis accident

# LTC Overview

- Robust Long Term Cooling (LTC)
  - Numerous ECCS water sources to keep core cooled
    - Peak clad temperature during design basis LOCA is about half of the limit
  - Ultimate Heat Sink (UHS) has adequate water to provide cooling for 30 days without make-up
- Potential Challenges to Long Term Cooling are addressed
  - Strainers meet NPSH guidance
    - Strainers sized based on very conservative debris loading
    - AC Independent Water Addition system can provide core cooling water without using strainers (as a backup)
  - Containment integrity is maintained
  - Due to design features ECCS gas accumulation not an issue
  - Downstream fuel effects will be tested 18 months prior to operation
    - Long Term Cooling (LTC) met even with fuel assembly inlet blocked

# LTC Overview - Conservatisms in Downstream Fuel Test

- Primary challenge to long term cooling is debris passing through the ECCS suction strainers and causing downstream effects on the fuel
- Design features that help ensure downstream fuel effects are mitigated:
  - Diverse water injection capability
    - HPCF from above core
    - ACIWA
  - State-of-the-art suction strainers
  - No fiber, calcium silicate, or aluminum in primary containment
  - Minimal zinc in primary containment (only in qualified coatings)
  - Design fuel assembly bypass flow
- Programmatic controls over containment and suppression pool cleanliness ensure latent debris amounts are low

# LTC Overview - Conservatism in Downstream Fuel Test

- There are a number of conservatisms in the downstream fuel test:
  - Debris Assumptions
  - Analysis for Acceptance Criteria
  - Test Performance

# LTC Overview - Conservatism in Debris Assumptions

- Chemical amounts assume:
  - No solubility of zinc or aluminum corrosion products in the approximately one million gallon suppression pool
  - All chemical products form gelatinous precipitates
- No credit for settling of debris in locations where it will not impact the strainers or fuel, such as lower drywell, bottom of suppression pool, and lower plenum
- Latent fiber is all assumed to be 100 % fiber fines, with 100 % passing through the strainers
  - Since fibrous materials are prohibited, actual latent fiber in the plant is assumed to be rags and rope left in the upper drywell, which are not likely to pass through the strainer openings

# LTC Overview - Conservatisms in Analysis for Acceptance Criteria

- Decay heat held constant at value at 5 minutes after shutdown
- Debris predicted to take more than 2 hours to all reach the strainer the first time, at which point decay heat would be 40% of the value at 5 minutes
  - Chemical precipitates such as zinc oxide are predicted to take about 15 days to reach the values used in the test
- Factor of 4 margin in acceptance criteria (factor of 2 in flow)
- Void Fraction of 0.95 at hot assembly exit (flow rate is greater than twice boil-off rate)
- No HPCF or fuel assembly design bypass flow is credited
  - Each by itself sufficient to provide adequate cooling

# LTC Overview - Conservatisms in Test Performance


- Debris added in a manner that:
  - Minimizes clumping
  - Maximizes establishment of a fiber bed
  - Provides for the formation of a thin-bed

# LTC Overview - Conservatism in Downstream Fuel Test

- The collective conservatisms in the downstream fuel test translate to roughly a factor of 8 in flow margin
  - Analysis based on 5 min decay heat ( ~ twice the decay heat at the expected debris deposition time )
  - Analysis acceptance criteria (0.95 Void Fraction) requires twice the boil-off flow rate
  - Conservatism in acceptance criteria results in twice the required flow

# ACRS Meetings on Long Term Cooling/ECCS Suction Strainers

- June 24, 2010
- March 8, 2011
- June 21, 2011
- October 4, 2011



## 6/24/2010 Meeting – Chapter 6


- Presented departure to upgrade suction strainers
- Discussed strainer design
- Presented strainer sizing analysis
- Introduced post-COL downstream fuel test

## 3/8/2011 Meeting

- Clarified the downstream test would use 1 ft<sup>3</sup> fiber and that chemical precipitates would be included in the test as well
- Provided comprehensive presentation on STP 3 & 4 long term cooling
  - ECCS and UHS more than adequate to provide cooling for 30 days
  - Potential challenges to LTC addressed
- Detailed discussion on the downstream fuel test

## 3/8/2011 Meeting *(continued)*

- Presented “defense-in-depth” analyses showing that high pressure core flood flow from above the core and fuel assembly bypass flow each by itself can provide adequate cooling for the core in the event the inlet to the hot assembly were to plug completely
- These bounding analyses provide additional assurance that LTC will not be compromised by downstream effects



## 6/21/2011 and 10/4/2011 Meetings

- Addressed follow-up items
- Table on next page shows summary of follow-up items

STP 3&4 LTC ACRS Follow-up Items		Meeting Date			
No.	Description	6/24/10	3/8/11	6/21/11	10/4/11
46	Boron concentration in sodium pentaborate tank	O	C		
47	a) Detailed briefing on downstream test b) Basis for only 10% of fiber passing through strainer	O	C		
49	Briefing on vacuum breaker protection	O	C		
50	Provide Toshiba technical reports used to size strainers	O	C		
72	Hydrodynamic loads on strainers		O	C	
73	Does analysis for Japanese plants bound thin bed effects		O	C	
74	Use of Nukon as a fiber surrogate		O	C	
75	Use of ALOOH as a chemical surrogate		O	C	
76	Zinc injection		O	C	
77	Justify partial length test		O	C	
78	Justify unheated test		O	C	
79	Justify use of NRC protocol for debris addition		O	C	
80	Pressure Drop vs. flow exponent of 2.0		O		
81	Address multiple tests		O	C	
82	Justify shorter loop transit time		O	C	
83	Inlet flow distribution assumption		O	C	
84	Parametric study of results vs. assembly inlet K-factor		O	C	
98	Modeling of perforated strainer screen			O	C
99	Zinc oxide concentration			O	C

O = Follow-up Item Opened

C = Follow-up Item Closed

# Summary of Actions from ACRS Meetings

- As a result of ACRS feedback:
  - Include 100% of 1 ft<sup>3</sup> fiber in downstream fuel test
  - Include chemical debris in downstream testing
  - Perform multiple downstream tests to account for inherent randomness of debris blockage behavior
  - Review industry experience with downstream tests for lessons learned prior to performing test

# Remaining Follow-up Item

- Follow-up Item # 80

*“Provide the basis for test acceptance criteria utilizing square relationship, vs. use of some other exponent such as 1.2 for debris bed.”*

# Follow-up Item # 80 – Pressure Drop vs. Flow Exponent *(continued)*


- The conservative test acceptance criteria is:

$$\left[ \frac{\Delta P_f}{\Delta P_i} \right]_{(\text{Test-Measured})} \leq 1200 * \left( \frac{W_f}{W_i} \right)_{(\text{Test-Measured})}^2$$


- The criteria limits the increase in pressure drop due to the debris and is based upon an exponent of 2 in the Darcy equation
  - The allowed increase in pressure drop is determined from the GOBLIN analysis that ensures the core is covered by the 2-phase level.
- Exponent of 2 is reasonable value for higher debris loadings

# Sensitivity Study for Debris Modeling

- The following overhead provides example calculations of the analysis acceptance criteria using different debris pressure drop vs. flow rate (Q) relationships
  - $\Delta P = f(Q^{1.5})$
  - $\Delta P = f(Q^{1.2})$
- These are compared with the analysis acceptance criteria (using  $\Delta P = f(Q^2)$ ) and the conservative test acceptance criteria (based upon  $\Delta P = (1/4) f(Q^2)$ )



# Study for Debris Modeling



## Follow-up Item # 80 - Conclusion

- The conservative test acceptance criteria bounds the debris pressure drop vs. flow dependency variations.
- As discussed previously we believe the test acceptance criteria is appropriate and conservative

$$\left[ \frac{\Delta P_f}{\Delta P_i} \right]_{(\text{Test-Measured})} \leq 1200 * \left( \frac{W_f}{W_i} \right)_{(\text{Test-Measured})}^2$$

# Summary

- We believe we have addressed all the ACRS follow-up items
- There is adequate core cooling to meet LTC
  - ECCS and UHS are more than adequate to provide 30 days of cooling
  - Design basis LOCA peak clad temperature about half the limit
- Challenges to LTC (containment integrity, ECCS gas accumulation, and strainer NPSH) were satisfactorily addressed
- Primary challenge to LTC is debris passing through the ECCS suction strainers and causing downstream effects on the fuel
  - Conservative downstream test will confirm the design is not vulnerable to this challenge
  - Furthermore, defense-in-depth calculations show that there are two separate means of cooling a fully blocked assembly
- STP 3 & 4 meets regulatory requirements for long term cooling

# **Long-Term Cooling for ABWR STP Units 3 and 4 October 2, 2012**

Jim Gilmer: Downstream Effects (Reactor Systems Branch)  
Greg Makar: Chemical Effects (Component Integrity Branch)  
Harry Wagage: Containment (Containment and Ventilation Branch)  
Tuan Le: Component Integrity (Engineering Mechanics Branch)

# **ABWR Long-Term Cooling**

- Long-term core cooling is provided by RHR and HPCF pumps
- Long-term suppression pool temperature is maintained by operating RHR in suppression pool cooling mode
- Analysis showed that containment pressure can be maintained below its design value
- Analysis showed that adequate core cooling can be maintained by keeping the RPV level above the top of active fuel

## **ABWR Long-Term Cooling (continued)**

- The staff review approach for STP Units 3 and 4 is consistent with previous LTC reviews, and ensures that the requirements of 10 CFR 50.46(b)(5) are satisfied. The assessment includes:
  - ECCS strainer performance
  - Downstream effects
  - Chemical effects

## **Strainer Performance**

- STP 3 and 4 ECCS suction strainers designed in accordance with RG 1.82 Rev. 3
  - Bounded by Reference Japanese ABWR strainer analysis and testing
- Primary containment - 100% Reflective Metallic Insulation
- Suppression pool
  - Stainless steel liner
  - Suppression pool cleanup system
- FSAR describes the Foreign Material Exclusion and cleanliness programs
- Restricted from containment by administrative procedures: fiber, CaSil, Al, and TSP

## **In-Vessel Effects**

- STP demonstrated through analysis that 0.95 void fraction is maintained
- STP calculated peak cladding temperature is well within criteria specified in 10 CFR 50.46
- There are diverse ECCS injection sources and injection paths to core
- Fuel tests must demonstrate low impact on core flow due to debris blockage

# Conservatisms in STP Design/Analyses

- The relative reduced likelihood of latent debris generation compared to operating BWRs and PWRs (restricted access to the containment, the suppression pool cleanup system, the operational program for suppression pool cleanup)
- Minimal LOCA-generated debris (elimination of recirculation piping, no fibrous insulation)
- All breaks above top of active fuel
- All corroded aluminum and zinc assumed to precipitate in gelatinous form
- ABWR design features that minimize the transport of accident-generated debris
- Diversity of ECCS delivery locations, systems, and water sources
- The analyses include a factor of four conservatism

# License Condition 06.02-1

- STP incorporates by reference the certified ABWR design
- The License Condition ensures that the fuel to be loaded will perform satisfactorily with debris blockage
- The proposed license condition includes test acceptance criteria that must be met for any type of fuel before it can be loaded
- FSAR COM 6C-1 commits to submission of the test results and analyses at least 18 months prior to scheduled fuel load
- FSAR COM 6C-2 commits to provide the complete, detailed test plan (which will reflect Industry experience in performing such tests) six months prior to the tests

# License Condition 06.02-1 (continued)

- Acceptance criterion provides conservative measure of long-term fuel performance over the expected operating range

## **Long-Term Cooling: Conclusion**

- Adequate core cooling is maintained
- Containment pressure and temperature are maintained below containment design values
- STP meets 10 CFR 50.46(b)(5)