

PRIORITY Normal

DISPOSITION OF THE ORIGINAL DOCUMENT WILL BE TO
THE TRANSMITTAL SIGNATURE UNLESS RECIPIENT IS
OTHERWISE IDENTIFIED BELOW

Date: 10/17/12

Document Transmittal #:

DUK122910060

QA CONDITION

☐ Yes ☒ No

OTHER ACKNOWLEDGEMENT REQUIRED

☒ Yes

IF QA OR OTHER ACKNOWLEDGEMENT REQUIRED, PLEASE
ACKNOWLEDGE RECEIPT BY RETURNING THIS FORM TO:

Duke Energy
4800 Concord Road
Document Management
CN04DM
York, South Carolina 29745

Rec'd By _____

Date _____

Duke Energy DOCUMENT TRANSMITTAL FORM

REFERENCE

CATAWBA NUCLEAR STATION
SELECTED LICENSEE COMMITMENTS
(CONTINUED)

Page 2 of 3

DOCUMENT NO	QA COND	REV #/ DATE	DISTR CODE	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	TOTAL
SECTION 16.8-1-45	NA	004 08/02/12	CADM-03	V1	V1	V1	V1	V1	V1	V10	V1	X	V26	V1	V1	V1	V1	V1	72
SECTION 16.8-1-46	NA	004 08/02/12																	
SECTION 16.8-1-47	NA	004 08/02/12																	
SECTION 16.8-1-48	NA	004 08/02/12																	
SECTION 16.8-1-49	NA	004 08/02/12																	

REMARKS: THIS IS A CONTINUATION UPDATE TO TRANSMITTAL #**DUK122910056** DATED
10/17/2012.

PLEASE REFER TO THE ATTACHED MEMO FOR FILING INSTRUCTION

K HENDERSON
VICE PRESIDENT
CATAWBA NUCLEAR STATION

BY:

K BYERS CN01RC KB/RJA

A053
NCC

Table 16.8-1-2
Unit 2 CPCOPDs

DEVICE NUMBER AND LOCATION	SYSTEM POWERED
PHP2C-F01B Primary Bkr Backup Fuse	Pressurizer Heaters 19, 20, and 45
PHP2C-F01C Primary Bkr Backup Fuse	Pressurizer Heaters 24, 51, and 52
PHP2C-F01D Primary Bkr Backup Fuse	Pressurizer Heaters 29, 57, and 58
PHP2C-F02C Primary Bkr Backup Fuse	Pressurizer Heaters 34, 63, and 64
PHP2C-F02D Primary Bkr Backup Fuse	Pressurizer Heaters 39, 69, and 70
PHP2C-F02E Primary Bkr Backup Fuse	Pressurizer Heaters 44, 75, and 76
PHP2D-F01A Primary Bkr Backup Fuse	Pressurizer Heaters 3, 4, and 25
PHP2D-F01B Primary Bkr Backup Fuse	Pressurizer Heaters 15, 16, and 40
PHP2D-F01C Primary Bkr Backup Fuse	Pressurizer Heaters 23, 49, and 50
PHP2D-F02C Primary Bkr Backup Fuse	Pressurizer Heaters 33, 61, and 62
PHP2D-F02D Primary Bkr Backup Fuse	Pressurizer Heaters 38, 67, and 68

Table 16.8-1-2
Unit 2 CPCOPDs

DEVICE NUMBER AND LOCATION		SYSTEM POWERED
	PHP2D-F02E Primary Bkr Backup Fuse	Pressurizer Heaters 43, 73, and 74
4.	250 VDC Reactor Building Deadlight Panelboard	
	2DLD-2 Primary Bkr Backup Fuse	Lighting Panelboard No. 2LR1, 2LR2, 2LR3, 2LR4
	2DLD-3 Primary Bkr Backup Fuse	Lighting Panelboard No. 2LR13, 2LR14
	2DLD-4 Primary Bkr Backup Fuse	Lighting Panelboard No. 2LR5, 2LR6
	2DLD-5 Primary Bkr Backup Fuse	Lighting Panelboard No. 2LR10, 2LR11
	2DLD-10 Primary Bkr Backup Fuse	Lighting Panelboard No. 2LR8
5.	120 VAC Panelboards	
	2ELB-5 Primary Bkr Backup Fuse	Emergency AC Lighting
	2ELB-7 Primary Bkr Backup Fuse	Emergency AC Lighting
	2ELB-13 Primary Bkr Backup Fuse	Emergency AC Lighting
	2ELB-15 Primary Bkr Backup Fuse	Emergency AC Lighting

Table 16.8-1-2
Unit 2 CPCOPDs

DEVICE NUMBER AND LOCATION	SYSTEM POWERED
2ELB-17 Primary Bkr Backup Fuse	Emergency AC Lighting
2KPM-1 Primary Bkr Backup Fuse	NC Pump Motor 2A Space Heater
2KPM-2 Primary Bkr Backup Fuse	NC Pump Motor 2C Space Heater
2KPM-7-1 Primary Bkr Backup Fuse	Lower Cont Ventilation Unit 2A Fan Motor Space Heater
2KPM-8-1 Primary Bkr Backup Fuse	Lower Cont Ventilation Unit 2C Fan Motor Space Heater
2KPM-24 Primary Bkr Backup Fuse	Control Rod Drive Ventilation Fan Motor 2A, 2B, 2C, 2D Space Heaters
2KPM-24-10 Primary Fuse Backup Fuse	Control Rod Drive Ventilation Fan Motor 2A Space Heaters
2KPM-24-11 Primary Fuse Backup Fuse	Control Rod Drive Ventilation Fan Motor 2B Space Heaters
2KPM-24-12 Primary Fuse Backup Fuse	Control Rod Drive Ventilation Fan Motor 2C Space Heaters
2KPM-24-13 Primary Fuse Backup Fuse	Control Rod Drive Ventilation Fan Motor 2D Space Heaters
2KPM-33 Primary Bkr Backup Fuse	NI Temperature Transmitters 2NITT5800, 2NITT5810, 2NITT5820, 2NITT5830
2KPM-33-06	NI Temperature Transmitter

Table 16.8-1-2
Unit 2 CPCOPDs

DEVICE NUMBER AND LOCATION	SYSTEM POWERED
Primary Fuse	2NITT5800
2KPM-33-07 Primary Fuse	NI Temperature Transmitter 2NITT5810
2KPM-33-08 Primary Fuse	NI Temperature Transmitter 2NITT5820
2KPM-33-09 Primary Fuse	NI Temperature Transmitter 2NITT5830
2KPN-1 Primary Bkr Backup Fuse	NC Pump Motor 2B Space Heater
2KPN-2 Primary Bkr Backup Fuse	NC Pump Motor 2D Space Heater
2KPN-7-1 Primary Bkr Backup Fuse	Lower Cont Ventilation Unit 2B Fan Motor Space Heater
2KPN-08 Primary Bkr Backup Fuse	Lower Cont Ventilation Unit 2D Fan Motor Space Heater, NC Pump Seal Standpipe Vent and Drain Vlvs 2NV105, 2NV106, 2NV110, 2NV111, 2NV115, 2NV116, 2NV120, 2NV121
2KPN-08-01 Primary Fuse Backup Fuse	Lower Cont Ventilation Unit 2D Fan Motor Space Heater
2KPN-08-02 Primary Fuse Backup Fuse	NC Pump 2A Standpipe Drain and Overflow Vlvs 2NV105 and 2NV106
2KPN-08-03 Primary Fuse Backup Fuse	NC Pump 2B Standpipe Drain and Overflow Vlvs 2NV110 and 2NV111
2KPN-08-04 Primary Fuse Backup Fuse	NC Pump 2C Standpipe Drain and Overflow Vlvs 2NV115 and 2NV116

Table 16.8-1-2
Unit 2 CPCOPDs

DEVICE NUMBER AND LOCATION		SYSTEM POWERED
2KPN-08-05 Primary Fuse Backup Fuse		NC Pump 2D Standpipe Drain and Overflow Vlvs 2NV120 and 2NV121
2KPN-11 Primary Bkr Backup Fuse		Misc Control Power for 2ATC24
6. DC Welding Circuits		
2EQCB0001 Primary Bkr – AA Backup Bkr – AB		Spare
2EQCB0002 Primary Bkr – AA Backup Bkr – AB		Spare