

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21

UNITED STATES
NUCLEAR REGULATORY COMMISSION
BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

-----X
In re: Docket Nos. 50-247-LR; 50-286-LR
License Renewal Application Submitted by ASLBP No. 07-858-03-LR-BD01
Entergy Nuclear Indian Point 2, LLC, DPR-26, DPR-64
Entergy Nuclear Indian Point 3, LLC, and
Entergy Nuclear Operations, Inc. November 8, 2012
-----X

PRE-FILED WRITTEN REBUTTAL TESTIMONY OF
DR. DAVID J. DUQUETTE
REGARDING CONTENTION NYS-38 / RK-TC-5

On behalf of the State of New York ("NYS" or "the State"),
the Office of the Attorney General hereby submits the following
rebuttal testimony by David J. Duquette, Ph.D. regarding
Contention NYS-38/RK-TC-5.

Q. Please state your full name.

A. David J. Duquette.

Q. What is the purpose of this rebuttal testimony you are
now providing?

*Pre-filed Written
Rebuttal Testimony
of David J. Duquette
Contention NYS-38/RK-TC-5*

1 A. The State of New York has asked me to respond to
2 Entergy's August 20, 2012 and NRC Staff's August 20, 2012
3 testimony and statements on Contention NYS-38/RK-TC-5.

4 Q. What documents did you review in preparation for this
5 rebuttal testimony?

6 A. I reviewed Entergy's August 20, 2012 Statement of
7 Position Regarding Contention NYS-38/RK-TC-5 (ENT000520),
8 Entergy's Pre-filed Testimony of Entergy witnesses Nelson
9 Azevedo, Robert Dolansky, Alan Cox, Jack Strosnider, Robert
10 Nickel, Ph.D., and Mark Gray Regarding Contention NYS-38/RK-TC-5
11 (ENT000521), and the accompanying exhibits. I also reviewed the
12 NRC Staff's August 20, 2012 Statement of Position on Contention
13 NYS-38/RK-TC-5 (NRC000147), NRC's Pre-filed Testimony of NRC
14 Witnesses Dr. Allen Hiser and Kenneth Karwoski Concerning
15 Portions of Contention NYS-38/RK-TC-5 (NRC000161), which focuses
16 on steam generator issues, and the accompanying exhibits.¹ In
17 addition, I have reviewed documents previously submitted by the
18 State on this contention and various additional documents

¹ NRC Staff also submitted pre-filed testimony on another aspect of Contention NYS-38/RK-TC-5, namely NRC000148. That testimony focused on metal fatigue issues and did not discuss my June 2012 testimony or report on steam generator issues. NRC Staff's Pre-filed Testimony of NRC witnesses Dr. Allen Hiser, On Yee, and Dr. Ching Ng, Concerning Portions of Contention NYS-38/RK-TC-5 (NRC000148). Accordingly, my rebuttal testimony here does not discuss NRC000148.

*Pre-filed Written
Rebuttal Testimony
of David J. Duquette
Contention NYS-38/RK-TC-5*

1 including a presentation from the EPRI Steam Generator Task
2 Force (SGTF) to the NRC entitled "NRC/EPRI Steam Generator Task
3 Force Meeting", dated August 21, 2012 (NYS000463), a NRC chart
4 identifying original and replacement steam generators at U.S.
5 plants prepared in 2009 (NYS000458), a paper numbered ICONE18-
6 29457 entitled "Inspection of the Steam Generator Divider
7 Plate," presented at the 18th International Conference on Nuclear
8 Engineering, authored by D. D'Annucci and E. Lecour of
9 Westinghouse for the May 2010 ICONE meeting (ENT000526), EPRI
10 Report 1025133, "Steam Generator Management Program: Assessment
11 of Channel Head Susceptibility to Primary Water Stress Corrosion
12 Cracking," dated June 2012 (ENT000524), and various summary or
13 demonstrative exhibits prepared by the State (NYS000454 to
14 NYS000456).

15 Q. What are your overall conclusions regarding NRC Staff
16 and Entergy's testimony?

17 A. It appears that both Entergy and the NRC staff agree
18 with my assessment that there are no qualified techniques
19 currently in use in the United States to inspect the channel
20 head, and specifically the divider plates of the steam
21 generators in use at Indian Point Unit 2 and Unit 3. While both
22 Entergy and NRC Staff indicate that there may be techniques

*Pre-filed Written
Rebuttal Testimony
of David J. Duquette
Contention NYS-38/RK-TC-5*

1 currently used in other countries to perform these inspections,
2 their testimony makes clear that those techniques have not been
3 qualified for service in the United States. In essence, since
4 the rebuttal testimony by Entergy and NRC staff suggests that
5 divider cracking has not been observed to date in United States-
6 based steam generators it is unlikely to occur in the future,
7 and Entergy's general approach to aging management issues will
8 effectively provide adequate safety measures if cracking were to
9 occur. Thus, the rebuttal testimony has a "trust us" attitude
10 in the absence of real data, or an active and sufficiently
11 detailed aging management program specifically focused on the
12 divider plates. Both Entergy and NRC Staff testimonies
13 acknowledge that the EPRI-sponsored Steam Generator Task Force
14 is currently conducting an extensive research program to address
15 cracks in the divider plates that may propagate and compromise
16 pressure boundary components. It is unrealistic to recommend
17 that divider plate cracking and the development of divider plate
18 inspection programs can be either ignored or deferred while the
19 aforementioned research program is ongoing. The EPRI research
20 program also addresses research into the development of
21 potential remote inspection techniques to monitor primary water
22 stress corrosion cracking (PWSCC) crack propagation. Until a

*Pre-filed Written
Rebuttal Testimony
of David J. Duquette
Contention NYS-38/RK-TC-5*

1 qualified inspection technique has been identified for use in
2 the United States and at the Indian Point steam generators, it
3 is unreasonable to continue to operate the steam generators for
4 extended periods of time without some method for determining the
5 possibility and/or extent of cracking.

6 Q. Did the Entergy and NRC Staff testimony and exhibits
7 change the opinions that you previously presented in connection
8 with this Contention NYS-38/RK-TC-5?

9 A. Absolutely not. I did not find any of their testimony
10 or exhibits to be compelling.

11 Q. Please summarize your rebuttal testimony.

12 A. This rebuttal testimony reinforces my initial position
13 on Contention NYS-38/RK-TC-5.

14 1. Both Entergy and the NRC staff agree that the Indian
15 Point Unit 2 and Indian Point Unit 3 steam generators have
16 divider plates that are constructed from Alloy 600 and that the
17 weld materials are also an Alloy 600 derivative (Alloy 82/182).
18 It is well known that Alloy 600 is susceptible to PWSCC.

19 2. The susceptibility of the divider plates to PWSCC and
20 the possibility of the propagation of stress corrosion cracks
21 into the pressure boundary components are still under
22 investigation by the SGTf. The investigation includes

*Pre-filed Written
Rebuttal Testimony
of David J. Duquette
Contention NYS-38/RK-TC-5*

1 development of possible inspection techniques for the detection
2 of cracks and of crack propagation.

3 3. While conventional inspection techniques may be
4 available to detect cracking, there are no qualified techniques
5 that are currently accepted in the United States for divider
6 plate cracking that will assure the safety of inspecting
7 personnel.

8 4. Entergy has elected to "analyze" the possibility of
9 crack initiation in the divider plates that may propagate into
10 the pressure boundary components including the tube-to-tubesheet
11 welds. It implies that actual inspections are unlikely when it
12 states: "in the unlikely event that inspections become necessary
13 . . ." Entergy Pre-filed Testimony, at 112, Q/A 145
14 (ENT000521). However, it does not state how the analyses they
15 will perform to reach this ultimate conclusion will be
16 performed, nor does it state what observations or events would
17 trigger the need for inspections. To reiterate, with the
18 possible exception of conventional *in situ* inspection
19 techniques, which Entergy admits could present a potential for
20 high personnel radiation exposure, it does not and cannot
21 present a reliable, defined program for remote inspection.
22 Instead, it will have to wait for the SGTF to possibly develop a

*Pre-filed Written
Rebuttal Testimony
of David J. Duquette
Contention NYS-38/RK-TC-5*

1 qualified procedure at some future, unspecified date. I also
2 note that locations at which steam generator tubes taper or
3 narrow can be susceptible to corrosion.

4 5. The evidence provided to date suggests that Entergy
5 has not attempted to inspect the divider plates in the eight
6 steam generators at Indian Point Unit 2 and Unit 3 by any
7 technique. Accordingly, the current state of those divider
8 plates appears to be entirely unknown.

9 6. Entergy has stated that its approach to the divider
10 cracking problem is not dependent on the results of EPRI
11 research, but that inspections being committed to by plants with
12 renewed licenses will occur at an "appropriate" time, and that
13 the IPEC Quality Assurance Program will "drive appropriate
14 safety evaluations." Neither of these statements is a cause for
15 celebration. "Appropriate" is an ill-defined term, and the IPEC
16 Quality Assurance Program, which is principally under the
17 auspices and control of the proponent, cannot be defined as good
18 engineering practice. Good engineering practice would suggest
19 external periodic reviews of safety related programs.

20 7. In my June 2012 report, I pointed out that EPRI has
21 generically stated that the divider plates in United States
22 steam generators are thicker than those that have experienced

*Pre-filed Written
Rebuttal Testimony
of David J. Duquette
Contention NYS-38/RK-TC-5*

1 cracking in international steam generators, and that factor may
2 mitigate against PWSCC initiation in United States steam
3 generators. Even if that general statement proved to be true
4 for the majority of United States steam generators, the divider
5 plates at Indian Point Unit 2 and Unit 3 are an exception to
6 this general rule. While the majority of steam generators in
7 the United States have divider plate thicknesses of
8 approximately 1.9 inches, the Westinghouse Model 44F steam
9 generators at Indian Point Unit 2 and Unit 3 have a plate
10 thickness of 1.26 inches, essentially the equivalent of the 1.3
11 inch thick divider plates used in the French steam generators
12 where PWSCC cracking was first discovered. Thus, barring the
13 possibility of differences in loading of the divider plates and
14 associated assemblies, the steam generators at Indian Point have
15 essentially the same sensitivity to PWSCC as the French steam
16 generators.

17 8. In my initial June 2012 testimony in this proceeding I
18 referred to cracking that had occurred in the steam generator at
19 Indian Point Unit 2. I agree with Entergy that replacement of
20 mill annealed Alloy 600 tubing with thermally treated Alloy 600
21 tubing will reduce (but not eliminate) the potential for PWSCC

*Pre-filed Written
Rebuttal Testimony
of David J. Duquette
Contention NYS-38/RK-TC-5*

1 in steam generator tubes.² However, no evidence has been
2 presented that the divider plates are constructed from thermally
3 treated alloys. Even if they were, the geometry of cracking
4 that has been observed in foreign steam generators has occurred
5 near the welds joining the divider plates to the stub runners.
6 Welding of these components can be expected to lead to
7 dissolution of the grain boundary precipitates that are believed
8 to provide a degree of PWSCC resistance in thermally treated
9 alloys. Accordingly, the Entergy comments concerning the lack
10 of cracking in the steam generator with Alloy 600TT tubes has
11 little or no relevance to the possibility of PWSCC in the
12 divider plates or stub runners -- or for that matter in the
13 tube-to-tubesheet welds.

14 Q. Does this conclude your rebuttal testimony?

15 A. Yes. However, I reserve the right to offer further
16 opinions if new information is presented.

² Often times the abbreviation "TT" is used to designate thermally treated components, e.g., "Alloy 600 TT" tubes.

1 UNITED STATES

2 NUCLEAR REGULATORY COMMISSION

3 BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

4 -----X

5 In re: Docket Nos. 50-247-LR; 50-286-LR

6 License Renewal Application Submitted by ASLBP No. 07-858-03-LR-BD01

7 Entergy Nuclear Indian Point 2, LLC, DPR-26, DPR-64

8 Entergy Nuclear Indian Point 3, LLC, and

9 Entergy Nuclear Operations, Inc. November 8, 2012

10 -----X

11 **DECLARATION OF DAVID J. DUQUETTE**

12 I, David J. Duquette, do hereby declare under penalty of

13 perjury that my statements in the foregoing rebuttal testimony

14 and my statement of professional qualifications are true and

15 correct to the best of my knowledge and belief.

16 Executed in Accord with 10 C.F.R. § 2.304(d)

17 

David J. Duquette, Ph.D.
 Materials Engineering Consulting Services
 4 North Lane
 Loudonville, New York 12211
 Tel: 518 276 6490
 Fax: 518 462 1206
 Email: duqued@rpi.edu
 November 8, 2012

18 *Pre-filed Written
 Rebuttal Testimony
 of David J. Duquette
 Contention NYS-38/RK-TC-5*