

Entergy Operations, Inc. P. O. Box 756 Port Gibson, MS 39150

Michael Perito Vice President, Operations Grand Gulf Nuclear Station Tel. (601) 437-6409

GNRO-2012/00132

November 9, 2012

U.S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555-0001

- SUBJECT: License Amendment Request for Revision of Technical Specification Allowable Value for Primary Containment and Drywell Isolation Instrumentation Function 3.c "RCIC Steam Supply Line Pressure – Low." Grand Gulf Nuclear Station, Unit 1 Docket No. 50-416 License No. NPF-29
- REFERENCE: NRC Administrative Letter 98-10, "Dispositioning of Technical Specifications that are Insufficient to Assure Plant Safety" dated December 29, 1989

Dear Sir or Madam:

In accordance with the provisions of Section 50.90 of Title 10 of the Code of Federal Regulations (10 CFR), Entergy Operations, Inc. is submitting a request for an amendment to the Technical Specifications (TS) for Grand Gulf Nuclear Station, Unit 1 (GGNS). The proposed amendment would revise the TS to support correction of a non-conservative technical specification allowable value.

- Attachment 1 provides an evaluation of the proposed changes.
- Attachment 2 provides the markup pages of existing TS to show the proposed changes.
- Attachment 3 provides revised (clean) TS pages.
- Attachment 4 provides calculation JC-Q1E31-N685-1 "RCIC Turbine Isolation on Low Inlet Steam Pressure"
- Attachment 5 provides JS09 Revision 1 "Grand Gulf Nuclear Station Instrument and Control Standard Methodology For The Generation Of Instrument Loop Uncertainty & Setpoint Calculations"

Entergy Operations, Inc. requests approval of the proposed license amendment by November 9, 2013 with the amendment being implemented within 90 days.

GNRO-2012/00132 Page 2 of 3

In accordance with 10 CFR 50.91 (a)(1), "Notice for Public Comment," the analysis about the issue of no significant hazards consideration using the standards in 10 CFR 50.92 is being provided to the Commission in accordance with the distribution requirements in 10 CFR 50.4. In accordance with 10 CFR 50.91 (b)(1), "State Consultation," a copy of this application and its reasoned analysis about no significant hazards considerations is being provided to the designated Mississippi Official.

This letter contains no new commitments.

If you have any questions or require additional information, please contact Jeffery A. Seiter at 601-437-2344.

I declare under penalty of perjury that the foregoing is true and correct. Executed on November 9, 2012.

MP/jas

Attachments:

- 1. Evaluation of Proposed Changes
- 2. Proposed Technical Specification Changes (Mark-up)
- 3. Revised Technical Specification Changes (Clean Copy)
- 4. Calculation JC-Q1E31-N685-1 "RCIC Turbine Isolation on Low Inlet Steam Pressure"
- 5 JS09 Revision 1 "Grand Gulf Nuclear Station Instrument and Control Standard Methodology For The Generation Of Instrument Loop Uncertainty & Setpoint Calculations"

cc: (see next page)

GNRO-2012/00132 Page 3 of 3

cc: Mr. John Boska, Project Manager Plant Licensing Branch I-1 Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Mail Stop O-8-C2 Washington, DC 20555

> Mr. Elmo E. Collins, Jr. Regional Administrator, Region IV U. S. Nuclear Regulatory Commission 1600 East Lamar Boulevard Arlington, TX 76011-4511

> U. S. Nuclear Regulatory Commission ATTN: Mr. A. Wang, NRR/DORL Mail Stop OWFN/8 G14 11555 Rockville Pike Rockville, MD 20852-2378

U. S. Nuclear Regulatory Commission ATTN: Mr. Nathaniel Ferrier, NRR/DORL Mail Stop OWFN/ 11 F 1 11555 Rockville Pike Rockville, MD 20852-2378

NRC Senior Resident Inspector Grand Gulf Nuclear Station Port Gibson, MS 39150

Dr. Mary Currier, M.D., M.P.H State Health Officer Mississippi Department of Health P. O. Box 1700 Jackson, MS 39215-1700 Attachment 1

GNRO-2012/00132

Evaluation of Proposed Changes

- It is converted a contrality contral of a manager

Indenender inn het die sonderen die son produktio

GNRO-2012/00132 Attachment 1 Page 1 of 6

1.0 SUMMARY DESCRIPTION

This letter is a request to the Nuclear Regulatory Commission (NRC) to amend Facility Operating License NPF-29 for the Grand Gulf Nuclear Station (GGNS). The requested change affects Technical Specification (TS) Table 3.3.6.1-1 Allowable Value for Primary Containment and Drywell Isolation Instrumentation Function 3.c "Reactor Core Isolation Cooling (RCIC) Steam Supply Line Pressure – Low". This request is submitted pursuant to 10 CFR 50.90 to correct a non conservative TS and, consistent with the guidance of NRC Administrative Letter 98-10, "Dispositioning of Technical Specifications that are Insufficient to Assure Plant Safety", dated December 29, 1989 (reference 6.1).

TS Allowable Value for Primary Containment and Drywell Isolation Instrumentation Function 3.c "RCIC Steam Supply Line Pressure – Low" is changed from greater than or equal to (\geq) 53 psig to greater than or equal to (\geq) 57 psig.

As demonstrated in this submittal, the proposed change does not adversely impact safety and is required by NRC Administrative Letter 98-10, "Dispositioning of Technical Specifications that are Insufficient to Assure Plant Safety". Entergy Operations, Inc. requests approval of the proposed license amendment by November 9, 2013. Once approved, Entergy will implement the amendment within 90 days.

2.0 DETAILED DESCRIPTION

2.1 Proposed Changes

A recent revision of Calculation JC-Q1E31-N685-1 "RCIC Turbine Isolation on Low Inlet Steam Pressure" (reference 6.4) updated the methodology and assumptions used in the calculation. This revision resulted in a new calculated allowable value of \geq 56.21 psig versus the current allowable value of \geq 53 psig. The current setpoint of 60 psig as delineated in Function 3. of RCIC System Isolation in Technical Requirement Manual (TRM) Table 3.3.6.1-1 "Technical Specification Isolation Instrumentation Trip Setpoints and Response Times" remains conservative with a calculated setpoint of 56.73 psig. The non-conservative allowable value is required to be revised in accordance with NRC Administrative Letter 98-10.

2.2 Need for Changes

The discovery of a non-conservative allowable value requires a change to technical specifications. This change is required to ensure that the TS is sufficient to assure nuclear safety.

2.3 TSTF-493 Considerations

GGNS is aware of the NRC position to encourage TSTF-493 (Reference 6.3) adoption by requiring licensees to provide a determination for each instrumentation function proposed for revision, as to whether the function is a Limiting Safety System Setting (LSSS) that protects a safety limit. A review of the TSTF-493 traveler for this particular instrument function indicates that this function is not an LSSS that protects a safety limit. Attachment A to TSTF-493, Revision 4, entitled "Identification of Functions to be Annotated with TSTF-493 Footnotes," identifies those functions that are LSSS. Under the Attachment A listing for

NUREG-1434, "Boiling Water Reactor/6 Plants", Technical Specification Table 3.3.6.1-1 "Allowable Value for Primary Containment and Drywell Isolation Instrumentation" Function 3.c "Reactor Core Isolation Cooling (RCIC) Steam Supply Line Pressure – Low" is not listed as a LSSS. Since this function is not a LSSS no change to the TS is required with respect to this function.

3.0 TECHNICAL EVALUATION

3.1 RIS-2005-20 Revision 1

In NRC GL 91-18 and superseded by RIS-2005-20 Revision 1(reference 6.2), the NRC provided guidance for prompt corrective action to correct or resolve a degraded or non-conforming condition. In the case of non-conservative TS, this includes the evaluation of compensatory measures, such as administrative controls, in accordance with 10 CFR 50.59 and prompt actions to correct the TS. This section provides a description of the methodology used by Entergy to complete the evaluation for the requested TS allowable value change.

GGNS utilizes the methodology documented in JS-09 Rev. 1 "Methodology for the Generation of Instrument Loop Uncertainty & Setpoint Calculations." (reference 6.5) to calculate loop uncertainties and setpoints. This methodology is used coincident with the GE instrument setpoint methodology published in NEDC-31336. This method includes using the available uncertainty data along with the following general steps to generate an appropriate loop Allowable Value and Nominal Trip Setpoint.

- Calculate the Loop Uncertainty (LU) by computing the SRSS of the Loop Device Uncertainty (A_L), the Loop Calibration Uncertainty (C_L), the Process Measurement Uncertainty (PM), and the Primary Element Uncertainty (PE).
- Calculate the Loop Drift (D_L) by computing the SRSS of the Device Drift (DR), the Temperature Drift (TD), and the Radiation Drift (RD) for each loop instrument as applicable.
- Calculate the Total Loop Uncertainty (TLU) by summing the Loop Uncertainty, the Loop Drift and any applicable biases.
- For process variables that increase to the Analytical Limit (AL), calculate the loop Allowable Value (AV) by subtracting the Loop Uncertainty from the Analytical Limit. For process variables that decrease to the Analytical Limit, calculate the loop Allowable Value by summing the value of the Loop Uncertainty and the Analytical Limit.
- For process variables that increase to the Analytical Limit (AL), calculate the loop Nominal Trip Setpoint (NTSP) by subtracting the value of the Total Loop Uncertainty from the Analytical Limit. For process variables that decrease to the Analytical Limit, calculate the loop Nominal Trip Setpoint (NTSP) by summing the value of the Total Loop Uncertainty and the Analytical Limit.

Calculation JC-Q1E31-N685-1 "RCIC Turbine Isolation on Low Inlet Steam Pressure" (reference 6.4 and found in attachment 4) determines the instrument loop uncertainty, limiting allowable values and setpoints for instrument loops to isolate the RCIC Turbine on low inlet steam pressure to protect the turbine. The revision to the calculation did not result in a setpoint change, only the allowable value was required to be changed. The functionality of the associated instrumentation for the RCIC Turbine Isolation on Low Inlet Steam Pressure setpoint are not in question since the actual plant setpoints are currently conservative with respect to the analytical limits. Therefore, the instrumentation can perform its specified TS safety function.

The TRM trip setpoint is not changed; therefore the system remains capable of performing its specified safety function in accordance with applicable design requirements and associated analyses. Since the system remains capable of performing its specified safety function, no compensatory measures are required. The condition report documenting the non-conservative technical specification is screened as operable degraded nonconforming (DNC) as required by GL-91-18 and this license application request (LAR) is submitted to request permission to revise technical specifications to eliminate the non-conservative allowable value.

4.0 REGULATORY SAFETY ANALYSIS

NRC GL 91-18 provides generic guidance to licensees on the type and time frame of any required corrective action for resolution of degraded and nonconforming conditions. As stated in the GL, whenever degraded or nonconforming conditions are discovered, 10 CFR Part 50, Appendix B, requires prompt corrective action to correct or resolve the condition. In the case of a deficient TS, this includes the evaluation of compensatory measures, such as administrative controls, in accordance with 10 CFR 50.59 and prompt actions to correct the TS. This request for license amendment provides the GGNS-specific actions to resolve the degraded or nonconforming condition. GGNS has determined that the proposed changes do not require any exemptions or relief from regulatory requirements, other than the TS, and do not affect conformance with any draft General Design Criteria differently than described in the GGNS UFSAR, as described below.

4.1 Applicable Regulatory Requirements/Criteria

Regulatory requirement 10 CFR 50.36, "Technical Specifications," provides the content required in a licensee's TS. Specifically, 10 CFR 50.36(c)(3) requires that the TS include surveillance requirements. The proposed TS allowable value (AV) change continues to support the requirements of 10 CFR 50.36(c)(3) to assure that the necessary quality of systems and components is maintained, that facility operation will be within safety limits, and that the limiting conditions for operation are met.

Calculation JC-Q1E31-N685-1 "RCIC Turbine Isolation on Low Inlet Steam Pressure" determines the instrument loop uncertainty, limiting allowable values and setpoints for instrument loops to isolate the RCIC Turbine on low inlet steam pressure to protect the turbine. This calculation documents the methodology and assumptions used for the calculation. The revision to the calculation did not result in a setpoint change; only the allowable value was required to be changed. This request for license amendment provides the GGNS specific calculation used to determine the setpoint and allowable value evaluation and provides a description of the methodology used by GGNS to complete the evaluation for the specific TS SR being revised.

In conclusion, based on the considerations discussed above, (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the

GNRO-2012/00132 Attachment 1 Page 4 of 6

Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

4.2 No Significant Hazards Consideration

10 CFR 50.91(a)(1) requires that licensee requests for operating license amendments be accompanied by an evaluation of no significant hazard posed by issuance of the amendment. Entergy has evaluated this proposed amendment with respect to the criteria given in 10 CFR 50.92(c). The following is the evaluation required by 10 CFR 50.91(a)(1). Entergy is requesting an amendment of the Operating License for the Grand Gulf Nuclear Station (GGNS) to revise the Technical Specification (TS) Allowable Value (AV) for Primary Containment and Drywell Isolation Instrumentation Function 3.c "RCIC Steam Supply Line Pressure – Low".

Entergy has evaluated whether or not a significant hazards consideration is involved with the proposed amendment by focusing on the three standards set forth in 10 CFR 50.92, "Issuance of amendment," as discussed below:

1. Does the proposed change involve a significant increase in the probability or consequences of an accident previously evaluated?

Response: No.

The proposed TS allowable value change involves a change in the margin between the allowable value and the setpoint. The proposed TS change does not change the trip setpoint. The proposed TS change does not degrade the performance of, or increase the challenges to, any safety systems assumed to function in the accident analysis. The proposed TS change does not impact the usefulness of the SRs in evaluating the operability of required systems and components, or the way in which the surveillances are performed. In addition, the the trip setpoint for the associated TRM function is not considered an initiator of any analyzed accident, nor does a revision to the allowable value introduce any accident initiators. Therefore, the proposed change does not involve a significant increase in the probability of an accident previously evaluated.

The consequences of a previously evaluated accident are not significantly increased. The proposed change does not affect the performance of any equipment credited to mitigate the radiological consequences of an accident. Evaluation of the proposed TS changes demonstrated that the availability of credited equipment is not significantly affected because of the reduction in margin between the allowable value and the trip setpoint.

Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Does the proposed change create the possibility of a new or different kind of accident from any accident previously evaluated?

Response: No.

The proposed TS change involves a change in the allowable value setting to correct a non-conservative value. The proposed TS change does not introduce any failure mechanisms of a different type than those previously evaluated, since there are no physical changes being made to the facility.

No new or different equipment is being installed. No installed equipment is being operated in a different manner. As a result, no new failure modes are being introduced. The way surveillance tests are performed remains unchanged.

Therefore, the proposed change does not create the possibility of a new or different kind of accident from any previously evaluated.

3. Do the proposed changes involve a significant reduction in a margin of safety?

Response: No.

The proposed TS change involves a change in the allowable value setting to correct a non-conservative value. The impact of the change on system availability is not significant, based on the frequency of the testing being unchanged, the existence of redundant systems and equipment, and overall system reliability. The proposed change does not significantly impact the condition or performance of structures, systems, and components relied upon for accident mitigation. The proposed change does not result in any hardware changes or in any changes to the analytical limits assumed in accident analyses. Existing operating margin between plant conditions and actual plant setpoints is not significantly reduced due to these changes. The proposed change does not impact any safety analysis assumptions or results.

Therefore, the proposed change does not involve a significant reduction in a margin of safety.

Based on the responses to the above questions, GGNS concludes that the proposed amendment with respect to the TS AV change presents no significant hazards consideration under the standards set forth in 10 CFR 50.92(c) and, accordingly, a finding of "no significant hazards consideration" is justified.

4.3 Conclusion

In conclusion, based on the considerations discussed above, (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commissions regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

GNRO-2012/00132 Attachment 1 Page 6 of 6

5.0 ENVIRONMENTAL CONSIDERATION

The proposed change would change a requirement with respect to installation or use of a facility component located within the restricted area, as defined in 10 CFR 20, and would change an inspection or surveillance requirement. However, the proposed change does not involve (i) a significant hazards consideration, (ii) a significant change in the types or significant increase in the amounts of any effluent that may be released offsite, or (iii) a significant increase in individual or cumulative occupational radiation exposure. Accordingly, the proposed change meets the eligibility criterion for categorical exclusion set forth in 10 CFR 51.22(c)(9). Therefore, pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the proposed change.

6.0 REFERENCES

- 6.1 NRC Administrative Letter 98-10, "Dispositioning of Technical Specifications that are Insufficient to Assure Plant Safety" dated December 29, 1989
- 6.2 RIS-2005-20 Revision 1, Revision to NRC Inspection Manual Part 9900 Technical Guidance, "Operability Determinations & Functionality Assessments for Resolution of Degraded or Nonconforming Conditions Adverse to Quality or Safety" Dated April 16, 2008
- **6.3** Technical Specification Taskforce Traveler Improved Standard Technical Specifications Change Traveler, TSTF 493, Revision 4, "Clarify Application of Setpoint Methodology for LSSS Functions.
- 6.4 Calculation JC-Q1E31-N685-1 "RCIC Turbine Isolation on Low Inlet Steam Pressure"
- **6.5** JS-09 Rev. 1 "Methodology for the Generation of Instrument Loop Uncertainty & Setpoint Calculations."

Attachment 2

GNRO-2012/00132

Proposed Technical Specification Changes (Mark-up)

ter a vertilitäite devon soona on maanka olee on maankade säärenden maa

s come - mantered construction projection consideration

Primary Containment and Drywell Isolation Instrumentation 3.3.6.1

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
3. Rea Coo Iso	ctor Core Isolation ling (RCIC) System lation					
a.	RCIC Steam Line Flow—High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 64 inches water
þ.	RCIC Steam Line Flow Time Delay	1,2,3	ï	f	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.7	≥ 3 seconds and ≤ 7 seconds
c.	RCIC Steam Supply Line Pressure—Low	1,2(d) ^{,3(d)}	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	€ ≥ 53 psig
đ.	RCIC Turbine Exhaust Diaphragm Pressure—High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 20 psig
e.	RCIC Equipment Room Ambient Temperature — High	1.2.3	1	ŕ	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 191°F
f.	Main Steam Line Tunnel Ambient Temperature — High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 191°F
g.,	Main Steam Line Tunnel Temperature Timer	1.2,3	1	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.7	≤ 30 minutes
h.	RHR Equipment Room Ambient Temperature — High	1,2,3	l per room	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 171°F
i .	RCIC/RHR Steam Line Flow - High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 43 inches water
						(continued)

Table 3.3.6.1-1 (page 3 of 5) Primary Containment and Drywell Isolation Instrumentation

(d) Not required to be OPERABLE in MODE 2 or 3 with reactor steam dome pressure less than 150 psig during reactor startup.

GRAND GULF

а.

_

....

3.3-56

n 9) in 191 mar 191 with a state and a state of the state

1

Amendment No. 120, 162

Attachment 3

GNRO-2012/00132

Revised Technical Specification Changes (Clean Copy)

5 A -

and a second second

or second and the

......

mer nin en se mense

Table 3.3.6.1-1 (page 3 of 5) Primary Containment and Drywell Isolation Instrumentation

	FUNCTION	APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS	REQUIRED CHANNELS PER TRIP SYSTEM	CONDITIONS REFERENCED FROM REQUIRED ACTION C.1	SURVEILLANCE REQUIREMENTS	ALLOWABLE VALUE
3. Re Co Isc	actor Core Isolation oling (RCIC) System vlation					
а.	RCIC Steam Line Flow C High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	\leq 64 inches water
b.	RCIC Steam Line Flow Time Delay	1,2,3	1	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.7	\geq 3 seconds and \leq 7 seconds
c.	RCIC Steam Supply Line Pressure C Low	1,2 ^(d) ,3 ^(d)	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≥ 57 psig
d.	RCIC Turbine Exhaust Diaphragm Pressure C High	1,2,3	2	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	\leq 20 psig
e.	RCIC Equipment Room Ambient Temperature C High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 191EF
f.	Main Steam Line Tunnel Ambient Temperature C High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 191EF
g.	Main Steam Line Tunnel Temperature Timer	1,2,3	1	F	SR 3.3.6.1.2 SR 3.3.6.1.4 SR 3.3.6.1.7	\leq 30 minutes
h.	RHR Equipment Room Ambient Temperature C High	1,2,3	1 per room	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.5 SR 3.3.6.1.7	≤ 171EF
i.	RCIC/RHR Steam Line Flow – High	1,2,3	1	F	SR 3.3.6.1.1 SR 3.3.6.1.2 SR 3.3.6.1.3 SR 3.3.6.1.6 SR 3.3.6.1.7	≤ 43 inches water
						(continued)

^(d) Not required to be OPERABLE in MODE 2 or 3 with reactor steam dome pressure less than 150 psig during reactor startup.

GRAND GULF

. .

and the second second

Amendment No. 120, 162

Attachment 4

GNRO-2012/00132

Calculation JC-Q1E31-N685-1 "RCIC Turbine Isolation on Low Inlet Steam Pressure"

ANO-1 ANO-2 JAF PNPS		GNS BS	□ IP-2 □ VY	☐ IP-3 ☐ W3	🗌 PLP
CALCULATION	⁽¹⁾ EC #	<u>39554</u>	•		⁽²⁾ Page 1 of <u>41</u>
COVER PAGE					
(3) Design Basis Calc. XYES	S 🗌 NC) (4)	CALCU	LATION	
⁽³⁾ Calculation No: JC-Q1E3	31-N685-1			******	(6) Revision: 001
⁽⁷⁾ Title: Instrument Loop Un E31 Loop N685 RCIC Turbing	certainty and solution of the	nd Setpoint I on Low Inlet	Determinatio Steam Press	n for System	⁽⁸⁾ Editorial
⁽⁹⁾ System(s): E31		(10) Review	w Org (Depa	rtment): NF	E (l&C Design)
(11) Safety Class:		⁽¹²⁾ Comp	onent/Equi	pment/Structu	re Type/Number:
Safety / Quality Related	ram	1E31N085	A,B	1E31N	V685A,B
La rion Darcey Related					
⁽¹³⁾ Document Type: J05.02					
⁽¹⁴⁾ Keywords (Description/To Codes): setpoint, uncertainty, R turbine	pical RCIC,				
	1	REVIE	VS		
(15) Name/Signature/Date Monocology Mary Contaro / 11-1-12 See associated EC	Name/Signat Robin Smit	the sector $\frac{1}{2} \frac{1}{12} $	(17) Nai Thomas W. THOMAS V See	me/Signature/Date Thoute 11/6/12 J. THORNTON associated EC	
Responsible Engineer	gn Verifier ewer		Super	visor/Approval	
	🛛 Comr	ments Attach	ed		nts Attached

÷



and the second second

CALCULATION SHEET

CALCULATION NO. JC-Q1E31-N685-1 SHEET 2 OF 41 REV. 1

SHEET_	2	OF	

Revision	Record of Revision
0	Original Issue
1	EC-39554. Revised to incorporate GEXI2000-00134, GIN 96-02302, updated references and referenced information, calculated PM error in section 5.11.1. Revised and reformatted calculation to meet current requirements of JS09. Incorporated 24 month drift per JC-Q1111-09019. Added computation of ALT and AFT per TSTF-493.
······	

- 1. The specific scalar and scalar and scalar and scalar and scalar scalar scalar scalar scalar and scal scalar and sc scalar and scalar scalar scalar and scal



CALCULATION NO. JC-Q1E31-N685-1

SHEET_3__OF _41___

_____ REV.___1

CALCULATION **REFERENCE SHEET**

----+-

CALCULATION NO: JC-Q1E31-N685-1 Rev 1

I. EC MARKUPs INCORPORATED (N/A to NP calculations): None

II Relationships:	Sht	Rev	Input	Output	Impact	Tracking No.
			Doc	Doc	Y/N	
1. JS09	0	001	Ø		N	
2. J1250L	024A	001	Ø		N	
3. J1250L	024B	001			N	
4. 06-IC-1E31-Q-1016	-	107	Ø		N	
5. M1090A	0	019			N	
6. 22A3124	0	005	N		N	······
7. 22A3735AA	0	004	Ø		N	······································
8. GIN96-02302	-	0	Ŋ		N	
9. GEXI2000-00134	-	0	V		N	
10. 460000047	0	300	Ŋ		N	
11. 460002635	0	300	Ŋ		N	
12. PERR91-6068	-	001	N		N	
13. A0012	0	015	Ŋ		N	
14. 184C4571	001	009	Ŋ		N	
15. 164C5150	001	018	Y		N	
16. 169C8394	002	008	V		N	
17. 865E517	002	014	$\mathbf{\nabla}$		N	
18. NEDC31336	-	0	M		N	
19. E100.0	0	007	Ŋ		N	
20. 865E516	002	008	Ø		N	
21. 368X543BA	0	044	N		N	
22. 368X551BA	0	021	Ø		N	
23. FSK-I-9999-249-C	-	006	Ø		N	
24. FSK-S-1090A-082-C	0	009	Z		N	
25. FSK-I-9999-152-C	-	009	Ŋ		N	
26. FSK-S-1090A-016-C	0	013	X		N	
27. FSK-S-1090A-017-C	0	015	Ø		N	
28. 06-IC-1E31-R-1016	-	103	Ø		N	
29. JC-Q1111-09019	0	000	Ø		N	
30. GGNS-NE-11-00011	0	000	Z		N	



9 - S. I. S.

CALCULATION SHEET

 SHEET ______
 OF ______

 CALCULATION NO. _____
 JC-Q1E31-N685-1
 REV. _____

IEE	T	0	
	_	 	

II Rel	ationships:	Sht	Rev	Input	Output	Impact	Tracking No.	
				Doc	Doc	Y/N		
31. J	1507A	0	001	<u>⊻</u>		N		
32. J	0400	0	018	 ⊻		N		
33. J	0401	0	014	<u>⊿</u>		<u>N</u>		
34. A	.0120	0	016	M		N		
35. A	.0014	0	009	N		N		
36. C	2P0399	-	013			N		
37. 4	60003606	0	300	M		N		
Ш.	III. CROSS REFERENCES:							
1.	1. Asset Suite Equipment Data Base (EDB)							
2.	UFSAR, Section 5.4.6							
3.	Technical Specifications,	Table 3	.3.6.1-1					
4.	Technical Specifications,	Table T	'R3.3.6	.1-1				
5.	"Flow Measurement Eng Book Company, 1983	ineering	Handb	ook" by R.W	.Miller, publi	shed by Mo	cGraw-Hill	
6.	ASME Steam Tables, Six	cth Editio	0 n					
IV.	SOFTWARE USED:							
Title:_	<u>N/A</u>	Ve	rsion/R	elease:	Disk/(CD No		
V.	DISK/CDS INCLUDE):						
Title:_	N/A	Ver	rsion/R	elease	Disk/(CD No		
VI.	OTHER CHANGES:	n <u></u>						
Relate	d references removed from	n the cal	culation	1:				
EDP 3	2, ES-19, 368X533, API 9	90/1253,	EAR E	900158, 06-1	IC-1E31-R-00	023, 46000	0944	
e.								

1. F. Construction of the descent state of the descent of the second state of the s

	CALCULATION	SHEET	
CALCULATION NO. JC-Q1E	231-N685-1	SHEET <u>5</u> OF REV	_ <u>41</u>

TABLE OF CONTENTS

<u>SHEET</u>

SECTION

1.0	PURPOSE	6
2.0	DESIGN REQUIREMENTS	6
3.0	REFERENCES	7
4.0	GIVEN	9
5.0	ASSUMPTIONS	14
6.0	METHODOLOGY	19
7.0	CALCULATION	21
8.0	CONCLUSION	27

ATTACHMENTS

. .

1	Design Verification	(5 sheets)
2	Owner's Review Comments	(6 sheets)

- (Chernel All and a second seco



1.0 PURPOSE

The purpose of this calculation is to determine the instrument loop uncertainties, limiting allowable values and setpoints for instrument loops 1E31-N685A & B. The values generated by this calculation are in accordance with reference 3.1.1.

2.0 DESIGN REQUIREMENTS

Design Basis Description

The RCIC system is provided to assure adequate core cooling in the event of reactor isolation from its primary heat sink and the loss of feedwater flow to the reactor vessel without requiring actuation of any of the Emergency Core Cooling System equipment (Ref. 3.1.28).

The RCIC turbine is tripped and isolated from its steam supply when the supply pressure drops below that required for safe operation. 1E31-PT-N085 monitors the pressure in the RCIC steam supply line just downstream of its tap off the Main Steam Line and, through trip switch 1E31-PIS-N685, furnishes a trip signal on decreasing pressure to the RCIC steam isolation valve trip logic (Ref. 3.1.30, 3.1.28).

Design Basis Event (DBE)

Since the RCIC turbine is not required for any design basis accidents, the initiating event for RCIC steam supply isolation is low reactor steam pressure in the event of reactor isolation from its primary heat sink and the loss of feedwater flow to the reactor vessel. This event would cause the suppression pool to heat up, but would not change any of the environmental conditions in the drywell or the containment. Therefore, these instruments do not have to operate during accident conditions.

These instruments are classified as QF1 (Ref. 3.2.3). Therefore, this equipment is required to operate under SSE (Safe Shutdown Earthquake) conditions. However per Reference 3.1.1, seismic effects are not required to be considered for setpoint loops. Therefore seismic effects will not be considered for the subject loops.

Reference 3.1.32 identifies the design limit (AL) for the RCIC turbine low steam pressure as 50 psig. The Technical Specification Allowable Value (AV) is \geq 53 psig (Ref. 3.2.1). The Technical Specification nominal trip setpoint (NTSP) is \geq 60 psig (Ref. 3.2.2).



3.0 **REFERENCES**

3.1 Relationships

- 3.1.1 JS09, Instrumentation & Control Standard Safety Related Methodology For The Generation Of Instrument Loop Uncertainty & Setpoint Calculation
- 3.1.2 Loop Diagrams J1250L-024A J1250L-024B
- 3.1.3 GIN96-02302, Calculation Change Due To Replacement Of Power Supply By ER96-0514 Revision 0
- 3.1.4 M1090A, Piping & Instrumentation Diagram Leak Detection System
- 3.1.5 GEXI2000-00134, Statistical Variation Associated With Published Performance Variable
- 3.1.6 460003606, "Fluke" Fluke 45 Dual Display Digital Multimeter
- 3.1.7 NEDC31336, General Electric Instrument Setpoint Methodology
- 3.1.8 06-IC-1E31-R-1016, RCIC Steam Supply Low Pressure Calibration
- 3.1.9 460002635, "GE" Operations & Maintenance Instructions For Analog Trip System Qualified To IEEE 323-1971
- 3.1.10 460000047, Rosemount Inc. Trip/Calibration System
- 3.1.11 E100.0, Technical Specification For Environmental Safety Related Parameter
- 3.1.12 169C8394-002, Gage Pressure Transmitter
- 3.1.13 06-IC-1E31-Q-1016, RCIC Steam Supply Low Pressure Functional Test
- 3.1.14 368X543BA, Reactor Vessel & Level & Pressure Local Panel A
- 3.1.15 368X551BA, Main Steam Flow Local Panel A
- 3.1.16 865E516-002, Division 2 Residual Heat Removal Relay VB
- 3.1.17 865E517-002, Division 1 Low Pressure Core Spray & Residual Heat Removal Relay VB
- 3.1.18 164C5150-001, Purchased Part Trip Unit
- 3.1.19 184C4571-001, Purchased Part Power Supply
- 3.1.20 FSK-I-9999-249-C, 1E31-PDT-NO84 1E31-PT-N085A Instrument Tubing Run
- 3.1.21 FSK-S-1090A-082-C, DCB-27 St Fr DBA-24 Elb Ftg To PDTN084A





4.0 GIVEN

4.1 Instrument Loop Block Diagram

Transmitter	<u>Trip Unit</u>	Power	<u>P&ID</u>	Loop <u>Diagram</u>
1E31- PT-N085A,B	1E31- PIS-N685A,B	E21K702 (E21- PS2) E12K701 (E12- PS1)	3.1.4	3.1.2
		[]		

РТ	 PIS

2.5 Second device on the Andrew Conference in the second constant and a second consta



4.2 Transmitter Environment (1E31-PT-N085A,B)

Description	Data	Reference
Tag Number	1E31-PT-N085A,B	
Instrument Location:		
Panel	1H22-P004, P015	3.1.2
Room	IA313	3.1.27, 3.1.33
Environmental Conditions:		
Normal:	Zone N-068	3.1.11
Temperature	60-105°F	3.1.11
Pressure	-1.0 to -0.1 in.wg.	3.1.11
Radiation (Gamma)	3.1E03 rads (40 yr TID)	3.1.11
	0.011 Rads/hr gamma	3.1.11
Humidity	20 to 90% RH	3.1.11
DBE or Accident:	N/A	Section 2.0
Seismic Conditions:	Not Required	Section 2.0
Surveillance Intervals:	24 months	3.2.1
4.3 Trip Unit Environment		
Description	Data	Reference
Tag Number	1E31-PIS-N685A,B	
Instrument Location:		
Panel	1H13-P629, P618	3.1.2
Room	0C703/0C504	3.1.26, 3.1.34 - 3.1.36
Environmental Conditions:		
Normal:	Zone N-028	3.1.11
Temperature	69-90°F	3.1.11
Pressure	0.1 to 1.0 in wg.	3.1.11
Radiation (Gamma)	1.8E2 rads (40 yr TID)	3.1.11
	0.5 mRads/hr dose rate	
Humidity	20 to 50% RH	3.1.11
DBE or Accident:	Same as Normal	3.1.11
Surveillance Intervals	92 days	3.2.1

el Service en la companya companya de companya de la companya de companya de companya de la companya de companya



CALCULATION NO. JC-Q1E31-N685-1

SHEET__11__OF _41__ _____REV.__1____

4.4 **Transmitter Vendor Data**

Description Tag Number	<u>Data</u> 1531-PT-N085A P	Reference
3	1251-11-14005A,B	
Manufacturer	Rosemount 3.1.12	2, 3.1.14, 3.1.15
Model	1152GP7N22T0280PB 3.1.12	, 3.1.14, 3.1.15
URL	300 psig	3.1.9
Maximum span	0-300 psi	3.1.9
Minimum span	0-50 psi	3.1.9
Calibrated Span	200 psi	3.1.8
Accuracy:	$\pm 0.25\%$ span (3 σ)	3.1.9, 3.1.5
Drift:	±1.346% Span for 30 months	3.1.31
Power Supply:	$<0.005\%$ span per volt (3 σ)	3.1.9, 3.1.5
Temperature:	± 5.00% Span/100°F @ min spar ± 1.25% Span/100°F @ max spa	n (3σ) 3.1.9, n (3σ) 3.1.5
Humidity:	Sealed unit - no effects	3.1.9
Radiation:	± 5.00% URL	3.1.9
Static Press:	N/A for gauge pressure transmitte	er 3.1.9
Overpressure:	< ± 3.00% URL per 2000 psi (30) 3.1.9, 3.1.5
Seismic:	± 0.25% URL for 3g peak	3.1.9
Output Range	4-20 madc	3.1.9
Process Head Correction:	1E31-PT-N085A = +2.4 psi 1E31-PT-N085B = +14.5 psi	3.1.8 3.1.8

Antiperstance of the second



4.5 **Trip Unit Vendor Data**

Description	Data	Reference
Tag Number	1E31-PIS-N685A,B	
Manufacturer	Rosemount	3.1.16 - 3.1.18
Model	510DU/710DU	3.1.16 - 3.1.18 Assumption 5.4
Repeatability:	± 0.2% span	3.1.10, Note 1
Drift:	N/A	Assumption 5.7
Input Range	4-20 madc	3.1.10

OF

41

Note 1: Table 5 of reference 3.1.10 defines environmental conditions at the Trip Switch in terms of "operating condition" and "environment." Conditions in Zone N-028 are bounded by line 2 defined as "adverse operating conditions" and "normal environment" The corresponding line on Table 6 specifies repeatability under the defined conditions as $\pm 0.2\%$. This repeatability is valid for six months operation. An allowance for power supply effects, temperature effects, humidity effects, drift and radiation effects are included in the repeatability.

4.6 **Power Supplies**

Power Supply Nominal	24.0 volts	Assumption 5.3
Power Supply Variations	23.0 - 28 vdc	Assumption 5.3



CALCULATION NO. JC-Q1E31-N685-1

SHEET_	13	_ OF	_41
	R	EV1	

4.7 Instrument Tubing Run Data

Description	Data	Reference
Tag Number	1E31-PT-N085A; B	
Room Normal Temp (N-068) Accident Temp Vertical Rise (ft)	1A313 3.1 60-105°F N/A 8' 3" (1E31-PT-N085A) 7' 6-3/4" (1E31-PT-N085B)	1.20, 3.1.21, 3.1.27 3.1.11 Section 2.0 3.1.20, 3.1.21 3.1.22, 3.1.23
Room Normal Temp (N-003) Accident Temp Vertical Rise (ft)	1A112 3.1.2 65-150°F N/A 12' 3-1/2" (1E31-PT-N085A +21' 0" (1E31-PT-N085B)	22 - 3.1.25, 3.1.27 3.1.11 Section 2.0) 3.1.21 3.1.22, 3.1.24



5.0 ASSUMPTIONS

- 5.1 All uncertainties given in vendor data specifications are assumed to be 2 sigma unless otherwise specified.
- 5.2 Per reference 3.1.1, the M&TE error is normally assumed to be equal to the reference accuracy of the transmitter. Per reference 3.1.8, a Fluke 45 (± 0.040 ma, Ref. 3.1.6) and a pressure gauge (± 0.5 psi) are used to calibrate the transmitters. The total M&TE error (MTE_{call}) for this device is the SRSS of the two. Converting the ma error to psi: (0.040 ma)(200 psi / 16 ma) = 0.5 psi. The SRSS of 0.5 and 0.5 is ± 0.71 psi. The setting tolerance from reference 3.1.8 is ± 0.04 ma, or ± 0.5 psi. As the test equipment error is larger than the reference accuracy of the transmitter (± 0.34 psi) and the setting tolerance, ± 0.71 psi will be assumed for the M&TE error.

Per reference 3.1.13, a Rosemount readout assembly is used to calibrate the Rosemount trip units. Per reference 3.1.10, the accuracy of the readout assembly (MTE_{cal2}) is ±0.01 ma, which is equal to $(0.01 \text{ ma})(200 \text{ psi}/16 \text{ ma}) = \pm 0.13 \text{ psi}$ and the accuracy of the trip unit is ±0.20% span = $0.20\%(200 \text{ psi}) = \pm 0.40 \text{ psi}$. Reference 3.1.13 specifies a setting tolerance of ±0.04 ma = (0.04)(200/16) = 0.5 psi. The larger ±0.5 psi setting tolerance value will be assumed for the M&TE error.

- 5.3 A maximum value of 28 vdc and minimum of 23 vdc will be assumed for power supply variation, as this is the value provided in PPD 184C4571 for the 24 vdc power supplies (Ref. 3.1.19). This results in an assumed voltage variation of +4, -1 vdc. Per reference 3.1.3, the loop power supplies were replaced with a Vicor model VI-N53-IM DC-DC converter that has a maximum variation of 0.55%, which is bounded by the original power supply variation. For conservatism, ±4 vdc will be used in this calculation.
- 5.4 Since Rosemount 510DU model is obsolete, they may be replaced with 710DU models in the future (Ref. 3.1.29). The performance specifications for the 710DU is equal to or better than those of the 510DU.
- 5.5 Overpressure consists of pressure above the URL, in this case 300 psi (Section 4.4). Normally, the transmitter sees full RCS pressure, approximately 1150 psi. Therefore, the transmitter may see overpressure conditions prior to performing its trip function. Since overpressure is a non-linear effect, the full value will be used.
- **5.6** The radiation drift for the transmitters and trip units is assumed to be negligible because of the low normal dose rates. Per reference 3.1.7 section 2.6, there is no effect on transmitters below 0.1 Mrad.



CALCULATION NO. JC-Q1E31-N685-1

SHEET <u>15</u> OF <u>41</u> _____ REV. 1

- 5.7 The accuracy of the Rosemount trip units $(\pm 0.20\% \text{ span})$ is valid for six months (Ref. 3.1.10). The trip units are calibrated every 115 days (Assumption 5.9). Therefore, drift is included in reference accuracy.
- 5.8 Harsh environments may affect the cabling by reducing insulation resistance. Since this loop does not have to work during accident conditions (Section 2.0), no cable degradation is expected and $IR = \pm 0.0$ psi.
- 5.9 A calibration interval of 30 months will be assumed for the transmitters, which is the nominal 24-month period, plus a 25% grace period (Ref. 3.2.1). A calibration interval of 115 days will be assumed for the trip units which is the nominal 92 day period, plus a 25% grace period (Ref. 3.2.1).
- 5.10 This loop does not employ a primary element separate from the pressure transmitter. Therefore, no additional errors due to inaccuracies in the primary element exist and PE = ± 0.0 psi.
- 5.11 Three sources of process measurement error exist in this application: one due to the water filled tubing, one due to the location of the tap on the piping, and the other due to ambient pressure during accident conditions.
 - 1. Process Measurement errors can arise from changes in density of water in sensing line (tubing) used to connect the transmitter to the process line. Since the error is in a definite direction, the PM error will be a bias term. Each tubing run is sufficiently different that maximum error will be calculated for each tubing run and the largest error used in the calculation.

The method used will be to compare the calibrated static head correction to the static head conditions during the minimum and maximum environmental conditions. This is done by summing the heads due to each of the vertical lengths in different environments. The difference between these values will be the change due to actual plant conditions, which is the process measurement error desired.

Head $= \Sigma$ [vertical length * density]

Process Measurement Error = Head (actual) - Head (calibrated)

(Note that if the actual static head is higher than the calibrated head, the transmitter output will be higher than desired: a positive PM error).

For N085B loop, the PM error will be determined for the minimum temperature and maximum pressure (1150 psig, Assumption 5.5) during normal conditions and the maximum temperature and minimum pressure (0 psig, conservatively) during normal conditions. For the N085A loop, because the transmitter is located above the penetration and the static head effect is reversed for the length of tubing between the penetration and the transmitter,



CALCULATION NO. JC-Q1E31-N685-1

SHEET<u>16</u>OF <u>41</u> ______REV.<u>1</u>____

the temperature/pressure extremes for that portion of tubing will be reversed as well. Per section 2.0, these loops are not required to operate during accident conditions. Section 4.7 lists the environments and vertical runs. The various water densities for these temperature and pressures can be found in reference 3.2.6. Note that:

density $(lb/ft^3) / 1728 = density (lb/in^3)$

Loop: N085A Calibration Process Head Correction: 2.4 psi (Ref. 3.1.8)				
	Max	Static Head	Conditions	
Length	Temp	Press	Density	Head
-99 in	105°F	0 psig	61.93 lb/ft ³	-3.548 psi
147.5 in	65°F	1150 psig	62.57 lb/ft ³	5.341 psi
Maximum Static Head +1.793 psi			+1.793 psi	
	Min	Static Head	Conditions	
		Static Head	conditions	
Length	Temp	Press	Density	Head
Length -99 in	Temp 60°F	Press 1150 psig	Density 62.60 lb/ft ³	Head -3.586 psi
Length -99 in 147.5 in	Temp 60°F 150°F	Press 1150 psig 0 psig	Density 62.60 lb/ft ³ 61.19 lb/ft ³	Head -3.586 psi 5.223 psi
Length -99 in 147.5 in Minimum Static	Temp 60°F 150°F Head	Press 1150 psig 0 psig	Density 62.60 lb/ft ³ 61.19 lb/ft ³	Head -3.586 psi 5.223 psi +1.637 psi
Length -99 in 147.5 in Minimum Static Loop N085A	Temp 60°F 150°F Head	Press 1150 psig 0 psig PM (max	$\frac{\text{Density}}{62.60 \text{ lb/ft}^3}$ 61.19 lb/ft^3 $\text{static head} = $	Head -3.586 psi 5.223 psi +1.637 psi -0.607 psi



CALCULATION NO. JC-Q1E31-N685-1

SHEET 17 OF

____OF __41_ REV. 1

Loop: N085B				
Calibration Process Head Correction: 14.5 psi (Ref. 3.1.8)				
Max Static Head Conditions				
Length	Temp	Press	Density	Head
90.75 in	60°F	1150 psig	62.60 lb/ft ³	3.288 psi
252 in	65°F	1150 psig	62.57 lb/ft ³	9.125 psi
Maximum Static Head+12.413 psi				
	Min	Static Head	Conditions	
	IVIIII	Static Head	Conditions	
Length	Temp	Press	Density	Head
Length 90.75 in	Temp 105°F	Press 0 psig	Density 61.93 lb/ft ³	Head 3.252 psi
Length 90.75 in 252 in	Temp 105°F 150°F	Press 0 psig 0 psig	Density 61.93 lb/ft ³ 61.19 lb/ft ³	Head 3.252 psi 8.924 psi
Length 90.75 in 252 in Minimum Static	Temp 105°F 150°F Head	Press 0 psig 0 psig	Density 61.93 lb/ft ³ 61.19 lb/ft ³	Head 3.252 psi 8.924 psi +12.176 psi
Length 90.75 in 252 in Minimum Static Loop N085B	Temp 105°F 150°F Head	Press 0 psig 0 psig PM (max	$\frac{\text{Density}}{61.93 \text{ lb/ft}^3}$ 61.19 lb/ft^3 $\text{static head} = $	Head 3.252 psi 8.924 psi +12.176 psi -2.087 psi

Because this is a decreasing setpoint, negative bias errors need not be considered. Therefore, the PM error due to density variation is zero.

2. The loop employs elbow taps in the main steam line for pressure measurement points. The flow around the elbow causes a high pressure area on the outside of the elbow and a low pressure area on the inside, the square root of the difference being proportional to the flow (Ref. 3.2.4).

1E31-PT-N085A taps off the outside of an elbow. This results in PT-N085A reading higher than actual system pressure, a positive bias error. 1E31-PT-N085B taps off the inside of the elbow. The effects are exactly the same, but results in 1E31-PT-N085B reading lower than system pressure, a negative bias error.

1E31-PDT-N084 measures this differential pressure and generates a trip signal on high differential pressure corresponding to high steam flow, an indication of a steam line break. From reference 3.2.1, the allowable value for this trip is 64 inwc. Half of this is due to elevating the pressure at the outer tap, half due to the drop at the inner tap (Ref. 3.2.4).



Therefore, 1E31-PT-N085A will read from 0 to 32 inches high as flow varies from 0 to the allowable value. This must be treated as a positive bias error, since it always makes the reading high.

Similarly, 1E31-PT-N085B will read from 0 to 32 inches low as flow varies from 0 to the allowable value. This must be treated as a negative bias error. Since this will cause an early trip, no credit will be taken for it, and the worst case value will be used:

$$PM = +32$$
 inches

3. The final source of process error arises from the fact that 1E31-PT-N085 actually measures differential pressure between the process and local ambient pressure (psig). Since this loop does not have to work during accident conditions (Section 2.0), no significant variation in local ambient pressure is expected (Section 4.2), and no error will exist due to this effect.



6.0 METHODOLOGY

6.1 Device Uncertainties

For each module, the uncertainty terms applicable to this application will be specified and combined into the following module errors:

RA	-	reference accuracy
L	-	negative bias uncertainty
Μ	-	positive bias uncertainty
MTE	-	measurement and test equipment inaccuracies
D	-	drift

6.2 Loop Uncertainties

The random and bias components of:

PE	-	errors associated with the Primary Element
PM	-	errors in Process Measurement, and
IR	-	errors due to degradation in Insulation Resistance

will be quantified, the loop error equation given, and the device and loop uncertainties combined to produce:

A _L	-	SRSS of all device random uncertainties except drift
L	-	The sum of all negative bias uncertainties
M_L	-	The sum of all positive bias uncertainties
CL	-	SRSS of all measurement and test equipment imacuracies
		used for calibration.
DL	-	SRSS of all drifts
LU	-	SRSS(A _L , C _L , PE, PM) \pm IR - L ₁ + M ₁

6.3 Total Loop Uncertainty

The total loop uncertainty will be calculated using the reference 3.1.1 equation:

 $TLU = LU + D_L$

6.4 Allowable Value

The allowable value for the loop will be calculated using the r^{-1} ence 3.1.1 equation:

$$AV = AL \pm LU$$



6.5 Nominal Trip Setpoint

The nominal trip setpoint will be calculated using the reference 3.1.1 equation:

 $NTSP = AL \pm TLU$

6.6 Spurious Trip Avoidance

The probability of a spurious trip during normal plant operation using the Tech Spec setpoint will be evaluated using the methodology of reference 3.1.1 and calculated loop errors. Per reference 3.1.1, a 95% probability of no spurious trip is acceptable.

6.7 LER Avoidance

The probability of exceeding the Tech Spec allowable value without a trip at the tech spec setpoint will be evaluated using the methodology of reference 3.1.1 and calculated loop errors. Per reference 3.1.1, a 90% probability of avoiding LERs is acceptable.

Note: When considering the probability of a spurious trip, any late actuation will be conservative. Similarly, when considering the probability of an LER, any early actuation will be conservative. This means that single sided distributions are appropriate for this evaluation. Per reference 3.1.1, a Z of 1.645 corresponds to a probability of 95%. Similarly, a Z of 1.28 corresponds to a probability of 90%.

6.8 Nomenclature

The nomenclature of reference 3.1.1, Section 1.6, will be used. Errors associated with the transmitter will be subscripted with a "1", errors associated with the trip unit will be subscripted with a "2", while loop errors will be subscripted with an "L". For example, D_1 would be the transmitter drift, D_2 would be the trip unit drift, and D_L would be the loop drift.

6.9 Worst Case Loop

The equipment and environments for each loop are identical; therefore, no worst case calculation is required.



7.0 CALCULATION

7.1 Transmitter Uncertainties

Using the vendor data from Section 4.4:

URL	= 300 psig
SPAN	= 200 psi
RA ₁	$= \pm 0.25\% \text{ span } (3\sigma)$ = \pm (2/3)*(0.0025)*(200) psi = \pm 0.34 psi

Temperature effect is specified at maximum and minimum span (Section 4.5). Maximum and minimum spans are 300 psi and 50 psi (Ref. 3.1.9). Using a linear interpolation between these values for the temperature effect at 200 psi:

(Cal Sp - Min Sp) =(X-TE @ Min Sp)(Max Sp – Min Sp) (TE @ Max Sp - TE @ Min Sp)(200 - 50)(X - 5.00)= (300 - 50)(1.25 - 5.00)150*(-3.75) = 250X - 1250X = (150*(-3.75)) + 1250250 X = 2.75 TE $= \pm 2.75\%$ Span/100°F (3 σ) $= \pm (2/3)^*(0.0275)^*(200 \text{ psi})$ $= \pm 3.67 \text{ psi}/100^{\circ}\text{F}$

Temperature effect will be broken into TD (65-90°F per reference 3.1.1), TEN (90-105°F, the balance of the normal range from Section 4.2). Per Section 2.0, no accident conditions need to be addressed.

Therefore:

TD	= $(3.67)*(25/100)$ = ± 0.92 psi				
TEN	= (3.67)*(15/100) = ± 0.56 psi				
ENTERGY		LCULATION SHEET			
--	----------------------------------	---	----------------------------	--	--
CALCULATION NO	• D. <u>JC-Q1E31-N6</u>	SHEET <u>22</u> 585-1	OF <u>41</u> REV1		
Per reference 3.1.9, humidity has no effect on the sealed transmitter.					
	HE	$= \pm 0.00 \text{ psi}$			
]	Radiation Drift (nor	mal)			
	RD ₁	$= \pm 0.00 \text{ psi}$	Assumption 5.6		
	Per Section 4.6, the	worst power supply variations are take	en as ± 4.0 volts.		
	PSı	= $\pm 0.005\%$ span / volt variation (2 = $\pm (2/3)*(0.00005)*(200 \text{ psi})*(4)$ = $\pm 0.03 \text{ psi}$	3σ) volts)		
:	Seismic Effect				
	SE	= ± 0.00 psi	Section 2.0		
	Overpressure Effect	:			
	OVP ₁	= \pm 3.0% URL for 2000 psi (3 σ) = \pm (2/3)*(0.03)*(300 psi) = \pm 6.00 psi	Assumption 5.5		
]	Drift				
	DR	= $\pm 1.346\%$ Span for 30 months = $\pm (0.01346)*(200 \text{ psi})$ = $\pm 2.70 \text{ psi}$			
2	Summarizing for the	e transmitter:			
	A ₁	$= \pm SRSS(RA_1, TEN_1, PS_1, SE_1, C)$ = \pm SRSS(0.34, 0.56, 0.03, 0.00, 6) = \pm 6.04 psi	0VP ₁) .00)		
	L ₁ M ₁	= + 0.0 psi = - 0.0 psi			
	Cı	$= \pm 0.71 \text{ psi}$	Assumption 5.2		
	Dı	= \pm SRSS(DR ₁ , TD ₁) = \pm SRSS(2.70, 0.92) psi = \pm 2.86 psi			

- Koharri kanakana dari tarih dalam



Using the vendor values from Section 4.5:

	Span	= 200 psi	
	A ₂	= \pm 0.20% span = \pm (0.0020)*(200 psi) = \pm 0.40 psi	
	L ₂ M ₂	= + 0.00 psi = - 0.00 psi	
	C ₂	= ± 0.50 psi	Assumption 5.2
	D ₂	$=\pm 0.00$ psi	Assumption 5.7
7.3	Primary Element	Accuracy	
	PE	= ±0.0 psi	Assumption 5.10
7.4	Process Measurem	ent Accuracy	
	PM	= +1.16 psi	Assumption 5.11
7.5	Insulation Resistan	nce Bias	
	IR	= 0.0 psi	Assumption 5.8
7.6	Loop Uncertaintie	S	
	Using the equations	from reference 3.1.1 and the	values from above:
	$A_{L} = \pm SRSS(A)$ $= \pm SRSS(6)$ $= \pm 6.06 \text{ psi}$	A1, A2) .04, 0.40)	
	$L_L = L_1 + L_2 = M_1 + M_2 $	-0.0 psi = +0.0 psi	

 $C_{L} = \pm SRSS(C_{1}, C_{2})$ $= \pm SRSS(0.71, 0.50)$ $= \pm 0.87 \text{ psi}$



CALCULATION SHEET

SHEET 24 OF 41

CALCULATION NO. JC-Q1E31-N685-1

REV. 1

- D_L $=\pm$ SRSS(D₁, D₂) $=\pm$ SRSS(2.86, 0.00) $= \pm 2.86 \text{ psi}$
- LU+ = + SRSS(A_L, C_L) + PM = + SRSS(6.06, 0.87) + 1.16 = + 7.29 psi

7.7 **Total Loop Uncertainty**

 $TLU = LU_+ + D_L$ =7.29 + 2.86= + 10.15 psi

7.8 **Allowable Value**

AV $= AL + LU_{+}$ = 50 + 7.29= 57.29 psig

The Technical Specification Allowable Value of \geq 53.0 psig, is non-conservative with respect to the calculated AV value.

Based on the reference 3.1.1, section 7, statistical techniques may be considered to reduce margin. Because the setpoint is approached from only one direction and there is no increasing setpoint, the setpoint errors (LU) have a single side of interest and may be reduced by a factor of 1.645 / 2 to maintain a 95% probability of a trip.

 $LU'_{+} = ((LU_{+} - PM)*1.645 / 2) + PM.$ =((7.29-1.16)*0.8225)+1.16= 5.05 + 1.16= + 6.21 psi

AV' = 50 + 6.21= 56.21 psig

The calculated AV does not support the existing Technical Specification Allowable Value of \geq 53.0 psig. Therefore a new technical specification allowable value of \geq 57 psig is **recommended**.



Nominal Trip Setpoint

NTSP

= AL + TLU = 50 psig + 10.15 psi = 60.15 psig

The Technical Specification NTSP of ≥ 60.0 psig, is non-conservative with respect to the calculated NTSP value.

Per Section 7 of reference 3.1.1, TLU may be reduced by using the single-sided distribution and SRSS (LU,D_L) methods. Therefore:

 $TLU' = (1.645/2)(SRSS(LU_+, D_L))$ = (0.8225)(SRSS((7.29 - 1.16), 2.86)) + 1.16= + 6.73 psig

Recalculating NTSP

NTSP' = AL + TLU'= 50 + 6.73= 56.73 psig

The Technical Specification NTSP and plant setpoint of 60 psig is conservative with respect to the calculated value.

7.10 **Spurious Trip Avoidance**

Ζ = ABS(NTSP - X_T) / SRSS(Sigma_n, Sigma_i) where:

Sigma_i = (1/n)*(SRSS((LU'₊ - PM), D_L))+ PM Ref. 3.1.1 = 2 n Assumption 5.1 Sigma_i = (1/2)*(SRSS((6.21 - 1.16), 2.86)) + 1.16 = 4.07

Reference 3.2.5 notes that the RCIC turbine steam input pressure in the LP (Low Pressure) Condition cannot fall below 135 psig. Trips below this limit would not be considered spurious since there is no longer any need for the RCIC turbine.

XT = 135 psi

The confidence of this X_T is high; therefore, the appropriate value of Sigma_N is zero.

 $Sigma_N = 0.00$



7.11 LER Avoidance

Using the recommended AV of 57 psig from section 7.8:

Z = $ABS(AV-NTSP) / 1/n*SRSS(A_L, C_L, D_L)$ Ref. 3.1.1 = $ABS(57 - 60) / \frac{1}{2} SRSS(6.06, 0.87, 2.86)$ = 0.88

This is <u>below</u> the Section 6.7 minimum acceptable Z value of 1.28 for 90%.



7.12 As-Left Tolerance

Note: For the purposes of calculating ALT, the actual MTE values, MTE_{1cal} and MTE_{2cal} , are used.

ALT_T – Transmitter TSTF-493 Calculation

MTE _{1cal}	=	± 0.71 psi	Assumption 5.2
ALTT	=	\pm SRSS (RA ₁ , MTE _{1cal})	•
	=	± SRSS (0.34, 0.71) psi	
	=	± 0.79 psi	

Converting to loop current:

 $ALT_T = \pm (0.79 \text{ psi}/200 \text{ psi})*16 \text{ mA}$

$$= \pm 0.06 \text{ mA}$$

ALT_{Tcal} – Transmitter As-Left Tolerance for Calibration Procedures

In field calibration procedures, use only the Reference Accuracy (RA) for establishing the Transmitter ALT.

 $\begin{array}{rcl} ALT_{Tcal} &=& RA_1 &=& \pm 0.34 \mbox{ psi}\\ Converting to loop current:\\ ALT_{Tcal} &=& \pm (0.34 \mbox{ psi}/200 \mbox{ psi}) * 16 \mbox{ mA}\\ &=& \pm 0.03 \mbox{ mA} \end{array}$

The current calibration setting tolerance for the transmitter is ± 0.04 mA, which is conservative to the TSTF-493 required value. Because of perceived difficulty in calibration to the derived value, the current ALT is retained.

 $ALT_{Tcal} = \pm 0.04 \text{ mA}$

ALT_{TU} – Trip Unit TSTF-493 Calculation

MTE _{2cal}	=	± 0.13 psi	Assumption 5.2
ALT _{TU}	=	\pm SRSS (A ₂ , MTE _{2cal})	
	=	± SRSS (0.40, 0.13)	
	=	± 0.42 psi	



CALCULATION NO. JC-Q1E31-N685-1

ENTERGY

SHEET <u>28</u> OF <u>41</u>

 $\frac{1}{\text{REV. } 1}$

Converting to loop current:

ALT_{TU} = \pm (0.42 psi/200 psi) * 16 mA = \pm 0.03 mA

ALT_{TUcal} - Trip Unit for Calibration Procedures

In field calibration procedures, use only the Reference Accuracy (RA) for establishing the Trip Unit ALT.

 $ALT_{TUcal} = A_2$ = ± 0.40 psi

Converting to loop current:

ALT_{TUcal} = $\pm (0.40 \text{ psi}/200 \text{ psi}) * 16 \text{ mA}$ = $\pm 0.03 \text{ mA}$

7.13 As-Found Tolerance (AFT)

AFT_T - Transmitter TSTF-493 Calculation

For calculating AFT_T, the actual MTE value is used:

 $AFT_{T} = \pm SRSS (RA_{1}, MTE_{1cal}, D_{1}) psi$ = $\pm SRSS (0.34, 0.71, 2.86) psi$ = $\pm 2.97 psi$

Converting to loop current:

 $AFT_T = \pm (2.97 \text{ psi}/200 \text{ psi}) * 16 \text{ mA}$ = $\pm 0.24 \text{ mA}$

AFT_{Tcal} – Transmitter As-Found Parameter for Field Procedures

Defining AFT_{Tcal} , the value used in calibration procedures for monitoring performance:

Surveillance Interval = 30 Months DR₁ = $\pm 2.70 \text{ psi}$ AFT_{Tcal} = DR₁ = $\pm 2.70 \text{ psi}$ = $\pm (2.70 \text{ psi}/200 \text{ psi}) * 16 \text{ mA}$ = $\pm 0.22 \text{ mA}$

AFT_{TU} – Trip Unit TSTF-493 Calculation

The surveillance period for the trip units is 115 days.



$$= \pm SRSS (0.40, 0.13, 0) psi = \pm 0.42 psi$$

Converting to loop current:

AFT_{TU} =
$$\pm (0.42 \text{ psi}/200 \text{ psi}) * 16 \text{ mA}$$

= $\pm 0.03 \text{ mA}$

AFT_{TUcal} - Trip Unit As-Found Parameter for Field Procedures

Surveillance Interval = 115 Days $D_2 = \pm 0.00 \text{ psi}$ Because there is no drift value for the trip unit, AFT_{TUcal} will be set equal to AFT_{TU} . $AFT_{TUcal} = AFT_{TU}$ $= \pm 0.42 \text{ psi}/200 \text{ psi} * 16 \text{ mA}$ $= \pm 0.03 \text{ mA}$

7.14 Loop Tolerances

ALT_L – As-Left Loop Tolerance

$$ALT_L = \pm SRSS (ALT_{Tcal}, ALT_{TUcal})$$

= $\pm SRSS (0.34, 0.40) \text{ psi}$
= $\pm 0.52 \text{ psi}$
= $\pm (0.52 \text{ psi}/200 \text{ psi}) * 16 \text{ mA}$
= $\pm 0.04 \text{ mA}$

AFT_L – As-Found Loop Tolerance

AFTL		\pm SRSS (AFT _{Tcal} , AFT _{TUcal})
	=	±SRSS (2.70, 0.42) psi
	=	± 2.73 psi
	=	± (2.73 psi/200 psi) * 16 mA
	=	± 0.22 mA



8.0 CONCLUSION

The Technical Specification allowable value is non conservative with respect to the calculated values. The Technical Specification NTSP is conservative with respect to the calculated values. Using the recommended AV yields unfavorable LER avoidance.

	SUMMARY OF RES	SULTS
SYST	EM	E31
LOOP NU	MBERS	N685A,B
TOTAL LOOP UI	NCERTAINTY	+6.73 psi
LOOP UNCE	RTAINTY	+ 6.21 psi
DRIFT ALLOWANCE		± 2.86 psi
M&1	TE	± 0.87 psi
	SPECIFIED (psig)	CALCULATED (psig)
Design Limit	50	-
Allowable Value	≥ 53 ≥ 57**	56.21
Nominal Trip Setpoint ≥ 60		56.73

** Recommended value

Summary of Calibration Tolerances	
Transmitter As-Left Tolerance TSTF-493 (ALT _T)	±0.06 mA
Transmitter ALT Cal (ALT _{Tcal})	±0.04 mA
Trip Unit As-Left Tolerance TSTF-493 (ALT _{TU})	±0.03 mA
Trip Unit ALT Cal (ALT _{TUcal})	±0.03 mA
Transmitter AFT TSTF-493 (AFT _T)	±0.24 mA
Transmitter AFT Cal (AFT _{Tcal})	±0.22 mA
Trip Unit AFT TSTF-493 (AFT _{TU})	±0.03 mA
Trip Unit AFT Cal (AFT _{TUcal})	±0.03 mA
As-Left Loop Tolerance (ALT _L)	±0.52 psi
As-Left Loop Tolerance (ALT _L)	±0.04 mA
As-Found Loop Tolerance (AFT _L)	±2.73 psi
As-Found Loop Tolerance (AFT _L)	±0.22 mA

		ATTACH DESIGN VE	IMENT 1 RIFICATION	JC-Q1E31-N Si	685-1, Rev. 1 HEET 31 OF 41
Sheet 1 of 1	DESIG	N VERIFICATIO			
ANO-1	☐ ANO-2 ☐ VY	☐ iP-2 ⊠ GGNS	IP-3 IRBS	☐ JAF ☐ W3	PLP NP
Document No.	JC-Q1E31-N685-1		Revision No. 1	Page 1 of 4	
Title: Instrum Isolatic	aent Loop Uncertainty an on on Low Inlet Steam Pr	d Setpoint Determinati essure	on for System E31 Lo	op N685 RCIC T	urbine
DV Method:	Quality Related Design Review	Augmented Qu	uality Related	fication Testing	

VERIEICA	TION PROLUBED	DISCIPLING	
TEIGHICK HOR REQUIRED		DISCIPLINE	VERIFICATION COMPLETE AND
1			COMMENTS RESOLVED (DV print size
			of the state of the state of the sign,
			and date)
		Electrical	
		Mechanical	
	\boxtimes	Instrument and Control	Robin Smith
		Civil/Structural	program in inc
		Nuclear	
<u></u>		MO Cathlan II	1.10
Unginator:	Mary Coffaro	/ www.	-1-12
		Print/Sign And After Comm	ante Have Dave Durit 1
		Alter Colum	ieurs nave been kesolved
	1		

e e e este este aconstruction de la construction de la construction de la construction de la construction de la

.

ATTACHMENT 1 DESIGN VERIFICATION

JC-Q1E31-N685-1, Rev. 1 SHEET 32 OF 41

ATTACHMENT 9.6 DESIGN VERIFICATION				ON CHECKLIST
Sheet 1 of 3				
IDENTIFICATIO	N:			DISCIPLINE:
Document Title:	Instrument Loop Uncerta Loop N685 RCIC Turbin	inty and Setpoint Determine Isolation on Low Inlet S	nation for System E31 team Pressure	
Doc. No.:	JC-Q1E31-N685-	1 Rev. 1	QA Cat.: SR	
Verifier:	<u>Robin Smith</u> Print	<u>See AS for signature</u> Sign	Date	
Manager authorizatic supervisor performin	n for g			Other
Verification.				
🛛 N/A				
	Print	Sign	Date	
METHOD OF VER	IFICATION:			
Design Review 🛛		Alternate Calculations	Quali	fication Test

The following basic questions are addressed as applicable, during the performance of any design verification. [ANSI N45.2.11 – 1974] [NP] [QAPD, Part II, Section 3] [NQA-1-1994, Part II, BR 3, Supplement 3s-1].

- NOTE The reviewer can use the "Comments/Continuation sheet" at the end for entering any comment/resolution along with the appropriate question number. Additional items with new question numbers can also be entered.
- 1. Design Inputs Were the inputs correctly selected and incorporated into the design?

(Design inputs include design bases, plant operational conditions, performance requirements, regulatory requirements and commitments, codes, standards, field data, etc. All information used as design inputs should have been reviewed and approved by the responsible design organization, as applicable.

identifying inputs.)

All inputs need to be retrievable or excerpts of documents used should be attached. See site specific design input procedures for guidence in identified.

Dee site i	specific design input	procedures for guidance in
Yes 🛛	No 🗖	N/A

- 2. Assumptions Are assumptions necessary to perform the design activity adequately described and reasonable? Where necessary, are assumptions identified for subsequent re-verification when the detailed activities are completed? Are the latest applicable revisions of design documents utilized? Yes ⊠ No □ N/A □

			ATTACHMENT 1 DESIGN VERIFICATION	JC-Q1E31-N685-1, REV. 1 SHEET 33 OF 41
ATTA	CHMENT 9.6		Design Ver	FICATION CHECKLIST
Shee	t 2 of 3			
4.	Codes, Stand requirements, in Yes 🖾	lards and Regulat ncluding issue and a No []	ory Requirements – Are the applicable codes addenda properly identified and are their require N/A	, standards and regulatory ements for design met?
5.	Construction considered?	and Operating E	xperience – Have applicable construction a	and operating experience been
	Yes 🗖	No 🗖	N/A 🖾	
6.	Interfaces –	Have the design in	nterface requirements hear active a state	10
	Yes 🗌	No 🗌	N/A 🛛	cumented?
7.	Methods – W Yes ⊠	/as an appropriate No □	e design or analytical (for calculations) met	hod used?
8.	Design Outp	uts – Is the output	t reasonable compared to the inputs?	
			N/A []	
9.	Parts, Equipr required appli	nent and Processe cation?	es – Are the specified parts, equipment, and	processes suitable for the
	Yes 🗌	No 🗖	N/A 🛛	
10.	Materials Co environmental	mpatibility – Are conditions to whi	the specified materials compatible with each ich the material will be exposed?	h other and the design
	Yes 🗖	No 🗖	N/A 🖾	
11.	Maintenance Yes 🗖	requirements – H No □	ave adequate maintenance features and req	uirements been specified?
12.	Accessibility	for Maintenance	- Are accessibility and other design provisi	ions adequate for performance of
	Yes 🗌	No 🗌	N/A 🛛	
13.	Accessibility service inspect	for In-service Institution expected to be	pection – Has adequate accessibility been p e required during the plant life?	provided to perform the in-
	Yes 🗖	No 🗖	N/A	
14.	Radiation Exp personnel?	oosure – Has the c	lesign properly considered radiation exposi	ure to the public and plant
	Yes 🗌	No 🗖	N/A	
5.	Acceptance C verification that	riteria – Are the a	ecceptance criteria incorporated in the desig	n documents sufficient to allow
	Yes 🛛	No 🗌	N/A	,
6.	Test Requiren	nents – Have adeq	uate pre-operational and subsequent period	lic test requirements been
	Yes		N/A 🕅	

			ATTACHMENT 1 DESIGN VERIFICATION	JC-Q1E31-N685-1, REV. 1 N SHEET 34 OF 41
Αττα	CHMENT 9.6		Desic	IN VERIFICATION CHECKLIST
Sheet	: 3 of 3			
17.	Handling, requirement	Storage, Cleaning s specified?	and Shipping – Are adequate handlin	ng, storage, cleaning and shipping
	Yes 🗖	No 🗖	N/A 🖾	
18.	Identificati	on Requirements	- Are adequate identification require	ments specified?
	Yes 🗖	No 🗖	N/A 🛛	
19.	Records ar adequately s documentatio Yes 🛛	nd Documentation pecified? Are all d n storage method? No 🗌	 Are requirements for record prepare ocuments prepared in a clear legible man Have all impacted documents been identi N/A 	ration, review, approval, retention, etc., ner suitable for microfilming and/or other fied for update as necessary?
20.	Software Q GOTHIC, S site SQA Pro ENS sites: T the calculation Yes	Puality Assurance- YMCORD), was i ogram? his is an EN-IT-1 on? No 🗆	ENN sites: For a calculation that util t properly verified and validated in a 04 task. However, per ENS-DC-126, N/A 🖾	lized software applications (e.g., ccordance with EN- IT-104 or previous for exempt software, was it verified in
21.	Has advers verified, bee	e impact on peripl n considered?	eral components and systems, outsid	e the boundary of the document being
	Yes 🗖	No 🗖	N/A 🖾	

ATTACHMENT 1 DESIGN VERIFICATION

JC-Q1E31-N685-1, REV. 1 SHEET 35 OF 41

ATTACHMENT 9.7

DESIGN VERIFICATION COMMENT SHEET

Comments / Continuation Sheet

Ouestion	Comments		
#	Conunerus	Resolution	Initial/Date
<u> </u>			
	Density-related PM error should be	Incorporated. (This section moved to	PS/01412
	determined in Assumption 5.14 for normal		K5/9-14-12
	conditions	5.11).	
	conditions.		
<u>}</u>			

enery collification contents of a second

ATTACHMENT 2 OWNER'S REVIEW COMMENTS

JC-Q1E31-N685-1, REV. 1 SHEET 36 OF 41



ATTACHMENT 9.10 SHEET 1 OF 1

ENGINEERING CHANGE COMMENT FORM

Comment No.	Reviewer	Department / Discipline / Program	Comment	Comment Date	Resolution	Date
Owner's Review Comments to JC-Q1E31-N685-1 (EC 39554) General Issues 1 R. Hannigan Services reference for the Design Basis 8/10/12 The subject paragraph was not affected						
		Corp.	Events statement listed in Section 2. Need to add a cross-reference for this. Should also check accident analyses and confirm the events credited. That whole paragraph under "Design Basis Event (DBE)" is confusing and poorly written. I realize it may be out of Enercon's scope but it would be nice to rework it. Paragraph under "Design Basis Event (DBE)" What value does the 2 rd sentence provide? It appears that the 2 rd sentence is supposed to be the justification for the next sentence stating that these instruments do not have to operate under accident conditions but it isn't clear. Again, this may be out of Enercon's scope.		of the calculation and is not required to be updated. The 2nd sentence of the paragraph is basically stating that the suppression pool heatup caused by RCIC operation has an insignificant affect on the surrounding environment.	

onientalio orientenalitzialitzialenalitziaren erazioaren erazioaren eta erazioaren eta erazioaren eta eta eta e

			ATTACHMEN OWNER'S REVIEW (T 2 COMMEN	JC-Q1E31	-N685-1, REV. 1 SHEET 37 OF 41
Comment No.	Reviewer	Department / Discipline / Program	Comment	Comment Date	Resolution	Date Resolved
		2	Owner's Review Comments to JC-C	21E31-N685	-1 (EC 39554)	I
2	R. Hannigan	EXCEL Services Corp.	Section 2.0 – 2 nd paragraph under Design Basis Events – prior to using terms QF1 and SSE consider defining them. Also, is this paragraph supposed to be under the "Design Basis Event (DBE)" heading or is it a separate subject, i.e. "Seismic Requirements"? I realize that may change based on new direction from 8/16/2 telecon.	8/10/12	Defined SSE. At GGNS SE in normally addressed under DBE.	09/26/12
3	R. Hannigan	EXCEL Services Corp.	Section 2.0 – last paragraph – if the 50 psig Design Limit is going to be used to replace the previous Analytical then it should be clearly stated in this section. If so then for the remainder of the calculation you should use the term Design Limit or "DL". Also, for this section consider not listing the previous AV & NTSP but rather state that this revision will establish new AV & NTSP in association with the 24 Month Project. We know that there are going to be AV and possibly NTSP changes so might as well state it here. Also, is this paragraph still a sub- part under the heading "Design Basis Event (DBE)" or should there should be a new heading?	8/10/12	Added (AL) after design limit. This is an adequate method of noting this. This calculation is consistent with GGNS setpoint calculation format. Generally AL and technical specification values are identified after DBE.	09/26/12

na de la companya de la contra companya de la comp

			ATTACHMEN OWNER'S REVIEW (T 2 COMMEN	JC-Q1E3	1-N685-1, Rev.
Comment No.	Reviewer	Department / Discipline / Program	Comment	Comment Date	Resolution	Date Resolved
		2	wner's Review Comments to JC-0	21E31-N685	-1 (EC 39554)	
4	R. Hannigan	EXCEL Services Corp.	Reference 3.1.9 – need to correct to 460002635.	8/10/12	Changed reference 460000944 to 460002635.	09/26/12
5	R. Hannigan	EXCEL Services Corp.	Section 4.2 – The TID rad dose for Zone N-068 has been changed in E100.0 Rev. 7 to 3.1E3 Rads. The dose rate has been changed	8/10/12	Incorporated.	09/26/12
			in E100.0 Rev. 7 to 0.011 Rad/hr.			
6	R. Hannigan	EXCEL Services Corp.	Section 4.3 – The temperature for Zone N-028 has been changed in E100.0 Rev. 7 to 69 – 90F.	8/10/12	Incorporated.	09/26/12
7	R. Hannigan	EXCEL Services Corp.	Section 4.4 – Process Head Correction referenced in this section differs from that in Ref 3.1.8 (surv test 06-IC-1E31-R- 1016). The head correction for 1E31-PT-N085A & B is +2.1/+13.3 psi in surv test vs. +2.4/+14.5 psi in calc.	8/10/12	The <u>process</u> head stated in the calculation agrees with reference 3.1.8. No change required.	09/26/12
8	R. Hannigan	EXCEL Services Corp.	Section 4.4 – Need to redo Rosemount transmitter uncertainties based on new direction regarding 2σ/3σ values. This should help knock down the Overpressure Uncertainty.	8/10/12	Incorporated the new guidelines concerning Rosemount transmitter confidence levels into the calculation.	09/26/12

Learner permit a straight promi

en ander en anter en

e te stalkante traverse en alt

			ATTACHMEN OWNER'S REVIEW (T 2 COMMEN	JC-Q1E31	-N685-1, REV. 4
Comment No.	Reviewer	Department / Discipline / Program	Comment	Comment Date	Resolution	Date Resolved
		9	Owner's Review Comments to JC-	21E31-N685	-1 (EC 39554)	1
9	R. Hannigan	EXCEL Services Corp.	Section 4.7 – When referring to the transmitters be consistent with the tag name – if you are going to express it as 1E31-PT-N085A & B then use the same tag id throughout the step and the rest of the calc.	8/10/12	Revised tag numbers in section 4.7.	09/26/12
			Same for trip units – be consistent with tag names.			
10	R. Hannigan	EXCEL Services Corp.	Section 5.1– Modify/remove as per new direction regarding Rosemount transmitter uncertainty.	8/10/12	Incorporated based on new guidelines.	09/26/12
11	R. Hannigan	EXCEL Services Corp.	Section 5.3 – Why are you using the ± 4 volts if both power supplies have been replaced with the better converters?	8/10/12	Any gains in using different values for power supply effect is negligible since the total power supply effect is 0.03 psi currently.	09/26/12
12	R. Hannigan	EXCEL Services Corp.	Section 5.14 – When you are computing the Max & Min Static Head Conditions it appears as though you have sensing lines that are seeing 0 psig in one section and 1150 psig in an adjacent connected section. That isn't possible. Do you really mean to do that?	8/10/12	This technique is applied to the A loop only because the transmitter is located above the penetration as explained in section 5.14.1. (This section moved to 5.11).	09/26/12

Development of the second consideration

			OWNER'S REVIEW	COMMEN	JC-Q1E3	1-N685-1, Rev. Sheet 40 of 4
Comment No.	Reviewer	Department / Discipline / Program	Comment	Comment Date	Resolution	Date Resolved
			Owner's Review Comments to JC-	Q1E31-N685	-1 (EC 39554)	
13	R. Hannigan	EXCEL Services Corp.	Section 5.14 – For the loop N085A & B PM value at the bottom of the table explain how you derived those values from the table and exactly what these values mean – it isn't clear. I figured it out but you might want to just add how you came up with the value.	8/10/12	This is explained in section 5.14.1 in the paragraph preceding the actual calculations. This is an adequate method of presenting this material. (This section moved to 5.11).	09/26/12
14	R. Hannigan	EXCEL Services Corp.	Section 7.1 – The TD_1 temperature effect should be 60F to 90F – not 65F to 90F. This will affect TD1, D1, and DL computations.	8/10/12	JS09 section 3.2.3 (65F – 90F).	09/26/12
15	R. Hannigan	EXCEL Services Corp.	Section 7.1 – Need to redo Rosemount transmitter uncertainties based on new direction regarding 20/30 values. This should help knock down the Overpressure Uncertainty.	8/10/12	Incorporated the new guidelines concerning Rosemount transmitter confidence levels into the calculation.	09/26/12
16	R. Hannigan	EXCEL Services Corp.	Section 7.1 – Delete seismic from A1 computation per new direction.	8/10/12	Incorporated the new guidelines concerning SE into the calculation.	09/26/12

ersten of an entropy and the manufacture of the control of the control of the control of the second state of the

EN-DC-115, Rev. 10

.

			ATTACHMEN OWNER'S REVIEW	T 2 COMMEN	rs	JC-Q1E31-N685-1, REV. 1 SHEET 41 OF 41
Comment No.	Reviewer	Department / Discipline / Program	Comment	Comment Date	Resolution	Date Resolved
	1	9	Owner's Review Comments to JC-4	21E31-N685	-1 (EC 39554)	
17	R. Hannigan	EXCEL Services Corp.	Section 7.8 – If we adopt the Design Limit then replace AL with DL. Also, should we change the approach to go from saying that the AV is non-conservative to saying that we are establishing a new AV in association with the 24 Month Project? This may be outside your scope or direction – if so disregard.	8/10/12	See response to item 3.	09/26/12
18	R. Hannigan	EXCEL Services Corp.	Section 7.9 – If we adopt the Design Limit then replace AL with DL.	8/10/12	See response to item 3.	09/26/12
19	R. Hannigan	EXCEL Services Corp.	Section 7.10 – In the sentence starting with "Reference 3.2.5 notes" define term "LP" before using it.	8/10/12	Incorporated.	09/26/12
20	R. Hannigan	EXCEL Services Corp.	Section 8.0 – The AV will definitely be exceeded although you may be ok with the NTSP. Would it be better to say in this section that new AV and NTSP values are being generated to support the 24 Month Projec?	8/10/12	GGNS to determine. Left as is.	09/26/12

dimension construction

- -----

Attachment 5

GNRO-2012/00132

JS09 Revision 1 "Grand Gulf Nuclear Station Instrument and Control Standard Methodology For The Generation Of Instrument Loop Uncertainty & Setpoint Calculations"

and the second state of the second second

Engineering Change Mark-up	EC #: 39605		Page 1 of 7		
DOC #: JS09			SHT # 0	REV 1	
Before View		Contro	Room Drawin	g: 🔲	
Supersedes Mark-up from EC #: N/A			Issued per ECN #: N/A		
Tim Bryant Prepared By:	<u>9/21/12</u> Date	<u>S</u>	ee AS Reviewer Name	e (Optional)	

STANDARD NO.; GGNS-JS-09 REVISION: 1 PAGE 3 of 32

SECTION I: PURPOSE

EN-DC-200)

SECTION 2: SCOPE and ORGANIZATION

This standard is based on ISA RP67.04 Part II, 1994, - <u>Methodologies for the Determination</u> of <u>Setpoints for Nuclear Safety-Related Instrumentation</u> and NEDC 31336P-A, 1996, - General Electric Instrument Setpoint Methodology.

The topical areas listed below are discussed in the following sections of this document:

- Terminology to be used in the generation of instrument loop uncertainty and setpoint calculations (Section 3)
- Methodology to be used in the generation of setpoint calculations for Nuclear Safety-Related Instrumentation which are addressed in the GGNS Technical Specifications (Section 4)
- Methodology to be used in the generation of setpoint calculations for Nuclear Safety-Related Instrumentation which do not form a part of the GGNS Technical Specifications (Section 5)
- Methodology to be used in the generation of general instrument indication uncertainty calculations (Section 6)
- Methods to be used to increase calculated margins (Section 7)
- Methodology for determining the probability of Spurious Trips and the probability of occurrence of events which would result in Licensee Event Reports (Appendix A)
- Analytical techniques for determining possible measurement uncertainty effects due to specific process variations (Appendix B)
- Analytical techniques for determining possible measurement uncertainty due to degraded loop insulation resistance (Appendix C)

Engineering Change Mark-up Continuation Sheet						
Before View	EC #:39605	Page	2 of 7			
DOC #: JS09		SHT # 0	REV 1			
		STANDARD N REVISION: 1 PAGE 7 of 32				

Repeatability

Repeatability is defined as the closeness of agreement among a number of consecutive measurements of the output for the same value of the input under the same operating conditions approaching from the same direction, for full range transverses. [Ref. 8.2]

3.2.3 Temperature Effects - TE

Temperature Effects are defined as the changes in the input/output relationship of a device due to fluctuations in the ambient temperature to which the device is exposed.

This effect may only be assumed to be applicable for temperature variations outside the assumed normal calibration temperature range of 65°F to 90°F (i.e. from the minimum expected ambient temperature to 65°F or from 90°F up to the maximum expected ambient temperature). The effects of temperature variations within the calibration temperature band must be addressed under Temperature Drift effects (See Section 3.2.12). [Ref. 8.3]

3.2.4 Humidity Effects - HE

Humidity Effects are defined as the changes in the input/output relationship of a device due to fluctuations in the ambient humidity levels to which the device is exposed. [Ref. 8.3]

3.2.5 Seismic Effects - SE

Seismic Effects are defined as the changes in the input/output relationship of a device due to the effects of seismic vibrations during or after a seismic event. [Ref. 8.3] Consideration of seismic effects is not required in Grand Gulf setpoint or indication uncertainty calculations. A Safe Shutdown Earthquake (SSE) occurring concurrently with a Design Basis Event (DBE) is not considered credible. [Ref. 8.7] If an SSE or OBE were to occur, the plant is required to promptly shutdown. [Ref. 8.11] Prior to re-start, affected transmitters must be re-calibrated. [Ref. 8.7] Seismic Effect errors for seismic events below the OBE threshold are considered insignificant because the OBE threshold is very low (0.075g).

3.2.6 Radiation Effects - RE

Radiation Effects are defined as the changes in the input/output relationship of a device due to radiation exposure considering both the dose rate and total dose. [Ref. 8.3]

Engineering Change Mark-up Continuation Sheet					
Before View	EC #:39605	Pag	ge 3 of 7		
DOC #: JS09		SHT # 0	REV 1		

STANDARD NO.: GGNS-JS-09 REVISION: 1 PAGE 8 of 32

3.2.7 Power Supply Effects - PS

Power Supply Effects are defined as the changes in the input/output relationship of a device due to fluctuations in the power supply feeding the device. Voltage and/or frequency fluctuations may result in Power Supply Effects. [Ref. 8.1]

3.2.8 Static Pressure Effect - SPE

Static Pressure Effect is defined as the uncertainty introduced in differential pressure instruments which are calibrated at a static pressure that is different from the normal operating pressure. SPE may affect both the span and zero of the instrument.

3.2.9 Overpressure Effects - OVP

Overpressure Effects are defined as the changes in the input/output relationship of a pressure sensing device after exposure to process pressure in excess of its specified Upper Range Limit.

3.2.10 Device Drift - DR

Drift is defined as an undesired change in output over a period of time where change is unrelated to the input, environment or load. [Ref 8.1] Uncertainty due to drift is dependent on the calibration frequency of the device. Drift values can be based on published vendor specifications or the values can be determined based on statistical analysis of as-found/as-left calibration data per ECH-NE-08-00015 and EPRI TR-103335 rev 1.

3.2.11 Radiation Drift - RD

Radiation Drift is defined as the time dependant change in the input/output relationship of a device that can be directly related to radiation exposure.

3.2.12 Temperature Drift - TD

Temperature Drift is defined as the change in the input/output relationship of a device due to ambient temperature swings over a calibration period.

Engineering Change Mark-up Continuation Sheet						
Before View	EC #:39605		Page 4	of 7		
doc #: JS09		SHT # (0	REV 1		

STANDARD NO.: GGNS-JS-09 REVISION: 1 PAGE 9 of 32

Temperature Drift effects may be assumed to be applicable only over the expected range of temperature during calibration (typically 65°F to 90°F). The possible uncertainty due to temperature variations outside this range is addressed under Temperature Effects. (See Section 3.2.3) [Ref. 8.3]

3.2.13 Measurement and Test Equipment Effects - MTE

Measurement and Test Equipment Effects are defined as those uncertainties introduced into a device as a result of the uncertainties associated with the equipment used to calibrate the device. MTE values can be based on published specifications of the test equipment. When confirmed to be conservative MTE can be also set equal to either the reference accuracy or the tolerance specified in the calibration procedure (whichever is larger).

3.3 Loop Specific Random Uncertainty Terms

3.3.1 Loop Device Uncertainty - AL

The Loop Device Uncertainty is defined as the square root sum of the squares (SRSS) of all the individual Device Uncertainty terms for a given instrument loop. [Ref. 8.3]

3.3.2 Loop Calibration Uncertainty - C1

The Loop Calibration Uncertainty is defined as the SRSS of all the Measurement and Test Equipment effects that may be incurred during calibration of each of the devices in a given loop. [Ref. 8.3]

3.3.3 Loop Drift - DL

The Loop Drift is defined as the SRSS of the all the drift terms for each of the loop devices. The Loop Drift includes (as applicable) allowances for Device Drift, Temperature Drift, and Radiation Drift for each device in the loop. [Ref. 8.3]

3.3.4 Process Measurement Uncertainty - PM

Process Measurement Uncertainties are those uncertainties that may be introduced in an instrument loop due to limitations in modeling the physical system; or more commonly, those uncertainties introduced in an instrument loop due to fluctuations in the process for which the loop instrumentation cannot automatically compensate. (see Appendix B) For the Reactor water level setpoint calculations, the density changes in the reactor vessel do not need to be considered when calculating PM error. Per NEDC 31336, only the density changes in the reference and variable legs need to be considered.

STANDARD NO.: JS-09 REVISION: 1 PAGE 17 of 32

Engineering Change Mark-up Continuation Sheet				
Before View	EC #:39605		Page 5	of 7
DOC #: JS09		SHT #)	REV 1

4.6 Spurious Trip and LER Avoidance Analysis

A Spurious Trip and LER Avoidance Analysis must be performed as described in Appendix A to demonstrate the acceptability of the setpoint margins. These analyses must be performed for the setpoint that is employed in the field. These analyses are not required for calculated setpoints that are not to be implemented in the field.

4.7 Calculation of As-Left Tolerance – ALT [Ref. 8.9]

For the purposes of calculating the ALT, actual (published) MTE values are used instead of using the assumption that MTE = RA. (Section 4.1.2)

 $ALT = \pm SRSS (RA, MTE)$

Since a smaller ALT is more conservative it is acceptable to ignore MTE and simplify the equation.

$$ALT = RA$$

4.8 Calculation of As-Found Tolerance - AFT [Ref. 8.9]

For the purposes of calculating the AFT, the actual (published) MTE value is used instead of the assumption that MTE = RA.

 $AFT = \pm SRSS (RA, MTE, DR)$

Drift values determined by statistical analysis of historical as-found/as-left calibration data is actually a combination of RA, MTE and DR because there is no deterministic method to separate these individual components. The AFT equation can therefore be simplified when statistically derived drift values are utilized.

$AFT = \pm DR$

4.9 As-Left Loop Tolerance and As-Found Loop Tolerance [Ref. 8.9]

The equation for As-Left Loop Tolerance would be:

 $ALT_L = \pm SRSS (ALT_{1cal}, ALT_{2cal}, ..., ALT_{Xcal})$

The equation for As-Found Loop Tolerance would be:

 $AFT_L = \pm SRSS (AFT_{1cal}, AFT_{2cal}, ..., AFT_{Xcal})$

Engineering Change Mark-up Continuation Sheet				
Before View	EC #:39605		Page 6	of 7
DOC #: JS09		SHT #	0	REV 1

STANDARD NO.: GGNS-JS-09 REVISION: 1 PAGE 31 of 32

6.3 Calculation of Total Loop Uncertainty - TLU



SECTION 7: METHODS FOR INCREASING CALCULATED MARGINS

Calculations generated using the methodology presented in this standard may, due to the indepth treatment of the uncertainty terms, generate setpoint and instrument uncertainty estimates which are more conservative than previously calculated values.

If in the generation of setpoints and loop Allowable Values, a large difference is noted between the existing and calculated values, various techniques should be considered to isolate and possibly reduce these differences if appropriate.

In certain cases, the following may be valid techniques to reduce calculated uncertainty terms:

- 7.1 Review the environmental limits to reduce them as necessary to reflect only the specific event requirements for which the device is required to function.
- 7.2 Review the value used for Insulation Resistance Effects to ensure that it is not overly conservative
- 7.3 Review the Measurement & Test Equipment values used in the calculation as a term to be reduced, especially if the M&TE values have been assumed to be equal to the Reference Accuracy of the individual loop devices.
- 7.4 A Single-sided Distribution approach to the uncertainty may be considered, depending on the application. This approach may not be applicable to all setpoints due to the possible impact on operational margins or other system setpoints. Note, if this approach is employed, all data should be normalized for Single-Sided Distribution. With the 2σ data applied to Single-Sided Distribution, the accuracy will exceed the 95% confidence level. (See Reference 8.3)
- 7.5 The Total Loop Uncertainty may be reduced using the square root sum of the squares approach to combine the Loop Uncertainty and the Loop Drift. Generally, this approach should be avoided since it minimizes the margin between the loop Allowable Value and the Nominal Trip Setpoint. Values calculated using this approach should be reviewed to ensure adequate margin exists between the Nominal Trip Setpoint and the Allowable Value.
- 7.6 Drift values determined by statistical analysis of historical as-found/as-left calibration data is actually a combination of RA, MTE and DR because there is no deterministic method to separate these individual components. If additional NTSP margin is required, this can be credited and the RA and MTE values can be set equal to zero.

Engineering Change Mark-up Continuation Sheet				
Before View	EC #:39605	Page	7 of 7	
DOC #: JS09		SHT # 0	REV 1	
DOC #: 3309		5111 # 0		

STANDARD NO.: GGNS-JS-09 REVISION: I PAGE 32 of 32

SECTION 8: REFERENCES

- 8.1 ISA RP67.04, Part II, 1994, <u>Methodologies for the Determination of Setpoints for</u> Nuclear Safety-Related Instrumentation
- 8.2 Process Measurement Instrument Engineers' Handbook Revised Edition Bela G. Liptak & Kristzta Venczel, 1982 - Chilton Book Co., Radnor Pennsylvania
- 8.3 NEDC-31336P-A, 1996, General Electric Instrument Setpoint Methodology W.H. Cooley, J.R., J.L. Leong, M.A. Smith, S. Wolf, - General Electric Co.
- 8.4 CRANE Technical Paper No. 410 Flow of Fluids through Valves, Fittings and Pipe CRANE Engineering Division, 1985 Crane Co.
- 8.5 Nuclear Plant Engineering Desk Top Procedure EDP-032 Rev. 1 Instrument Loop Uncertainty and Setpoint Calculations
- 8.6 USNRC Regulatory Guide 1.105 Rev. 1 Instrument Setpoints
- 8.7 EC-39605, Revise Standard JS-09 Methodology
- 8.8 EN-DC-200, Revision 0, I&C Uncertainties / Setpoint Calculations & Determinations
- 8.9 TSTF-493, Revision 4, Technical Specifications Task Force Traveler Clarify Application of Setpoint Methodology for LSSS Functions
- 8.10 ECH-NE-08-00015, Revision 0, Drift Analysis Design Guide
- 8.11 05-S-02-VI-3, Revision 107, Earthquake Off-Normal Event Procedure

STANDARD NO.: GGNS-JS-09 REVISION: 1 | DATE: 1/7/2000

GRAND GULF NUCLEAR STATION

INSTRUMENTATION AND CONTROL STANDARD

METHODOLOGY FOR THE GENERATION OF INSTRUMENT LOOP UNCERTAINTY & SETPOINT CALCULATIONS

- SAFETY RELATED -

a construction of the second second

.....

GRAND GULF NUCLEAR STATION

NUCLEAR PLANT ENGINEERING

REVIEW AND APPROVAL SHEET

STANDARD NO.: _GGNS-JS-09	REVISION:1
STANDARD TITLE: <u>Methodology for the Generation of Instrumen</u> Calculations	t Loop Uncertainty & Setpoint
This document specifies items related to nuclear safety YES	[X] NO []
This document contains Special Requirements YES	[] NO [X]
Signatures certify that the above standard was originated, verified, review	ved or waived and approved as noted below:
ORIGINATED BY: <u>Floys</u> Thom	DATE: 1/6/2000
VERIFIED BY:	DATE: 1/6/00
REVIEWED BY: <u>M.2. Mup func</u> Group Supervisor	DATE: <u>1-6-00</u>
DESIGN ENGINEERING SECTION REVIEWED BY	REVIEW WAIVED BY DATE
ELECTRICAL/I&C M.Z. Mussium	1/6/2000
MECHANICAL/CIVIL	N. Deslpand 1/6/2000
ENGINEERING PROGRAMS	Multer 1/2/2000
SAFETY ANALYSIS	Jufinit Distion 1/7/2000
ANII:	DATE:
APPROVED BY:	DATE: 1/1/00
-	

. ,

· -----

.

- Level And and an alternative descent and an alternative descent and a second and an and a second and alternative descent and a second and a second and a second as a

--

STANDARD NO.: GGNS-JS-09 REVISION: 1 PAGE 1 of 32

REVISION STATUS SHEET

STANDARD REVISION SUMMARY

REVISION	ISSUE DATE	DESCRIPTION
0	03/23/93	Issued for use
1	1/7/00	General revision & incorporate
		SCN 98/0001

PAGE REVISION STATUS

PAGE NO.	REVISION	PAGE NO.	REVISION
01	1	17	1
02	1	18	1
03	1	19	1
04	1	20	1
05	1	21	1
06	1	22	1
07	1	23	1
08	1	24	1
09	1	25	1
10	1	26	1
11	1	27	1
12	1	28	1
13	1	29	1
14	1	30	1
15	1	31	1
16	1	32	1

************* *******

· ····

APPENDIX / ATTACHMENT REVISION STATUS

APPENDIX NO.	REVISION	ATTACHMENT NO.	REVISION
Α	1	1	1
В	1		-
С	0		
D	0		

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 2 of 32

TABLE OF CONTENTS

SECTION	PAGE
1.0 PURPOSE	3
2.0 SCOPE AND ORGANIZATION	3
3.0 DEFINITIONS AND TERMINOLOGY	4
4.0 SAFETY RELATED SETPOINT CALCULATIONS (TECH. SPEC.)	11
5.0 SAFETY RELATED SETPOINT CALCULATIONS (NON-TECH. SPEC.)	19
6.0 INSTRUMENT INDICATION UNCERTAINTY CALCULATIONS	26
7.0 METHODS FOR INCREASING CALCULATED MARGINS	31
8.0 REFERENCES	32

APPENDICES

1.1.8.4 H. H.

and being one weight standard and a standard and a standard and the standard standard

-*---

Appendix A - SPURIOUS TRIP AND LER AVOIDANCE ANALYSIS
Appendix B - PROCESS MEASUREMENT UNCERTAINTIES
Appendix C - INSULATION RESISTANCE EFFECTS
Appendix D - ACRONYMS AND ABBREVIATIONS

a company procession of the second

.

STANDARD N0.: GGNS-JS-09 REVISION: 1 | PAGE 3 of 32

SECTION 1: PURPOSE

The purpose of this engineering standard is to provide the user with the basic terminology and methodology to be employed in the generation of instrument loop uncertainty and setpoint calculations at GGNS. This standard, when used in conjunction with Desktop Procedure EDP-032, will promote uniformity in instrument loop uncertainty and setpoint calculations generated by Design Engineering.

SECTION 2: SCOPE and ORGANIZATION

This standard is based on ISA RP67.04 Part II, 1994, - <u>Methodologies for the Determination</u> of Setpoints for Nuclear Safety-Related Instrumentation and NEDC 31336P-A, 1996, - General Electric Instrument Setpoint Methodology.

The topical areas listed below are discussed in the following sections of this document:

- Terminology to be used in the generation of instrument loop uncertainty and setpoint calculations (Section 3)
- Methodology to be used in the generation of setpoint calculations for Nuclear Safety-Related Instrumentation which are addressed in the GGNS Technical Specifications (Section 4)
- Methodology to be used in the generation of setpoint calculations for Nuclear Safety-Related Instrumentation which do not form a part of the GGNS Technical Specifications (Section 5)
- Methodology to be used in the generation of general instrument indication uncertainty calculations (Section 6)
- Methods to be used to increase calculated margins (Section 7)

.

- Methodology for determining the probability of Spurious Trips and the probability of occurrence of events which would result in Licensee Event Reports (Appendix A)
- Analytical techniques for determining possible measurement uncertainty effects due to specific process variations (Appendix B)
- Analytical techniques for determining possible measurement uncertainty due to degraded loop insulation resistance (Appendix C)

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 4 of 32

SECTION 3: DEFINITIONS and TERMINOLOGY

3.1 General Terminology

3.1.1 Allowable Value - AV

A limiting value that the trip setpoint may have when tested periodically, beyond which appropriate action shall be taken. [Ref. 8.1]

3.1.2 Analytical Limit - AL

The value of the sensed process variable established as part of the safety analysis prior to or at the point that a desired action is to be initiated to prevent the safety process variable from reaching the associated Licensing Safety Limit. [Ref. 8.3]

3.1.3 Abnormally Distributed Uncertainty - F

A term used to denote uncertainties that do not have a normal distribution. This type of uncertainty is treated as a bias against both the positive and negative components of a module's uncertainty [Ref. 8.1]

3.1.4 Bias

A Bias is a component of uncertainty that consistently has the same algebraic sign, and is expressed as an estimated limit of error. [Ref. 8.1]

Positive Bias - M

A Positive Bias is a known error in process measurement that consistently has a known positive value with respect to the process variable.

Negative Bias - L

A Negative Bias is a known error in process measurement that consistently has a known negative value with respect to the process variable.

Bias terms should only be accounted for if the bias acts in a conservative direction with respect to the calculated variable.

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 5 of 32

3.1.5 Design Basis Event - DBE

The limiting abnormal transient or an accident which is analyzed using the analytical limit value for the setpoint to determine the bounding value of a process variable. [Ref. 8.3]

3.1.6 Licensee Event Report - LER

A report which must be filed with the NRC by the utility when a Tech. Spec. limit is known to be exceeded, as required by 10CFR50.73. [Ref. 8.3]

3.1.7 Licensing Safety Limit - LSL

The limit on a safety process variable that is established by licensing requirements to provide conservative protection for the integrity of physical barriers that guard against uncontrolled release of radioactivity. [Ref. 8.3]

3.1.8 Limiting Normal Operating Transient - X_T

The most severe transient event affecting a process variable during normal operation for which trip initiation is to be avoided. [Ref. 8.3]

3.1.9 Process Limit - PL

The Process Limit is the limiting process value (maximum or minimum) required for proper system operation. (e.g. pump net positive suction head and min. flow requirements may be loop Process Limits)

3.1.10 Span

Span is defined as the algebraic difference between the upper and lower values of a calibrated range. [Ref. 8.1]

3.1.11 Trip Environment

The environment that exists up to and including the time when the instrument channel performs its initial safety (trip) function during an event. [Ref. 8.3]

STANDARD NO.: GGNS-JS-09 REVISION: 1 PAGE 6 of 32

3.1.12 Upper Range Limit - URL

Upper Range Limit is defined as the maximum value of the process variable that a device can accurately measure. [Ref. 8.2]

3.2 Device Specific Random Uncertainty Terms

3.2.1 Device Uncertainty - Ax

The Device Uncertainty is defined as the square root sum of the squares (SRSS) of all the applicable individual components of uncertainty associated with a given device. (i.e. the SRSS of the uncertainty effects listed in Sections 3.2.2 - 3.2.9) [Ref. 8.3]

3.2.2 Reference Accuracy - RA

Reference Accuracy (or Accuracy Rating) is a number or quantity that defines a limit that errors will not exceed when a device is used under specified operating conditions. Reference accuracy includes, as applicable, the combined effects of: deadband, hysteresis, linearity and/or repeatability. [Ref. 8.2]

Deadband

Deadband is defined as the range through which an input can be varied without initiating an observable response at the output (usually expressed in percent of span). [Ref. 8.2]

Hysteresis

Hysteresis is defined as that property of an element evidenced by the dependence of the value of the output, for a given excursion of the input, upon the history of prior excursions and the direction of the current transverse. [Ref. 8.2]

Linearity

Linearity is defined as the maximum deviation of the calibration curve (average of the upscale and downscale readings) from a straight line which is so positioned as to minimize the maximum deviation. [Ref. 8.2]

.
Repeatability

Repeatability is defined as the closeness of agreement among a number of consecutive measurements of the output for the same value of the input under the same operating conditions approaching from the same direction, for full range transverses. [Ref. 8.2]

3.2.3 Temperature Effects - TE

Temperature Effects are defined as the changes in the input/output relationship of a device due to fluctuations in the ambient temperature to which the device is exposed.

This effect may only be assumed to be applicable for temperature variations outside the assumed normal calibration temperature range of 65°F to 90°F (i.e. from the minimum expected ambient temperature to 65°F or from 90°F up to the maximum expected ambient temperature). The effects of temperature variations within the calibration temperature band must be addressed under Temperature Drift effects (See Section 3.2.12). [Ref. 8.3]

3.2.4 Humidity Effects - HE

Humidity Effects are defined as the changes in the input/output relationship of a device due to fluctuations in the ambient humidity levels to which the device is exposed. [Ref. 8.3]

3.2.5 Seismic Effects - SE

Seismic Effects are defined as the changes in the input/output relationship of a device due to the effects of seismic vibrations during or after a seismic event. [Ref. 8.3]

3.2.6 Radiation Effects - RE

Radiation Effects are defined as the changes in the input/output relationship of a device due to radiation exposure considering both the dose rate and total dose. [Ref. 8.3]

• •••• • • • •

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 8 of 32

3.2.7 Power Supply Effects - PS

Power Supply Effects are defined as the changes in the input/output relationship of a device due to fluctuations in the power supply feeding the device. Voltage and/or frequency fluctuations may result in Power Supply Effects. [Ref. 8.1]

3.2.8 Static Pressure Effect - SPE

Static Pressure Effect is defined as the uncertainty introduced in differential pressure instruments which are calibrated at a static pressure that is different from the normal operating pressure. SPE may affect both the span and zero of the instrument.

3.2.9 Overpressure Effects - OVP

Overpressure Effects are defined as the changes in the input/output relationship of a pressure sensing device after exposure to process pressure in excess of its specified Upper Range Limit.

3.2.10 Device Drift - DR

An undesired change in output over a period of time where change is unrelated to the input, environment or load. [Ref. 8.1] Uncertainty due to drift is dependent on the calibration frequency of the device.

3.2.11 Radiation Drift - RD

Radiation Drift is defined as the time dependant change in the input/output relationship of a device that can be directly related to radiation exposure.

3.2.12 Temperature Drift - TD

Temperature Drift is defined as the change in the input/output relationship of a device due to ambient temperature swings over a calibration period.

a la secola

STANDARD N0.: GGNS-JS-09 **REVISION: 1** PAGE 9 of 32

I

Temperature Drift effects may be assumed to be applicable only over the expected range of temperature during calibration (typically 65°F to 90°F). The possible uncertainty due to temperature variations outside this range is addressed under Temperature Effects. (See Section 3.2.3) [Ref. 8.3]

3.2.13 Measurement and Test Equipment Effects - MTE

Measurement and Test Equipment Effects are defined as those uncertainties introduced into a device as a result of the uncertainties associated with the equipment used to calibrate the device.

3.3 Loop Specific Random Uncertainty Terms

3.3.1 Loop Device Uncertainty - At

The Loop Device Uncertainty is defined as the square root sum of the squares (SRSS) of all the individual Device Uncertainty terms for a given instrument loop. [Ref. 8.3]

3.3.2 Loop Calibration Uncertainty - C₁

The Loop Calibration Uncertainty is defined as the SRSS of all the Measurement and Test Equipment effects that may be incurred during calibration of each of the devices in a given loop. [Ref. 8.3]

3.3.3 Loop Drift - DL

The Loop Drift is defined as the SRSS of the all the drift terms for each of the loop devices. The Loop Drift includes (as applicable) allowances for Device Drift, Temperature Drift, and Radiation Drift for each device in the loop. [Ref. 8.3]

3.3.4 Process Measurement Uncertainty - PM

a segue de la companya de la company

Process Measurement Uncertainties are those uncertainties that may be introduced in ł an instrument loop due to limitations in modeling the physical system; or more commonly, those uncertainties introduced in an instrument loop due to fluctuations in the process for which the loop instrumentation cannot automatically compensate. (See Appendix B)

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 10 of 32

3.3.5 Primary Element Uncertainty - PE

Primary Element Uncertainty is defined as the uncertainty introduced in an instrument loop due to the uncertainties associated with the loop's primary measuring device. Primary Element Uncertainty applies to the uncertainty associated with flow elements, elbow taps, and similar devices which may not typically be considered instruments.

3.3.6 Insulation Resistance Effects - IR

. . .

··· ··· ·

.

Insulation Resistance Effects are defined as those uncertainties introduced in an instrument loop due to changes in the insulation resistance properties of the cables, penetrations, splices and terminations within the loop. Insulation Resistance Effects may be bias type errors as opposed to random uncertainties depending on the type of instrument loop under consideration. (See Appendix C)

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 11 of 32

SECTION 4: SAFETY RELATED SETPOINT CALCULATIONS (Tech. Spec.)

As stated in Regulatory Guide 1.105, the accuracy of instrument setpoints should be equal to or better than the accuracy assumed in the safety analysis. Therefore, Safety Related Setpoint Calculations employ normal distribution uncertainty data specified to at least 2 standard deviations (20), or 95% confidence level.

To ensure the calculated setpoint and associated calculated margins are capable of accommodating the worst case uncertainty, the trip environment for the postulated design basis event should be determined. Once these worst case environmental effects have been determined, the appropriate uncertainty values can be included in the calculation to account for any environmental effects to the instrumentation or the process variable.

Using the available uncertainty data, the following general steps (outlined in Sections 4.1 - 4.5) should be used to generate an appropriate loop Allowable Value and Nominal Trip Setpoint.

- Calculate the Loop Uncertainty (LU) by computing the SRSS of the Loop Device Uncertainty (A_L), the Loop Calibration Uncertainty (C_L), the Process Measurement Uncertainty (PM), the Primary Element Uncertainty (PE), and the loop Insulation Resistance Effects (IR).
- Calculate the Loop Drift (D_L) by computing the SRSS of the Device Drift (DR), the Temperature Drift (TD), and the Radiation Drift (RD) for each loop instrument as applicable.
- Calculate the Total Loop Uncertainty (TLU) by summing the Loop Uncertainty and the Loop Drift.
- For process variables that increase to the Analytical Limit (AL), calculate the loop Allowable | Value (AV) by subtracting the Loop Uncertainty from the Analytical Limit. For process variables that decrease to the Analytical Limit, calculate the loop Allowable Value by summing the value of the Loop Uncertainty and the Analytical Limit.
- For process variables that increase to the Analytical Limit (AL), calculate the loop Nominal Trip Setpoint (NTSP) by subtracting the value of the Total Loop Uncertainty from the Analytical Limit. For process variables that decrease to the Analytical Limit, calculate the loop Nominal Trip Setpoint by summing the value of the Total Loop Uncertainty and the Analytical Limit.

Once the loop Allowable Value and Nominal Trip Setpoint have been established, Spurious Trip and LER Avoidance analysis must be performed as described in Section 4.6 for the field setpoint. These analyses will demonstrate the adequacy of the margins associated with the setpoint.

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 12 of 32

4.1 Calculation of Loop Uncertainty - LU

The Loop Uncertainty (LU), which defines the margin between the loop Analytical Limit and Allowable Value, is given by the equation:

$$LU = \pm \sqrt{(A_L)^2 + (C_L)^2 + (PM)^2 + (PE)^2 + (IR)^2}$$

Where the variables A_L, C_L, PM, PE, and IR are determined as follows:

4.1.1 Loop Device Uncertainty - AL

For a loop consisting of instruments A, B, C, ... X, the loop device uncertainty is given by the equation:

$$A_{L} = \pm \sqrt{(A_{A})^{2} + (A_{B})^{2} + (A_{C})^{2} + \dots + (A_{X})^{2}}$$

Where each of the individual device uncertainties A_A , A_B , A_C , ... A_X are formed from the SRSS of the components of uncertainty listed in Sections 3.2.2 - 3.2.9 (as applicable).

$$A_{X} = \pm \sqrt{(RA_{X})^{2} + (TE_{X})^{2} + (HE_{X})^{2} + (SE_{X})^{2} + (RE_{X})^{2} + (PS_{X})^{2} + (SPE_{X})^{2} + (OVP_{X})^{2}}$$

Where:

 $RA_x = Reference Accuracy of device X$

 TE_x = Temperature Effects for device X

 HE_x = Humidity Effects for device X

 $SE_x = Seismic Effects for device X$

 RE_x = Radiation Effects for device X

 $PS_x = Power Supply Effects for device X$

 $SPE_x = Static Pressure Effects for device X$

 $OVP_X = Overpressure Effects for device X$

....

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 13 of 32

4.1.2 Loop Calibration Uncertainty - CL

For a loop consisting of instruments A, B, C, ... X, the loop calibration uncertainty is given by the equation:

$$C_{L} = \pm \sqrt{(MTE_{A})^{2} + (MTE_{B})^{2} + (MTE_{C})^{2} + ... + (MTE_{X})^{2}}$$

Where:

- MTE_A = SRSS of the measurement and test equipment effects incurred during calibration of instrument A
- $MTE_B = SRSS$ of the measurement and test equipment effects incurred during calibration of instrument B
- $MTE_x = SRSS$ of the measurement and test equipment effects incurred during calibration of instrument X

Since the uncertainties associated with specific pieces of field measurement/test equipment are often difficult to obtain, an alternate (and typically more conservative) approach may be used to determine the Loop Calibration Uncertainty.

This alternate approach is based on the assumption that the Measurement and Test Equipment effects associated with each loop device are equal to the Reference Accuracy of that device (i.e. $MTE_x = RA_x$). Thus, the Loop Calibration Uncertainty may be expressed as:

$$C_{L} = \pm \sqrt{(RA_{A})^{2} + (RA_{B})^{2} + (RA_{C})^{2} + \dots + (RA_{X})^{2}}$$

.

STANDARD N0.: GGNS-JS-09 REVISION: 1 | PAGE 14 of 32

4.1.3 Process Measurement Uncertainty - PM

Any loop uncertainty that may be attributable to effects similar to those described in Appendix B must be determined by appropriate analytical techniques and accounted for under Process Measurement Uncertainty.

4.1.4 Primary Element Uncertainty - PE

If the instrument loop has a device which is essential to the measurement of the process variable, other than those devices previously addressed in the calculation of the Loop Device Uncertainty (A_L), the base uncertainty associated with this device must be determined and accounted for under Primary Element Uncertainty.

4.1.5 Insulation Resistance Effects - IR

If the instrument loop cable, penetrations, splices or terminal blocks may be exposed to harsh environments at any time before the instrumentation is to perform its trip function, the possible effects of degraded insulation resistance must be determined as in Appendix C and accounted for under Insulation Resistance Effects.

Note, the basic equation for the Loop Uncertainty (given below) assumes all the variables in the equation are random in nature and are specified to two standard deviations (2σ) .

Basic Loop Uncertainty Equation:

$$LU = \pm \sqrt{(A_L)^2 + (C_L)^2 + (PM)^2 + (PE)^2 + (IR)^2}$$

If some or all of the variables are known to a higher level of confidence (e.g. three standard deviations, 3σ), the basic equation may be modified to produce a Loop Uncertainty normalized to two standard deviations (if desired) by dividing each variable by its associated standard deviation (n) and then multiplying the total equation by 2 as shown below. [Ref. 8.3]

$$LU = \pm 2\sqrt{\left(\frac{A_L}{n}\right)^2 + \left(\frac{C_L}{n}\right)^2 + \left(\frac{PM}{n}\right)^2 + \left(\frac{PE}{n}\right)^2 + \left(\frac{IR}{n}\right)^2}$$

If one or more of the variables is known to be a <u>conservative</u> Bias as opposed to a random uncertainty, those variables should not be included under the radical and must simply be added to, or subtracted from, the SRSS of the remaining variables to form the Loop Uncertainty.

and a second

STANDARD NO.: GGNS-JS-09 REVISION: 1 PAGE 15 of 32

4.2 Calculation of Loop Drift - D_L

For a loop consisting of instruments A, B, C, ... X, the loop drift is given by the equation:

$$D_{L} = \pm \sqrt{(DR_{A})^{2} + (TD_{A})^{2} + (RD_{A})^{2} + \dots + (DR_{X})^{2} + (TD_{X})^{2} + (RD_{X})^{2}}$$

Where:

 DR_A = the Device Drift associated with instrument A

 TD_A = the Temperature Drift Effect for instrument A

 RD_A = the Radiation Drift Effect for instrument A

 DR_x = the Device Drift associated with instrument X

 TD_x = the Temperature Drift Effect for instrument X

 RD_x = the Radiation Drift Effect for instrument X

Since the Device Drift (DR) is directly related to the length of the calibration period, it may be necessary to scale the vendor supplied drift specification to accommodate the calibration interval.

Conservatively, this may be accomplished by multiplying the given drift specification by the ratio of the desired calibration interval to the supplied drift specification interval. Device Drift should only be scaled when the supplied drift specification interval is less than the calibration interval.

The Device Drift for all applicable loop instruments must be valid (scaled if necessary) for the maximum calibration interval allowed by the GGNS Technical Specifications.

STANDARD NO.: GGNS-JS-09 REVISION: 1 PAGE 16 of 32

4.3 Calculation of Total Loop Uncertainty - TLU

The Total Loop Uncertainty (TLU), which defines the margin between the loop Analytical Limit and the Nominal Trip Setpoint, is given by the equation:

$$TLU = LU + D_L$$

4.4 Calculation of Loop Allowable Value - AV

Using the existing documented Analytical Limit and the Loop Uncertainty calculated as shown in Section 4.1:

The loop Allowable Value for a process variable that <u>increases</u> to the Analytical Limit is given by the equation:

$$AV = AL - |LU|$$

And, the loop Allowable Value for a process variable that <u>decreases</u> to the Analytical Limit is given by the equation:

$$AV = AL + |LU|$$

4.5 Calculation of Loop Nominal Trip Setpoint - NTSP

Using the existing documented Analytical Limit and the Total Loop Uncertainty calculated as shown in Section 4.3:

The loop Nominal Trip Setpoint for a process variable that <u>increases</u> to the Analytical limit is given by the equation:

$$NTSP = AL - |TLU|$$

And, the loop Nominal Trip Setpoint for a process variable that <u>decreases</u> to the Analytical Limit is given by the equation:

$$NTSP = AL + |TLU|$$

STANDARD N0.: GGNS-JS-09 REVISION: 1 | PAGE 17 of 32

4.6 Spurious Trip and LER Avoidance Analysis

A Spurious Trip and LER Avoidance Analysis must be performed as described in Appendix A to demonstrate the acceptability of the setpoint margins. These analyses must be performed for the setpoint that is employed in the field. These analyses are not required for calculated setpoints that are not to be implemented in the field.

.

STANDARD N0.: GGNS-JS-09 REVISION: 1 | PAGE 18 of 32



a a contra te actual accurate accurate accurate

FIGURE 1: Tech. Spec. Trip Setpoint Uncertainty Breakdown

····. ···

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 19 of 32

SECTION 5: SAFETY RELATED SETPOINT CALCULATIONS (Non-Tech Spec.)

As with the methodology presented in Section 4, Non-Tech. Spec. setpoint calculations employ normal distribution uncertainty data specified to at least 2 standard deviations (2σ) which are applicable to the worst case environmental conditions assumed for the trip environment.

Non-Tech. Spec. setpoint calculations, however, differ in methodology from Tech. Spec. setpoint calculations in that no Analytical Limit is applicable and thus no Allowable Value can be computed. Non-Tech. Spec. setpoint calculations simply add to (or subtract from) the associated Process-Limit the value of the Total Loop Uncertainty to determine the Nominal Trip Setpoint.

The following general steps (outlined in Sections 5.1 - 5.4) should be used to generate an appropriate Nominal Trip Setpoint for Non-Tech. Spec. variables.

- Calculate the Loop Uncertainty (LU) by computing the SRSS of the Loop Device Uncertainty (A_L), the Loop Calibration Uncertainty (C_L), the Process Measurement Uncertainty (PM), the Primary Element Uncertainty (PE), and the loop Insulation Resistance Effects (IR).
- Calculate the Loop Drift (D_L) by computing the SRSS of the Device Drift (DR), the Temperature Drift (TD), and the Radiation Drift (RD) for each loop instrument as applicable.
- Calculate the Total Loop Uncertainty (TLU) by summing the Loop Uncertainty and the Loop Drift.
- For process variables that increase to the Process Limit (PL), calculate the Loop Nominal Trip Setpoint (NTSP) by subtracting the value of the Total Loop Uncertainty from the Process Limit. For process variables that decrease to the Process Limit, calculate the Loop Nominal Trip Setpoint by summing the value of the Total Loop Uncertainty and the Process Limit.

Once the Nominal Trip Setpoint has been established a Spurious Trip analysis as described in Section 5.5 must be performed for the field setpoint. This analysis will demonstrate the adequacy of the margin associated with the setpoint.

5.1 Calculation of Loop Uncertainty - LU

The Loop Uncertainty (LU) is defined by the equation:

$$LU = \pm \sqrt{(A_L)^2 + (C_L)^2 + (PM)^2 + (PE)^2 + (IR)^2}$$

Where the variables A_L, C_L, PM, PE, and IR are determined as follows:

5.1.1 Loop Device Uncertainty - AL

For a loop consisting of instruments A, B, C, ... X, the loop device uncertainty is given by the equation:

$$A_{L} = \pm \sqrt{(A_{A})^{2} + (A_{B})^{2} + (A_{C})^{2} + \dots + (A_{X})^{2}}$$

Where each of the individual device uncertainties A_A , A_B , A_C , ... A_X are formed from the SRSS of the components of uncertainty listed in Sections 3.2.2 - 3.2.9 (as applicable).

$$A_{\chi} = \pm \sqrt{(RA_{\chi})^{2} + (TE_{\chi})^{2} + (HE_{\chi})^{2} + (SE_{\chi})^{2} + (RE_{\chi})^{2} + (PS_{\chi})^{2} + (SPE_{\chi})^{2} + (OVP_{\chi})^{2}}$$

Where:

 $RA_x = Reference Accuracy of device X$

 TE_x = Temperature Effects for device X

 $HE_x =$ Humidity Effects for device X

 $SE_x = Seismic Effects for device X$

 $RE_x = Radiation Effects for device X$

 $PS_x = Power Supply Effects for device X$

 $SPE_x = Static Pressure Effects for device X$

 $OVP_x = Overpressure Effects for device X$

5.1.2 Loop Calibration Uncertainty - CL

For a loop consisting of instruments A, B, C, ... X, the loop calibration uncertainty is given by the equation:

$$C_{L} = \pm \sqrt{(MTE_{A})^{2} + (MTE_{B})^{2} + (MTE_{C})^{2} + \dots + (MTE_{X})^{2}}$$

Where:

- MTE_A = SRSS of the measurement and test equipment effects incurred during calibration of instrument A
- MTE_B = SRSS of the measurement and test equipment effects incurred during calibration of instrument B
- MTE_x = SRSS of the measurement and test equipment effects incurred during calibration of instrument X

Since the uncertainties associated with specific pieces of field measurement/test equipment are often difficult to obtain, an alternate (and typically more conservative) approach may be used to determine the Loop Calibration Uncertainty.

This alternate approach is based on the assumption that the Measurement and Test Equipment effects associated with each loop device are equal to the Reference Accuracy of that device (i.e. $MTE_x = RA_x$). Thus, the Loop Calibration Uncertainty may be expressed as:

$$C_{L} = \pm \sqrt{(RA_{A})^{2} + (RA_{B})^{2} + (RA_{C})^{2} + \dots + (RA_{X})^{2}}$$

5.1.3 Process Measurement Uncertainty - PM

Any loop uncertainty that may be attributable to effects similar to those described in Appendix B must be determined by appropriate analytical techniques and accounted for under Process Measurement Uncertainty.

5.1.4 Primary Element Uncertainty - PE

If the instrument loop has a device which is essential to the measurement of the process variable, other than those devices previously addressed in the calculation of the Loop Device Uncertainty (A_L) , the base uncertainty associated with this device must be determined and accounted for under Primary Element Uncertainty.

5.1.5 Insulation Resistance Effects - IR

If the instrument loop cable, penetrations, splices or terminal blocks may be exposed to harsh environments at any time before the instrumentation is to perform its trip function, the possible effects of degraded insulation resistance must be determined as in Appendix C and accounted for under Insulation Resistance Effects.

Note, the basic equation for the Loop Uncertainty (given below) assumes all the variables in the equation are random in nature and are specified to two standard deviations (2σ) .

Basic Loop Uncertainty Equation:

$$LU = \pm \sqrt{(A_L)^2 + (C_L)^2 + (PM)^2 + (PE)^2 + (IR)^2}$$

If some or all of the variables are known to a higher level of confidence (e.g. three standard deviations, 3σ), the basic equation may be modified to produce a Loop Uncertainty normalized to two standard deviations (if desired) by dividing each variable by its associated standard deviation (n) and then multiplying the total equation by 2 as shown below. [Ref. 8.3]

$$LU = \pm 2\sqrt{\left(\frac{A_L}{n}\right)^2 + \left(\frac{C_L}{n}\right)^2 + \left(\frac{PM}{n}\right)^2 + \left(\frac{PE}{n}\right)^2 + \left(\frac{IR}{n}\right)^2}$$

If one or more of the variables is known to be a <u>conservative</u> Bias as opposed to a random uncertainty, those variables should not be included under the radical and must simply be added to, or subtracted from, the SRSS of the remaining variables to form the Loop Uncertainty.

5.2 Calculation of Loop Drift - D_L

For a loop consisting of instruments A, B, C, ... X, the loop drift is given by the equation:

$$D_{L} = \pm \sqrt{(DR_{A})^{2} + (TD_{A})^{2} + (RD_{A})^{2} + \dots + (DR_{X})^{2} + (TD_{X})^{2} + (RD_{X})^{2}}$$

Where:

 DR_A = the Device Drift associated with instrument A

 TD_A = the Temperature Drift Effect for instrument A

 RD_A = the Radiation Drift Effect for instrument A

 DR_x = the Device Drift associated with instrument X

 TD_x = the Temperature Drift Effect for instrument X

 RD_x = the Radiation Drift Effect for instrument X

Since the Device Drift (DR) is directly related to the length of the calibration period, it may be necessary to scale the vendor supplied drift specification to accommodate the calibration interval.

Conservatively, this may be accomplished by multiplying the given drift specification by the ratio of the desired calibration interval to the supplied drift specification interval. Device Drift should only be scaled when the supplied drift specification interval is less than the calibration interval.

The Device Drift for all applicable loop instruments must be valid (scaled if necessary) for the maximum calibration interval allowed for the instrument loop.

.

STANDARD N0.: GGNS-JS-09 REVISION: 1 | PAGE 24 of 32

5.3 Calculation of Total Loop Uncertainty - TLU

The Total Loop Uncertainty (TLU), which defines the margin between the loop Process Limit and the Nominal Trip Setpoint, is given by the equation:

$$TLU = LU + D_L$$

5.4 Calculation of Loop Nominal Trip Setpoint - NTSP

Using the Process Limit derived from existing documentation and the Total Loop Uncertainty calculated as shown in Section 5.3:

The loop Nominal Trip Setpoint for a process variable that <u>increases</u> to the Process Limit is given by the equation:

$$NTSP = PL - |TLU|$$

And, the loop Nominal Trip Setpoint for a process variable that <u>decreases</u> to the Process Limit is given by the equation:

$$NTSP = PL + |TLU|$$

5.5 Spurious Trip Analysis

A Spurious Trip Analysis must be performed as described in Appendix A to demonstrate the acceptability of the setpoint margins. This analysis must be performed for the setpoint that is employed in the field; but is not required for calculated setpoints that are not to be implemented in the field.

a second second second



We be regaring a second of the second of the

- - ------

FIGURE 2: Non-Tech. Spec. Trip Setpoint Uncertainty Breakdown

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 26 of 32

SECTION 6: INSTRUMENT INDICATION UNCERTAINTY CALCULATIONS

As with the methodologies presented in Sections 4 & 5, Instrument Indication Uncertainty Calculations employ normal distribution uncertainty data specified to at least 2 standard deviations (2σ) which are applicable to the worst case environmental conditions postulated for the instrument location. For instrumentation used to monitor Reg. Guide 1.97 variables, the worst case environmental effects specific to the instrument location associated with the Design Basis Accident are to be used in the calculation.

Indication Uncertainty Calculations differ in methodology from setpoint calculations in that the Loop Drift is not calculated separately from the Loop Uncertainty. Instead the Loop Drift is included with the other random uncertainty components under the radical to form the Total Random Loop Uncertainty (RLU).

Another important difference between indication uncertainty calculations and setpoint calculations is that indication uncertainty calculations must address the man-machine interface associated with the indicator. For indicators with linear scales, this possible source of uncertainty is assigned a value equal to 1/2 the value of the indicator's minor scale division. This allowance accounts for the effects of parallax and the mental interpolation required of the operator and is termed the 'Readability of the Indicator' (RI).

For loops using indicators with non-linear scales (i.e. square-law or log scales) the RI term should be calculated based on decades or other appropriate ranges rather than process units to alleviate the inequity between the size of the minor divisions at the upper an lower extremes of the indicator's scale. Note, 'Readability' is not applicable for recorders and digital readout devices.

The following general steps (outlined in Sections 6.1 - 6.3) should be used to determine the worst case instrument indication uncertainty for a given loop:

- Calculate the Readability term (RI) by taking 1/2 the value of the indicator's minor scale division (or another appropriate value estimated for indicators with non-linear scales).
- Calculate the Random Loop Uncertainty (RLU) by computing the SRSS of the Loop Device Uncertainty (A_L), the Loop Calibration Uncertainty (C_L), the Loop Drift (D_L), the Process Measurement Uncertainty (PM), the Primary Element Uncertainty (PE), and the loop Insulation Resistance Effects (IR).
- Calculate the Total Loop Uncertainty (TLU) by combining the Random Loop Uncertainty, Readability and any conservative bias terms.

6.1 Calculation of Readability - RI

For indicators with linear scales the 'Readability' of the Indicator is:

 $RI = \pm \frac{1}{2}$ (minor indicator scale division)

6.2 Calculation of Random Loop Uncertainty - RLU

The Random Loop Uncertainty (RLU) is defined by the equation:

$$RLU = \pm \sqrt{(A_L)^2 + (C_L)^2 + (D_L)^2 + (PM)^2 + (PE)^2 + (IR)^2}$$

Where the variables A_L, C_L, D_L, PM, PE, and IR are determined as follows:

6.2.1 Loop Device Uncertainty - A_L

For a loop consisting of instruments A, B, C, ... X, the loop device uncertainty is given by the equation:

$$A_{L} = \pm \sqrt{(A_{A})^{2} + (A_{B})^{2} + (A_{C})^{2} + \dots + (A_{X})^{2}}$$

Where each of the individual device uncertainties A_A , A_B , A_C , ... A_X are formed from the SRSS of the components of uncertainty listed in Sections 3.2.2 - 3.2.9 (as applicable).

...........

$$A_{\chi} = \pm \sqrt{(RA_{\chi})^{2} + (TE_{\chi})^{2} + (HE_{\chi})^{2} + (SE_{\chi})^{2} + (RE_{\chi})^{2} + (PS_{\chi})^{2} + (SPE_{\chi})^{2} + (OVP_{\chi})^{2}}$$

Where:

 $RA_x = Reference Accuracy of device X$

 $TE_x = Temperature Effects for device X$

 $HE_x = Humidity Effects for device X$

 $SE_x = Seismic Effects for device X$

 $RE_x = Radiation Effects for device X$

 $PS_x = Power Supply Effects for device X$

 SPE_x = Static Pressure Effects for device X

 $OVP_x = Overpressure Effects for device X$

6.2.2 Loop Calibration Uncertainty - C₁

For a loop consisting of instruments A, B, C, ... X, the loop calibration uncertainty is given by the equation:

$$C_{L} = \pm \sqrt{(MTE_{A})^{2} + (MTE_{B})^{2} + (MTE_{C})^{2} + \dots + (MTE_{X})^{2}}$$

Where:

- $MTE_A = SRSS$ of the measurement and test equipment effects incurred during calibration of instrument A
- $MTE_B = SRSS$ of the measurement and test equipment effects incurred during calibration of instrument B
- MTE_x = SRSS of the measurement and test equipment effects incurred during calibration of instrument X

Since the uncertainties associated with specific pieces of field measurement/test equipment are often difficult to obtain, an alternate (and typically more conservative) approach may be used to determine the Loop Calibration Uncertainty.

This alternate approach is based on the assumption that the Measurement and Test Equipment effects associated with each loop device are equal to the Reference Accuracy of that device (i.e. $MTE_x = RA_x$). Thus, the Loop Calibration Uncertainty may be expressed as:

$$C_{L} = \pm \sqrt{(RA_{A})^{2} + (RA_{B})^{2} + (RA_{C})^{2} + \dots + (RA_{X})^{2}}$$

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 29 of 32

6.2.3 Calculation of Loop Drift - D_L

For a loop consisting of instruments A, B, C, ... X, the loop drift is given by the equation:

$$D_{L} = \pm \sqrt{(DR_{A})^{2} + (TD_{A})^{2} + (RD_{A})^{2} + \dots + (DR_{X})^{2} + (TD_{X})^{2} + (RD_{X})^{2}}$$

Where:

 DR_A = the Device Drift associated with instrument A

 TD_A = the Temperature Drift Effect for instrument A

 RD_A = the Radiation Drift Effect for instrument A

 DR_x = the Device Drift associated with instrument X

 TD_x = the Temperature Drift Effect for instrument X

 RD_x = the Radiation Drift Effect for instrument X

Since the Device Drift (DR) is directly related to the length of the calibration period, it may be necessary to scale the vendor supplied drift specification to accommodate the calibration interval.

Conservatively, this may be accomplished by multiplying the given drift specification by the ratio of the desired calibration interval to the supplied drift specification interval. Device Drift should only be scaled when the supplied drift specification interval is less than the calibration interval.

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 30 of 32

6.2.4 Process Measurement Uncertainty - PM

Any loop uncertainty that may be attributable to effects similar to those described in Appendix B must be accounted for under Process Measurement Uncertainty.

6.2.5 Primary Element Uncertainty - PE

If the instrument loop has a device which is essential to the measurement of the process variable, other than those devices previously addressed in the calculation of the Loop Device Uncertainty (A_L) , the base uncertainty associated with this device must be accounted for under Primary Element Uncertainty.

6.2.6 Insulation Resistance Effects - IR

If the instrument loop cable, penetrations, splices or terminal blocks may be exposed to harsh environments at any time before the instrumentation is to perform its trip function, the possible effects of degraded insulation resistance must be determined as in Appendix C and accounted for under Insulation Resistance Effects.

Note, the basic equation for the Random Loop Uncertainty (given below) assumes all the variables in the equation are random in nature and are specified to two standard deviations (2σ) .

Basic Random Loop Uncertainty Equation:

$$RLU = \pm \sqrt{(A_L)^2 + (C_L)^2 + (D_L)^2 + (PM)^2 + (PE)^2 + (IR)^2}$$

If some or all of the variables are known to a higher level of confidence (e.g. three standard deviations, 3σ), the basic equation may be modified to produce a Random Loop Uncertainty normalized to two standard deviations (if desired) by dividing each variable by its associated standard deviation (n) and then multiplying the total equation by 2 as shown below. [Ref. 8.3]

$$RLU = \pm 2\sqrt{\left(\frac{A_L}{n}\right)^2 + \left(\frac{C_L}{n}\right)^2 + \left(\frac{D_L}{n}\right)^2 + \left(\frac{PM}{n}\right)^2 + \left(\frac{PE}{n}\right)^2 + \left(\frac{IR}{n}\right)^2}$$

STANDARD N0.: GGNS-JS-09 REVISION: 1 PAGE 31 of 32

6.3 Calculation of Total Loop Uncertainty - TLU

TLU = RLU + RI + Bias

SECTION 7: METHODS FOR INCREASING CALCULATED MARGINS

Calculations generated using the methodology presented in this standard may, due to the indepth treatment of the uncertainty terms, generate setpoint and instrument uncertainty estimates which are more conservative than previously calculated values.

If in the generation of setpoints and loop Allowable Values, a large difference is noted between the existing and calculated values, various techniques should be considered to isolate and possibly reduce these differences if appropriate.

In certain cases, the following may be valid techniques to reduce calculated uncertainty terms:

- 7.1 Review the environmental limits to reduce them as necessary to reflect only the specific event requirements for which the device is required to function.
- 7.2 Review the value used for Insulation Resistance Effects to ensure that it is not overly conservative
- 7.3 Review the Measurement & Test Equipment values used in the calculation as a term to be reduced, especially if the M&TE values have been assumed to be equal to the Reference Accuracy of the individual loop devices.
- 7.4 A Single-sided Distribution approach to the uncertainty may be considered, depending on the application. This approach may not be applicable to all setpoints due to the possible impact on operational margins or other system setpoints. Note, if this approach is employed, all data should be normalized for Single-Sided Distribution. With the 2σ data applied to Single-Sided Distribution, the accuracy will exceed the 95% confidence level. (See Reference 8.3)
- 7.5 The Total Loop Uncertainty may be reduced using the square root sum of the squares approach to combine the Loop Uncertainty and the Loop Drift. Generally, this approach should be avoided since it minimizes the margin between the loop Allowable Value and the Nominal Trip Setpoint. Values calculated using this approach should be reviewed to ensure adequate margin exists between the Nominal Trip Setpoint and the Allowable Value.

.....

STANDARD N0.: GGNS-JS-09 REVISION: 1 | PAGE 32 of 32

SECTION 8: REFERENCES

- 8.1 ISA RP67.04, Part II, 1994, <u>Methodologies for the Determination of Setpoints for</u> Nuclear Safety-Related Instrumentation
- 8.2 <u>Process Measurement Instrument Engineers' Handbook</u> Revised Edition Bela G. Liptak & Kristzta Venczel, 1982 - Chilton Book Co., Radnor Pennsylvania
- 8.3 NEDC-31336P-A, 1996, <u>General Electric Instrument Setpoint Methodology</u> W.H. Cooley, JR., J.L. Leong, M.A. Smith, S. Wolf, - General Electric Co.
- 8.4 CRANE Technical Paper No. 410 Flow of Fluids through Valves, Fittings and Pipe CRANE Engineering Division, 1985 Crane Co.
- 8.5 Nuclear Plant Engineering Desk Top Procedure EDP-032 Rev. 1 Instrument Loop Uncertainty and Setpoint Calculations
- 8.6 USNRC Regulatory Guide 1.105 Rev. 1 Instrument Setpoints

.

STANDARD NO.: GGNS-JS-09 APPENDIX: A REVISION: 1 | PAGE 1 OF 5

APPENDIX A

SPURIOUS TRIP AND LER AVOIDANCE ANALYSIS

a ana ang ang a

lener someranssonnen och som skiller

STANDARD N0.: GGNS-JS-09 APPENDIX: A REVISION: 1 PAGE 2 OF 5

INTRODUCTION

The Spurious Trip and Licensee Event Report (LER) Avoidance analysis techniques that follow are used to demonstrate the acceptability of field setpoints with respect to specific operating margins. These techniques and the associated terminology are referenced from NEDC 31336P-A, 1996, General Electric Instrument Setpoint Methodology.

In both the Spurious Trip and LER Avoidance analysis, the probability that the margin of interest will not be exceeded is determined by the area under the normal standard deviation curve from $-\infty$ to Z, where Z is derived by dividing the magnitude of each respective margin by the appropriate standard deviation.

The standard normal distribution curve is shown below with the minimum "Z" values for 90% and 95% probability, the acceptance criteria for LER Avoidance and Spurious Trip Avoidance respectively.



STANDARD N0.: GGNS-JS-09 APPENDIX: A REVISION: 1 | PAGE 3 OF 5

1.0 SPURIOUS TRIP ANALYSIS

Spurious Trip analysis is performed to demonstrate the acceptability of the margin between a Nominal Trip Setpoint and the value of the limiting process transient variation associated with the setpoint. If the setpoint is acceptable, there should be at least a <u>95% probability</u> that this margin will not be exceeded and no spurious trip will occur.

The probability of avoiding spurious trips for a single channel is determined by calculating a value "Z" as shown below. This Z value is then used to determine the area under the standard normal distribution curve from $-\infty$ to Z using standard statistical tables. Note, any $Z \ge 1.645$ will meet the acceptance criteria of 95% spurious trip avoidance.

A Spurious Trip analysis should be performed for all field setpoints validated by calculation and may be performed for calculated setpoints that are not to be employed in the field.

$$Z_{\Delta} = \frac{\left| NTSP - X_T \right|}{\sqrt{\left(\sigma_n\right)^2 + \left(\sigma_i\right)^2}}$$

Discussion of Variables:

NTSP - Nominal Trip Setpoint

X_T - Limiting Operating Transient Variation

 $X_T = X_o + T + T_c$, if the process variable increases to the Analytical Limit

 $X_T = X_o - T - T_c$, if the process variable decreases to the Analytical Limit

Where:

 X_{o} = maximum or minimum steady state operating value

T = magnitude of the limiting transient variation

 $T_c = modeling bias or uncertainty$

· · · · · · ·

STANDARD N0.: GGNS-JS-09 APPENDIX: A REVISION: 1 | PAGE 4 OF 5

The limiting operating transient (X_T) is typically calculated as shown; however, this value may be specifically noted in the system operating instruction. Unless justification is provided, the value of X_T should not be closer to the operating limit than the setpoint.

The steady state operating value (X_o) may be determined from the system operating instructions, Technical Specifications, design specifications or similar documentation.

The limiting transient variation (T) is typically the margin between the steady state operating value and the process setpoint, but the limiting variation may be related to some other operating limit/restriction invoked by the system operating instructions or the Technical Specification.

The modeling bias or uncertainty (T_c) is typically zero when using existing documented operating restrictions. This term is used to add any margin for uncertainty when specifying the limiting transient variation based on engineering judgement.

- σ_N The standard deviation associated with the limiting operating transient (σ_N), is equal to zero when the limiting operating transient is based on existing documented operating restrictions. This term is used to account for any deviation associated with the limiting operating transient when the limiting transient is based on engineering judgement.
- σ_i The standard deviation associated with the loop uncertainty, denoted σ_i , is calculated as shown below:

$$\sigma_{l} = \frac{1}{n} \sqrt{(A_{L})^{2} + (C_{L})^{2} + (D_{L})^{2} + (PM)^{2} + (PE)^{2}}$$

Where:

- n = number of standard deviations used in expressing the individual components of uncertainty
- A_L = Loop Device Uncertainty
- C_L = Loop Calibration Uncertainty
- $D_L = Loop Drift$
- PM = Process Measurement Uncertainty
- PE = Primary Element Uncertainty

STANDARD N0.: GGNS-JS-09 APPENDIX: A REVISION: 1 | PAGE 5 OF 5

2.0 LER AVOIDANCE ANALYSIS

LER Avoidance analysis is performed to demonstrate the acceptability of the margin between a loop Allowable Value and Nominal Trip Setpoint. If the setpoint is acceptable, there should be at least a <u>90% probability</u> that this margin will not be exceeded.

The probability of LER avoidance for a single channel is determined by calculating a value "Z" as shown below. This Z value is then used to determine the area under the standard normal distribution curve from $-\infty$ to Z. Note, any $Z \ge 1.28$ will meet the acceptance criteria of 90% LER avoidance.

An LER Avoidance analysis should be performed for each field setpoint/allowable value validated by calculation and may be performed for calculated values that are not to be employed in the field.

$$Z = \frac{|AV - NTSP|}{\frac{1}{n}\sqrt{(A_L)^2 + (C_L)^2 + (D_L)^2}}$$

Where:

AV = Allowable Value

NTSP = Nominal Trip Setpoint

 A_{L} = Loop Device Uncertainty

 $C_L = Loop Calibration Uncertainty$

 $D_L = Loop Drift$

n = number of standard deviations used in specifying the individual components of uncertainty

STANDARD NO.: GGNS-JS-09 APPENDIX: B REVISION: 1 | PAGE 1 OF 9

APPENDIX B

PROCESS MEASUREMENT UNCERTAINTIES

INTRODUCTION

Process measurement uncertainties are: those uncertainties which may be introduced in an instrument loop due to limitations in modeling the physical system; or more commonly, those uncertainties introduced in an instrument loop due to fluctuations in the process for which the loop instrumentation can not automatically compensate.

Note, this Appendix is not intended to be an exhaustive discussion of Process Measurement Uncertainty but rather is intended only to present specific analysis techniques used to address common uncertainties associated with process measurement.

1.0 FLOW MEASUREMENT UNCERTAINTY - (FLUID DENSITY EFFECTS)

In systems that use differential pressure transmitters to detect flow, measurement uncertainty may be introduced by density changes in the process fluid. Such variations in fluid density are generally the result of temperature transients in the system.

As shown in the equations below, a change in the density of the process fluid will result in a variation of the sensed variable (DP) if the flow rate is constant. Therefore, the flow derived from the pressure measurement will not be a true representation of the actual flow.

$$Q = K(A) \sqrt{\frac{DP}{Density}} \quad \text{(volumetric flow rate)}$$

$$W = K(A)\sqrt{DP(Density)}$$
 (mass flow rate)

Where:

- Q = Volumetric flow rate
- W = Mass flow rate
- A = Cross sectional area of the pipe
- K = Constant
- DP = Differential pressure measured across the orifice plate

and the second sec

Density = Density of the process fluid

STANDARD NO.: GGNS-JS-09 APPENDIX: B REVISION: 1

By assuming Q, the volumetric flow rate of the system, remains constant between a base calibration condition (Density 1) and some final condition (Density 2) the measurement uncertainty due to fluid density changes may be derived as follows:

Q2 = Q1

$$K(A)\sqrt{\frac{DP2}{Density2}} = K(A)\sqrt{\frac{DP1}{Density1}}$$
$$\frac{DP2}{Density2} = \frac{DP1}{Density1}$$

Since density is the inverse of specific volume (SV), the results above may be expressed as':

$$\frac{DP2}{DP1} = \frac{SV1}{SV2}$$

Clearly, if the specific volume of the process fluid changes between condition 1 and condition 2, the differential pressure will also change. This change in differential pressure (ΔDP) is given by:

$$\Delta DP = DP2 - DP1$$

* Since the density of water is given in the ASME Steam Tables in terms of specific volume, relating DP to specific volume is generally more convenient than relating DP to density.

the state and share and shares

By expressing DP2 in terms of DP1 and substituting, the DP uncertainty can be expressed as:

$$\Delta DP = DP \mathbf{I} \left[\left(\frac{SV1}{SV2} \right) - 1 \right]$$

Where:

DP1	=	Differential pressure sensed at calibration temperature (T1)
SV1	=	Specific volume of the process fluid at calibration temperature (T1)
SV2	=	Specific volume of the process fluid at any arbitrary temperature (T2)

NOTE:

- If SV2 > SV1 (T2 > T1): the indicated flow is <u>less</u> than the actual flow
- If SV2 < SV1 (T2 < T1): the indicated flow is greater than the actual flow
- If DP1 is maximized, the uncertainty is maximized.

· · · · · · · · · · · ·

Although the results above are applicable only to volumetric flow rate; the same methodology may also be used to determine mass flow rate density effects.

STANDARD NO.: GGNS-JS-09 APPENDIX: B REVISION: 1 | PAGE 5 OF 9

2.0 LEVEL MEASUREMENT UNCERTAINTIES - (FLUID DENSITY EFFECTS)

When differential pressure transmitters are used to measure liquid level, changes in the density of the liquid within the vessel and/or the transmitter reference leg fluid may result in process measurement uncertainty. The following discussion addresses both open vessel and closed vessel level measurement uncertainties attributable to density variations in the process.

2.1 Open Vessel Liquid Level Measurement

For measurement of liquid level in an open vessel, no reference leg considerations are applicable since both the vessel and pressure transmitter are vented to the atmosphere. Therefore, the only density variation to be considered is that of the liquid within the vessel.

The equation below shows the relationship between the density of the liquid within the vessel and the pressure sensed by the transmitter in an open system.

$$P = H_v \times SG_v$$

OR

$$P = H_{\nu} \times \left[\frac{\text{density of the liquid in the vessel}}{\text{density of water at ref. conditions.}} \right]$$

Where:

P = Pressure sensed by the transmitter (in inches of water) $H_v =$ Height of the liquid in the vessel measured from the transmitter tap(in inches) $SG_v =$ Specific gravity of the liquid within the vessel

.

By using the inverse relationship between density and specific volume (SV), the pressure at the transmitter may also be expressed as:

$$P = H_{v} \times \left[\frac{SV \text{ of water at ref. conditions}}{SV \text{ of the liquid in the vessel}} \right]$$
STANDARD NO.: GGNS-JS-09 APPENDIX: B REVISION: 1 | PAGE 6 OF 9

From the equations derived for 'P', the pressure sensed at the transmitter, the error (ΔP) resulting from density variations in the process liquid can be calculated as shown below:

$$\Delta P = H_{\nu} \left(SG_{\nu 2} - SG_{\nu 1} \right)$$

OR

$$\Delta P = H_{\nu} \left(\frac{SV_{W3}}{SV_{\nu 2}} - \frac{SV_{W3}}{SV_{\nu 1}} \right)$$

Where:

 H_v = Height of the liquid in the vessel measured from the transmitter tap (in inches)

 SG_{v1} = Specific gravity of the process liquid at calibration temperature (T1)

 SG_{v2} = Specific gravity of the process liquid at any arbitrary temperature (T2)

 SV_{v1} = Specific volume of the process liquid at calibration temperature (T1)

 SV_{v2} = Specific volume of the process liquid at any arbitrary temperature (T2)

 SV_{w3} = Specific volume of water at some reference temperature (T3)

If the process liquid is <u>water</u> and the reference temperature (T3) is the temperature at calibration (T1), the equations above may be reduced to the form shown below:

$$\Delta P = H_{\nu} \left[\frac{SV_{\nu_1}}{SV_{\nu_2}} - 1 \right]$$

NOTE:

• If $SV_{v2} > SV_{v1}$ (T2 > T1): the indicated level is less than the actual level

• If $SV_{v2} < SV_{v1}$ (T2 < T1): the indicated level is greater than the actual level

2.2 Closed Vessel Liquid Level Measurement (low pressure system)

For measurement of liquid level in a closed vessel, the density variations in the transmitter reference leg fluid must be considered in conjunction with the density variations of the liquid within the vessel.

If the transmitter reference leg is dry (i.e. pressurized only by the gaseous volume above the liquid in the vessel) and the vessel is at a relatively low temperature and pressure, the only significant density variation due to temperature transients will be in the vessel liquid. The density variations of the gaseous volume and thus the pressure variations in the reference leg under low pressure conditions are generally negligible. Therefore, the level measurement uncertainty due to density variations would be calculated as if the vessel were vented.

However, if the transmitter reference leg is wet (i.e. pressurized by a column of liquid), both the density variations of the vessel liquid and the reference leg liquid could contribute to process measurement uncertainty.

The equations below show the relationship between the density of the process liquid, the density of the reference leg liquid and the differential pressure sensed by the transmitter in a low pressure closed vessel system.

$$DP = (H_R \times SG_R) - (H_V \times SG_V)$$

OR

$$DP = H_{R} \left[\frac{Density_{R}}{Density_{W}} \right] - H_{V} \left[\frac{Density_{V}}{Density_{W}} \right]$$

Where:

- DP = Differential pressure sensed by the transmitter (in "WC)
- H_R = Height of the liquid in the reference leg measured from the transmitter tap (in inches)
- H_v = Height of the liquid in the vessel measured from the transmitter tap (in inches)
- SG_R = Specific gravity of the liquid within the reference leg

 $SG_v = Specific gravity of the liquid within the vessel$

- $Density_R = Density$ of the liquid within the reference leg
- $Density_v = Density$ of the liquid within the vesse
- $Density_w = Density$ of water at some reference condition

.

STANDARD NO.: GGNS-JS-09 APPENDIX: B REVISION: 1 | PAGE 8 OF 9

By using the inverse relationship between density and specific volume (SV), the differential pressure may also be expressed as:

$$DP = H_R \left(\frac{SV_W}{SV_R}\right) - H_V \left(\frac{SV_W}{SV_V}\right)$$

From the equations derived for 'DP', the differential pressure sensed at the transmitter, the error (Δ DP) introduced in the low pressure closed vessel system as a result of density variations can be calculated as shown below:

$$\Delta DP = H_R (SG_{R2} - SG_{R1}) - H_V (SG_{V4} - SG_{V3})$$

OR

$$\Delta DP = H_R \left[\frac{SV_{WS}}{SV_{R2}} - \frac{SV_{WS}}{SV_{R1}} \right] - H_V \left[\frac{SV_{WS}}{SV_{V4}} - \frac{SV_{WS}}{SV_{V3}} \right]$$

Where:

- H_R = Height of the liquid in the reference leg measured from the transmitter tap (in inches)
- H_v = Height of the liquid in the vessel measured from the transmitter tap (in inches)
- SG_{R1} = Specific gravity of the reference leg liquid at calibration temperature (T1)
- SG_{R2} = Specific gravity of the reference leg liquid at any arbitrary temperature (T2)
- SG_{v_3} = Specific gravity of the vessel liquid at calibration temperature (T3)
- SG_{v4} = Specific gravity of the vessel liquid at any arbitrary temperature (T4)
- SV_{R1} = Specific volume of the reference leg liquid at calibration temperature (T1
- SV_{R2} = Specific volume of the reference leg liquid at any arbitrary temperature (T2)

and the second second

- SV_{v_3} = Specific volume of the process liquid at calibration temperature (T3)
- SV_{v4} = Specific volume of the process liquid at any arbitrary temperature (T4)
- SV_{ws} = Specific volume of water at some reference temperature (T5)

I

The preceding equations can be somewhat confusing since the reference leg liquid and the liquid within the vessel are not necessarily at the same temperature or density at any moment.

However, assuming the reference leg liquid and the liquid within the vessel are <u>water</u> and the reference temperature (T5) is equal to the temperature of the reference leg liquid at the time of calibration (T1), the equations may be reduced to:

$$\Delta DP = H_R \left[\frac{SV_{R1}}{SV_{R2}} - 1 \right] - H_V \left[\frac{SV_{R1}}{SV_{V4}} - \frac{SV_{R1}}{SV_{V3}} \right]$$

Closed vessel <u>high pressure</u> systems differ from low pressure closed vessel systems in that the density variations of the vapor region above the vessel liquid must also be considered to determine the total measurement uncertainty. A detailed discussion of this type of system is not included here but is presented in Reference 8.1 for a steam/water system.

The defining equation for this type of measurement is:

$$DP = (H_R \times SG_R) - (H_V \times SG_V) - (H_{VAP} \times SG_{VAP})$$

Where:

- DP = Differential pressure sensed by the transmitter (in "WC)
- H_R = Height of the liquid in the reference leg measured from the transmitter tap (in inches)

.......

- H_v = Height of the liquid in the vessel measured from the transmitter tap (in inches)
- H_{VAP} = Height of the vapor region above the vessel liquid (in inches)
- SG_{R} = Specific gravity of the liquid within the reference leg
- SG_v = Specific gravity of the liquid within the vessel
- SG_{VAP} = Specific gravity of the vapor above the vessel liquid

STANDARD NO.: GGNS-JS-09 APPENDIX: C REVISION: 0 PAGE 1 OF 6

a stream the state of the state

APPENDIX C

INSULATION RESISTANCE EFFECTS

n. franke en en en

STANDARD NO.: GGNS-JS-09 APPENDIX: C REVISION: 0 PAGE 2 OF 6

INTRODUCTION

Cables, splices, connectors, terminal blocks, and penetrations may experience a reduction in insulation resistance under conditions of high humidity and temperature associated with a highenergy line break (HELB). This reduction in insulation resistance causes an increase in leakage currents from individual conductors to ground, and from one conductor to another.

Normally, leakage currents are negligibly small, and may be compensated for during calibration. However, under accident conditions, leakage currents may increase causing a significant uncertainty in measurement. This type of signal uncertainty, known as Insulation Resistance Effects (IR), is of great concern for instrument channels with logarithmic signals, and may be of concern for circuits with sensitive, low level, signals (e.g. current transmitters, resistive temperature devices, thermocouples, etc.).

1.0 INSULATION RESISTANCE TEST DATA

LOCA simulation qualification test reports may be referenced for cable insulation resistance data. The insulation resistance data taken during LOCA simulation testing are conservative with respect to all postulated accident conditions, and are usually based on leakage currents for various cable types and measurement configurations.

Since test report data will generally be given for a test cable of much shorter length than the field cable of interest, it is necessary to determine the "ohms-foot" value of the insulation resistance. This factor allows the insulation resistance for a particular length of field cable to be determined.

The "ohms-foot" value is obtained by multiplying the value of insulation resistance measured for the sample cable by the length of the sample cable. The resistance of varying lengths of field cable is then determined by <u>dividing the ohms-foot value</u> by the length of the field cable.

STANDARD NO.: GGNS-JS-09 APPENDIX: C REVISION: 0 PAGE 3 OF 6

2.0 IR EFFECTS FOR A CURRENT SOURCE LOOP (General Example)

The model shown below represents a typical transmitter loop with potential leakage current paths associated with the cables, cable splices and a penetration. This model and the analysis techniques that follow are intended as a guide and can be modified to determine the insulation resistance effect for loops with different physical configurations.



Figure C-1

Where:

 $I_s = Transmitter output, current source$

 $V_s = Loop$ power supply, voltage source

 R_{XI} = Leakage current resistance path from conductor 1 to ground

 R_{x2} = Leakage current resistance path from conductor 2 to ground

 R_{x_3} = Leakage current resistance path from conductor 1 to conductor 2

 $R_{Load} = Load$ resistance

Note: R_{x_1} , R_{x_2} , and R_{x_3} should be referenced from LOCA simulation qualification test reports as described in the previous section.

STANDARD NO.: GGNS-JS-09 APPENDIX: C REVISION: 0 PAGE 4 OF 6

In general, the leakage resistance paths shown in Figure C-1 can be grouped into three different types: paths between conductor 1 and conductor 2, paths from conductor 1 to ground, and paths from conductor 2 to ground. If these distinctions are made, the original model may be reduced by combining like resistance paths using the equations shown below to form the equivalent model shown in Figure C-2.

Combining all paths from conductor 1 to ground:

$$\frac{1}{R_{C1}} = \frac{1}{R_{11}} + \frac{1}{R_{21}} + \frac{1}{R_{31}} + \frac{1}{R_{41}}$$

Combining all paths from conductor 2 to ground:

$$\frac{1}{R_{C2}} = \frac{1}{R_{12}} + \frac{1}{R_{22}} + \frac{1}{R_{32}} + \frac{1}{R_{42}}$$

Combining all conductor - to - conductor resistances:

$$\frac{1}{R_{CC}} = \frac{1}{R_{13}} + \frac{1}{R_{23}} + \frac{1}{R_{33}} + \frac{1}{R_{43}}$$



Figure C-2

Again, the circuit of Figure C-2 can be reduced to further simplify the model by using the equation below to yield the equivalent circuit of Figure C-3.

Combining the potential leakage current path resistances:

$$\frac{1}{R_{LEAKAGE}} = \frac{1}{R_{CC}} + \frac{1}{R_{C1} + R_{C2}}$$



Ideally, if no leakage resistance paths existed, the source current (I_s) and the current delivered to the load (I_{Load}) would be equivalent. However, due to the postulated degradation of the insulation resistance, the leakage resistance is no longer so great that leakage current is negligible. As the leakage resistance decreases the leakage current (or IR effect) becomes greater. To relate this effect to loop uncertainty, the leakage current must be determined using the following equations from basic circuit analysis.

From Figure C-3, the source current is the difference between the current delivered to the load and the leakage current:

$$I_{s} = I_{load} - I_{leakage}$$
OR

$$I_{LEAKAGE} + I_{S} = I_{LOAD}$$

STANDARD NO.: GGNS-JS-09 APPENDIX: C REVISION: 0 PAGE 6 OF 6

Also from Figure C-3, the source voltage is given by:

$$V_{s} = I_{LEAKAGE}(R_{LEAKAGE}) + I_{LOAD}(R_{LOAD})$$

Or equivalently:

$$I_{LEAKAGE} = \frac{V_s - I_{LOAD}(R_{LOAD})}{R_{LEAKAGE}}$$

Substituting for I_{Load} and solving for I_{Leakage}:

$$I_{LEAKGE} = \frac{V_{S} - (I_{LEAKAGE} + I_{S})R_{LOAD}}{R_{LEAKAGE}}$$

$$I_{LEAKGE}(R_{LEAKAGE} + R_{LOAD}) = V_S - I_S(R_{LOAD})$$

Therefore, the leakage current is given by:

$$I_{LEAKAGE} = \frac{V_s - I_s(R_{LOAD})}{R_{LEAKAGE} + R_{LOAD}}$$

And the leakage resistance in percent of span, or IR Effect is:

$$I_{LEAKAGE} (\% SPAN) = \frac{I_{LEAKAGE}}{I_{S \max} - I_{S \min}} (100\%)$$

The equations above lead to the following general conclusions regarding insulation resistance effects for current loops:

- The IR effect for a transmitter (current) loop is a positive **bias** with respect to the loop current.
- The IR effect increases with increased source (power supply) voltage.
- The IR effect increases with decreased source (transmitter) current.

.

• The IR effect increases with decreased load resistance.

STANDARD NO.: GGNS-JS-09 APPENDIX: D REVISION: 0 PAGE 1 OF 3

APPENDIX D

ACRONYMS AND ABBREVIATIONS

.

STANDARD NO.: GGNS-JS-09 APPENDIX: D REVISION: 0 PAGE 2 OF 3

ACRONYMS AND ABBREVIATIONS

AL	-	Analytical Limit
A_L	_	Loop Device Uncertainty
AV	-	Allowable Value
A _x	-	Individual Device Uncertainty
C_L	_	Loop Calibration Uncertainty
DBE		Design Basis Event
D_L	-	Loop Drift
DR	-	Device Drift
F	-	Arbitrarily Distributed Loop Uncertainties
HE		Humidity Effects
HELB	-	High Energy Line Break
IR		Insulation Resistance Effects
ISA		Instrument Society of America
L	-	Bias in the Negative Direction
LER	-	Licensee Event Report
LSL	-	Licensing Safety Limit
LU	-	Loop Uncertainty
Μ	_	Bias in the Positive Direction
MTE	-	Measurement and Test Equipment Effects
NTSP	-	Nominal Trip Setpoint
n	-	Number of Standard Deviations
OVP	-	Overpressure Effects
PAM	-	Post Accident Monitoring

•• ·· ·

.

STANDARD NO.: GGNS-JS-09 APPENDIX: D REVISION: 0 PAGE 3 OF 3

PE	-	Primary Element Uncertainty
PL	-	Process Limit
PM	-	Process Measurement Uncertainty
PS	-	Power Supply Effects
RA	-	Reference Accuracy
RD	-	Radiation Drift
RE	-	Radiation Effects
RI	-	Readability of Indicator
RLU		Random Loop Uncertainty
SE	-	Seismic Effects
SPE	-	Static Pressure Effects
SRSS	-	Square Root Sum of the Squares
SSE	-	Safe Shutdown Earthquake
Т	-	Magnitude of the Limiting Transient Variation
T _c	-	Modeling Bias or Uncertainty
TE	_	Temperature Effects
TD		Temperature Drift Effects
TLU	_	Total Loop Uncertainty
URL		Upper Range Limit
X _o	-	Max. or Min. Steady State Loop Operating Value
X _T	_	Magnitude of the Limiting Operating Transient

• • • • • • • • • • • • • • • •

••••••

.

Entergy	50.59 SC	Page /	or 3	
Facility: Grand	Gulf Nuclear Station			
SIGNATURES				
Preparer: Slow 1	no	Floyd J. Br	own	1/6/2000
Signa	ture	Name (pri	nt)	Date
Reviewer:	~5 -	TIMOTHI M B	WYANT	1/6/00
Signa	ture	Name (pri	nt)	Date
. OVERVIEW				
Ocument Evaluated: (Includ	e document number, revis	sion, and title)		
GGNS-JS-09, Rev. 1 – Methodo Calculations	ology for the Generati	on of Instrument Lo	op Uncertainty 8	Setpoint
Brief Description of the Pro	posed Change:			

General revision and incorporate SCN 98-0001

III. 50.59 SCREENING

TECHNICAL SPECIFICATION SCREENING

Does the proposed Change represent a change to:				
Operating License	☐ Ye ⊠ No	s If yes, process a change per 10CFR50.90 and obtain NRC approval prior to implementing the Change.		
Technical Specifications	☐ Ye ⊠ No	If yes, process a change per 10CFR50.90 and obtain NRC approval prior to implementing the Change.		
NRC Orders (ANO only)	Yes No X N/A	If yes, process a change per 10CFR50.90 and obtain NRC approval prior to implementing the Change.		

SAR SCREENING

Does the proposed Change represent a change to the facility or procedure which alters information, operation, function or ability to perform the function of a system, structure or component described in the SAR (site-specific documents)?

TS Bases section	\square	Yes No	If yes, perform a 50.59 Evaluation.
UFSAR (including pending changes)	\square	Yes No	If yes, perform a 50.59 Evaluation.
TRM		Yes No	If yes, perform a 50.59 Evaluation. ATTACHMENT: <u>1</u> TO: <u>C-GNS - 35 - D9 R</u> ev I PAGE: <u>1 OF 3</u>

Entergy	50.	59 S(CREEN	ling	Page	2	ot	3
Core Operating Limits Repo	rt		Yes No	lf yes, perform a	50.59 Eva	luation	1.	
Fire Hazards Analysis (Included in RBS' USAR)			Yes No N/A	lf yes, perform a	50.59 Eva	luatior	1.	
NRC SERs		\square	Yes No	If yes, perform a (See Section 5.1.	50.59 Eva 19.)	lluation).	
Does the proposed Chang or experiment not describe	e involve a test Id in the SAR?		Yes No	If yes, perform a	50.59 Eva	luation	i.	
Does the proposed Change potential impact to equipm utilized for Ventilated Stora activities?	e result in any rent or facilities age Cask		Yes No N/A	If yes, perform a 1	72.48 Rev	i ew .		
	ADDITIONA	L SC	REENI	NG				
Does the proposed Change	e represent a ch	ange t	o :					
Quality Assurance Program	n Manual		Yes No	If yes, notify the q a 50.54 Evaluation	uality dep n is perfor	artmer med.	nt and	l ensure
Emergency Plan			Yes No	If yes, notify the e department and e	mergency Insure a 5	v plann 0.54 E	ing valua	tion is

BASIS: [A brief written response providing the basis for answering the questions must be provided. Adequate basis must be provided within the Screening such that a third-party reviewer can reach the same conclusions. Simply stating that the change does not affect TS or the SAR is not an acceptable basis. Also discuss the methodology for performing the LBD search. State the location of relevant licensing document information and explain the scope of the review such as electronic search criteria used (e.g., key words) or the general extent of manual searches per Section 5.1.18.6.]

No No

performed.

- ----

Standard GGNS-JS-09 presents the methodology for the generation of instrument loop uncertainty and setpoint calculations. This standard is intended to promote uniformity in instrument calculations performed at GGNS, and is based on accepted industry standards.

JS-09 is not specifically addressed in the Technical Specifications or the SAR. The changes made in Revision 1 of JS-09 will not invalidate the general descriptions of setpoint / allowable value development contained in the Tech. Spec. Bases.

Electronic search keywords: setpoint methodology, JS-09 Documents searched: UFSAR, Technical Specifications, TRM

ATTACHMENT: TO: GGNS-35-09 Rev 1 PAGE: 2 OF



Page	२	to	2
	2		2

IV. ENVIRONMENTAL EVALUATION APPLICABILITY REVIEW

--- ---

.

If any of the following questions is answered "YES", then an Environmental Evaluation must be performed.

Will the Change being evaluated:

YES	NO	
	\boxtimes	Disturb land that is beyond that initially disturbed during construction (i.e., new construction of buildings, creation or removal of ponds, or other terrestrial impact)?
	\boxtimes	Increase thermal discharges to the river, lake or atmosphere?
	\boxtimes	Increase concentration or quantity of chemicals discharged to the atmosphere, ground water, or surface water?
	\boxtimes	Increase quantity of chemicals to cooling lake or atmosphere through discharge canal or tower?
	\boxtimes	Modify the design or operation of cooling tower that will change flow characteristics?
	\boxtimes	Install any new transmission lines leading offsite?
	\boxtimes	Change the design or operation of the intake or discharge structures?
	\boxtimes	Discharges any chemicals new or different from that previously discharged?
	\boxtimes	Potentially cause a spill or unevaluated discharge that may effect neighboring soils, surface water or ground water?
	\boxtimes	Involve burying or placement of any solid wastes in the site area that may effect runoff, surface water or ground water?
	\boxtimes	Involve incineration or disposal of any potentially hazardous materials on the site?
	\boxtimes	Result in a change to non-radiological effluents or licensed reactor power level?
	\boxtimes	Potentially change the type or increase the amount of non-radiological air emissions from the site?



Date: 1/7/00

To: Mr. J. E. Venable, GGNS General Manager, Plant Operations

From: A. D. Barfield, Manager, Design Engineering

Subject: Engineering Issuance of Standard GGNS-JS-09, Revision 1, for Use

Title Methodology for the Generation of Instrument Loop Uncertainty & Setpoint Calculations

Engineering is issuing the subject Standard for use at GGNS.

- X The subject specification/standard was not issued for review. Therefore, if this issuance impacts any procedure, requires re-training, or effects materials, contact Engineering.
- _____ The subject specification/standard was previously issued for review. All comments have been incorporated. Plant review indicated no material impacts, retraining, or procedure revisions are required.
- The subject specification/standard was previously issued for review. All comments have been incorporated. Plant review indicated material impacts, retraining, or procedure revisions are required. See the attached completed Advance Change Notification Department Response.

It should be noted that a master reproducible copy of this document is being transmitted to Plant Staff Document Control so that members of your staff will be able to obtain controlled copies.

......

FJB: the tanfield

Attachment

pc: E. D. Harris, w/a (M&E/Engineering), w/a
J. C. Roberts (BADM/QP), w/o
C. D. Stafford (G-ADM1-OPS), w/a
D. P. Wiles (U2WHSE/MATL), w/a
Configuration. Management (ESC), w/a
File (applicable), w/a
File (NPE), w/o

FORM 015-9/1/1999

Date:	1/6/2000
-------	----------

To: Ms. K. M. Bilbro, Document Control Supervisor

From: M. L. Humphries, Group Supervisor, Electrical / I&C

Subject: File Documentation

. .

DOCUMENT NAME AND NUMBER

DCP: _____

MCP: _____

CALC: _____

CN: _____

OTHER: GGNS-JS-09, Rev. 1

Documents are attached and forwarded for inclusion in the appropriate subject file.

1-6-2000 Am Group Supervisor /Date

Total number of pages including this sheet _____.

FORM035-9/2/1999

ENGINEERING PROGRAMS APPLICABILITY REVIEW/ACCOUNTABILITY RECORD

Document Evaluated GGNS-JS-09 Brief Description of Change General revision and incorporate SCN 98/0001

Rev. 1 Supplement N/A

	<u>N/A</u>	NO	YES	N/R
ALARA (if YES, refer to NPEAP 311) Does document install or modify a component: 1) where				
radiation exposure to plant personnel (> 2.5 mrem/hr) can occur either during normal or outage				
conditions, or during manipulation of an SSC following an accident; 2) involve work inside the				
fund boundary of a radioactive system; 3) require a modification of shielding; or 4) is there a				
potential for Cobalt reduction in systems communicating with the Reactor Vessel? Note: Records				
of plant radiological conditions during various operational modes are maintained by the GGNS				
Health Physics department.				
SEISMIC QUALIFICATION (if YES, refer to NPEAP 314) Does document delete or modify				
seismically qualified equipment; install new safety related or post accident monitoring equipment,				
or affect equipment which interacts with seismically qualified equipment in a manner which could				ليسبب
affect the performance capabilities or seismic/dynamic characteristics?				
FIRE PROTECTION (if YES, refer to NPEAP 317) Does document involve or affect		<u> </u>	r1	
combustibles, fire protection equipment, obstructions to fire suppression/detection features,				
penetrations/ space separators, or structural steel fireproofing, raceway fire barrier enclosures		<u> </u>	<u> </u>	
(Thermo-Lag/Kaowool), cable tray covers or Pre-Fire Plans; add or remove safety related equipment?				
SAFE SHUTDOWN (if YES, refer to NPEAP 317) Does document involve equipment listed in				
FPP-1, described on safe shutdown P&ID drawings, or involve any of the following systems: B21				
E12, P41, P75, T46, T51, X77, Y47, C61, M71, Z77, or systems which support these systems:				
address a change to equipment in an area containing redundant safe shutdown components; involve				
non-safe shutdown circuits that share power supplies, signal sources or enclosures with safe				
shutdown circuits; or affect the function of 8 hour emergency lighting?				
HUMAN FACTORS (if YES, refer to NPEAP 333) Does document include a change to control				
room labeling or annunciator wording which differs from, or is not listed in Amendix A of ES-17-				
or modifies display equipment on control room panels or control room operator controls?				
HYDROGEN CONTROL (if YES, refer to NPEAP 336) Does document address a change to				
equipment or structures in the containment or drywell?				
ASME SECTION XI (if YES, refer to NPEAP 337) Does document add or delete any safety				
related pressure boundary welds, components, or component supports; affect the performance or				
testing of a safety related pump or safety related valve; or the function or function classification of				
any pump or valve as stated in GGNS-M-189.3?				
ENVIRONMENTAL QUALIFICATION (if YES, refer to NPEAP 803) Does document			······	
add EQ equipment; remove, replace, change the function of, change the power supply of or alter				
any EQ equipment; result in a change or potential change to local environmental conditions (e.g.	لسسا			
heat load, cooling source or radiation source) during normal, abnormal or post accident operations				
including changes to HELB barriers (e.g. doors); add, change or alter safety related equipment				
located inside a line break area/containment which share common power supplies or circuit				
breakers with EQ equipment; or alter a system required to detect/mitigate a LOCA or HELB?				
EROSION/CORROSION - MIC (if YES, refer to NPEAP 903) Does the document affect				
any aspect of a water/steam system (e.g., flow path geometry, material, flow rate, duration,				
chemistry, new weld location, temperature, pressure, or steam quality); or affect the piping				
component wall thickness (e.g., welding overlay, different pipe schedule, eroded areas, etc.) for				
elbow, tee, reducer, piping, pump, tank, or valve within the piping system (not to include pipe				
supports); or add external weight to the piping system (such as lead shielding or larger actuator); or				
make any changes to the drawings listed in Attachment 1 to NPEAP 903?				
Justification: Revision 1 of JS-09 is a general revision and incorporates SCN of	2/AAA1			
These changes consist of minor methodology revisions, adjusted also	0/0001	•		
The revision does not in minor methodology revisions, editorial changes and	update	es to re	eference	<u>s.</u>
The revision does not impact the original design inputs.				
Responsible Engineer: 41 1111		-	Ŀ	1
Loup 1 Stor		Date	: 1/6	1200
Group Supervisor:			7,7	/
		Date	: <u> 6 </u>	2000
Form 330.2. Rev. 4				
,				
rorm 330.2, Kev. 4				

and the second sec

		Page 1 of 1		
	DESIGN VERIFI	ICATION RECORD		
Document Number: JS-09)	Revision 1		
	····			
METHOD				
Verification methods to be u	ised:			
X Design Re Qualificat Alternate	eview ion Testing Calculations			
DOCUMENT(S) REVIEW	ED: (Attach Additi	tional Sheet(s), if needed)		
Document Number	Revision	Document Title		
NEDC-31336P-A	1996	GE setpoint methodology		
ISA RP67.04, Part II	1994	ISA setpoint methodology		
EDP-032	1	Setpoint/uncertainty desktop procedure NRC instrument setpoint reg guide		
USNRC RG 1.105	1			
JS-09	0	-		
SUMMARY OF REVIEW: A review was done to verify review was done to ensure th acceptable for issuance. The	(Attach Additiona the accuracy of the pat all procedural re methodology for g	al Sheet(s), if needed) the information presented in JS-09 rev 1. A requirements were met. JS-09 rev 1 is generating instrument uncertainty and setpo		
Design Verification Completed By	plained.	Date: 1/6/00		

waters after assessment and the

A second s

and a second second