

Enclosure 5c  
Probabilistic Risk Evaluation

# CONTENTS

Contents.....	ii
1. Introduction .....	1
2. Risk Insights from Previous Analyses .....	2
2.1 Individual Plant Examinations.....	2
2.2 Integrated Leak Rate Test Extensions .....	3
2.3 Severe Accident Mitigation Alternatives .....	4
3. Technical Approach .....	6
3.1 Assumptions .....	8
3.2 Delineation of Accident Sequences .....	8
3.2.1 List of Top Events.....	9
3.2.2 List of Sequences.....	10
3.2.3 Mapping Sequences to MELCOR/MACCS2 Calculations.....	13
3.2.4 Quantitative Information .....	14
4. Results .....	16
5. Conclusions .....	25

# 1. INTRODUCTION

A risk evaluation was performed to estimate the reduction in risk resulting from the installation of a severe accident (SA) venting system in a boiling-water reactor (BWR) with either a Mark I or Mark II containment design. This information provides a major input to the regulatory and backfit analyses of the SA venting system. In addition, the risk evaluation discusses accident sequences where the inclusion of filters to the SA venting system is and is not beneficial, as directed by the Commission in a staff requirements memorandum (SRM) (M120807B) issued on August 24, 2012, following a staff briefing held August 7, 2012, on the status of actions taken in response to lesson learned from the Fukushima Dai-ichi accident.

The purpose of an SA venting system is to prevent an uncontrolled large release of radioactive material during a severe accident as a result of containment failure due to overpressurization from the buildup of steam and noncondensable gases generated during core degradation. An SA venting system should significantly reduce the amount of radioactive material released from the containment when compared to an uncontrolled release. An SA venting system is different than the reliable, hardened venting system mandated by Order EA-12-050, as shown in Table 1.

<b>Table 1. Differences Between a Severe Accident Venting System and a Reliable Hardened Venting System</b>		
<b>Characteristic</b>	<b>Severe Accident Venting System</b>	<b>Reliable Hardened Venting System</b>
Purpose	Prevent containment overpressurization failure after core damage	Provide a pathway for decay heat removal in order to prevent core damage
Period of Use	After core damage	Prior to core damage
Vented Materials	Radioactive steam and noncondensable gases resulting from core damage	Mildly radioactive steam (limited to activity contained in the reactor coolant system that exists during normal operations)
Release of Radioactive Materials to the Environment	Small if the severe accident venting system operates as designed to prevent containment overpressurization failure, includes a filter or other means to scrub fission products, and other containment failure modes (such as liner melt-through) are prevented  Otherwise, potentially large	Very small if the reliable, hardened vent operates as designed to prevent core damage

The following sections discuss risk insights related to SA venting obtained from previous analyses, explain the technical approach used, list the assumptions used, describe the delineation of post-core-damage accident sequences pertaining to SA venting, provide the quantitative information used, and present the results of the risk evaluation.

## 2. RISK INSIGHTS FROM PREVIOUS ANALYSES

As an initial step in the risk evaluation, the staff reviewed information from the individual plant examinations completed in response to Generic Letter 88-20, license amendment requests for integrated leak rate testing (ILRT) extensions, and severe accident mitigation alternatives (SAMA) analyses submitted with license renewal requests. The purpose of this review was to gain insight into the causes and likelihood of containment failure and to understand how SA venting has been considered in previous probabilistic risk assessments (PRAs) and risk-informed applications. The following sections summarize the information obtained.

### 2.1 Individual Plant Examinations

The results of individual plant examinations (IPEs) indicated that the likelihood of Mark I and Mark II containment failure due to severe accident phenomena is not insignificant. Figure 1 illustrates the range of conditional containment failure probabilities for BWR Mark I containments as reported in the IPE submittals.




Figure 1. Reported IPE conditional probabilities of failure for BWR Mark I containments

With respect to the likelihood of BWR Mark I containment failure modes, NUREG-1560 indicates that liner melt-through is the most important contributor to early containment failure.

Overpressurization failures are generally associated with late containment failure, as discussed in NUREG-1560, "Individual Plant Examination Program: Perspectives on Reactor Safety and Plant Performance":

Because of a high containment pressure capability and the energy absorbing capacity of the suppression pool, a typical Mark I containment is unlikely to fail because of overpressure early in the accident sequence. However, accidents in which both containment heat removal and containment venting are not available

or inadequate (such as occurs in some sequences in which the reactor vessel fails at high pressure, or in some anticipated transient without scram (ATWS) sequences) can cause early containment failure. For these sequences, containment may fail either before or at vessel breach because of the high containment pressures.

As noted in Table 10.4 of NUREG-1560, the design pressures for BWR Mark I containments range from 56 to 62 psig, and the median failure pressures estimated for the IPEs range from 98 to 190 psig.

Figure 2 illustrates the range of conditional containment failure probabilities for BWR Mark II containments as reported in the IPE submittals.




Figure 2. Reported IPE conditional probabilities of failure for BWR Mark II containments

NUREG-1560 states that containment overpressure failure caused by a loss of containment heat removal (primarily during ATWS sequences) is important in most Mark II IPE analyses, and that rapid pressure and temperature increases at the time of reactor vessel failure are significant in only a few Mark II IPE analyses. Specific plant features play an important role in accident progression in Mark II containments. As noted in Table 10.4 of NUREG-1560, the design pressures for BWR Mark II containments range from 45 to 55 psig, and the median failure pressures estimated for the IPEs range from 140 to 191 psig.

## 2.2 Integrated Leak Rate Test Extensions

In recent years, a number of BWR Mark I and Mark II plants have applied for and been granted extensions of their ILRT intervals. ILRTs are conducted to satisfy the requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, "Domestic Licensing of Production and Utilization Facilities," Appendix J, "Primary Reactor Containment Leakage Testing for Water-Cooled Power Reactors." Relevant to SA venting, license amendments requests for

ILRT extension provide information that can be used to estimate conditional containment failure probabilities. A review of this information was made to determine how licensees' understanding of conditional containment failure probability has evolved since completion of their IPEs. Table 2 summarizes the contributions to conditional containment failure probability for selected ILRT extension requests. Note that the contributions to conditional containment failure probability by specific accident-induced failures (overpressurization, liner melt-through, etc.) are not provided in ILRT extension requests.

<b>Table 2. Conditional Containment Failure Probabilities from ILRT Extensions</b>						
<b>Plant</b>	<b>Type</b>	<b>ILRT Interval</b>	<b>Accident Phenomena</b>	<b>Bypass (ISLOCA)</b>	<b>Isolation Failures</b>	<b>Total CCFP</b>
Cooper	Mark I	3 in 10y	94.6%	0.0%	1.0%	95.6%
		1 in 10y	94.6%	0.0%	1.0%	95.6%
		1 in 15y	94.6%	0.0%	1.0%	95.6%
Nine Mile Point 1	Mark I	3 in 10y	62.4%	2.7%	9.7%	74.8%
		1 in 10y	62.4%	2.7%	9.7%	74.9%
		1 in 15y	62.4%	2.7%	9.8%	74.9%
Peach Bottom	Mark I	3 in 10y	61.1%	2.4%	2.7%	66.2%
		1 in 10y	61.1%	2.4%	3.4%	67.0%
		1 in 15y	61.1%	2.4%	4.0%	67.5%
Pilgrim	Mark I	3 in 10y	97.7%	0.6%	0.0%	98.3%
		1 in 10y	97.7%	0.6%	0.1%	98.3%
		1 in 15y	97.7%	0.6%	0.1%	98.4%
Vermont Yankee	Mark I	1 in 10y	86.8%	1.1%	0.1%	88.0%
		1 in 15y	86.8%	1.1%	0.2%	88.1%
LaSalle	Mark II	3 in 10y	82.9%	2.4%	0.4%	85.7%
		1 in 10y	82.9%	2.4%	0.6%	85.9%
		1 in 15y	82.9%	2.4%	0.8%	86.1%
Limerick	Mark II	3 in 10y	62.4%	1.3%	0.7%	64.4%
		1 in 10y	62.4%	1.3%	1.5%	65.2%
		1 in 15y	62.4%	1.3%	2.0%	65.7%

### **2.3 Severe Accident Mitigation Alternatives**

Table 3 provides a breakdown by plant type of how filtered containment vent (FCV) systems have been considered in SAMA analyses. SAMA analyses have used two approaches when considering FCV systems. A screening approach compares the cost of a FCV system to the monetized baseline risk of the plant. This approach is conservative since it assumes that installation of a FCV system will completely eliminate all plant risk. A detailed approach attempts to approximate the risk reduction that would be achieved by installing a FCV system by adjusting the source terms that are used in a Level 3 PRA. Three early SAMA analyses stated that they had considered FCV systems, but the discussion does not describe the approach taken to assess the risk reduction or provide the numerical results. To date, no SAMA analysis has determined that FCV systems are cost justified.

**Table 3. Consideration of Filtered SA Venting in SAMA Analyses, as of February 2012**

<b>Plant Type</b>	<b>FCV Not Considered</b>	<b>FCV Considered (Screening Analysis)</b>	<b>FCV Considered (Detailed Analysis)</b>	<b>License Renewal Granted, but Limited SAMA</b>	<b>License Renewal Application Not Submitted</b>	<b>Total</b>
BWR Mark I	5	11	5	1	1	23
BWR Mark II	1	3		2	2	8
BWR Mark III			1		3	4
PER large dry containment	22	10	14		9	55
PWR subatmospheric containment			5			5
PWR ice condenser		2	4		3	9
Totals	28	26	29	3	18	104

### 3. TECHNICAL APPROACH

The addition of an SA venting system does not change a plant’s core damage frequency (CDF); rather, it affects the frequency of releases to the environment resulting from core damage and also the consequences of these releases. Release frequencies are estimated using Level 2 PRA methods, and consequences are estimated using Level 3 PRA methods. The staff has developed three proof-of-concept Level 2 Standardized Plant Analysis of Risk (SPAR) models, but does not routinely use them to support regulatory decisionmaking. In addition, the staff does not have any Level 3 PRA models. As a result, a simplified event tree was constructed to estimate the frequencies of the MELCOR scenarios developed to support the assessment of SA venting, as described in Enclosure 5a. Coupled with the MACCS2 consequence results, described in Enclosure 5b, developed for each MELCOR scenario, this simplified event tree provides the information needed to assess the reduction in risk resulting from the installation of an SA venting system.

There are a variety of ways to design an SA venting system, depending on where the vent attached (wetwell or drywell), how the vent is actuated (manually by the operator or passively using a rupture disk), and whether the SA venting system has a filter. The simplified event tree structure used to estimate release sequence frequencies was designed to allow assessment of a wide range of SA vent system designs. Specifically, the same simplified event tree structure was used to assess nine hypothetical plant modifications (“mods”), which are defined in Table 4.

<b>Table 4. Hypothetical Plant Modifications Assessed in the Risk Evaluation</b>			
<b>Plant Modification Identifier</b>	<b>SA Vent Filter</b>	<b>SA Vent Location</b>	<b>SA Vent Actuation</b>
Mod 0 (current situation)	n/a	None	n/a
Mod 1	No	Wetwell	Manual
Mod 2	No	Wetwell	Passive
Mod 3	No	Drywell	Manual
Mod 4	No	Drywell	Passive
Mod 5	Yes	Wetwell	Manual
Mod 6	Yes	Wetwell	Passive
Mod 7	Yes	Drywell	Manual
Mod 8	Yes	Drywell	Passive

The first two characteristics that define the plant modification (the presence of a filter and the vent location) only affect the consequences associated with the release sequences defined in the simplified event tree. For example, the addition of a filter or venting through the wetwell would reduce the consequences. The third characteristic (vent actuation method) only affects the frequency of the release sequences. For example, utilization of a passive mechanism (e.g., rupture disk) to actuate the vent path is expected to be more reliable than operator action, and therefore, the frequency of large releases is expected to decrease more when a passive vent is used than when relying on manual operation.



In order to support the regulatory and backfit analyses, the following risk metrics were estimated for each hypothetical plant modification:

- 50-mile population dose risk (person-rem/reactor-year)
- 50-mile offsite cost risk (\$/reactor-year)
- onsite worker dose risk (person-rem/reactor-year)
- onsite cleanup and decontamination cost (\$/reactor-year)

Using the risk metrics identified above, the risk reductions (relative to Mod 0, which is the current situation) due to implementation of each hypothetical plant modification (Mod 1 through Mod 8) were estimated. These risk reductions are used as an input to the regulatory and backfit analyses:

- Reduction in 50-mile population dose risk ( $\Delta$ person-rem/reactor-year)
- Reduction in 50-mile offsite cost risk ( $\Delta$ \$/reactor-year)
- Reduction in onsite worker dose risk ( $\Delta$ person-rem/reactor-year)
- Reduction in onsite cleanup and decontamination cost ( $\Delta$ \$/reactor-year)

In addition to the risk metrics listed above, a risk metric pertaining to land contamination was estimated. It should be noted that the impact of accident releases on land contamination that occurs within 50 miles of the site is included in the offsite cost risk. A direct measure of land contamination risk (including contaminated land that is farther than 50 miles from the site) is desirable to gain perspective on the risk reductions that can be achieved through implementation of the hypothetical plant modifications. Mathematically, risk is defined as the sum of the product of the release sequence frequency and the consequence of the release:

$$R = \sum_i f_i c_i$$

where  $R$  denotes the risk,  $f_i$  denotes the frequency of the  $i$ th release sequence, and  $c_i$  denotes the consequences associated with the  $i$ th release sequence, and the summation is taken over all release sequences. One measure of the consequences of a release with respect to land contamination is the amount of area (in  $\text{km}^2$ ) that is contaminated above  $15 \mu\text{Ci}/\text{m}^2$  with cesium-137 ( $^{137}\text{Cs}$ )<sup>1</sup>. Using this consequence measure, land contamination risk has the units of  $\text{km}^2/\text{ry}$  (square kilometers/reactor year), which is rather difficult to interpret. A potentially more insightful risk metric is conditional contaminated land area (CCLA), as defined by:

$$CCLA = \frac{\sum_i f_i c_i}{\sum_i f_i} = \frac{R}{CDF}$$

That is, the CCLA is the frequency-weighted average area contaminated above  $15 \mu\text{Ci}/\text{m}^2$  with  $^{137}\text{Cs}$ , conditional on the occurrence of a core-damage accident. Accordingly, a reduction in CCLA due to implementation of one of the hypothetical SA vent modifications measures the effectiveness of that modification with respect to reducing land contamination.

<sup>1</sup> Annex I to IAEA TECDOC-1240, "Present and future environmental impact of the Chernobyl accident," zoned land surrounding the Chernobyl site according to the level of radionuclide soil deposition. Land that was contaminated above  $15 \mu\text{Ci}/\text{m}^2$  with  $^{137}\text{Cs}$  was called an "obligatory (subsequent) resettlement zone." Permanent residence and the production of commodities within the obligatory (subsequent) resettlement zone is forbidden.

### **3.1 Assumptions**

The following assumptions were used to conduct the risk evaluation:


- (1) The existing regulatory analysis guidance provided in NUREG/BR-0058, "Regulatory Analysis Guidelines of the U.S. Nuclear Regulatory Commission," and NUREG/BR-0184, "Regulatory Analysis Technical Evaluation Handbook," have been used. Accordingly:
  - (a) The risk evaluation was developed on a "per-reactor" basis
  - (b) Multi-unit accidents were not addressed
  - (c) Accidents involving spent fuel (stored either in the spent fuel pool or in dry casks) were not addressed
- (2) Except for bypass sequences (ISLOCAs (interfacing-systems loss-of-coolant accidents) and large external hazards that directly fail the containment), severe accident containment venting is always required to prevent a containment overpressurization failure. This assumption follows from the results of the MELCOR calculations performed to support the regulatory and backfit analyses of SA venting.
- (3) No credit was given for recovering offsite power if core damage was caused by an external hazard (seismic event, high winds, etc.).
- (4) The consequences of accident sequence that result in radioactive releases are reasonably approximated by determining the consequences of station blackout (SBO) sequences.
- (5) The reactor core isolation cooling (RCIC) system operates for 16 hours (16-hour battery depletion).
- (6) If the SA venting system includes a filter, then it has a decontamination factor of 10 (wetwell venting) or 1,000 (drywell venting)..
- (7) If an accident sequence involves failure to open the SA vent or containment bypass (such as an ISLOCA) then use of a portable pump to provide core spray or drywell spray following core damage is precluded due to a harsh work environment (high dose rates, high temperatures, etc.).

### **3.2 Delineation of Accident Sequences**

The simplified release event tree (Figure 3) traces the accident progression starting from the onset of core damage. The initial event tree headings parse the total CDF according to the type of initiating event and core-damage sequence. Subsequent event tree headings consider operation of the SA vent and the availability of a water supply to the drywell. Each sequence has been assigned to a unique containment status:

- Vented: The SA vent is opened, preventing containment overpressurization failure. A source of water to the drywell exists, preventing liner melt-through.

- LMT: The SA vent is opened, preventing containment overpressurization failure. No source of water to the drywell exists, and liner melt-through occurs.
- OP: The SA vent is closed, resulting in containment overpressurization failure. A source of water to the drywell exists, preventing liner melt-through.
- OP + LMT: The SA vent is closed, resulting in containment overpressurization failure. No source of water to the drywell exists, and liner melt-through occurs.



**Figure 3. Simplified release event tree**

### 3.2.1 List of Top Events

The release event tree consists of six event tree headings (top events), which are described in the following sections.

- Event “CD”: Represents the occurrence of core damage, which is the starting point of the risk evaluation. It should be noted that the risks resulting from radiological releases are directly proportional to the CDF.
- Event “hazard”: Partitions core-damage sequences according to their initiating event hazard type; either internal hazards (such as a loss-of-coolant accident (LOCA) or external hazards (such as a seismic event). This partitioning is included in the event tree structure to determine if offsite power is recoverable.
- Event “sequence type”: Partitions core-damage sequences according to their timing or influence on containment integrity. For internal hazards:
  - Sequence “other” denotes the internal hazard sequences that are not “SBO,” “bypass,” or “fast.”
  - Sequence type “SBO” denotes core-damage sequences that involves station blackout. In these sequences, it may be possible to recover offsite power, which

allows the use of in-plant systems (such as condensate) to provide a source of water to the containment drywell.

- Sequence type “bypass” denotes core-damage sequences that involve containment bypass (such as ISLOCAs). In these sequences, venting the containment is not helpful because the containment has already functionally failed.
- Sequence type “fast” denotes sequences that evolve quickly (such as medium LOCAs (MLOCAs), large LOCAs (LLOCAs), and anticipated transients without scram (ATWS)) and, thus, reduce the available time for the operator to manually open the SA vent.

For external hazards:

- Sequence “other” denotes the external hazard sequences that are not “bypass.”
- Sequence type “bypass” denotes core-damage sequences that involve containment bypass (such as large seismic events that directly damage the containment). In these sequences, venting the containment is not helpful because the containment has already functionally failed.
- Event “vent”: Identifies if the SA vent is opened.
- Event “OSP recovery”: Identifies if offsite power is recovered.
- Event “portable pump”: Identifies if a portable pump is used to provide water to the drywell floor via the core spray system or drywell spray system following core damage.

### **3.2.2 List of Sequences**

The release event tree delineates 16 post-core-damage accident sequences, which are summarized in the following paragraphs.

- Sequence 1 (status “vented”): Following core damage caused by an internally initiated sequence that does not involve SBO, ISLOCAs, or quickly developing sequences (e.g., MLOCA, LLOCA, or ATWS), the SA vent is opened, thereby preventing containment overpressurization failure. In-plant equipment (such as the emergency core cooling system (ECCS)) is assumed to be unavailable (if it was available, core damage would not have occurred in the first place). However, a portable pump is successfully installed and operated to provide water to the drywell floor, thereby preventing liner melt-through.
- Sequence 2 (status “LMT”): Following core damage caused by an internally initiated sequence that does not involve SBO, ISLOCAs, or quickly developing sequences (e.g., MLOCA, LLOCA, or ATWS), the SA vent is opened, thereby preventing containment overpressurization failure. In-plant equipment (such as the ECCS) is assumed to be unavailable (if it was available, core damage would not have occurred in the first place). Moreover, a portable pump to provide water to the drywell floor is either not installed or fails. As a result, liner melt-through occurs.

- Sequence 3 (status “OP + LMT”): Following core damage caused by an internally initiated sequence that does not involve SBO, ISLOCAs, or quickly developing sequences (e.g., MLOCA, LLOCA, or ATWS), the SA vent remains closed and the containment fails due to overpressurization. In-plant equipment (such as the ECCS) is assumed to be unavailable (if it was available, core damage would not have occurred in the first place). Moreover, use of a portable pump to provide water to the drywell floor is precluded since the operator cannot access areas of the plant needed to install the pump and associated equipment. As a result, liner melt-through occurs.
- Sequence 4 (status “vented”): Following core damage caused by an internally initiated SBO sequence, the SA vent is opened, thereby preventing containment overpressurization failure. Offsite power is recovered, which allows the use of in-plant equipment (such as the condensate system) to provide water to the drywell floor and avoid liner melt-through.
- Sequence 5 (status “vented”): Following core damage caused by an internally initiated SBO sequence, the SA vent is opened, thereby preventing containment overpressurization failure. Offsite power is not recovered, which prevents the use of in-plant equipment to provide water to the drywell floor. However, a portable pump is successfully installed and operated to provide water to the drywell floor, thereby preventing liner melt-through.
- Sequence 6 (status “LMT”): Following core damage caused by an internally initiated SBO sequence, the SA vent is opened, thereby preventing containment overpressurization failure. Offsite power is not recovered, which prevents the use of in-plant equipment to provide water to the drywell floor. Moreover, a portable pump to provide water to the drywell floor is either not installed or fails. As a result, liner melt-through occurs.
- Sequence 7 (status “OP”): Following core damage caused by an internally initiated SBO sequence, the SA vent remains closed and the containment fails due to overpressurization. Offsite power is recovered, which allows the use of in-plant equipment (such as the condensate system) to provide water to the drywell floor and avoid liner melt-through.
- Sequence 8 (status “OP + LMT”): Following core damage caused by an internally initiated SBO sequence, the SA vent remains closed and the containment fails due to overpressurization. Offsite power is not recovered, which prevents the use of in-plant equipment to provide water to the drywell floor. Moreover, use of a portable pump to provide water to the drywell floor is precluded since the operator cannot access areas of the plant needed to install the pump and associated equipment. As a result, liner melt-through also occurs.
- Sequence 9 (status “OP + LMT”): Core damage occurs due to an internally initiated ISLOCA sequence. Venting the containment is not necessary because overpressurization cannot occur (the steam and noncondensable gases caused by core degradation pass through the ISLOCA and, hence, bypass the containment). The risk evaluation assumes that the consequences resulting from containment bypass are the same as the consequences resulting from containment overpressurization, followed by liner melt-through. Moreover, use of a portable pump to provide water to the drywell floor is precluded since the operator cannot access areas of the plant needed to install the pump and associated equipment. As a result, liner melt-through also occurs.

- Sequence 10 (status “vented”): Following core damage caused by an internally initiated, quickly developing sequences (e.g., MLOCA, LLOCA, or ATWS), the SA vent is opened, thereby preventing containment overpressurization failure. In-plant equipment (such as the ECCS) is assumed to be unavailable due to equipment failure or a nonrecoverable loss of offsite power (if it was available, core damage would not have occurred in the first place). However, a portable pump is successfully installed and operated to provide water to the drywell floor, thereby preventing liner melt-through. This sequence is similar to Sequence 1; however, there is less available time to open the SA vent.
- Sequence 11 (status “LMT”): Following core damage caused by an internally initiated, quickly developing sequences (e.g., MLOCA, LLOCA, or ATWS), the SA vent is opened, thereby preventing containment overpressurization failure. In-plant equipment (such as the ECCS) is assumed to be unavailable due to equipment failure or a nonrecoverable loss of offsite power (if it was available, core damage would not have occurred in the first place). Moreover, a portable pump to provide water to the drywell floor is either not installed or fails. As a result, liner melt-through occurs. This sequence is similar to Sequence 2; however, there is less available time to open the SA vent.
- Sequence 12 (status “OP + LMT”): Following core damage caused by an internally initiated, quickly developing sequences (e.g., MLOCA, LLOCA, or ATWS), the SA vent remains closed and the containment fails due to overpressurization. In-plant equipment (such as the ECCS) is assumed to be unavailable (if it was available, core damage would not have occurred in the first place). Moreover, use of a portable pump to provide water to the drywell floor is precluded since the operator cannot access areas of the plant needed to install the pump and associated equipment. As a result, liner melt-through also occurs. This sequence is similar to Sequence 3; however, there is less available time to open the SA vent.
- Sequence 13 (status “vented”): Following core damage caused by an externally initiated sequence that does not involve containment bypass, the SA vent is opened, thereby preventing containment overpressurization failure. In-plant equipment (such as the ECCS) is assumed to be unavailable (if it was available, core damage would not have occurred in the first place). However, a portable pump is successfully installed and operated to provide water to the drywell floor, thereby preventing liner melt-through. This sequence is similar to Sequence 1; however, it is an external hazard sequence rather than an internal hazard sequence.
- Sequence 14 (status “LMT”): Following core damage caused by an externally initiated sequence that does not involve containment bypass, the SA vent is opened, thereby preventing containment overpressurization failure. In-plant equipment (such as the ECCS) is assumed to be unavailable due to equipment failure or a nonrecoverable loss of offsite power (if it was available, core damage would not have occurred in the first place). Moreover, a portable pump to provide water to the drywell floor is either not installed or fails. As a result, liner melt-through occurs. This sequence is similar to Sequence 2; however, it is an external hazard sequence rather than an internal hazard sequence.
- Sequence 15 (status “OP + LMT”): Following core damage caused by an externally initiated sequence that does not involve containment bypass, the SA vent remains closed and the containment fails due to overpressurization. In-plant equipment (such as the ECCS) is assumed to be unavailable (if it was available, core damage would not

have occurred in the first place). Moreover, use of a portable pump to provide water to the drywell floor is precluded since the operator cannot access areas of the plant needed to install the pump and associated equipment. As a result, liner melt-through also occurs. This sequence is similar to Sequence 3; however, it is an external hazard sequence rather than an internal hazard sequence.

- Sequence 16 (status “OP + LMT”): Core damage occurs due to an externally initiated sequence that involves containment bypass. Venting the containment is not necessary because overpressurization cannot occur (the steam and noncondensable gases caused by core degradation bypass the containment). The risk evaluation assumes that the consequences resulting from containment bypass are the same as the consequences resulting from containment overpressurization, followed by liner melt-through. Moreover, use of a portable pump to provide water to the drywell floor is precluded since the operator cannot access areas of the plant needed to install the pump and associated equipment. As a result, liner melt-through also occurs. This sequence is similar to Sequence 9; however, it is an external hazard sequence rather than an internal hazard sequence.

### 3.2.3 Mapping Sequences to MELCOR/MACCS2 Calculations

As previously discussed, each sequence in the simplified release event tree has been assigned to a unique containment status. This mapping has been used, along with the definitions of the hypothetical plant modifications, to determine the specific MELCOR/MACCS2 (Enclosures 5a and 5b) calculation that applies to each sequence as shown in Table 5.

Table 5. Mapping to Release Sequences to MELCOR/MACCS2 Calculations							
Modification Description				Release Sequence Status			
Mod	Filter	Location	Actuation	Vented	LMT	OP	OP + LMT
				<ul style="list-style-type: none"> <li>• Vent: open</li> <li>• DW: wet</li> <li>• Seq: 1, 4, 5, 10, and 13</li> </ul>	<ul style="list-style-type: none"> <li>• Vent: open</li> <li>• DW: dry</li> <li>• Seq: 2, 6, 11, and 14</li> </ul>	<ul style="list-style-type: none"> <li>• Vent: closed</li> <li>• DW: wet</li> <li>• Seq: 7</li> </ul>	<ul style="list-style-type: none"> <li>• Vent: closed</li> <li>• DW: dry</li> <li>• Seq: 3, 8, 9, 12, 15, and 16</li> </ul>
0	n/a	n/a	None	n/a	n/a	Case 6	Case 2
1	No	Wetwell	Manual	Case 7 or 15 (no filter)	Case 3 (no filter)	Case 6	Case 2
2	No	Wetwell	Passive				
3	No	Drywell	Manual	Case 13 (no filter)	Case 12 (no filter)	Case 14	Case 2
4	No	Drywell	Passive				
5	Yes	Wetwell	Manual	Case 7 or 15 (filter)	Case 3 (filter)	Case 6	Case 2
6	Yes	Wetwell	Passive				
7	Yes	Drywell	Manual	Case 13 (filter)	Case 12 (filter)	Case 14	Case 2
8	Yes	Drywell	Passive				

### 3.2.4 Quantitative Information

Parameters values used to estimate the release sequence frequencies were taken from a variety of sources, as shown in Table 6.

<b>Table 6. Parameter Values Used in the Risk Evaluation</b>			
<b>Parameter</b>	<b>Value</b>		<b>Basis</b>
CDF	2E-5/reactor-year		SPAR external hazard models
Fraction of total CDF due to external hazards	0.8		SPAR external hazard models; review of previous PRAs
Breakdown of sequence types for internal hazards	Other (not SBO, bypass or fast)	0.83	SPAR internal hazard models
	SBO	0.12	
	Bypass (ISLOCAs)	0.05	
	Fast (MLOCAs, LLOCAs, ATWS)	0.01	
Breakdown of sequence types for external hazards	Other (not bypass)	0.95	Review of previous PRAs; engineering judgment
	Bypass	0.05	
Probability that SA vent fails to open	Mod 0	1	
	Mods 1, 3, 5, 7—other or SBO	0.3	SPAR-H method (manual vent; longer available time)
	Mods 1, 3, 5, 7—fast	0.5	SPAR-H method (manual vent; shorter available time)
	Mods 2, 4, 6, 8	0.001	Engineering judgment (passive vent mechanical failure)
Conditional probability that offsite power is not recovered by the time of lower head failure given not recovered at the time of core damage (internal hazards)	0.38		Historical data (NUREG-6890)
Probability that portable pump for core spray or drywell spray fails	0.3		SPAR-H; consistent with SPAR B.5.b study done by Idaho National Laboratory

The consequence per release for population dose, offsite cost, and contaminated area were obtained from MELCOR/MACCS2 calculations (Enclosures 5a and 5b). Table 7 lists the results of these calculations which have been used in the risk evaluation.



<b>Table 7. Consequences Determined by MELCOR/MACCS2 Calculations</b>							
<b>Case</b>	<b>Core Spray</b>	<b>Drywell Spray</b>	<b>Venting</b>	<b>Location</b>	<b>Population Dose (person-rem/event)</b>	<b>Offsite Cost (\$/event)</b>	<b>Land Contamination (km<sup>2</sup>/event)</b>
2	no	no	no	n/a	514,000	\$1,910,000,000	354
3F	no	no	yes	wetwell	183,000	\$274,000,000	8
3NF	no	no	yes	wetwell	397,000	\$1,730,000,000	54
6	yes	no	no	n/a	305,000	\$847,000,000	91
7F	yes	no	yes	wetwell	37,300	\$17,600,000	0.4
7NF	yes	no	yes	wetwell	235,000	\$484,000,000	34
12F	no	no	yes	drywell	232,000	\$391,000,000	28
12NF	no	no	yes	drywell	3,810,000	\$33,300,000,000	9,150
13F	no	yes	yes	drywell	59,990	\$37,700,000	2
13NF	no	yes	yes	drywell	3,860,000	\$33,000,000,000	8,830
14	no	yes	no	n/a	86,100	\$116,000,000	12
15F	no	yes	yes	wetwell	43,300	\$20,200,000	0.3
15NF	no	yes	yes	wetwell	280,000	\$588,000,000	28

Table 8 lists the onsite consequences that were used in the risk evaluation, consistent with the existing regulatory analysis guidance in NUREG/BR-0184.

<b>Table 8. Onsite Consequences</b>		
<b>Release End State</b>	<b>Onsite Worker Dose Risk (person-rem/event)</b>	<b>Onsite Cost (\$/event)</b>
vented—filtered	1,000	\$1,900,000,000
vented—unfiltered	3,300	\$2,390,000,000
LMT, OP, or OP + LMT	14,000	\$3,190,000,000

## 4. RESULTS

Table 9 provides the frequencies and percent contributions for each end state defined in the risk evaluation. The frequencies and contributions are identical for those modifications that have the same vent actuation method (either manual or passive). This is expected since the venting actuation method (and its associated failure probability) is the only characteristic among the group of characteristics that define the hypothetical plant modifications which influences the event tree sequence frequencies. Comparison of the information in this table to the CCFP values presented in Table 2 demonstrates that the installation of an SA venting system helps to lower the CCFP.

<b>Table 9. Breakdown of Containment Failure Modes</b>							
Mod	Vent Filtered	Vent Location	Vent Actuation	End State			
				vent	LMT	OP	LMT + OP
0	n/a	None	n/a	0 0%	0 0%	3E-7 1.5%	2E-5 98.5%
1	No	Wetwell	Manual	9E-6 46.8%	4E-6 19.6%	9E-8 0.4%	7E-6 33.1%
3	No	Drywell	Manual				
5	Yes	Wetwell	Manual				
7	Yes	Drywell	Manual				
2	No	Wetwell	Passive	1E-5 66.9%	6E-6 28.0%	3E-10 0.0%	1E-6 5.1%
4	No	Drywell	Passive				
6	Yes	Wetwell	Passive				
8	Yes	Drywell	Passive				

Table 10 provides the point estimates of the risks for each of the nine hypothetical plant modifications (Mod 0, which is the current situation and Mods1 through 8). In comparison to Mod 0, in the available SAMA analyses, the baseline 50-mile population dose risks range from 3.3 to 144 person-rem/ry, and the offsite cost risks range from \$5,614/ry to \$976,847/ry.

**Table 10. Risk Evaluation Results (Point Estimates)**

Mod	Vent Filtered	Vent Location	Vent Actuation	50-mile Population Dose Risk (person-rem/ry)	50-mile Offsite Cost Risk (\$/ry)	Onsite Worker Dose Risk (person-rem/ry)	Onsite Cost risk (\$/ry)	CCLA (km <sup>2</sup> )
0	n/a	None	n/a	10.2	\$37,884	0.28	\$63,800	350.1
1	No	Wetwell	Manual	7.2	\$24,041	0.14	\$53,166	144.1
2	No	Wetwell	Passive	5.9	\$18,117	0.08	\$48,615	55.9
3	No	Drywell	Manual	54.5	\$452,466	0.14	\$53,166	6,048.4
4	No	Drywell	Passive	73.5	\$630,000	0.08	\$48,615	8,487.8
5	Yes	Wetwell	Manual	4.5	\$13,958	0.11	\$46,653	119.3
6	Yes	Wetwell	Passive	2.0	\$3,717	0.03	\$39,315	20.5
7	Yes	Drywell	Manual	4.9	\$14,540	0.11	\$46,653	123.6
8	Yes	Drywell	Passive	2.6	\$4,642	0.03	\$39,315	27.2

Table 11 provides the risk reductions (relative to Mod 0, the current situation) associated with implementation of the SA venting system plant modifications (Mods 1 through 8). Figures 4 through 8 graphically depict the information contained in Table 11.

**Table 11. Risk Reduction Results (Point Estimates)**

Mod	Vent Filtered	Vent Location	Vent Actuation	Reduction in 50-mile Population Dose Risk ( $\Delta$ person-rem/ry)	Reduction in 50-mile Offsite Cost Risk ( $\Delta$ \$/ry)	Reduction in Onsite Worker Dose Risk ( $\Delta$ person-rem/ry)	Reduction in Onsite Cost risk ( $\Delta$ \$/ry)	Reduction in CCLA ( $\Delta$ km <sup>2</sup> /ry)
1	No	Wetwell	Manual	3.0	\$13,842	0.14	\$10,634	206.0
2	No	Wetwell	Passive	4.3	\$19,767	0.29	\$15,185	294.2
3	No	Drywell	Manual	-44.3	-\$414,582	0.14	\$10,634	-5,698.3
4	No	Drywell	Passive	-63.3	-\$592,117	0.20	\$15,185	-8,137.7
5	Yes	Wetwell	Manual	5.7	\$23,926	0.17	\$17,147	230.8
6	Yes	Wetwell	Passive	8.2	\$34,166	0.25	\$24,485	329.5
7	Yes	Drywell	Manual	5.3	\$23,344	0.17	\$17,147	226.4
8	Yes	Drywell	Passive	7.6	\$33,242	0.25	\$24,485	322.9




Figure 4. Reduction in population dose risk




Figure 5. Reduction in offsite cost risk




Figure 6. Reduction in onsite worker dose risk





Figure 7. Reduction in onsite cost risk



**Figure 8. Reduction in conditional contaminated land area**

In order to gain further insight into the risk reductions afforded by the hypothetical plant modifications, a simple parametric Monte Carlo uncertainty analysis was performed. Each of the parameters used to quantify the sequence frequencies and each of the consequences was assigned a distribution as described in Table 12.

Table 12. Uncertainty Distributions			
Parameter	Mean		Distribution
CDF	2E-5/reactor year		Lognormal; error factor = 10
Fraction of total CDF due to external hazards	0.8		Beta; $\alpha = 0.5$ , $\beta = 0.125$
Breakdown of sequence types for internal hazards	Other (not SBO, bypass or fast)	0.83	Dirichlet $\alpha_1$ (other) = 41 $\alpha_2$ (SBO) = 6 $\alpha_3$ (bypass) = 2.5 $\alpha_4$ (fast) = 0.5
	SBO	0.12	
	Bypass (ISLOCAs)	0.05	
	Fast (MLOCAs, LLOCAs, ATWS)	0.01	
Breakdown of sequence types for external hazards	Other (not bypass)	0.95	Beta; $\alpha$ (bypass) = 0.5, $\beta$ (bypass) = 9.5
	Bypass	0.05	
Probability that SA vent fails to open	Mod 0	1	Held constant
	Mods 1, 3, 5, 7—other or SBO	0.3	Beta; $\alpha = 0.5$ , $\beta = 1.167$
	Mods 1, 3, 5, 7—fast	0.5	Beta; $\alpha = 0.5$ , $\beta = 0.5$
	Mods 2, 4, 6, 8	0.001	Beta; $\alpha = 0.5$ , $\beta = 499.5$
Conditional probability that offsite power is not recovered by the time of lower head failure given not recovered at the time of core damage (internal hazards)	0.38		Beta; $\alpha = 0.5$ , $\beta = 0.816$
Probability that portable pump for core spray or drywell spray fails	0.3		Beta; $\alpha = 0.5$ , $\beta = 1.167$
Consequences	Per Tables X-7 and X-8		Lognormal; error factor = 10  Within a given consequence category, consequences were assumed to be totally dependent.

Results of the parametric uncertainty analysis are shown in Figures 9 through 13. The mean values are very close, although somewhat higher, to the point estimates. In general, the ratio of the 95th percentile to the point estimate varies from about 3.5 to 4.0 depending on the consequence category. The major contributors to uncertainty in the risk reduction results are uncertainty in the core-damage frequency and uncertainty in the sequence consequences.




Figure 9. Uncertainty in the reduction in population dose risk




Figure 10. Uncertainty in the reduction in offsite cost risk






Figure 11. Uncertainty in the reduction in onsite worker dose risk




Figure 12. Uncertainty in the reduction in onsite cost risk




Figure 13. Uncertainty in the reduction in conditional contaminated land area

## 5. CONCLUSIONS

The risk evaluation presented above, which incorporates information and insights from the MELCOR analysis in Enclosure 5a and the MACCS analysis in Enclosure 5b, makes a compelling technical argument for a strategy to mitigate the radiological consequences of severe accidents in BWR Mark I containments that includes a combination of SA venting and core debris cooling, supplemented further by the installation of an external filter. In other words, the risk evaluation provides a technical basis to support Option 3 in the regulatory analysis. The risk evaluation presented here leads to the following specific conclusions on SA venting:

- The installation of an unfiltered wetwell SA venting system would reduce public health risk, offsite economic cost risk, and land contamination risk. In contrast, the installation of an unfiltered drywell SA venting system would increase public health risk, offsite economic cost risk, and land contamination risk.
- The installation of a filtered SA venting system (attached to either the wetwell or the drywell) would reduce public health risk, offsite economic cost risk, and land contamination risk. That is, the incorporation of an external filter into the SA venting systems is preferable.
- By preventing containment overpressurization failure, the successful operation of an SA venting system promotes access to plant areas where portable pumps would be installed to provide core debris cooling.
- The installation of an SA venting system (unfiltered or filtered, attached to the wetwell or the drywell) would reduce onsite worker health risk and onsite cost risk.
- Passive actuation (via a rupture disk) is preferred to manual actuation because it is more reliable and, hence, results in larger risk reductions.
- The uncertainty in the amount of risk reduction achieved by the installation of an SA venting system is mainly due to uncertainty in the CDF and uncertainty in the offsite and onsite consequences resulting from radiological releases.