

Lent, Susan

From: SEITER, JEFFERY ALAN [jseiter@entergy.com]
Sent: Monday, November 19, 2012 3:55 PM
To: Wang, Alan
Cc: Rufus, Ernest
Subject: GGNS ISI Relief Request

Alan,

This is in regards to our phone conversation earlier today. If you recall, the CRD housing has two welds, an upper weld and a lower weld. Per our Programs and Components Engineering, GGNS was able to achieve 100% examination of the CRD Housing upper welds with no indications present. GGNS was able to perform a 50% inspection of four lower weld locations with no indications present. The remaining lower weld locations are inaccessible.

Best Regards;

Jeff