



NUREG-1935

State-of-the-Art Reactor Consequence Analyses (SOARCA) Report

Office of Nuclear Regulatory Research

AVAILABILITY OF REFERENCE MATERIALS IN NRC PUBLICATIONS

NRC Reference Material

As of November 1999, you may electronically access NUREG-series publications and other NRC records at NRC's Public Electronic Reading Room at <http://www.nrc.gov/reading-rm.html>. Publicly released records include, to name a few, NUREG-series publications; *Federal Register* notices; applicant, licensee, and vendor documents and correspondence; NRC correspondence and internal memoranda; bulletins and information notices; inspection and investigative reports; licensee event reports; and Commission papers and their attachments.

NRC publications in the NUREG series, NRC regulations, and Title 10, "Energy," in the *Code of Federal Regulations* may also be purchased from one of these two sources.

1. The Superintendent of Documents
U.S. Government Printing Office
Mail Stop SSOP
Washington, DC 20402-0001
Internet: bookstore.gpo.gov
Telephone: 202-512-1800
Fax: 202-512-2250
2. The National Technical Information Service
Springfield, VA 22161-0002
www.ntis.gov
1-800-553-6847 or, locally, 703-605-6000

A single copy of each NRC draft report for comment is available free, to the extent of supply, upon written request as follows:

Address: U.S. Nuclear Regulatory Commission
Office of Administration
Publications Branch
Washington, DC 20555-0001

E-mail: DISTRIBUTION.RESOURCE@NRC.GOV
Facsimile: 301-415-2289

Some publications in the NUREG series that are posted at NRC's Web site address <http://www.nrc.gov/reading-rm/doc-collections/nuregs> are updated periodically and may differ from the last printed version. Although references to material found on a Web site bear the date the material was accessed, the material available on the date cited may subsequently be removed from the site.

Non-NRC Reference Material

Documents available from public and special technical libraries include all open literature items, such as books, journal articles, transactions, *Federal Register* notices, Federal and State legislation, and congressional reports. Such documents as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings may be purchased from their sponsoring organization.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at—

The NRC Technical Library
Two White Flint North
11545 Rockville Pike
Rockville, MD 20852-2738

These standards are available in the library for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from—

American National Standards Institute
11 West 42nd Street
New York, NY 10036-8002
www.ansi.org
212-642-4900

Legally binding regulatory requirements are stated only in laws; NRC regulations; licenses, including technical specifications; or orders, not in NUREG-series publications. The views expressed in contractor-prepared publications in this series are not necessarily those of the NRC.

The NUREG series comprises (1) technical and administrative reports and books prepared by the staff (NUREG-XXXX) or agency contractors (NUREG/CR-XXXX), (2) proceedings of conferences (NUREG/CP-XXXX), (3) reports resulting from international agreements (NUREG/IA-XXXX), (4) brochures (NUREG/BR-XXXX), and (5) compilations of legal decisions and orders of the Commission and Atomic and Safety Licensing Boards and of Directors' decisions under Section 2.206 of NRC's regulations (NUREG-0750).

DISCLAIMER: This report was prepared as an account of work sponsored by an agency of the U.S. Government. Neither the U.S. Government nor any agency thereof, nor any employee, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product, or process disclosed in this publication, or represents that its use by such third party would not infringe privately owned rights.

State-of-the-Art Reactor Consequence Analyses (SOARCA) Report

Manuscript Completed: June 2012
Date Published: November 2012

Prepared by:
Richard Chang, Jason Schaperow, Tina Ghosh,
Jonathan Barr, Charles Tinkler, Martin Stutzke

ABSTRACT

Accident phenomena and offsite consequences of severe reactor accidents have been the subjects of considerable research over the last several decades by the U.S. Nuclear Regulatory Commission (NRC). As a consequence of this research focus, analyses of severe accidents at nuclear power reactors are more detailed, integrated, and realistic than at any time in the past. A desire to leverage this capability to address conservative aspects of previous reactor accident analyses was a major motivating factor in the genesis of the State-of-the-Art Reactor Consequence Analyses (SOARCA) project. By applying modern analysis tools and techniques, the SOARCA project developed a body of knowledge regarding the realistic outcomes of select severe nuclear reactor accidents. To accomplish this objective, the SOARCA project's integrated modeling of accident progression and offsite consequences used both state-of-the-art computational analysis tools and best modeling practices drawn from the collective wisdom of the severe accident analysis community. This study has focused on providing a realistic evaluation of accident progression, source term, and offsite consequences for select scenarios for the Peach Bottom Atomic Power Station and Surry Power Station. By using the most current emergency preparedness practices and plant capabilities, as well as the best available modeling, these analyses are more realistic than past analyses. These analyses also consider mitigative measures (e.g., emergency operating procedures, severe accident management guidelines, and Title 10 to the *Code of Federal Regulations* (10 CFR) 50.54(hh) measures), contributing to a more realistic evaluation.

Paperwork Reduction Act Statement

The NUREG does not contain information collection requirements and, therefore, is not subject to the requirements of the Paperwork Reduction Act of 1995 (44 USC 3501, et seq.).

Public Protection Notification

The NRC may not conduct or sponsor, and a person is not required to respond to, a request for information or an information collection requirement unless the requesting document displays a current valid OMB control number.

CONTENTS

ABSTRACT	iii
FIGURES	viii
TABLES	ix
EXECUTIVE SUMMARY	xi
ACKNOWLEDGEMENTS	xxi
ACRONYMS and ABBREVIATIONS	xxiii
1.0 INTRODUCTION	1
1.1 Background	1
1.2 Objective	2
1.3 Approach	3
1.4 Historical Perspectives	4
1.4.1 WASH-1400 (NUREG-75/014), “Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants,” 1975	4
1.4.2 NUREG/CR-2239, “Technical Guidance for Siting Criteria Development,” 1982	6
1.4.3 NUREG-1150, “Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants,” 1990.....	6
1.5 Scope	7
1.6 Basis of Accident Selection.....	9
1.7 Mitigated and Unmitigated Cases	10
1.8 Uncertainty Analysis	12
1.9 Structure of NUREG-1935 and Supporting Documents	12
2.0 ACCIDENT SCENARIO SELECTION	15
2.1 Approach	15
2.2 Scenarios Initiated by Internal Events.....	18
2.3 Scenarios Initiated by External Events.....	19
2.4 Accident Scenarios Selected for Surry	20
2.4.1 Surry Internal Event Scenarios	20
2.4.2 Surry External Event Scenarios	22
2.5 Accident Scenarios Selected for Peach Bottom	23
2.5.1 Peach Bottom Internal Event Scenarios.....	23
2.5.2 Peach Bottom External Event Scenarios.....	23

2.6	Generic Factors.....	24
3.0	MITIGATIVE MEASURES ASSESSMENT	27
3.1	Site-Specific Mitigation Strategies.....	27
3.1.1	Scenarios Initiated by External Events	28
3.1.2	Scenarios Initiated by Internal Events	31
3.2	Truncation of Releases	32
4.0	SOURCE TERM ANALYSIS	33
4.1	Source Term Study Background	33
4.2	The MELCOR Code.....	35
4.3	MELCOR Modeling Approach.....	37
4.3.1	Plant Models	38
4.3.2	Best Modeling Practices	45
4.3.3	Radionuclide Modeling.....	46
4.3.4	Radionuclide Inventory.....	47
5.0	OFFSITE CONSEQUENCE ANALYSES.....	51
5.1	Weather Sampling	52
5.2	Weather Data.....	52
5.2.1	Summary of Weather Data.....	53
5.3	Emergency Response Modeling.....	55
5.3.1	Base Case Analyses of Emergency Response	57
5.3.2	Sensitivity Analyses of Emergency Response.....	59
5.4	Source Term Evaluation.....	60
5.5	Site-Specific Parameters.....	61
5.6	Non-Site-Specific Parameters	63
5.7	Estimating Latent Cancer Fatality Health Effects.....	65
5.8	Risk Metrics Reported.....	68
6.0	RESULTS AND CONCLUSIONS	69
6.1	Mitigation	69
6.2	Accident Progression and Radionuclide Release	69
6.3	Offsite Radiological Consequences.....	74
6.4	Comparison to NUREG/CR-2239 (the 1982 Siting Study SST1 case).....	79
6.5	Sensitivity Analyses on the Size of the Evacuation Zone	82
6.6	Conclusions	84

7.0 REFERENCES 87

APPENDIX A: SOARCA AND THE FUKUSHIMA DAIICHI ACCIDENT A-1

**APPENDIX B: SOARCA PEER REVIEW COMMITTEE FINAL LETTERS
AND SOARCA PEER REVIEW COMMENT RESOLUTION
REPORT.....B-1**

APPENDIX C: SOARCA PUBLIC COMMENTS SUMMARY.....C-1

FIGURES

Figure 1	The State-of-the-Art Reactor Consequence Analyses process	3
Figure 2	SOARCA accident scenario selection and analysis process.....	16
Figure 3	Timeline of key nuclear power events and safety studies.....	33
Figure 4	MELCOR integration of separate effects codes	36
Figure 5	The Peach Bottom MELCOR nodalization	41
Figure 6	The Surry MELCOR nodalization.....	44
Figure 7	Schematic of modeling detail for BWR GNF 10×10 assembly.....	49
Figure 8	Peach Bottom—Year 2006—wind-rose and atmospheric stability chart.....	54
Figure 9	Surry—Year 2004—wind-rose and atmospheric stability chart.....	55
Figure 10	10- and 20-mile radial distances around the Peach Bottom site	56
Figure 11	Typical evacuation routing	58
Figure 12	Iodine releases to the environment for SOARCA unmitigated scenarios and the 1982 Siting Study SST1 case	73
Figure 13	Cesium releases to the environment for SOARCA unmitigated scenarios and the 1982 Siting Study SST1 case	73
Figure 14	Comparison of average individual LCF risk results for SOARCA mitigated and unmitigated scenarios to the NRC Safety Goal and to extrapolations of the 1982 Siting Study SST1	81
Figure 15	Mean, individual, LNT, scenario-specific LCF risk for the Peach Bottom unmitigated STSBO scenario without RCIC blackstart for people within a circular area of specified radius from the plant.....	83
Figure 16	Mean, individual, LNT, scenario-specific LCF risk for the Surry unmitigated ISLOCA scenario for people within a circular area of specified radius from the plant.	83

TABLES

Table 1	Summary of Core Damage Frequency from NUREG-1150	7
Table 2	Statistical Summary of Raw Meteorological Data for SOARCA Nuclear Sites.....	54
Table 3	Deposition Velocities Used in the SOARCA Analyses	61
Table 4	Peach Bottom Accident Progression Timing Results.....	71
Table 5	Surry Accident Progression Timing Results	72
Table 6	Peach Bottom Results for Scenarios Assuming LNT Dose-Response Model	76
Table 7	Surry Results for Scenarios Assuming LNT Dose-Response Model.....	77
Table 8	Peach Bottom Results for Scenarios without Successful Mitigation for LNT and Alternative Dose-Response models.....	78
Table 9	Surry Results for Scenarios without Successful Mitigation for LNT and Alternative Dose-Response Models	79
Table 10	Conditional (i.e., assuming accident occurs), Mean, LNT, Scenario-Specific Probabilities of LCF for People within the Specified Radii of the Peach Bottom Site.....	80
Table 11	Conditional, Mean, LNT, Scenario-Specific Probabilities of LCF for People within the Specified Radii of the Surry Site.....	80
Table 12	Effect of Size of Evacuation Zone on Mean, Individual, LNT, Scenario-Specific LCF Risk for People within the Specified Radii of the Plant for the Peach Bottom Unmitigated STSBO without RCIC Blackstart and the Surry Unmitigated ISLOCA.....	82

EXECUTIVE SUMMARY

The U.S. Nuclear Regulatory Commission (NRC), the nuclear power industry, and the international nuclear energy research community have devoted considerable research over the last several decades to examining severe reactor accident phenomena and offsite consequences. Following the terrorist attacks of 2001, an NRC initiative reassessed severe accident progression and offsite consequences in response to security-related events. These updated analyses incorporated the wealth of accumulated research and used more detailed, integrated, and best-estimate modeling than past analyses. An insight gained from these security assessments was that the NRC needed updated analyses of severe reactor accidents to reflect realistic estimates of the more likely outcomes, considering the current state of plant design and operation and the advances in understanding of severe accident behavior.

The NRC initiated the State-of-the-Art Reactor Consequence Analyses (SOARCA) project to develop best estimates of the offsite radiological health consequences for potential severe reactor accidents for two pilot plants: the Peach Bottom Atomic Power Station in Pennsylvania and the Surry Power Station in Virginia. Peach Bottom is generally representative of U.S. operating reactors using the General Electric boiling-water reactor (BWR) design with a Mark I containment. Surry is generally representative of U.S. operating reactors using the Westinghouse pressurized-water reactor (PWR) design with a large, dry (subatmospheric) containment. SOARCA results, while specific to Peach Bottom and Surry, may be generally applicable to plants with similar designs. Additional work would be needed to confirm this, however, since differences exist in plant-specific designs, procedures, and emergency response characteristics.

The SOARCA project evaluates plant improvements and changes not reflected in earlier NRC publications such as NUREG/CR-2239, “Technical Guidance for Siting Criteria Development,” [1] NUREG-1150, “Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants,” [2] and WASH-1400, “Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants,” [3]. SOARCA includes system improvements, improvements in training and emergency procedures, offsite emergency response, and security-related improvements, as well as plant changes such as power uprates and higher core burnup. To provide perspective between SOARCA results and more conservative offsite consequence estimates, SOARCA results are compared to NUREG/CR-2239, “Technical Guidance for Siting Criteria Development,” issued in 1982 and referred to in this report as the Siting Study [1]. Specifically, SOARCA results are compared to the Siting Study siting source term 1 (SST1). SST1 assumes severe core damage, loss of all safety systems, and loss of containment after 1.5 hours. The SOARCA report helps the NRC to communicate its current understanding of severe-accident-related aspects of nuclear safety to stakeholders, including Federal, State, and local authorities, licensees, and the general public.

The SOARCA project sought to focus its resources on the more important severe accident scenarios for Peach Bottom and Surry. The project narrowed its approach by using an accident sequence’s possibility of damaging reactor fuel, or core damage frequency (CDF), as a surrogate

for risk. The SOARCA scenarios were selected from the results of existing probabilistic risk assessments (PRAs). Core damage sequences from previous staff and licensee PRAs were identified and binned into core damage groups. A core damage group consists of core damage sequences that have similar timing for important severe accident phenomena and similar containment or engineered safety feature operability. It is important to note that each core damage sequence that belongs to a given core damage group is initiated by a specific cause (for example, a seismic event, a fire, or a flood), and that the frequency of each core damage group was estimated by aggregating the CDFs of the individual sequences that belong to the group. This approach was taken to help ensure that the contributions from all core damage sequences were accounted for during the sequence selection process. During the consequence analysis, the core damage groups for station blackouts were analyzed as if they were initiated by a seismic event. This approach was taken because seismically induced equipment failures occur immediately following the seismic event, which produces the most severe challenge to the plant. The groups were screened according to their approximate CDFs to identify the most risk significant groups. SOARCA analyzed scenarios with a CDF equal to or greater than 10^{-6} (1 in a million) per reactor-year. SOARCA also sought to analyze scenarios leading to an early failure or bypass of the containment with a CDF equal to or greater than 10^{-7} (1 in 10 million) per reactor-year, since these scenarios have a potential for higher consequences and risk. This approach allowed a more detailed analysis of accident consequences for the more likely, although still remote, accident scenarios.

The staff used updated and benchmarked standardized plant analysis risk (SPAR) models and available plant-specific external events information in the scenario-selection process and identified two major groups of accident scenarios for analysis. The first group common to both Peach Bottom and Surry includes short-term station blackout (STSBO) and long-term station blackout (LTSBO). Both types of SBOs involve a loss of all alternating current (ac) power. The STSBO also involves the loss of turbine-driven systems through loss of direct current (dc) control power or loss of the condensate storage tank and therefore proceeds to core damage more rapidly (hence “short term”). The STSBO has a lower CDF, since it requires a more severe initiating event and more extensive system failures. SBO scenarios can be initiated by external events such as a fire, flood, or earthquake. SOARCA assumes that an SBO is initiated by a seismic event since this is the most extreme case in terms of both the timing and amount of equipment that fails. Notwithstanding the SOARCA scenario screening process, SBO scenarios are commonly identified as important contributors in PRA because of the common cause of failure for both reactor safety systems and containment safety systems.

SOARCA’s second severe accident scenario group, which was identified for Surry only, is the containment bypass scenario. For Surry, two containment bypass scenarios were identified and analyzed. The first bypass scenario is a variant of the STSBO scenario, involving a thermally-induced steam generator tube rupture (TISGTR). The second bypass scenario involves an interfacing systems loss-of-coolant accident (ISLOCA) caused by an unisolated rupture of low-head safety injection piping outside containment. The CDF for the ISLOCA, 3×10^{-8} (3 in 100 million) per reactor-year, falls below the SOARCA screening criterion for bypass events but it is analyzed for completeness because NUREG-1150 identified ISLOCA, in addition to SBO and SGTRs, as principal contributors to mean early and latent cancer fatality risks [2]. This scenario-

selection process captured the more important internally and externally initiated core damage scenarios.

SOARCA's analyses were performed with two computer codes, MELCOR for accident progression and the MELCOR Accident Consequence Code System, Version 2 (MACCS2) for offsite consequences. The NRC staff's preparations for the analyses included extensive cooperation from the licensees of Peach Bottom and Surry to develop high-fidelity plant systems models, define operator actions including the most recently developed mitigation actions, and develop models for simulation of site-specific and scenario-specific emergency planning and response. Moreover, in addition to input for model development, licensees provided information on accident scenarios from their PRAs. Through tabletop exercises of the selected scenarios with senior reactor operators, PRA analysts, and other licensee staff, licensees provided input on the timing and nature of the operator actions to mitigate the selected scenarios. The licensee input for each scenario was used to develop assumed timelines of operator actions and equipment configurations for implementing available mitigation measures which include mitigation measures beyond those routinely credited in current PRA models. A human reliability analysis, commonly included in PRAs to represent the reliability of operator actions, was not performed for SOARCA, but instead tabletop exercises, plant walkdowns, simulator runs and other inputs from licensee staff were employed to ensure that operator actions and their timings were correctly modeled.

SOARCA modeled mitigation measures, including those in emergency operating procedures (EOPs), severe accident management guidelines (SAMGs), and Title 10 to the *Code of Federal Regulations* (10 CFR) 50.54(hh). The 10 CFR 50.54(hh) mitigation measures refer to additional equipment and strategies required by the NRC following the terrorist attacks of September 11, 2001, to further improve each plant's capability to mitigate events involving a loss of large areas of the plant caused by fire and explosions. To assess the benefits of 10 CFR 50.54(hh) mitigation measures and to provide a basis for comparison to the past analyses of unmitigated severe accident scenarios, the SOARCA project also analyzed each scenario without 10 CFR 50.54 (hh) equipment and procedures. The analysis that credits successful implementation of the 10 CFR 50.54 (hh) equipment and procedures in addition to actions directed by the EOPs and SAMGs is referred to as the mitigated case. The analysis without 10 CFR 50.54(hh) equipment and procedures is referred to as the unmitigated case (SAMGs were considered but not implemented in the unmitigated case). The unmitigated case of the Surry ISLOCA is an exception to this general principle because it was necessary to assume that at least one of the EOP actions failed to occur for the scenario to lead to core damage. Chapter 3 of NUREG/CR-7110, Volume 1, "SOARCA Peach Bottom Integrated Analysis" and Volume 2, "SOARCA Surry Integrated Analysis", details the specific equipment and operator actions credited for each scenario.

For the LTSBO scenarios for both Peach Bottom and Surry (the most likely severe accident scenario for each plant considered in SOARCA) analyzed assuming no mitigation, core damage begins in 9 to 16 hours, and reactor vessel failure begins at about 20 hours. Offsite radiological release due to containment failure begins at about 20 hours for Peach Bottom (BWR) and at 45 hours for Surry (PWR). The SOARCA analyses therefore show that time may be available for operators to take corrective action and get additional assistance from plant technical support centers even if initial efforts are assumed unsuccessful. For the most rapid events (i.e., the

unmitigated STSBO in which core damage may begin in 1 to 3 hours), reactor vessel failure begins at roughly 8 hours, possibly allowing time to restore core cooling and prevent vessel failure. In these cases, containment failure and radiological release begins at about 8 hours for Peach Bottom and at 25 hours for Surry. For the unmitigated Surry ISLOCA, the offsite radiological release begins at about 13 hours and in the other bypass event analyzed, the TISGTR, the radiological release begins at about 3.5 hours but is shown by analyses to be substantially smaller than the 1982 Siting Study SST1 release.

In addition to delayed radiological releases relative to the 1982 Siting Study SST1 case, the SOARCA study demonstrates that the amount of radioactive material released is much smaller as shown in Figures 1 (Iodine-131) and 2 (Cesium-137) below. The Surry ISLOCA iodine release is calculated to be 16 percent of the core inventory, but the results are more generally in the range of 0.5 to 2 percent for iodine and cesium for the other scenarios analyzed. By contrast, the 1982 Siting Study SST1 case calculated an iodine release of 45 percent and a cesium release of 67 percent of the core inventory.




Figure ES-1 Iodine release to the environment for SOARCA unmitigated scenarios and the 1982 Siting Study SST1 case




Figure ES-2 Cesium release to the environment for SOARCA unmitigated scenarios and the 1982 Siting Study SST1 case

Past PRAs and consequence studies showed that sequences involving large early releases were important risk contributors. For example, the PWR SBO with a TISGTR was historically believed to result in a large, relatively early release potentially leading to higher offsite consequences. However, MELCOR analysis of Surry performed for SOARCA shows that the release is small, because other reactor coolant system piping inside containment (i.e., hot leg nozzle) fails soon after the tube rupture and thereby retains the fission products within the containment. Additional work would be needed to determine if this result generally applies for all types of PWRs.

While this report does not determine the respective likelihoods of the mitigated and unmitigated cases of each scenario, the SOARCA results demonstrate the potential benefits of employing 10 CFR 50.54(hh) mitigation enhancements for the scenarios analyzed. MELCOR analyses were used both to confirm the time available to implement mitigation measures and to confirm that those measures, once taken, are effective in preventing core damage or significantly reducing radiological releases. When successful mitigation is assumed, the MELCOR results indicate no core damage for all scenarios except the Surry STSBO and its TISGTR variant. The security-related mitigation measures that provide alternative ac power and portable diesel-driven pumps are especially helpful in counteracting SBO scenarios. For the Surry STSBO and its TISGTR variant, the mitigation is sufficient to flood the containment through the containment spray system to cover core debris resulting from vessel failure. For the ISLOCA scenario, installed equipment unrelated to 10 CFR 50.54(hh) is effective in preventing core damage owing to the time available for corrective action.

For scenarios that release radioactive material to the environment, MACCS2 uses site-specific weather data to predict the downwind concentration of material in the plume and the resulting

population exposures and health effects. The analysis of offsite consequences in SOARCA incorporates the improved modeling capability reflected in the MELCOR and MACCS2 codes as well as detailed site-specific public evacuation models. These models were developed for each scenario based on site-specific emergency preparedness programs and State emergency response plans to reflect timing of onsite and offsite protective action decisions and the evacuation time estimates and road networks at Peach Bottom and Surry. Scenarios that are assumed to be initiated by a seismic event consider the earthquake's impact on implementing emergency plans from loss of infrastructure (i.e., long-span bridges, traffic signals, sirens).

The unmitigated versions of the scenarios analyzed in SOARCA have lower risk of early fatalities than calculated in the 1982 Siting Study SST1 case. SOARCA's analyses show essentially zero risk of early fatalities. Early fatality risk was calculated to be $\sim 10^{-14}$ for the unmitigated Surry ISLOCA (for the area within 1 mile of Surry's exclusion area boundary) and zero for all other SOARCA scenarios. In comparison, 92 early fatalities for Peach Bottom and 45 early fatalities for Surry were calculated for the SST1 case in the 1982 Siting Study.

SOARCA results indicate that bypass events (e.g., Surry ISLOCA) do not pose a higher scenario-specific latent cancer fatality risk than non-bypass events (e.g., Surry SBO). While consequences are greater when the bypass scenario happens, this is offset by the scenario being less likely to happen. SOARCA reinforces the importance of external events relative to internal events and the need to continue ongoing work related to external events risk assessment.

Offsite radiological consequences were calculated for each scenario expressed as the average individual likelihood of an early fatality and latent cancer fatality. Tables ES-1 (Peach Bottom) and ES-2 (Surry) show, for both mitigated and unmitigated cases, conditional (on the occurrence of the core damage scenario) scenario-specific probabilities of a latent cancer fatality for an individual located within 10 miles of the plant. Tables ES-1 and ES-2 show the results using the linear no-threshold (LNT) dose-response model, which assumes that the health risk is directly proportional to the exposure and even the smallest radiation exposure carries some risk. The tables also provide the scenario-specific latent cancer fatality risk for an individual located within 10 miles of the plant, taking into account the scenario's core damage frequency.

Table ES-1 Offsite Consequence Results for Peach Bottom Scenarios Assuming Linear No-Threshold (LNT) Dose-Response Model

Scenario	Core damage frequency (CDF) (per reactor-year)*	Mitigated		Unmitigated	
		Conditional scenario-specific probability of latent cancer fatality for an individual located within 10 miles	Scenario-specific risk (CDF x Conditional) of latent cancer fatality for an individual located within 10 miles (per reactor-year)	Conditional scenario-specific probability of latent cancer fatality for an individual located within 10 miles	Scenario-specific risk (CDF x Conditional) of latent cancer fatality for an individual located within 10 miles (per reactor-year)
Long-term SBO	3×10^{-6}	No Core Damage		9×10^{-5}	$\sim 3 \times 10^{-10}$ ****
Short-term SBO with RCIC Blackstart**	3×10^{-7}	No Core Damage ***		7×10^{-5}	$\sim 2 \times 10^{-11}$ ****
Short-term SBO without RCIC Blackstart		Not Applicable ***		2×10^{-4}	$\sim 6 \times 10^{-11}$ ****

* The CDF assumes that 10 CFR 50.54(hh) equipment and procedures were not used.

** Blackstart of the reactor core isolation cooling (RCIC) system refers to starting RCIC without any ac or dc control power. Blackrun of RCIC refers to the long-term operation of RCIC without electricity, once it has been started. This typically involves using a portable generator to supply power to indications such as reactor pressure vessel (RPV) level to allow the operator to manually adjust RCIC flow to prevent RPV overfill and flooding of the RCIC turbine. STSBO RCIC blackstart and limited blackrun is credited as an unmitigated case for SOARCA purposes because the licensee has included its use in procedures. Past NRC severe accident analyses of STSBO scenarios did not credit blackstart of RCIC. A sensitivity calculation without blackstart was therefore performed to provide a basis for comparison to past analyses.

*** A scenario with 10 CFR 50.54(hh) mitigation, but without RCIC blackstart was not analyzed.

**** Estimated risks below 1×10^{-7} per reactor year should be viewed with caution because of the potential impact of events not studied in the analyses and the inherent uncertainty in very small calculated numbers.

Table ES-2 Offsite Consequence Results for Surry Scenarios Assuming LNT Dose-Response Model

Scenario	Core damage frequency [CDF] (per reactor-year)*	Mitigated		Unmitigated	
		Conditional scenario-specific probability of latent cancer fatality for an individual located within 10 miles	Scenario-specific risk [CDF x Conditional] of latent cancer fatality for an individual located within 10 miles (per reactor-year)	Conditional scenario-specific probability of latent cancer fatality for an individual located within 10 miles	Scenario-specific risk [CDF x Conditional] of latent cancer fatality for an individual located within 10 miles (per reactor-year)
Long-term SBO	2×10^{-5}	No Core Damage		5×10^{-5}	$\sim 7 \times 10^{-10}$ ****
Short-term SBO	2×10^{-6}	No Containment Failure **		9×10^{-5}	$\sim 1 \times 10^{-10}$ ****
Short-term SBO with TISGTR	4×10^{-7}	3×10^{-4} ***	$\sim 1 \times 10^{-10}$ ****	3×10^{-4}	$\sim 1 \times 10^{-10}$ ****
Interfacing systems LOCA	3×10^{-8}	No Core Damage		3×10^{-4}	$\sim 9 \times 10^{-12}$ ****

* The CDF assumes that 10 CFR 50.54(hh) equipment and procedures were not used.

** Accident progression calculations showed that source terms in the mitigated case are smaller than in the unmitigated case. Offsite consequence calculations were not run, since the containment fails at about 66 hours. A review of available resources and emergency plans shows that adequate mitigation measures could be brought onsite within 24 hours and connected and functioning within 48 hours. Therefore 66 hours would allow ample time for mitigation through measures transported from offsite.

*** Containment failure is delayed by about 46 hours in the mitigated case relative to the unmitigated case. Rounding to one significant figure shows conditional LCF probabilities of 3×10^{-4} for both mitigated and unmitigated cases, however the original values were 2.8×10^{-4} for the mitigated case and 3.2×10^{-4} for the unmitigated case.

**** Estimated risks below 1×10^{-7} per reactor year should be viewed with caution because of the potential impact of events not studied in the analyses and the inherent uncertainty in very small calculated numbers.

LCF risks using alternate dose-response models, as well as LCF risks for circular areas out to a radius of 50 miles, are also presented. Using a dose-response model that truncates annual doses below normal background levels (including medical exposures) results in a further reduction to the latent cancer fatality risks (by a factor of 100 for smaller releases and a factor of 3 for larger releases). Latent cancer fatality risk calculations are generally dominated by long-term exposure

to small annual doses (~500 mrem per year corresponding to state return criteria) by evacuees returning to their homes after the accident and being exposed to residual radiation over a long period of time. SOARCA’s calculated LCF risk results are smaller than extrapolations of 1982 Siting Study SST1 LCF risk results. However, the difference diminishes when considering larger areas, out to a distance of 50 miles from the plant.

Figure 3 compares SOARCA’s scenario-specific latent cancer fatality risks for an individual within 10 miles of the plant to the NRC Safety Goal [72] and to an extrapolation of the 1982 Siting Study SST1¹ results.




Figure ES-3 Comparison of average individual LCF risk results for SOARCA mitigated and unmitigated scenarios to the NRC Safety Goal and to extrapolations of the 1982 Siting Study SST1 (plotted on logarithmic scale)

The NRC Safety Goal for latent cancer fatality risk from nuclear power plant operation (i.e., 2×10^{-6} or two in one million) is set 1,000 times lower than the sum of cancer fatality risks resulting from all other causes (i.e., 2×10^{-3} or two in one thousand). The calculated cancer fatality risks from the selected, important scenarios analyzed in SOARCA are thousands of times

¹ The Siting Study did not calculate LCF risks. Therefore, to compare the Siting Study SST1 case to LCF results for SOARCA, the SST1 source term was put into the MACCS2 offsite consequence code files for the Peach Bottom and Surry unmitigated STSBO calculations.

lower than the NRC Safety Goal and millions of times lower than the general U.S. cancer fatality risk [73].

Comparisons of SOARCA's calculated LCF risks to the NRC Safety Goal [72] and the average annual US cancer fatality risk from all causes [73] are provided to give context that may help the reader to understand the contribution to cancer risks from these nuclear power plant accident scenarios. However, such comparisons have limitations for which the reader should be aware. Relative to the safety goal comparison, the safety goal is intended to encompass all accident scenarios. SOARCA does not examine all scenarios typically considered in a PRA, even though it includes the important scenarios. SOARCA represents a mix of limited PRA models with a deterministic treatment of various long-term mitigating features. In fact, any analytical technique, including PRAs, will have inherent limitations of scope and method. As a result, comparison of SOARCA's scenario-specific calculated LCF risks to the NRC Safety Goal is necessarily incomplete. However, it is intended to show that adding multiple scenarios' low risk results in the $\sim 10^{-10}$ range to approximate a summary risk from all scenarios, would yield a summary result that is also below the NRC Safety Goal of 2×10^{-6} or two in one million.

Relative to the U.S. average individual risk of a cancer fatality comparison, the sources of an individual's cancer risk include a complex combination of age, genetics, lifestyle choices, and other environmental factors whereas the consequences from a severe accident at a nuclear plant are involuntary and unlikely to be experienced by most individuals.

The SOARCA analyses show that emergency response programs, implemented as planned and practiced, reduce the scenario-specific risk of health consequences among the public during a severe reactor accident. Sensitivity analyses of seismic impacts on site-specific emergency response (e.g., loss of bridges, traffic signals, and delayed notification) at Peach Bottom and Surry do not significantly affect LCF risk.

In summary, the staff believes SOARCA has achieved its objective to develop a body of knowledge regarding detailed, integrated, state-of-the-art modeling of the more important severe accident scenarios for Peach Bottom and Surry. SOARCA analyses indicate that successful implementation of existing mitigation measures can prevent reactor core damage or delay or reduce offsite releases of radioactive material. All SOARCA scenarios, even when unmitigated, progress more slowly and release much less radioactive material than the 1982 Siting Study SST1 case. As a result, the calculated risks of public health consequences from severe accidents modeled in SOARCA are very small.

The SOARCA study was nearing completion when the Fukushima Daiichi accident occurred on March 11, 2011. The Fukushima accident has many similarities and differences with some of the Peach Bottom severe accident scenarios analyzed in SOARCA. While there are significant gaps in information and uncertainties regarding what occurred in the Fukushima reactors, an appendix to this report compares and contrasts the SOARCA study and the Fukushima accident based on currently available information for the following topics: (1) operation of the RCIC system, (2) hydrogen release and combustion, (3) 48-hour truncation of releases in SOARCA, (4) multiunit risk, and (5) spent fuel pool risk.

ACKNOWLEDGEMENTS

The SOARCA project and this document are the result of the efforts of many NRC staff and the staff of its contractors, Sandia National Laboratories, and dycoda, LLC. The project has also benefited greatly from the contributions of senior risk analysts and selected other NRC staff members in specific areas of the project. The SOARCA team also recognizes the support provided by staff of the licensees of the two pilot plants, Peach Bottom and Surry.

The following individuals were members of the SOARCA project team.

Dorothy Andreas (née Collins)	Jocelyn Mitchell
Jonathan Barr	AJ Nosek
Terry Brock	José Pires
Scott Burnell	Robert Prato
Richard Chang	Jason Schaperow
Donald Chung	Martin Stutzke
Donald Dube	Randolph Sullivan
Tina Ghosh	Charles Tinkler
Anthony Huffert	James Vail
Chris Hunter	Thomas Weaver

The following individuals provided management oversight:

Kathy Halvey Gibson	Jennifer Uhle
Patricia Santiago	Jimi Yerokun
Brian W. Sheron	

The following members of the SOARCA Steering Committee provided senior leadership:

Marc Dapas	Brian Holian
William M. Dean	Robert Lewis
Daniel Dorman	James Lyons
Jack Grobe	Cynthia Pederson
Gary Holahan	Jennifer Uhle

The external peer review committee provided invaluable feedback on the project. The members were:

Ken Canavan (Electric Power Research Institute)
Bernard Clément (Institut de Radioprotection et de Sûreté Nucléaire)
Jeff Gabor (ERIN Engineering)
Robert Henry (Fauske and Associates)
Roger Kowieski (Natural and Technological Hazards Management Consulting, Inc.)
David Leaver (WorleyParsons Polestar)
Bruce Mrowca (Information Systems Laboratories)
Kevin O’Kula (Washington Safety Management Solutions)
John Stevenson (JD Stevenson Consulting Engineering Company)
Karen Vierow (Texas A&M University)
Jacquelyn Yanch (Ioneyes, Inc. and Massachusetts Institute of Technology)

ACRONYMS and ABBREVIATIONS

ac	alternating current
AEC	Atomic Energy Commission
ATWS	anticipated transient without scram
BEF	biological effectiveness factor
BEIR	Biological Effectiveness of Ionizing Radiation
BWR	boiling-water reactor
CDF	core damage frequency
CFR	<i>Code of Federal Regulations</i>
CRAC	Calculation of Reactor Accident Consequences
Cs	cesium
CST	condensate storage tank
dc	direct current
DOE	U.S. Department of Energy
ECCS	emergency core cooling system
ECST	emergency condensate storage tank
EOF	emergency operating facility
EOP	emergency operating procedure
EPA	U.S. Environmental Protection Agency
EPR	Evolutionary Power Reactor
EPZ	emergency planning zone
ESBWR	economic simplified boiling-water reactor
ETE	evacuation time estimate
FGR	Federal guidance report
FR	<i>Federal Register</i>
GNF	Global Nuclear Fuel
gpm	gallons per minute
HPCI	high-pressure coolant injection
HPS	Health Physics Society
hr	hour
I	iodine
IAEA	International Atomic Energy Agency
ICRP	International Commission on Radiological Protection
INPO	Institute of Nuclear Power Operations
kg	kilogram
KI	potassium iodide
IPEEE	individual plant examination of external events
ISLOCA	interfacing systems loss-of-coolant accident
LCF	latent cancer fatality
LHSI	low-head safety injection
LNT	linear no-threshold
LOCA	loss-of-coolant accident
LOOP	loss of offsite power
LTSBO	long-term station blackout
LWR	light-water reactor

MACCS2	MELCOR Accident Consequence Code System, Version 2
m/s	meters per second
MOX	mixed oxide
MTU	metric ton of uranium
MW	megawatts
MWd	megawatt days
NCRP	National Council on Radiation Protection and Measurements
NPP	nuclear power plant
NRC	U.S. Nuclear Regulatory Commission
NRF	National Response Framework
ORNL	Oak Ridge National Laboratory
ORO	offsite response organizations
PGA	peak ground acceleration
PRA	probabilistic risk assessment
PWR	pressurized-water reactor
RCIC	reactor core isolation cooling
RCS	reactor coolant system
RG	regulatory guide
RPV	reactor pressure vessel
RWST	refueling water storage tank
SAMG	severe accident management guideline
SBO	station blackout
SGTR	steam generator tube rupture
SGTS	standby gas treatment system
SNL	Sandia National Laboratories
SOARCA	State-of-the-Art Reactor Consequence Analyses
SPAR	standardized plant analysis risk
SSE	safe shutdown earthquake
SST	siting source term
STCP	Source Term Code Package
STSBO	short-term station blackout
Sv	sieverts
TDAFW	turbine-driven auxiliary feedwater
TID	Technical Information Document
TISGTR	thermally induced steam generator tube rupture
TMI	Three Mile Island
TRANS	transients
TSC	technical support center
UFSAR	updated final safety analysis report
UO ₂	uranium dioxide

1.0 INTRODUCTION

This document describes the U.S. Nuclear Regulatory Commission's (NRC's) state-of-the-art, realistic assessment of the accident progression, radiological releases, and offsite consequences for important severe accident sequences.

The overall objective of the State-of-the-Art Reactor Consequence Analyses (SOARCA) project is to develop a body of knowledge on the realistic outcomes of severe reactor accidents. The results from the SOARCA project to date provide an updated reference of the likely outcomes of severe reactor accidents at the Peach Bottom and Surry nuclear power sites, based on the most current emergency preparedness and plant capabilities. The NRC also anticipates that the study will be a resource for future modeling improvements and verification efforts.

1.1 Background

The evaluation of accident phenomena and offsite consequences of severe reactor accidents has been the subject of considerable research. Most recently, with Commission guidance and as part of plant security assessments, updated analyses of severe accident progression and offsite consequences were completed using the wealth of accumulated research. These analyses are more detailed (in terms of the fidelity of the representation and resolution of facilities and emergency response), realistic (in terms of the use of currently accepted phenomenological models and procedures), and integrated (in terms of the intimate coupling between accident progression and offsite consequence models).

The results of those security-related studies confirmed and quantified what was suspected but not well-quantified—namely, that some past studies were conservative to the point that predictions were not useful for characterizing results. The communication of risk attributable to severe reactor accidents should properly consider realistic estimates of the more likely outcomes and should reflect both the many improvements and changes to plants and the advances in understanding of severe accident behavior.

In addition to the improvements in understanding and calculational capabilities that have resulted from these studies, numerous influential changes have occurred in the training of operating personnel and the increased use of plant-specific capabilities. These changes include the following:

- The transition from event-based to symptom-based emergency operating procedures (EOPs) for the boiling-water reactor (BWR) and pressurized-water reactor (PWR) designs.
- The performance and maintenance of plant-specific probabilistic risk assessments (PRAs) that cover the spectrum of accident scenarios.
- The implementation of plant-specific, full-scope control room simulators to train operators.

- An industrywide technical basis, owners-group-specific guidance, and plant-specific implementation of the severe accident management guidelines (SAMGs).
- Additional safety enhancements, described in Title 10, Section 50.54(hh) of the *Code of Federal Regulations* (10 CFR 50.54(hh)). These enhancements are intended to be used to maintain or restore core cooling, containment, and spent fuel pool cooling capabilities under the circumstances associated with loss of large areas of the plant due to explosions or fire, to include strategies in the following areas: (i) fire fighting; (ii) operations to mitigate fuel damage; and (iii) actions to minimize radiological release. For the SOARCA scenarios, successful implementation of this equipment and procedures would prevent core damage or delay or prevent the release.
- Improved phenomenological understanding of influential processes such as the following:
 - in-vessel steam explosions
 - Mark I containment drywell shell attack
 - dominant chemical forms for fission products
 - direct containment heating
 - hot-leg creep rupture
 - reactor pressure vessel (RPV) failure and molten core-concrete interactions

Additional changes in plant operation have occurred over time, including the following:

- power uprates
- higher core burnups

1.2 **Objective**

The overall objective of the SOARCA project is to develop a body of knowledge regarding the realistic outcomes of severe reactor accidents. Corresponding and supporting objectives are as follows:

- Incorporate the significant plant improvements and changes not reflected in earlier assessments, including system improvements, training and emergency procedures, offsite emergency response, and recent security-related enhancements described in 10 CFR 50.54(hh), as well as plant changes in the form of power uprates and higher core burnup.
- Incorporate state-of-the-art integrated modeling of severe accident behavior, which includes the insights of several decades of research into severe accident phenomenology and radiation health effects.
- Evaluate the potential benefits of recent security-related mitigation improvements in preventing core damage and reducing or delaying an offsite release, should one occur.

- Enable the NRC to communicate severe-accident-related aspects of nuclear safety to stakeholders, including Federal, State, and local authorities; licensees; and the general public.
- Update quantification of offsite consequences found in earlier NRC publications, such as NUREG/CR-2239, “Technical Guidance for Siting Criteria Development,” issued December 1982 [1].

1.3 Approach

The approach was to use the detailed, integrated, phenomenological modeling of accident progression (reactor and containment thermal-hydraulic and radionuclide response) that is embodied in the MELCOR code, coupled with modeling of offsite consequences with the MELCOR Accident Consequence Code System, Version 2 (MACCS2) code, to predict the likely outcomes for the more significant, albeit still remote, core melt accidents. The basis for the selection of the events for analysis included insights from past and current PRAs and from research on accident behavior and important failure modes. The selection of events for quantification also properly included probability, to focus on more likely and important contributors.

Figure 1 illustrates the four main elements of SOARCA (i.e., scenario selection, mitigative measures analysis, accident progression and source term, and offsite radiological consequences).




Figure 1 The State-of-the-Art Reactor Consequence Analyses process

SOARCA provides a new and useful tool to, at this juncture, focus on specific important events and quantify the plant and offsite response rigorously and realistically. This approach can

complement and supplement other analytical methods to efficiently and explicitly address the benefits of additional mitigation in further reducing the likelihood of core damage and offsite consequences. The offsite consequence analyses were performed on a site-specific basis (reflecting site-specific population distributions, weather, and emergency preparedness). Selection of events considered individual plant examinations,¹ individual plant examinations of external events (IPEEEs), standardized plant analysis risk (SPAR) models, and NUREG-1150, “Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants,” issued 1990 [2]. The plant modeling included information related to system and procedural plant improvements that were incorporated as part of the industry’s response to the NRC’s security initiatives (e.g., the purchase and development of procedures for diesel-driven pumps in response to 10 CFR 50.54(hh) requirements), as well as necessary plant information.

1.4 Historical Perspectives

The following sections describe some of the important historical studies that preceded the SOARCA project.

1.4.1 WASH-1400 (NUREG-75/014), “Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants,” 1975

In the summer of 1972, the Atomic Energy Commission (AEC) initiated a major probabilistic study, “Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants” [3]. Professor Norman C. Rasmussen of the Massachusetts Institute of Technology served as the study director. Saul Levine of the AEC served as staff director of the AEC employees who performed the study with the aid of many contractors and consultants.

The study team attempted to estimate the potential effects of light-water reactor (LWR) accidents on public health and safety. The report analyzed in detail one BWR, Peach Bottom Unit 2, and one PWR, Surry Unit 1, to estimate the likelihood and consequences of potential accidents. The team chose these plants, because they were the largest plants of each type that were about to start operation.

The study’s purpose was to quantify the risks to the general public from commercial nuclear power plant (NPP) operation and to compare those risks with nonnuclear risks to provide perspective. This required identification, quantification, and phenomenological analysis of a wide range of low-frequency, relatively high-consequence scenarios that had not previously been considered in much detail. The introduction at this point of the concept of “scenario” is significant; as noted above, many design assessments simply look at system reliability (success probability), given a design-basis challenge. The review of nuclear plant license applications did essentially this, culminating in findings that specific complements of safety systems were single-failure proof for selected design-basis events. Going well beyond this, WASH-1400 modeled scenarios leading to large radiological releases from each of the commercial NPPs considered. It considered highly complex scenarios involving the success and failure of many

¹ As requested by the NRC in Generic Letter 88-20, “Individual Plant Examination for Severe Accident Vulnerabilities,” dated November 23, 1988, the utilities conducted risk analyses that considered the unique aspects of a particular NPP, identifying the specific vulnerabilities of the plant to severe accidents.

and diverse systems within a given scenario, as well as operator actions and phenomenological events.

The team adapted methods previously used by the U.S. Department of Defense and the National Aeronautics and Space Administration to predict the effect of failures of small components in large, complex systems. The overall methodology, PRA, is still used today.

The team first identified events that could potentially lead to core damage. It then used event trees to delineate possible sequences of successes or failures of systems provided to prevent core meltdown or the release of radionuclides, or both. Using fault trees, the team estimated the probabilities of system failures from available data on the reliability of system components. With these techniques, thousands of possible core melt accident sequences were assessed for their occurrence probabilities. Computational models developed as part of the overall effort calculated the public health and economic consequences of the identified severe accidents.

The insights gained from WASH-1400 included (1) “the possible consequences of potential reactor accidents are predicted to be no larger, and in many cases much smaller, than those of nonnuclear accidents,” (2) “the likelihood of reactor accidents is much smaller than that of many non-nuclear accidents having similar consequences. All non-nuclear accidents examined in this study, including fires, explosions, toxic chemical releases, dam failures, airplane crashes, earthquakes, hurricanes and tornadoes, are much more likely to occur and can have consequences comparable to, or larger than, those of nuclear accidents,” and (3) “non-nuclear events are about 10,000 times more likely to produce large numbers of fatalities than nuclear plants.”

While the risks from nuclear power appear to be very low, the Reactor Safety Study (WASH-1400) did indicate that core melt accidents were more likely than previously thought (approximately 5×10^{-5} per reactor-year for Surry and Peach Bottom²), and that LWR risks are mainly attributable to core melt accidents. The Reactor Safety Study also demonstrated the wide variety of accident sequences (initiators and ensuing equipment failures or operator errors or both) that can cause core melt. In particular, the report indicated that, for the plants analyzed, accidents initiated by transients or small loss-of-coolant accidents (LOCAs) were more likely to cause core melt than the traditional large design-basis LOCAs.

In addition to providing some quantitative perspective on severe accident risks, other significant WASH-1400 results helped increase the application of PRAs in the commercial nuclear power arena. They showed, for example, that some of the more frequent, less severe initiating events (e.g., “transients”) lead to severe accidents at higher expected frequencies than do some of the less frequent, more severe initiating events (e.g., very large pipe breaks). This led to the beginning of the understanding of the level of design detail that a PRA must include, if the scenario set is to support useful findings (e.g., consideration of support systems and environmental conditions). Following the severe core damage event at Three Mile Island in 1979, application of these insights gained momentum within the nuclear safety community,

² This value is derived from the following statement in the WASH-1400 Executive Summary: “The [probability of melting the core] value obtained was about one 1 in 20,000 per reactor per year.”

leading eventually to a PRA-informed reexamination of the allocation of licensee and regulatory safety resources. In the 1980s, this process led to some significant adjustments to safety priorities at NPPs; since the 1990s, the NRC has refocused its regulations on areas of plant safety where that attention is more risk important.

1.4.2 NUREG/CR-2239, “Technical Guidance for Siting Criteria Development,” 1982

The NRC contracted with Sandia National Laboratories (SNL) to develop a technical guidance report for siting future reactors [1]. The agency requested guidance on (1) criteria for population density and distribution surrounding future sites and (2) standoff distances of plants from offsite hazards.

Because the work was primarily focused toward the development of generic siting criteria, uncoupled from specific plant design, five types of accidents, with assumed representative radiological source terms, were imposed on each plant in the 91-site study. The accidents or “siting source term events” (SST events) were to be derived from the previous Reactor Safety Study (WASH-1400) [3], and each SST event would be assumed identical regardless of plant design.

- (1) SST1—Severe core damage. All safety systems and containment are lost after 1.5 hours.
- (2) SST2—Severe core damage. Containment systems (e.g., sprays, suppression pools) function to reduce radioactive release, but containment leakage is large after 3 hours.
- (3) SST3—Severe core damage. Containment systems function, but there is small containment leakage (1 percent per day) after 1 hour.
- (4) SST4—Modest core damage. Containment systems function but there is small containment leakage after ½ hour.
- (5) SST5—Limited core damage. Containment functions as designed with minimal leakage.

The early fatality results for most of the 91 sites were similar because of the low population density close to the sites. Using the extremely large and rapid SST1 radiological source term with a population density of 50 persons per square mile resulted in 47 to 140 early fatalities and 730 to 860 latent cancer fatalities (LCFs). For the release represented by SST2 events, the mean values from typical plants were zero early fatalities and 95 to 140 LCFs.

1.4.3 NUREG-1150, “Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants,” 1990

NUREG-1150 [2] documents the results of an extensive NRC-sponsored PRA. The study examined five plants representative of classes of reactor and containment designs to give an understanding of risks for these particular plants. Selected insights regarding the classes of plants were also obtained in the study. The improved PRA methodology used in the NUREG-1150 study greatly enhanced the understanding of risk at NPPs and is considered a significantly updated and improved revision to the Reactor Safety Study [3]. One improvement

was the specific inclusion of an uncertainty estimate for the core damage frequency (CDF) and source term portions of the study. This uncertainty estimate was based on extensive use of expert elicitation. For the offsite consequence portion of the study, random weather sampling addressed the uncertainty in health effects caused by weather variability.

The following five NPPs were analyzed in NUREG-1150:

- (1) Unit 1 of the Surry Power Station, a Westinghouse-designed, three-loop PWR reactor in a large, dry, subatmospheric containment building located near Williamsburg, VA
- (2) Unit 1 of the Zion Nuclear Power Plant, a Westinghouse-designed, four-loop PWR reactor in a large, dry containment building located near Chicago, IL
- (3) Unit 1 of the Sequoyah Nuclear Power Plant, a Westinghouse-designed, four-loop PWR reactor in an ice condenser containment building located near Chattanooga, TN
- (4) Unit 2 of the Peach Bottom Atomic Power Station, a General Electric-designed, BWR-4 reactor in a Mark I containment building located near Lancaster, PA
- (5) Unit 1 of the Grand Gulf Nuclear Station, a General Electric-designed, BWR-6 reactor in a Mark III containment building located near Vicksburg, MS

The various accident sequences that contribute to the CDF from internal initiators can be grouped by common factors into categories. NUREG-1150 uses the accident categories depicted in Table 1 below: station blackout (SBO), anticipated transients without scram (ATWS), other transients (TRANS), interfacing system LOCAs (SG/IF Sys), and other LOCAs. The selection of such categories is not unique but merely a convenient way to group the results.

Table 1 Summary of Core Damage Frequency from NUREG-1150

Plant Name	Internal Initiators					Core Damage Total/yr	External Initiators
	SBO	ATWS	TRANS	SG/IF Sys	LOCA [†]		Fire & Seismic
Surry	2.7×10^{-5}	1.6×10^{-6}	2.0×10^{-6}	3.4×10^{-6}	6.0×10^{-6}	4.0×10^{-5}	2.6×10^{-5}
Peach Bottom	2.2×10^{-6}	1.9×10^{-6}	1.4×10^{-7}	-	2.6×10^{-7}	4.5×10^{-6}	2.3×10^{-5}

[†]The LOCA category shown here includes LOCAs that are initiated by pipe break events. Transient-induced LOCAs are included under the other categories.

1.5 Scope

The central focus of the SOARCA project was to introduce the use of a detailed, best estimate, self-consistent quantification of scenarios based on current scientific knowledge and plant capabilities. The essence of the analysis methodology is the application of the integrated severe accident progression modeling tool, the MELCOR code. The analysis used an improved offsite consequence (MACCS2) code, including both improved code input and updated

scenario-specific emergency response. Because the priority of this work was to bring more detailed, best estimate, and consistent analytical modeling to bear in determining realistic outcomes of severe accident scenarios, the benefits of this state-of-the-art modeling could most efficiently be demonstrated by applying these methods to a set of the more important severe accident scenarios. Thus, the project elected to limit its analysis to a set of important accident scenarios considering both likelihood and potential consequences. The scenarios that were eventually selected (e.g., SBO, interfacing systems loss-of-coolant accident (ISLOCA), thermally induced steam generator tube rupture (TISGTR)) are, in fact, scenarios that were also considered to be important in recent and past probabilistic assessments.

The following several classes of accident events were not considered as part of the SOARCA project:

- multiunit accidents
- low-power and shutdown accidents
- extreme seismic events that lead directly to gross containment failure with simultaneous reactor core damage
- spent fuel pool accidents
- security events

Multiunit accidents (events leading to reactor core damage at multiple units on the same site) could be caused by certain initiators such as an earthquake. Most PRAs developed to date do not explicitly consider multiunit accidents, because the NRC policy is to apply the Commission's "Safety Goals for the Operation of Nuclear Power Plants" (51 *Federal Register* (FR) 28044) [4] and subsidiary risk acceptance guidelines (see Regulatory Guide (RG) 1.174, "An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis" [5]) on a "per reactor" basis. Therefore, multiunit accidents were not evaluated in the SOARCA project. The results of the unmitigated scenario analyses in SOARCA suggest that consideration of multiunit events would not substantially alter the study findings regarding low individual risk, but explicit analysis would be required to confirm the conclusion.

Low-power and shutdown accidents are potentially significant, because the plant configuration is altered—the containment may be open and the reactor safety systems may be realigned. However, offsetting mitigating attributes include a potentially much smaller decay heat level and low pressure that allows for easier cooling of the reactor fuel. In this area, SOARCA has focused on the accidents that historically have received the most attention—the accidents initiated at full power. Also, one of the objectives was to provide an updated quantification of risk from past studies such as the Siting Study [1], and that study similarly was confined to full-power reactor events.

The SOARCA study excluded extreme seismic events that involve failure of the containment and lead to core damage. Seismic fragility quantification for these extreme and rare seismic events,

in particular quantification of the size of a hole or amount of leakage, is currently subject to considerable uncertainty. More research is needed before undertaking a realistic, best estimate analysis of such rare events.

Spent fuel pool accidents can contribute to overall risk associated with nuclear reactors, because significant quantities of spent fuel are stored onsite in such pools. Past NRC studies, including NUREG-1738, “Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants,” issued February 2001 [62], would suggest that risk from the most severe spent fuel pool accidents is low, yet the consequences of the release of a large inventory of cesium (Cs) and other radioisotopes could be serious. Since that time, the NRC has undertaken substantial analytical and experimental research to improve the modeling of spent fuel pool accidents, as well as research to identify significant improvements to spent fuel pool safety, as part of the NRC’s security-related research following the terrorist attacks of September 11, 2001. Based on the results of this research, the NRC concludes that spent fuel pool risk, which was assessed very conservatively in past studies such as NUREG-1738, is now much lower, based on both the new physical safety improvements required by the NRC and the improved modeling capability. Therefore, when developing the SOARCA project, the NRC elected to exclude spent fuel pool accidents from its scope.

The NRC did not include security events as part of SOARCA to avoid providing any specific information that may materially assist in planning or carrying out a terrorist attack on an NPP. However, the NRC has stated that the security-related studies conducted after September 11, 2001, led it to conclude that previous risk studies used conservative radionuclide source terms and that plant improvements plus improved modeling would confirm that radionuclide releases and early fatalities were substantially smaller than suggested by earlier studies.

Offsite consequences of severe nuclear reactor accidents could include economic and environmental damage in addition to harmful effects on human health. SOARCA calculates offsite consequences in terms of the risks of human fatalities for the specific scenarios. These risks are quantified as the individual risk of an early fatality and the individual risk of a latent cancer fatality. This enables comparison of SOARCA’s results to the NRC Safety Goal [72] and to the 1982 Siting Study’s results [1].

1.6 Basis of Accident Selection

In the selection of important sequences, the SOARCA project ideally would have included those sequences found to be important to risk as demonstrated by a full-scope Level 3 PRA, which is an assessment of risk of offsite consequences in the event of a severe accident causing release of radioactive material to the environment. In practice, that was not feasible, because no current full-scope Level 3 PRAs (considering both internal and external events) were generally available to draw upon. However, the preponderance of Level 1 PRA information, combined with insights on severe accident behavior, is available on dominant core damage sequences, especially internal event sequences. This information, combined with the NRC’s understanding of containment loadings and failure mechanisms, and together with radionuclide release, transport, and deposition, allows the use of CDF as a surrogate criterion for risk. Thus, for SOARCA, the project team elected to analyze sequences with a CDF greater than 10^{-6} per reactor-year. In addition, the SOARCA team included sequences that have an inherent potential for higher

consequences (and risk) with a lower CDF (i.e., those with a frequency greater than 10^{-7} per reactor-year). Such sequences would be associated with events involving containment bypass or leading to an early failure of the containment. By adopting these criteria, the SOARCA team is reasonably assured that the more probable and important core melt sequences will be captured. Further, SOARCA includes certain scenarios that had CDFs lower than the screening criteria, because of their historical significance. Thus, the selection of scenarios has a more generic application to plants with designs similar to Peach Bottom and Surry.

1.7 Mitigated and Unmitigated Cases

An important objective of the SOARCA project was to assess the impact of severe accident mitigative features and reactor operator actions in mitigating an accident. This was done by evaluating in detail the operator actions and equipment that may be available (including 10 CFR 50.54(hh) equipment).

Early in the project (2007), SOARCA staff visited the Peach Bottom Atomic Power Station and the Surry Power Station. During the visits, tabletop exercises were conducted for each scenario. Participants included plant senior reactor operators and PRA analysts. SOARCA staff provided initial and boundary conditions, elicited how plant staff would respond, and, through the tabletop exercises, developed a timeline of operator actions for each scenario. These assessments of mitigative measures were qualitative but, nonetheless, consisted of detailed scenario-specific consideration of systems and operations, based on licensee-identified mitigative measures from EOPs, SAMGs, 10 CFR 50.54(hh) measures, assistance from the technical support center (TSC), and other severe accident guidelines that are applicable to and determined to be available during a specific scenario. The assessment of mitigation systems provided the basis for the assumptions on availability, capability, and timing used as input into the MELCOR analyses. For scenarios involving a seismic initiator, operator response times were lengthened to reflect the severity of the seismic event.

A traditional human reliability assessment has not been performed to quantify the probabilities of plant personnel succeeding in implementing these measures. Therefore, each scenario was analyzed twice: a “mitigated” case assuming mitigative equipment was available and operable and operators were completely successful in implementing mitigative actions; and an “unmitigated” case assuming mitigation was not available, was not implemented, or was not effective. This report does not determine the respective likelihoods of the mitigated and unmitigated cases for each scenario.

The NRC issued 10 CFR 50.54(hh) requiring plant licensees to possess the equipment, develop the strategies, and train plant personnel to implement these mitigative measures. The 10 CFR 50.54(hh) measures are the result of a major effort by industry and the NRC in the 2004–2008 timeframe to develop means to mitigate events involving a loss of large areas of the plant caused by fire and explosions. These mitigation measures were implemented by each plant on a per site basis rather than a per reactor basis, however some licensees have indicated plans to purchase additional equipment for the other unit. These measures are new and diverse and include the following major elements:

- procedures for manually operating turbine-driven injection (reactor core isolation cooling (RCIC) and turbine-driven auxiliary feedwater (TDAFW)) systems

- portable diesel-driven pumps for injecting into the reactor coolant system (RCS) (BWR) and steam generators (PWR)
- alternative means to depressurize
- portable power supplies for critical instrumentation such as reactor vessel water level

The assessment of mitigation measures has continued to receive attention since the initial assessment conducted with plant staff. The SOARCA team conducted additional site visits and system walkdowns in 2007, 2010, and 2011, with licensee personnel specifically reviewing the mitigation steps. The team used the results of accident progression calculations to characterize anticipated changes in plant conditions and describe the signatures of measurable parameters. It then estimated the time needed to assemble necessary personnel, tools, and equipment; align and start components; and establish a desired operating condition. SOARCA staff conducted followup site visits in June and August 2010 to explicitly address RCIC blackstart and blackrun for short-term station blackout (STSBO) and manual operation of TDAFW. The site visits included a review of RCIC blackstart and blackrun procedures, additional tabletop exercises to refine the PWR STSBO timeline, plant walkdowns of equipment areas, and detailed reviews of procedures. For the ISLOCA scenario, the licensee also had reactor operators use EOPs in a plant simulator to ensure timing for operator actions to be used in the SOARCA MELCOR calculations was accurate and reasonable.

For each scenario and the mitigation measures identified, the team conducted detailed accident progression analyses to assess the efficacy of those measures. For each scenario, it also performed accident progression and offsite consequence analyses, assuming key mitigative measures were not taken, to demonstrate the relative importance and significance of those measures and to allow comparison of offsite consequence predictions with earlier studies.

For each scenario, the project identified applicable mitigative measures that are potentially available (not eliminated by initial conditions). The systems and operations analyses were based on the initial conditions and anticipated subsequent failures to do the following:

- verify the availability of the primary system
- determine the availability of support systems and equipment
- determine time estimates for implementation

Based on these scenario specifications, the team used MELCOR to determine the effectiveness of those mitigative measures that are expected to be available at a given time.

1.8 Uncertainty Analysis

The SOARCA project included a number of sensitivity studies to examine issues associated with accident progression, mitigation, and offsite consequences for the accident scenarios of interest. The objective of these sensitivity studies was to examine specific issues and ensure the robustness of the conclusions documented in this report. Single sensitivity studies, however, do not form a complete picture of the uncertainty associated with accident progression and offsite consequence modeling. Such a picture requires a more comprehensive and integrated evaluation of modeling uncertainties.

A follow-on uncertainty study will evaluate the impact of uncertainty by randomly sampling distributions for key model parameters that were considered to have a potential impact on the offsite consequences. The intended purpose of this uncertainty study is to develop insight into the overall uncertainty of the SOARCA results on scenario-specific risk to the combined and integrated uncertainty in accident progression (MELCOR) and offsite health effects (MACCS2) modeling. By addressing key MELCOR and MACCS2 modeling uncertainties in an integrated fashion, the SOARCA team believes it will further its understanding of the importance of this modeling on risk and thereby reveal where improvements in understanding are likely to be of benefit. (It will not address uncertainty in the scenario frequency.) Of principal interest is a comparison of the mean value, as determined by the uncertainty analysis, with the best estimate value of scenario-specific risk contained in this report.

1.9 Structure of NUREG-1935 and Supporting Documents

The SOARCA project is documented in multiple reports. This volume, NUREG-1935, describes the approach and procedures used in the study and summarizes the project results and conclusions. NUREG/CR-7110, Volumes 1 and 2, contain detailed descriptions of the plant-specific SOARCA analyses and results for the Peach Bottom and Surry plants, respectively. Because this volume and the NUREG/CR reports rely on highly technical explanations, an information brochure (NUREG/BR-0359, "Modeling Potential Reactor Accident Consequences") was developed as a plain-language summary of SOARCA's methods, results, and conclusions.

The SOARCA team assembled a panel of independent, external technical experts from industry, consulting, academia, and research laboratories to review the SOARCA analyses and assure their technical accuracy. The 11 members of the committee possess technical expertise in the fields of severe accident phenomenology and modeling; plant design, operation, and maintenance; mitigation measures; offsite emergency planning, preparedness, and response; radiological health consequences; seismic and structural analysis; and probabilistic risk assessment applications. In addition to assuring technical accuracy, the committee also assessed whether the project's conclusions were supported by the underlying technical work. The SOARCA team provided draft reports of NUREG-1935 and NUREG/CR-7110 Volumes 1 and 2 to the peer review committee at various points and held meetings with the members of the committee in July 2009, September 2009, March 2010, October 2010, and December 2011. During some of these meetings, NRC staff explained how peer reviewer comments were considered and addressed. The final letters from the individual members of the peer review committee are provided in

Appendix B to this document. Individual letters rather than a consensus report were provided so that each member's points of view could be fully expressed. In addition, Appendix B includes the NRC letter which provided resolutions of open peer review comments from the March 2010 and October 2010 meetings.

The SOARCA project was nearly at the end of its peer review when the Fukushima Daiichi accident occurred in Japan on March 11, 2011. This accident presented real information regarding the progression of severe accidents and many insights with potential parallels to SOARCA's analysis of SBO scenarios at Peach Bottom, a similarly designed plant. The SOARCA team developed Appendix A to this volume which qualitatively compares and contrasts specific accident phenomena based on information available to date. As additional information becomes available, the NRC will continue to review it for lessons learned and insights potentially applicable to nuclear plants in the United States.

NUREG-1935 was released as a draft for public comments from January 31, 2012 through February 29, 2012. Comments related to the SOARCA project covered a wide range of topics. Appendix C to this document provides a summary of the different questions and comments received related to SOARCA along with NRC responses. The comments are related to the following general areas of the SOARCA project: project scope, scenario selection, MELCOR and accident progression analysis, emergency response analysis, and MACCS2 and offsite consequence analysis.

2.0 ACCIDENT SCENARIO SELECTION

An accident sequence begins with the occurrence of an initiating event (e.g., a loss of offsite power, a LOCA, or an earthquake) that perturbs the steady-state operation of the NPP. The initiating event challenges the plant's control and safety systems, the failure of which could cause damage to the reactor fuel and result in the release of radioactive fission products. Because an NPP has numerous diverse and redundant safety systems, many different accident sequences are possible, depending on the type of initiating event that occurs, the amount of equipment that fails, and the nature of the operator actions involved.

One way to systematically identify possible accident sequences is to develop accident sequence logic models using event tree analysis, as is done in PRAs. Pathways through an event tree represent accident sequences. Typically, the analysis is divided into two parts: (1) a Level 1 PRA that represents the plant's behavior from the occurrence of an initiating event until core damage occurs and (2) a Level 2 PRA that represents the plant's behavior from the onset of core damage until radiological release occurs. The development of accident sequence logic models requires detailed information about the plant and the expertise of engineers and scientists from a wide variety of technical disciplines. As a result, the construction of accident sequence logic models is a complex and time-consuming activity.

The NRC and NPP licensees have already completed many PRAs. However, because of the improvements in PRA technology and plant capabilities and performance, this study gave more importance to the most current PRA information.

2.1 Approach

Figure 1 illustrates the overall process used to identify and characterize accident scenarios for the SOARCA project. The SOARCA team selected scenarios from the results of existing PRAs. Some of these existing PRAs model accident sequences to the point of radiological release (i.e., they are Level 2 PRAs); however, the majority of existing PRAs are limited to the onset of core damage (i.e., Level 1 PRAs). The team identified core damage sequences from previous staff and licensee PRAs and separated them into core damage groups. A core damage group consists of core damage sequences that have similar timing for important severe accident phenomena and similar containment or engineered safety feature operability. The groups were screened according to their approximate CDFs to identify those that were the most significant. Finally, the accident scenario descriptions were augmented by assessing the status of containment systems (which are not typically modeled in Level 1 PRAs).




Figure 2 SOARCA accident scenario selection and analysis process

The scope of analyses using MELCOR and MACCS2 was generally confined to scenarios based on the following CDF screening guidelines:

- 10^{-6} per reactor-year for most scenarios
- 10^{-7} per reactor-year for scenarios that are known to have the potential for higher consequences (e.g., containment bypass scenarios such as steam generator tube rupture (SGTR) and ISLOCA initiators)

To accomplish this, the project grouped the release characteristics so that they are representative of scenarios binned into those groups. In addition, the groups are sufficiently broad to include the potentially risk significant but lower frequency scenarios. As a result of limitations in available Level 2 analyses and models, the team selected and screened the scenarios using CDF per reactor-year as the criterion, rather than radionuclide release frequency.

The application of the screening criteria to the available Level 1 PRA information for the pilot plants resulted in the identification of two basic types of scenarios: SBOs and bypass scenarios. This result presents certain advantages with respect to the inherent adequacy of the criteria and of the scope of scenarios. First, SBO scenarios are representative of a broad class of events in PRA—loss of heat removal events. Selection of SBO events in SOARCA ensures that the project covers that broader class of transients involving a loss of heat removal, and further, including an STSBO reasonably bounds the radionuclide release time and consequences of that class of accidents (which could include other events, such as loss of service water or loss of component cooling water but which develop more slowly). Also, for the PWR, the SBO includes, in part, the effect of a small LOCA by considering reactor coolant pump seal leakage. Additionally, selecting SBO sequences for analysis meant including the effects of loss of containment heat removal (fan coolers) and loss of containment spray systems (which are all electrically powered) to remove airborne radionuclides. Thus, the nonbypass sequences also

result in containment failure, which would not be the case for all other transients involving such loss of heat removal in a typical PRA. Therefore, while SOARCA used CDF for screening, in effect, the CDF in these cases also represents the radionuclide release frequency.

While the study did not include medium or large loss-of-inventory accidents—because of their very low frequency—it should be noted that such internal events are well below the screening criteria for the BWR and comfortably below the screening criterion for the PWR. For Peach Bottom, the medium and large LOCAs had CDFs of 2×10^{-9} and 1×10^{-9} per reactor-year. For Surry, the medium and large LOCAs had frequencies of 6×10^{-8} and 7×10^{-10} per reactor-year. Only a fraction of these sequences would have resulted in containment failure, because there may not have been a loss of containment heat removal. Since the Surry analyses included an ISLOCA sequence, it can also be argued that they reasonably bounded the radionuclide release time and consequences of events involving a LOCA inside containment for that plant.

The timing of a severe accident's offsite release has a major impact on both early and LCF risks. In this respect, the team examined candidate SOARCA sequences with the timing of both core damage and containment failure in mind. As part of this consideration, it addressed, for the Peach Bottom plant, an additional sequence, the STSBO, even though it fell below the screening criterion. The STSBO frequency is roughly an order of magnitude lower than the LTSBO (3×10^{-7} per reactor-year versus 3×10^{-6} per reactor-year); however, the STSBO has a more prompt radiological release and a slightly larger release over the same interval of time. The initial qualitative assessment of the STSBO concluded that it would not have greater risk significance than the LTSBO, because, while it has a more prompt release (8 hours versus 20 hours), the release is delayed beyond the time needed for successful evacuation. To demonstrate the points regarding risk versus frequency for lower frequency events, the study nonetheless included a detailed analysis of the STSBO. In a related fashion, the study included an ISLOCA sequence for Surry, even though it fell below the screening criterion of 1×10^{-7} per reactor-year for bypass scenarios. Past studies (e.g., NUREG-1150) cited this scenario as important, and it has the potential for larger releases because of its direct release outside the containment.

Finally, the team routinely considered core damage initiators and phenomenological containment failure modes in SOARCA that were considered in the past, except for those that were excluded by extensive research (alpha mode failure, direct containment heating, and gross failure without prior leakage). The detailed analysis includes modeling behavior (including radionuclide transport and release) associated with long-term containment pressurization, Mark I liner failure, induced SGTR, hydrogen combustion, and core concrete interactions.

SOARCA does not include analysis of an extreme earthquake that directly results in a large breach of the RCS (large LOCA), a large breach of the containment, and an immediate loss of safety systems. Given the considerable uncertainties in the quantification of seismic loads and seismic fragilities, in particular the quantification of the size of a hole or the amount of leakage, more research is needed to perform a best estimate analysis. In addition, it would not be sufficient to perform a nuclear plant risk evaluation of this event without also assessing the concomitant nonnuclear risk associated with such a large earthquake. This assessment would have to include an analysis of the impact on public health of an extremely large earthquake—

larger than that generally considered in residential or commercial construction codes—to provide the perspective on the relative risk posed by operation of the plant.

Additionally, SOARCA considered whether the seismic events evaluated for Surry could cause liquefaction-induced settlements large enough to result in containment failure at containment penetrations. A review of previous work related to liquefaction at the Surry site and preliminary analyses assessed the potential for liquefaction-induced soil deformations. According to NUREG/CR-4550 [68], liquefaction is expected to occur for a seismic event greater than the safe-shutdown earthquake (SSE) at Surry. Estimated liquefaction-induced settlements provided in NUREG/CR-4550 range between 2 and 4 inches for a peak ground acceleration of 0.3 to 0.4 g. Using geotechnical data provided in the Surry updated final safety analysis report [69] and the original geotechnical investigation report by Dames and Moore [70], analyses for the SOARCA study resulted in similar settlement estimates in the vicinity of the containment structure, auxiliary building, and turbine building for a peak ground acceleration of 0.4 g. These estimated settlements are considered to be a mean estimate. A site examination performed by engineers for the NUREG/CR-4550 study of the piping systems and cable penetrations going from the auxiliary, safety area, service, and turbine buildings into the containment indicated that such displacements were not likely to cause failure. NUREG/CR-4550 did not provide the basis for this assessment, and this study did not include additional analyses on piping systems to confirm this assessment. Additional settlement analyses were performed for a peak ground acceleration of 0.75 g, which is associated with an event having an annual frequency of occurrence on the order of 1×10^{-6} to 1×10^{-7} . At this ground motion level, mean settlement estimates increase to between 4 and 8 inches [71]. The effects of this magnitude of settlement on piping systems have not been assessed in SOARCA. Because of the considerable uncertainties in the quantification of these effects for this magnitude of settlement estimates, more research is needed to perform a best-estimate analysis.

In summary, SOARCA addresses the more likely (though still remote) and important sequences that are understood to compose much of the severe accident reactor risk from nuclear plants. NRC staff conclude that the general methods of SOARCA (i.e., detailed, consistent, phenomenologically based, sequence-specific, accident progression analyses) are applicable to PRA methodology and should be the focus of improvements in that regard.

2.2 Scenarios Initiated by Internal Events

The study identified scenarios initiated by internal events and the availability of containment systems for these scenarios using the NRC's plant-specific SPAR models, licensee PRAs, and NUREG-1150 [2]. The SPAR models support the NRC's oversight of licensed commercial NPPs and have been developed and maintained under a formal quality assurance program. The Peach Bottom SPAR model has been peer reviewed against staff-endorsed industry consensus PRA standards. Both the Surry and Peach Bottom licensee PRAs have been peer reviewed against the same standards. In addition, the SPAR model accident sequence results (including the sequence minimal cut sets) are periodically compared to the results from licensee PRAs under the Mitigating System Performance Index Program, which is part of the NRC's Reactor Oversight Process. As a result, both the qualitative and quantitative results from the Surry and

Peach Bottom SPAR models are in reasonable agreement with the corresponding licensee PRAs. Specific comparisons are discussed below.

The following process determined the scenarios for further SOARCA analyses:

- Candidate accident scenarios were identified in analyses using plant-specific SPAR models (Version 3.31).
 - Initial Screening. Screened-out sequences with a CDF less than 10^{-8} , eliminating 4 percent of the overall CDF for Peach Bottom and 7 percent of the overall CDF for Surry.
 - Sequence Evaluation. Identified and evaluated the dominant cutsets for the remaining sequences. Determined system and equipment availabilities and accident sequence timing.
 - Scenario Grouping. Grouped sequences with similar times to core damage and equipment availabilities into scenarios.
- Containment systems availabilities for each scenario were assessed using system dependency tables that delineate the support systems required for performance of the target front-line systems and from a review of existing SPAR model system fault trees.
- Core damage sequences from the licensee PRA model were reviewed and compared with the scenarios determined by using the SPAR models. Differences were resolved during meetings with licensee staff.
- The screening criteria (CDF less than 10^{-6} for most scenarios and less than 10^{-7} for containment bypass sequences) were applied to eliminate scenarios from further analyses.

This process provides the basic characteristics of each scenario. However, it is necessary to have more detailed information about each scenario than is contained in a PRA model. Capturing the additional scenario details requires further analysis of system descriptions and a review of procedures. This review includes the analysis of mitigation measures beyond those treated in current PRA models. Mitigation measures treated in SOARCA include the plant-specific EOPs, SAMGs, and 10 CFR 50.54(hh) mitigation measures. Section 0 describes the mitigation measures assessment process used to determine what measures would be available and the associated timing to implement them.

2.3 Scenarios Initiated by External Events

As explained in Section 2.1, the SOARCA team considered and selected accident scenarios (sequence groups, rather than individual sequences) based on both likelihood and potential consequences. The team identified core damage sequences from previous staff and licensee PRAs and separated them into core damage groups. It then screened the groups (not individual sequences) according to their approximate CDFs to identify the most significant ones. Since

core damage groups (i.e., scenarios) were considered, many individual lower order sequences would be captured in the aggregation into groups.

External events include internal flooding and fire; seismic events; extreme wind-, tornado-, and hurricane-related events; and similar events that may apply to a specific site. The external event scenarios developed for SOARCA analysis were derived from a review of past studies, such as the NUREG-1150 study [2], IPEEE submittals, and other relevant generic information. Detailed sequence characteristics are more difficult to specify for external event scenarios because of the general lack of external event PRA models industrywide. As a result, the SOARCA external event scenarios are heuristically based (i.e., experience based), as opposed to the internal event scenarios, which were developed through more formal, rigorous PRA methods.

These scenarios were initiated by a seismic, fire, or flooding event. The mitigation measures assessment for each of these scenarios assumed that the initiator was a seismic event, because it was judged to be limiting. Seismic initiators are considered to be limiting for two principal reasons. First, they are more likely to result in the near immediate failure of systems, whereas, fire and flood would be expected to result in delayed failures. Secondly, a seismic event may be more likely than a fire or flood to fail passive components, such as water tanks. Additionally, seismic initiators may be more likely to have sitewide and offsite impacts.

No attempt was made to match the frequencies of the external event scenarios to the actual sequence frequencies in any of the input information sources, because much of the available quantitative risk information on external events is dated. For example, since the publication of input information sources, new seismic hazard estimates have been developed. As a result, the estimated frequencies of the external event scenarios were based on expert judgment that considered the impact of changes in seismic data and methods on the published external-event PRA results. Care was taken to ensure that the external event scenario selection maintained the relative importance of external events CDF versus internal events CDF.

2.4 Accident Scenarios Selected for Surry

The SOARCA team selected four accident scenarios for the Surry plant (two initiated by internal events and two initiated by external events). The following sections identify each selected accident scenario, provide its representative CDF, and summarize the accident scenario in terms of its initiating event, equipment failures, and operator errors.

2.4.1 Surry Internal Event Scenarios

Two internal event scenarios for Surry met the criteria for further analysis.

(1) Initiating Event: Spontaneous SGTR

Representative CDF: 5×10^{-7} per reactor-year (SPAR)

Scenario Summary: This scenario is initiated by a spontaneous rupture in one steam generator tube. The operators fail to (1) isolate the faulted steam generator, (2) depressurize and cool down the RCS, and (3) refill the refueling water storage tank

(RWST) or cross-connect to the unaffected unit's RWST. Auxiliary feedwater, high-pressure injection, low-pressure injection, and containment spray are available, if needed. However, high-pressure recirculation, low-pressure recirculation, and the recirculation sprays will be unavailable as a result of lack of water in the containment sump.

Comparison with Licensee PRA: The licensee PRA calculates a CDF of 1×10^{-6} per reactor-year for this scenario. The conditional core damage probabilities are virtually identical for the SPAR analysis (1.4×10^{-4}) and for the licensee PRA (1.5×10^{-4}). The difference in the calculated CDFs is mainly attributable to the difference in initiating event frequency. Because both the SPAR model and licensee-calculated CDFs for this scenario are above the 1×10^{-7} per reactor-year threshold for containment bypass scenarios, this scenario was retained for further analysis.

(2) Initiating Event: ISLOCA in the Low-Head Safety Injection System

Representative Frequency: 3×10^{-8} per reactor-year (SPAR)

Scenario Summary: This scenario is initiated by a common-cause failure of both low-head safety injection (LHSI) inboard isolation check valves. The open pathway pressurizes and ruptures a section of the low-pressure piping outside the containment, which opens a containment bypass LOCA. This sequence group consists of the bypass LOCA, followed by operator failures to refill the RWST or cross-connect to the unaffected unit's RWST. The ability to inject using the LHSI is not possible because of the pipe rupture. The high-head injection system remains available, because the pumps are in a separate location. Core damage occurs because of RWST depletion and operator failure to refill the RWST or cross-connect to the unaffected unit's RWST.

Comparison with Licensee PRA: The ISLOCA scenario analyzed in SOARCA is a catastrophic failure of both of the inboard isolation check valve disks within the LHSI piping, together with failure to refill the RWST or to cross-connect to the unaffected unit's RWST. For this ISLOCA scenario, the NRC's SPAR model calculated a CDF of 3×10^{-8} per reactor-year, and the NRC's initial understanding was that the licensee's PRA calculated a CDF of 7×10^{-7} per reactor-year. SOARCA analyses originally included this scenario because the licensee's PRA for Surry included an ISLOCA frequency of 7×10^{-7} per reactor-year, and it has been commonly identified as an important contributor in PRA.

During Surry site visits on January 19, 2011, and October 26, 2011, the NRC staff learned that the licensee's current PRA model has the following two ISLOCA scenarios:

- scenario one: catastrophic failure of one check valve, leak-by of the second check valve, and the motor-operated isolation valve being unable to close
- scenario two: catastrophic failure of two check valves

Scenario one would result in a leak between 50–300 gallons per minute (gpm) from the RCS. Anything less than 50 gpm would be mitigated by a relief valve on the low pressure side of the LHSI injection line; pipe rupture would not occur. The frequency of the catastrophic failure of one check valve and the leak-by of the second check valve is 1×10^{-6} per reactor-year. When compounded by all the potential failure modes (including operator error and mechanical or electrical failures) of the motor-operated valve, that lowers the frequency of scenario one to 7×10^{-7} per reactor-year. This frequency does not include any consideration of averting core damage by refilling or cross-connecting RWSTs. This is a significant conservatism.

Scenario two would result in a leak above 300 gpm from the RCS. The licensee's current PRA model assumes that the probability for the catastrophic failure of both isolation check valves is approximately 3×10^{-8} per reactor-year. As with scenario one, this frequency does not include consideration of averting core damage by refilling or cross-connecting RWSTs. Scenario two does not meet the SOARCA screening criterion of 1×10^{-7} per reactor-year for a bypass event. However, the team elected to retain it, because it has been commonly identified as an important contributor in PRA.

2.4.2 Surry External Event Scenarios

Two external event scenarios for Surry met the criteria for further analysis.

(1) Initiating Event: Seismic-initiated LTSBO

Representative Frequency: 1×10^{-5} to 2×10^{-5} per reactor-year

Scenario Summary: This scenario is initiated by an earthquake of 0.3–0.5 g peak ground acceleration (PGA). The seismic event results in loss of offsite power (LOOP) and failure of onsite emergency alternating current (ac) power, resulting in an SBO event where neither onsite nor offsite ac power are recoverable. All systems dependent on ac power are unavailable, including the containment systems (containment spray and fan coolers). The TDAFW system is available initially. Eventually, loss of the TDAFW occurs because of battery depletion and the resulting loss of direct current (dc) power for sensing and control. The loss of pump seal cooling will cause a reactor coolant pump seal to leak.

(2) Initiating Event: Seismic-Initiated STSBO

Representative Frequency: 1×10^{-6} to 2×10^{-6} per reactor-year

Scenario Summary: This scenario is initiated by an earthquake of 0.5–1.0 g PGA. The seismic event results in a LOOP and failure of onsite emergency ac power, resulting in an SBO event where neither onsite nor offsite ac power are recoverable. All systems dependent on ac power are unavailable, including the containment systems (containment spray and fan coolers). The seismic event also results in a loss of dc power, resulting in the loss of automatic control of the TDAFW system. The earthquake ruptures the

emergency condensate storage tank (ECST), which is conservatively assumed to empty immediately, rendering the TDAFW system initially unavailable. This scenario is referred to as the STSBO, since the site loses all power, even the batteries, and therefore all of the safety systems become quickly inoperable in the “short term.”

(3) Initiating Event: Seismic-Initiated STSBO with Induced SGTR

Representative Frequency: 3×10^{-7} to 5×10^{-7} per reactor-year. The representative frequency for this event is estimated to be 3.75×10^{-7} per reactor-year, based on an assumed conditional tube failure probability of 0.25, selected from NUREG-1570, “Risk Assessment of Severe Accident-Induced Steam Generator Tube Rupture,” issued March 1998 [7].

Scenario Summary: An additional seismic-initiated STSBO scenario involves a variation that considers the conditional likelihood of a thermally induced steam generator tube rupture (TISGTR).

2.5 Accident Scenarios Selected for Peach Bottom

The SOARCA team selected two accident scenarios for the Peach Bottom plant (both initiated by a seismic event). In addition, SOARCA included a mitigation assessment for the Loss of Vital AC Bus E-12 scenario. The following sections identify each selected accident scenario, provide its representative CDF, and summarize the scenario in terms of its initiating event, equipment failures, and operator errors.

2.5.1 Peach Bottom Internal Event Scenarios

The Loss of Vital AC Bus E-12 was initially estimated to have a frequency above the SOARCA screening criterion of 1×10^{-6} per reactor-year and was therefore analyzed. However, after further review of the SPAR model and comparison with the licensee’s PRA, the team determined that the scenario had a CDF below the screening criteria. Because the MELCOR analysis provided unique insights into the mitigation and response of the plant for this internal event sequence, the team retained the MELCOR analysis.

2.5.2 Peach Bottom External Event Scenarios

(1) Initiating Event: Seismic-Initiated LTSBO

Representative Frequency: 1×10^{-6} to 5×10^{-6} per reactor-year

Scenario Summary: This scenario is initiated by an earthquake of 0.3–0.5 g PGA. The seismic event results in a LOOP, failure of onsite emergency ac power, and failure of the Conowingo Dam power line, resulting in an SBO event where neither onsite nor offsite ac power are recoverable. All systems dependent on ac power are unavailable, including the containment systems (containment spray). The turbine-driven injection systems—high-pressure coolant injection (HPCI) or RCIC, or both—are available until battery depletion.

(2) Initiating Event: Seismic-Initiated STSBO

Representative Frequency: 1×10^{-7} to 5×10^{-7} per reactor-year

Scenario Summary: This scenario is initiated by an earthquake of 0.5–1.0 g PGA. The seismic event results in a LOOP, failure of onsite emergency ac power, and failure of the Conowingo Dam power line, resulting in an SBO event where neither onsite nor offsite ac power are recoverable. All systems dependent on ac power are unavailable, including the containment systems (containment spray). In addition, HPCI and RCIC are initially assumed to be unavailable because of the loss of dc power. The larger earthquake ruptures the condensate storage tank (CST). The earthquake causes the fire water system to fail. This scenario is referred to as the short-term SBO since the site loses all power, even the batteries, and therefore all of the safety systems become quickly inoperable in the “short term.”

Note: The STSBO scenario does not meet the SOARCA screening criterion of 1×10^{-6} per reactor-year; however, the team retained the scenario for analysis to assess the risk importance of a lower frequency, potentially higher consequence scenario. This type of scenario has been a risk-important severe accident scenario in past PRA studies. The SOARCA study analyzed two variations of this scenario, one with and one without RCIC blackstart.

2.6 Generic Factors

The results of existing PRAs indicate that the likelihood of an NPP accident sequence that releases a significant amount of radioactivity is very small, owing to the diverse and redundant barriers and numerous safety systems in the plant, the training and skills of the reactor operators, testing and maintenance activities, and the regulatory requirements and oversight of the NRC. In addition, it is important to recognize that CDFs of NPPs have decreased over the years. Several reasons exist for these decreases:

- Utilities have completed plant modifications intended to remedy concerns raised in earlier PRAs.
- Plants exhibit better performance as evidenced by reductions in initiating event frequencies, improvements in equipment reliability, and higher equipment availability. NPP equipment has become more reliable and available because of improved maintenance practices motivated by the Maintenance Rule (10 CFR 50.65, “Requirements for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants”) [8].
- The NRC has issued new regulations, such as the Anticipated Transient without Scram (ATWS) Rule (10 CFR 50.62, “Requirements for Reduction of Risk from Anticipated Transients without Scram (ATWS) Events for Light-Water-Cooled Nuclear Power Plants”) [9] and the SBO Rule (10 CFR 50.63, “Loss of All Alternating Current Power”) [10] that directly affect the likelihood of certain types of accidents. Although

the NRC issued the ATWS Rule and the SBO Rule before it completed NUREG-1150 [2], it did not address the impact of these rules on risk in NUREG-1150.

- PRA methodologies have improved, allowing a more realistic assessment of risk. In this category, improvements in common-cause failures analysis are noteworthy.

As a result, risk estimates reflect the impacts of constantly changing plant operational, regulatory, and PRA technology environments. Any attempt to identify significant accident sequences should be viewed as a “snapshot” of the plant at the time the analysis was completed.

3.0 MITIGATIVE MEASURES ASSESSMENT

The overall objective of the SOARCA project is to develop a body of knowledge regarding the realistic outcomes of severe reactor accidents. Included within this objective is to provide insight into the effectiveness and benefits of mitigation measures currently employed at operating reactors. Section 2.0 describes the PRA information sources, including the NRC's SPAR models, licensees' PRA models, NUREG-1150, and additional expert judgment that this study used to identify risk-important sequence groups leading to core damage and containment failure or bypass. This section describes the methods that determined the mitigation measures that would be available and the associated timing to implement them. This includes mitigation measures beyond those treated in current PRA models. Mitigation measures treated in SOARCA include the licensee's EOPs, SAMGs, and 10 CFR 50.54(hh) mitigation measures. It is expected that the licensee's emergency response organization would implement these measures in accordance with the approved emergency plan.

3.1 Site-Specific Mitigation Strategies

In preparation for the detailed, realistic modeling of accident progression and offsite consequences, the SOARCA project staff had extensive cooperation from the licensees to develop high-fidelity plant systems models; define operator actions, including the most recently developed mitigative actions; and develop models to simulate site-specific and scenario-specific emergency planning. In addition to input for model development, licensees provided information from their own PRAs on accident scenarios. Through tabletop exercises (with senior reactor operators, PRA analysts, and other licensee staff) of the selected scenarios, licensees provided input on the timing and nature of the operator actions to mitigate the selected scenarios. The licensee input for each scenario was used to develop timelines of operator actions and equipment lineup or setup times for implementing the available mitigation measures. This includes mitigation measures beyond those treated in current PRA models.

The SOARCA team developed the timelines for implementing the mitigation measures directed in plant-specific procedures and mobilizing support organizations after discussing each scenario with licensee personnel who have experience in operations, engineering, and facility management. The team developed these timelines through multiple site visits and system walkdowns in 2007, 2010, and 2011, with licensee personnel specifically reviewing the steps to implement mitigation. Results of preliminary accident progression calculations were used to characterize anticipated changes in plant conditions and describe the signatures of measurable parameters. Estimates were then made for the time needed to assemble necessary personnel, tools, and equipment; align and start components; and establish a desired operating condition. For the ISLOCA scenario, where the timing of operator actions was judged to be important to the results, the licensee performed plant simulator runs with reactor operators to ensure that the timing for key actions was as realistic as possible.

Mitigation measures treated in SOARCA include EOPs, SAMGs, and 10 CFR 50.54(hh) mitigation measures. The 10 CFR 50.54(hh) mitigation measures refer to additional equipment and strategies required by the NRC following the terrorist attacks of September 11, 2001, to

further improve severe accident mitigation capability. NRC inspectors completed the verification of licensee implementation (i.e., equipment, procedures, and training) of 10 CFR 50.54(hh) mitigation measures in December 2008. These mitigation measures are for use during scenarios involving large fires and explosions. One such measure is portable, self-powered equipment, including generators and diesel-driven pumps. Portable generators provide electrical power to equipment that gives critical indications, such as the reactor vessel water level. Portable generators also provide electrical power needed to operate safety relief valves. Portable diesel-driven pumps provide a diverse and independent means of injecting water into the RCS and steam generators. Another such measure is starting and controlling, without electrical control power, the plant's existing turbine-driven injection systems, including the RCIC and TDAFW systems.

To quantify the benefits of the mitigation measures and to provide a basis for comparison to past analyses of unmitigated severe accident scenarios, the project team also analyzed the scenarios assuming that the events proceed as unmitigated by key available onsite mitigation measures, ultimately leading to core damage and an offsite release. This NUREG refers to these as "unmitigated scenarios," because they are not effectively mitigated by onsite resources. This report does not determine the respective likelihoods of the mitigated and unmitigated cases of each scenario.

3.1.1 Scenarios Initiated by External Events

Scenarios identified in SOARCA included both externally and internally initiated events. The externally initiated events included events for which seismic, fire, extreme wind, and flooding initiators were grouped together.

The PRA screening identified the following scenarios that were initiated by external seismic, fire, or flooding events:

- Peach Bottom LTSBO: 1×10^{-6} to 5×10^{-6} /reactor-year
- Surry LTSBO: 1×10^{-5} to 2×10^{-5} /reactor-year
- Surry STSBO: 1×10^{-6} to 2×10^{-6} /reactor-year
- Surry STSBO with TISGTR: 3×10^{-7} to 5×10^{-7} /reactor-year

The mitigation measures assessment for each of these scenarios assumed that the initiator was a seismic event, because it was judged to be limiting. Seismic initiators are considered to be limiting for two principal reasons. First, seismic initiators are more likely to result in the near immediate failure of systems, whereas, fire and flood would be expected to result in delayed failures. Secondly, a seismic event may be more likely than a fire or flood to fail passive components, such as water tanks. Additionally, seismic initiators may be more likely to have sitewide and offsite impacts.

It is important to note that, although it is not included in the above list, the seismically induced Peach Bottom STSBO was also retained for analysis. With a frequency of 1×10^{-7} to 5×10^{-7} /reactor-year, this scenario does not explicitly meet the SOARCA screening criterion. Nonetheless, it was retained to assess the risk importance of a lower frequency, potentially

higher consequence scenario. The STSBO has also been an important event in many past PRAs and is limiting in many transients.

Seismic events considered in SOARCA result in loss of offsite and onsite ac power and, for the more severe seismic events, loss of dc power. Under these conditions, the turbine-driven RCIC and TDAFW systems are important mitigation measures. BWR SAMGs include starting RCIC without electricity to cope with SBO conditions. This is known as RCIC blackstart. The 10 CFR 50.54(hh) mitigation measures have taken this a step further and also include long-term operation of RCIC without electricity (RCIC blackrun), using a portable generator to supply power to indications, such as the RPV level indication, to allow the operator to manually adjust RCIC flow to prevent RPV overfill and flooding of the RCIC turbine. Similar procedures have been developed for PWRs for TDAFW. For the Peach Bottom and Surry LTSBO scenarios, RCIC and TDAFW can be used to cool the core until battery exhaustion. In addition, blackstart procedures can be used for the Peach Bottom STSBO scenario. After battery exhaustion, blackrun of RCIC and TDAFW systems can continue to cool the core. The study used MELCOR calculations to demonstrate core cooling under these conditions.

Seismic PRAs for Peach Bottom and Surry do not describe general plant damage and accessibility. The damage was assumed to be widespread and accessibility to be difficult, consistent with the unavailability of many plant systems.

The seismic initiating event for the SBO accident scenarios might rupture the CST, which is the primary water reservoir for RCIC. However, the Peach Bottom CST is surrounded by a reinforced concrete dike or moat, which would retain water drained from the CST. Therefore, suction from the CST would not be interrupted by a loss of CST integrity. Makeup to the CST would likely be available from the cooling water tower basin (3.55 million gallons or 13,438 cubic meters), or the Susquehanna River; the diesel-driven portable pump (i.e., 10 CFR 50.54(hh) equipment) or other mobile equipment could be used.

For the Surry LTSBO, the TDAFW pump is available until the ECST empties. The ECST initially supplies the TDAFW pump but has finite resources (i.e., it empties in 5 hours). However, the team estimated that the operators would have sufficient time, access, and resources to make up water for injection into the ECST. The low-pressure injection and safety-related containment spray piping were judged not likely to fail for this scenario. The integrity of this piping provided a connection point for a portable, diesel-driven pump to inject into the RCS. Licensee staff estimated that transporting the pump and connecting it to plant piping would take about 2 hours, leading to vessel injection at 3.5 hours, or 2 hours after the operators and support staff recommended the action. Consequently, the cooling water would be supplied to the steam generators for RCS heat removal. The team assumed that operators would eventually provide makeup water to the ECST.

One Surry STSBO assumption was that the ECST would fail and an alternative reservoir would be available within 8 hours; using a fire truck or portable pump to draw from the discharge canal. The low-pressure injection and containment spray safety-related piping were judged not likely to fail, based primarily on NUREG/CR-4334, "An Approach to the Quantification of Seismic Margins in Nuclear Power Plants," issued in 1985 [11], to help extrapolate the potential viability

of safety-related piping after a 1.0 g event. This conclusion also considered related studies, including a 2007 German study, “Seismic PSA of the Neckarwestheim 1 Nuclear Power Plant” [12], that physically simulated ground motion equal to 1 g on an existing plant. The integrity of this piping provided a connection point for a portable, diesel-driven pump to inject into the RCS or into the containment spray systems. Licensee staff estimated that transporting the pump and connecting it to plant piping would take about 2 hours. However, for the STSBO, this mitigation measure was conservatively estimated to take 8 hours, owing to the higher level of damage. Because the installation time was beyond the estimated time to fuel damage and vessel failure (3 hours to core damage, 7 hours to lower head failure), the containment spray system was the preferred mitigation measure. A better understanding of the effect of large seismic events on general plant conditions would be helpful in reducing the uncertainty in availability and accessibility for mitigation measures. If accessibility was not significantly impaired and delay in using the portable pump was limited to 2 hours, then core damage could be averted.

The 10 CFR 50.54(hh) mitigation measures include portable equipment (such as portable power supplies to supply indication, portable diesel-driven pumps, and portable air bottles to open air-operated valves), together with procedures to implement these measures under severe accident conditions. Surry’s portable equipment and fire truck are stored onsite in a one-story, multibay garage. Some of Peach Bottom’s portable equipment is stored in an open bay in the water treatment building and some is stored outside under a tarp. The mitigated cases assumed that this equipment survived the seismic event and could be successfully implemented.

The SOARCA team estimated the time to implement individual mitigation measures based on licensee input for each scenario; these estimates take into account the plant conditions following the seismic event. Also, for portable equipment, the time estimates reflect exercises run by licensee staff that provided actual times to move the equipment into place and were adjusted (increased) to account for the larger seismic event. The time estimates for staffing the TSCs and the emergency operating facilities (EOFs) were based on regulatory requirements and the potential for additional delays resulting from the possible effect of the seismic event on roads and bridges.

The mitigation measures assessment noted the possibility of bringing in offsite equipment (e.g., fire trucks, pumps, and power supplies from sister plants or from contractors), but it did not quantify the types, amounts, and timing of this equipment arriving and being implemented. This equipment is also judged to be effective in mitigating an environmental release (by flooding core debris) after it begins. Section 3.2 provides additional information on equipment available offsite and time estimates for transporting this equipment.

Because the SOARCA project did not analyze multiunit accidents, the mitigation measures assessment for external events assumed that the operators only had to mitigate an accident at one reactor, even though Peach Bottom and Surry are two-unit sites. It also assumed minimum staffing and that half of the onsite operators mitigate the damaged unit. Peach Bottom had voluntarily arranged to provide redundant 10 CFR 50.54(hh) equipment to mitigate both units simultaneously; however, SOARCA did not examine this.

3.1.2 Scenarios Initiated by Internal Events

The PRA screening identified the following scenarios that were initiated by internal events:

- Surry interfacing systems loss-of-cooling accident (ISLOCA): 3×10^{-8} /reactor-year
- Surry spontaneous SGTR: 5×10^{-7} /reactor-year

These scenarios result in core damage as a result of assumed operator errors. For the ISLOCA, the operators fail to refill the RWST or cross-connect to the other unit's RWST. For the spontaneous SGTR, the operators fail to (1) isolate the faulted steam generator, (2) depressurize and cool down the RCS, and (3) refill the RWST or cross-connect to the unaffected unit's RWST.

The SPAR model and the licensee's PRA concluded that these two events proceed to core damage as a result of the above-postulated operator errors. However, these PRA models do not appear to have credited the significant time available for the operators to correctly respond to events. They also do not appear to credit technical assistance from the TSC and the EOF. For the ISLOCA, the realistic analysis of thermal-hydraulics presented in NUREG/CR-7110, Volume 2, estimated 6 hours until the RWST is empty and 13 hours until fission product release begins, providing time for the operators to correctly respond. The ISLOCA time estimates are based on a double-ended pipe rupture. These estimates would be longer for smaller break sizes. Also, if the operators throttle high-head safety injection to match decay heat, the time to empty the RWST and the beginning of core damage would be extended by an additional 24 hours. For the SGTR, the realistic analysis of thermal-hydraulics showed from 24 to 48 hours until core damage begins. Therefore, based on realistic time estimates by which the technical assistance is received from the TSC and the EOF, it was highly likely that the operators would correctly respond to the events. These time estimates considered indications that the operators would have of the bypass accident, operator training on plant procedures for dealing with bypass accidents and related drills, and assistance from the TSC and EOF, which were estimated to be fully staffed and operational by 1 to 1.5 hours into the event.

The mitigation measures assessment for internal events also included 10 CFR 50.54(hh) mitigation measures, but these were subsequently shown to be redundant to the wide variety of equipment and indications available for mitigating the ISLOCA and SGTR. ISLOCA and SGTR are internal events that involve few equipment failures and are controlled by operator errors.

The PRA screening for Peach Bottom initially identified the Loss of Vital ac Bus E12 scenario as exceeding the SOARCA screening criterion of 1×10^{-6} /reactor-year. However, a simplifying modeling assumption was subsequently found in the SPAR model, and the scenario frequency was determined to be below the SOARCA screening criterion. By the time the issue was discovered, the mitigation measures assessment and the MELCOR analysis were complete. The MELCOR analysis described in NUREG/CR-7110, Volume 1, demonstrated that this scenario did not result in core damage, even without crediting 10 CFR 50.54(hh) mitigation measures, contrary to the more conservative treatment in SPAR. Nevertheless, this report describes the

mitigation measures assessment and the MELCOR analysis for this scenario to demonstrate the benefit of a detailed review of success criteria using integrated thermal-hydraulic analysis.

3.2 Truncation of Releases

Many resources at the State, regional, and national level would be available to mitigate an NPP accident. The staff reviewed available resources and emergency plans and determined that adequate mitigation measures could be brought onsite within 24 hours and be connected and functioning within 48 hours.

Concurrent with the NRC and industry response, the National Response Framework (NRF) would establish a coordinated response of national assets. As described in the Nuclear/Radiological Incident Annex to the NRF, the NRC is typically the Coordinating Agency for incidents occurring at NRC-licensed facilities. As Coordinating Agency, the NRC has technical leadership for the Federal Government's response to the incident. Under an established agreement with the NRC, the U.S. Department of Homeland Security would be the Coordinating Agency for an event in which a general emergency is declared. The NRF is exercised periodically and provides access to the full resources of the Federal Government. The NRC has an extensive, well-trained, and exercised emergency response capability and has onsite resident inspectors. These onsite inspectors are equipped and available to provide firsthand knowledge of accident conditions. The NRC would activate the incident response team at the NRC regional office and Headquarters. The focus of the NRC response is to ensure that public health and safety are protected and to assist the licensee with the response by working with the Department of Homeland Security to coordinate the national response. Concurrently, the NRC regional office would send a site team to staff positions in the reactor control room, TSC, and EOF to support the response. The EOF and TSC are assumed manned and operational in roughly 1–2 hours, depending on the accident scenario. The NRC performs an independent assessment of the actions taken or proposed by the licensee to confirm that such actions will arrest the accident.

Both Surry and Peach Bottom are supported by an offsite EOF. The emergency response organization at the EOF has access to fleetwide emergency response personnel and equipment, including the 10 CFR 50.54(hh) mitigation measures and equipment from sister plants. These assets, as well as those from neighboring utilities and State preparedness programs, could be brought to bear on the accident if needed. Every licensee participates in full onsite and offsite exercises every 2 years where response to severe accidents and coordination with offsite response organizations (OROs) is demonstrated and inspected by the NRC and the Federal Emergency Management Agency. In addition, the Institute for Nuclear Power Operations and the Nuclear Energy Institute would activate their emergency response centers to assist the site as needed.

All of the described resources would be available to the site to mitigate the accident. Although some of these efforts would be ad hoc, knowledgeable personnel and an extensive array of equipment would be available and were considered in the conclusion that radiological releases would be truncated within 48 hours except for the Surry LTSBO sequence, which was truncated at 72 hours.

4.0 SOURCE TERM ANALYSIS

Section 4.1 describes some background in key studies for regulatory and probabilistic applications. Figure 3 shows a timeline of key events and NRC studies in the evolution of nuclear safety technology, as well as the key source term studies cited in the timeline that preceded the SOARCA program (also discussed in Section 4.1 below). Section 4.2 contains a history of the severe accident source term codes developed by the NRC and the scope of the MELCOR code. The MELCOR code is the culmination of the NRC research and code development of severe accident phenomena for source term evaluations. Section 4.3 presents the MELCOR modeling approach used in the SOARCA analyses. This includes the development of the plant models, the best practices approaches to important but uncertain phenomena and equipment performance, recent advances in source term models, and the methods used to calculate the radionuclide inventories.




Figure 3 Timeline of key nuclear power events and safety studies

4.1 Source Term Study Background

The Reactor Safety Study (WASH-1400) [3], was the first systematic attempt to provide realistic estimates of public risk from potential accidents in commercial NPPs. The 1975 study included analytical methods for determining both the probabilities and consequences of various accident scenarios. The study used event trees and fault trees to define important accident sequences and to quantify the reliability of engineered safety systems and contained a list of nine PWR and five BWR source terms. All the accidents that were believed to contribute significantly to the overall core melt frequency were grouped, or “binned,” into the source term categories. The

WASH-1400 source terms included characterizations of accident timing, the release duration (e.g., puff or sustained release), and the energy of the release for plume loft considerations. The description of radioactivity used eight chemical categories. The 54 most health-significant isotopes were used in health consequence calculations.

The WASH-1400 methodology used to predict the health effects from the source term was based on the newly developed Calculation of Reactor Accident Consequences (CRAC) code [18] that calculated the atmospheric dispersion and health consequences. However, an integrated tool for the calculation of the source term did not exist. The estimation of the source term used the best analytic procedures available at the time. When ample data were available, a model for the phenomenon was included as realistically as possible, but when data were lacking, consideration of the phenomenon was omitted. The resultant source terms reflected uncertainties and poor understanding of applicable phenomena. Uncertainties in accident frequencies were accounted for by adding 10 percent of the likelihood of each release category into the next larger and the next smaller category.

Subsequently, the NRC documented the technical basis for source terms in NUREG-0772, “Technical Bases for Estimating Fission Product Behavior during LWR Accidents,” issued June 1981 [19]. NUREG-0772 assessed the assumptions, procedures, and available data for predicting fission product behavior. Four conclusions of the NUREG-0772 study were (1) a new definition of the chemical form of iodine (I) (i.e., cesium iodide (CsI) was the dominant form), (2) the potential retention of CsI within the vessel or containment versus elemental iodine, (3) the inclusion of in-vessel retention, and (4) the role of containment engineering safety features (e.g., sprays, suppression pools, and ice condensers). However, NUREG-0772 based much of the quantitative assessment on scoping calculations that were applicable only to specific conditions. In particular, it conducted the examination of fission product behavior in different regions of the plant with different accidents in parallel with limited consideration of integral effects. The NRC examined the potential impact of the NUREG-0772 findings on reactor regulation and documented the results in draft NUREG-0771, “Regulatory Impact of Nuclear Reactor Accident Source Term Assumptions,” issued June 1981 [20].

The NUREG-0771 and NUREG-0772 studies formed the basis for the designation of five accident groups as representative of the spectrum of potential accident conditions documented in NUREG-0773, “The Development of Severe Accident Source Terms: 1957–1981,” issued November 1982 [21]. In 1982, the NRC issued the NUREG/CR-2239 siting study [1] using the NUREG-0773 source terms. It determined that the five source terms adequately spanned the range of possible source terms. The source terms, developed from separate effects computer code analyses that were performed in 1978, were used to calculate accident consequences at 91 U.S. reactor sites using site-specific population data and a mixture of site-specific and regionally specific meteorological data. An objective of the SOARCA study is to update this study.

In response to emerging regulatory needs, Battelle Columbus Laboratories conducted a study, “Radionuclide Release Under Specific LWR Accident Conditions,” published in 1985 [22], that developed and modified a number of separate effects severe accident computer codes based on emerging severe accident research. The codes, coupled together to form a code suite, could

calculate a complete accident sequence. The new Source Term Code Package (STCP) code [22] calculated the source terms for about 25 specific sequences for five operating plants. Although the STCP was a significant step forward in deterministic severe accident analysis, the code suite had some significant shortcomings. Because the code represented the linkage of many separate code modules, the data transfer and feedback effects were not always handled consistently. The technical basis for the models in the STCP is in NUREG-0956, "Reassessment of the Technical Bases for Estimating Source Terms," issued July 1986 [16]. The results from the STCP calculations supported the NUREG-1150 PRA [2], along with expert judgment and simplified algorithms for sequence-specific source terms.


The NUREG-1150 PRA was an effort to put the insights gained from the research on system behavior and phenomenological aspects of severe accidents into a risk perspective. An important characteristic of this study was the inclusion of the uncertainties in the calculations of CDF and source term caused by an incomplete understanding of reactor systems and severe accident phenomena at that time. NUREG-1150 therefore used sensitivity studies, uncertainty studies, and expert judgment to characterize the likelihood of alternative events that affect the course of an accident. The elicitation of expert judgment was used to develop probability distributions for many accident progression, containment loading, structural response, and source term issues. The insights from the NUREG-1150 study have been used in several areas of reactor regulation, including the development of alternative radiological source terms for evaluating design-basis accidents at nuclear reactors.

4.2 The MELCOR Code

The MELCOR code, a fully integrated, engineering-level computer code, has, as its primary purpose, to model the progression of accidents in LWR NPPs, as well as in nonreactor systems (e.g., spent fuel pool, dry cask). Current uses of MELCOR include estimation of fission product source terms and their sensitivities and uncertainties in a variety of applications. MELCOR is a modular code comprising three general types of packages: (1) basic physical phenomena (i.e., hydrodynamics, heat and mass transfer to structures, gas combustion, aerosol and vapor physics), (2) reactor-specific phenomena (i.e., decay heat generation, core degradation, ex-vessel phenomena, sprays, and engineering safety systems), and (3) support functions (thermodynamics, equations of state, other material properties, data-handling utilities, and equation solvers). As a fully integrated code, MELCOR models all major systems of a reactor plant and their important coupled interactions.


Figure 4 shows the MELCOR code integration of models for important phenomena previously treated in separate effects codes.

Modeling and Analysis of Severe Accidents in Nuclear Power Plants



Severe accident codes are the "repository" of phenomenological understanding gained through NRC and International research performed since the TMI-2 accident in 1979

Integrated models required for self-consistent analysis



Important Severe Accident Phenomena

	MELCOR	CONTAIN	VICTORIA	SCOMP	RELAP-5
Accident initiation	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Reactor coolant thermal hydraulics	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Loss of core coolant	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Core meltdown and fission product release	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Reactor vessel failure	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Transport of fission products in RCS and Containment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fission product aerosol dynamics	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Molten core/basemat interactions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Containment thermal hydraulics	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fission product removal processes	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Release of fission products to environment	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Engineered safety systems - sprays, fan coolers, etc iodine chemistry, and more	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Figure 4 MELCOR integration of separate effects codes

The scope of MELCOR includes the following:

- thermal-hydraulic response of the RCS, reactor cavity, containment, and confinement buildings
- core uncover (loss of coolant), fuel heatup, cladding oxidation, fuel degradation (loss of rod geometry), and core material melting and relocation
- heatup of reactor vessel lower head from relocated core materials and the thermal and mechanical loading and failure of the vessel lower head and transfer of core materials to the reactor vessel cavity
- core-concrete attack and ensuing aerosol generation
- in-vessel and ex-vessel hydrogen production, transport, and combustion
- fission product release (aerosol and vapor), transport, and deposition

- behavior of radioactive aerosols in the reactor containment building, including scrubbing in water pools and aerosol mechanics in the containment atmosphere, such as particle agglomeration and gravitational settling
- the impact of engineered safety features on thermal-hydraulic and radionuclide behavior

Most MELCOR models are mechanistic, and the use of parametric models is limited to areas of high phenomenological uncertainty where no consensus exists concerning an acceptable mechanistic approach. Current use of MELCOR often includes uncertainty analyses and sensitivity studies. To facilitate this, many of the mechanistic models have been coded with optional adjustable parameters. This does not affect the mechanistic nature of the modeling, but it does allow the analyst to easily address questions of how particular modeling parameters affect the course of a calculated transient. MELCOR does not use core radioactive nuclide inventories; rather, it uses masses and decay heats of chemical element groups. Appropriate code calculations for specific fuel and core design are carried out to the burnup of interest to provide the initial core inventories for MELCOR severe accident analysis (see Section 4.3.1).

After the completion of Version 1.8.1 in 1991, the NRC commissioned a peer review using recognized experts from national laboratories, universities, and the MELCOR user community [61]. The charter of the MELCOR peer review committee was to (1) provide an independent assessment of the MELCOR code through a peer review process, (2) determine the technical adequacy of the MELCOR code for the complex analyses it is expected to perform, and (3) issue a final report describing its technical findings. The committee offered a set of major findings that covered the various physics model numerics, missing models, modeling deficiencies, code assessment, and documentation. The NRC incorporated the findings into the research plan that governed the subsequent code development.

In 2000, the NRC began reducing the number of codes that it actively maintained by consolidating the CONTAIN, SCDAP/RELAP5, and VICTORIA code functionality and models into MELCOR. The assessment of MELCOR parity with CONTAIN showed that MELCOR results are comparable to CONTAIN. A comprehensive parity study of the MELCOR code with SCDAP/RELAP5 is ongoing. The assessment of fission product chemistry and transport is currently supported by foreign experiments (especially those from the Phebus facility in France). Hence, the scope of the evaluation of parity of the MELCOR to the VICTORIA code not only includes the phenomena treated in VICTORIA but also new experimental findings.

4.3 MELCOR Modeling Approach

Section 4.3.1 presents a high-level description of MELCOR models used for the SOARCA project. Existing MELCOR models for Surry and Peach Bottom were updated to current state-of-the-art modeling practices, as well as the latest version of the MELCOR code (Version 1.8.6). More detailed information describing the plant models is in the plant-specific analysis reports (i.e., NUREG/CR-7110, Volumes 1 and 2, for Peach Bottom and Surry, respectively).

The modeling and prediction of accident progression and radiological release in a severe accident requires the integration of a number of phenomenological models to address a range of

thermal-hydraulic, materials, structural, and fission product behavior, as well as models for component (e.g., safety relief valve) behavior. Section 4.3.2 describes the procedure to define the best practices approach to modeling important and uncertain phenomena. NUREG/CR-7008, “Best Practices for Simulation of Severe Accident Progression at Nuclear Power Plants” [6], provides a more detailed description of the best practices modeling approach. At the beginning of the SOARCA project, an independent review of MELCOR best practices modeling provided greater assurance of the technical soundness of the analytical modeling [42]. The NRC used that review to identify and incorporate subsequent modeling insights and improvements before the start of plant analyses. Moreover, members of the SOARCA peer review committee recommended additional sensitivity analyses to explore specific modeling issues that were viewed as both uncertain and potentially important to risk. These analyses, discussed in detail in NUREG/CR-7110, Volumes 1 and 2, help confirm that the modeling of MELCOR best practices is sound.

Section 4.3.3 summarizes some recent changes to the modeling of radionuclide release and cesium speciation, which is important to the source term results. Finally, Section 4.3.4 describes the methodology for calculating the radionuclide inventory.

4.3.1 Plant Models

The SOARCA program updated the MELCOR models for Peach Bottom and Surry to the most recent version of the MELCOR code.³ The scope of the models included the following:

- detailed five-ring reactor vessel models
- representation of the RCS (and secondary system through the main steam isolation valve for Surry)
- representation of the primary containment
- representation of the Peach Bottom reactor building and the Surry Safeguards and Auxiliary Buildings, and ventilation and filter systems, which were radionuclide pathways in the ISLOCA scenario
- representation of the emergency core cooling systems (and the auxiliary feedwater system for Surry)
- representations of the emergency portable water-injection systems

³ All SOARCA calculations used MELCOR Version 1.8.6.

The best practices updates to each input deck specified the following new models for both plants for these important but uncertain phenomena or equipment responses:

- Safety relief valve failure modeling addressing stochastic and high-temperature failure modes.
- An additional thermomechanical fuel collapse model for heavily oxidized fuel following molten Zircaloy breakout.
- Enhanced lower plenum coolant debris heat transfer that recognizes breakup and multidimensional cooling effects not present in the one-dimensional countercurrent flooding model in older versions of MELCOR (e.g., [23]).
- Updated, plant-specific chemical element masses and decay heats (see Section 4.3.4).
- A new Oak Ridge National Laboratory (ORNL) Booth chemical element release model and new cesium speciation model (see Section 4.3.3).
- A new turbulent deposition model for aerosol deposition in piping systems. NUREG/CR-7110, Volume 2 discusses this new model and its validation.
- Vessel failure based on gross failure [24] using the improved one-dimensional creep rupture model with the new hemispherical head model and radial heat transfer between lower head conduction node segments. A more complete discussion of this model is presented in NUREG/CR-7008 [6] and the MELCOR manual [31]. A penetration failure model was not used because the timing differences between gross lower head failure and penetration failure with the available penetration model are not significant to the overall accident progression (i.e., minutes difference). Also, Sandia lower head failure tests showed that gross creep rupture of the lower head was measured to be the most likely mechanism for vessel failure [24].
- Enhanced ex-vessel core debris heat transfer that reflects multidimensional effects and rates measured in MACE tests [25].

Sections 4.3.1.1 and 4.3.1.2 summarize the SOARCA program's recent enhancements to the MELCOR Peach Bottom and Surry models, respectively.

4.3.1.1 Peach Bottom MELCOR Model

Brookhaven National Laboratory originally developed the Peach Bottom MELCOR plant model for code Version 1.8.0. J. Carbajo at ORNL subsequently adopted the model to study differences in fission product source term behavior predicted by MELCOR 1.8.1 and those generated for use in NUREG-1150 [2] using the STCP [26]. Starting in 2001, SNL has made considerable refinements to the BWR/4 core nodalization to support the developmental assessment and release of MELCOR 1.8.5. These refinements concentrated on the spatial nodalization of the reactor

core (both in terms of fuel and structural material and hydrodynamic volumes) used to calculate in-vessel melt progression.

Subsequent work in support of several NRC research programs has motivated further refinement and expansion of the BWR/4 model in four broad areas. The first area involved the addition of models to represent a wide spectrum of plant design features, such as safety systems, to broaden the capabilities of MELCOR simulations to apply to a wider range of severe accident sequences. These enhancements include the following:


- modifications of modeling features needed to achieve steady-state reactor conditions (recirculation loops, jet pumps, steam separators, steam dryers, feedwater flow, control rod drive hydraulic system, main steamlines, turbine/hotwell, core power profile)
- new models and control logic to represent coolant injection systems (RCIC, HPCI, residual heat removal, low-pressure core spray) and supporting water resources (e.g., CST with switchover)
- new models to simulate reactor vessel pressure management (safety relief valves, safety valves, automatic depressurization system, and logic for manual actions to effect a controlled depressurization if torus water temperatures exceed the heat capacity temperature limit)

The second area focused on the spatial representation of the containment and the reactor building. The drywell portion of containment has been subdivided to distinguish thermodynamic conditions internal to the pedestal from those within the drywell itself. Also, refinements have been added to the spatial representation and flow paths within the reactor building. A containment failure model is included that accounts for leakage around the drywell head flange, leakage caused by elevated drywell temperature, and leakage caused by drywell melt-through (see NUREG/CR-7110, Volume 1, Section 4.6). The third area focused on bringing the model up to current “best practice” standards for MELCOR 1.8.6 (see Section 4.3.2). The fourth area of model improvements included a new radionuclide inventory and decay heat based on the recent plant operating history (see Section 4.3.4).

Although not new for SOARCA, the MELCOR Peach Bottom model includes a multiregion ex-vessel debris spreading model. The debris spreads according to its temperature relative to the solidus and liquidus temperatures of the concrete and the debris height. If the debris spreads against the drywell liner steel wall, and if the debris temperature is above the carbon steel melting temperature, the liner will fail.

The potential for creep rupture of a BWR main steam line (i.e., piping or RPV nozzle) was added to the Peach Bottom model developed for SOARCA.

NUREG/CR-7110, Volume 1, more fully describes the MELCOR Peach Bottom model. Figure 5 shows the MELCOR nodalization diagrams for Peach Bottom.



Reactor Coolant System and Emergency Core Cooling System

Figure 5 The Peach Bottom MELCOR nodalization

4.3.1.2 *Surry MELCOR Model*

In 1988, Idaho National Engineering Laboratory originally generated the Surry MELCOR model applied in this study. SNL periodically updated it (1990 to present) to test new models, advancing the state of the art in modeling PWR accident progression and providing support to the NRC for analyses of various issues that could affect operational safety. Significant changes were made during the last several decades in the approach to modeling core behavior and core melt progression, as well as the nodalization and treatment of coolant flow within the RCS and reactor vessel. In 2002, the reactor vessel and RCS nodalization were updated using the SCDAP/RELAP5 Surry model to include a five-ring vessel nodalization and countercurrent hot-leg representation for natural circulation flow [27]. The current MELCOR Surry model is a culmination of these efforts.

In preparation for the SOARCA analyses described in this report, the model was further refined and expanded in three areas. The first area is an upgrade to core modeling in MELCOR Version 1.8.6. These enhancements include the following:

- a hemispherical lower head model that replaces the flat-bottom cylindrical lower head model
- new models for the core former and shroud structures that are fully integrated into the material degradation modeling, including separate modeling of debris in the bypass region between the core barrel and the core shroud
- models for simulating the formation of molten pools in both the core and lower plenum, crust formation, convection in molten pools, stratification of molten pools into metallic and oxide layers, and partitioning of radionuclides between stratified molten pools
- a reflood quench model that separately tracks the component quench front and the quenched and unquenched temperatures
- a control rod aerosol release model
- addition of the new ORNL Booth radionuclide release model for modern high-burnup fuel

The second area focused on the addition of user-specified models to represent a wide spectrum of plant design features and safety systems to broaden the ability of MELCOR to apply to a wider range of severe accident sequences. These enhancements included the following:

- update of the containment leakage model to include nominal leakage and leakage caused by containment overpressure (see NUREG/CR-7110, Volume 2, Section 4.8)
- update of core degradation modeling practices

- models of the individual primary system and secondary system relief valves with failure logic for rated and degraded conditions
- update of the containment flooding characteristics
- heat loss from the reactor to the containment
- separate motor driven auxiliary feed water and TDAFW models with control logic for plant automatic and operator cooldown responses
- new TDAFW models for steam flow, flooding failure, and performance degradation at low pressure
- nitrogen discharge model for accumulators
- update of the fission product inventory, the axial and radial peaking factors, and an extensive fission product tracking control system
- improvements to the modeling of natural circulation in the hot leg and steam generator and the potential for creep rupture

NUREG/CR-7110, Volume 2, more fully describes the MELCOR Surry model. Figure 6 shows the MELCOR nodalization diagrams for Surry.




Figure 6 The Surry MELCOR nodalization

4.3.2 Best Modeling Practices

The SOARCA project's integrated modeling of the accident progression and offsite consequences uses both state-of-the-art computational analysis tools and best modeling practices drawn from the collective body of knowledge on severe accident behavior generated over the past several decades of research.

The MELCOR 1.8.6 computer code embodies much of this knowledge and was used for the accident and source term analysis. MELCOR includes capabilities to model the two-phase thermal-hydraulics, core degradation, fission product release, transport, deposition, and containment response. The SOARCA analyses include operator actions and equipment performance issues as prescribed by the sequence definition and mitigative actions. The MELCOR models are constructed using plant data, and the operator actions were developed based on tabletop exercises during site visits. The code models and user-specified modeling practices represent the current best practices.

While much has been learned through extensive research, uncertainties exist in understanding phenomena associated with severe accident progression and radionuclide transport. Consistent with the stated objective of SOARCA, phenomena were modeled using realistic characterization of phenomena and events. The accident progression analysts developed a list of key uncertain phenomena that can have a significant effect on the progression of the accident. Plant-specific reports for Peach Bottom (NUREG/CR-7110, Volume 1) and Surry (NUREG/CR-7110, Volume 2) outlined each issue and identified a modeling approach or base case values. NUREG/CR-7008 [6] discusses the specific modeling practices.

The SOARCA project excluded several early containment failure modes of historical interest because of their assessed low likelihood of occurrence. These include the following:

- Alpha mode containment failure would be caused by an in-vessel steam explosion during melt relocation that simultaneously fails the vessel and the containment. A group of experts in this field, referred to as the Steam Explosion Review Group, concluded, in a position paper published by the Nuclear Energy Agency Committee on the Safety of Nuclear Installations [28], that the alpha-mode failure issue for Western-style reactor containment buildings can be considered resolved from a risk perspective, having little or no significance to the overall risk from an NPP.
- Direct containment heating would be caused by containment failure in PWR containments. NRC research has shown that an early failure of the PWR RCS caused by high-temperature natural circulation will likely depressurize the RCS before vessel failure. Importantly, extensive NRC testing and analyses have also shown that, in the unlikely event of a high-pressure vessel failure, early containment failure caused by direct containment heating is very unlikely, with some variation depending on plant design [29]. In the case of Surry, the research concluded that no feasible likelihood exists of failing the containment.

- Early containment failure would be caused by drywell liner melt-through in a wet cavity in Mark I containments (e.g., Peach Bottom). Through a detailed assessment of the issue, the research concluded that, in the presence of water, the probability of early containment failure by melt-attack of the liner is so low as to be considered physically unreasonable [30].

At the start of the SOARCA project, a panel of experts reviewed the proposed modeling approach for SOARCA analyses during a public meeting sponsored by the NRC on August 21–22, 2006, in Albuquerque, NM. The panel examined the best modeling practices for the application of MELCOR to realistically evaluate accident progression and source term. The panel also reviewed a set of code enhancements and considered the SOARCA project in general.

4.3.3 Radionuclide Modeling

The radionuclide modeling was updated in the Peach Bottom and Surry models to apply a more mechanistic radionuclide release model (i.e., the ORNL-Booth model [31]) based on assessments of recent radionuclide release tests. These assessments identified an alternative set of Booth diffusion parameters recommended by ORNL (ORNL-Booth) [32] that produced significantly improved release signatures for cesium and other fission product groups. Some adjustments to the scaling factors in the ORNL-Booth model were made for selected fission product groups including uranium dioxide (UO₂), molybdenum (Mo), and ruthenium (Ru) to gain better comparisons with FPT-1 data [33]. The adjusted model, referred to as “Modified ORNL-Booth,” was subsequently compared to original ORNL VI fission product release experiments and to more recently performed VERCORS tests [34], and the comparisons were as favorable or better than the original CORSOR-M MELCOR default release model. These modified ORNL-Booth parameters were introduced into the MELCOR code as new defaults for the SOARCA project.

Although the analysis of the FPT-1 test with the ORNL-Booth parameters obtained significant improvements in release behavior, some additional modification to the MELCOR release model was pursued. Evidence from the Phebus experiments increasingly indicates that the dominant chemical form of released Cs is that of Cs₂MoO₄. This is based on deposition patterns in the Phebus experiment, where Cs is judged to be in aerosol form at 700 degrees Celsius, which explains deposits in the hot upper plenum of the Phebus test section and deposition patterns in the cooler steam generator tubes. In recognition of response, a Cs₂MoO₄ radionuclide class was defined with the vapor pressure Cs₂MoO₄ and the release coefficients developed for Cs. The Mo vapor pressure is so exceedingly low that the net release is limited by the vapor pressure transport term. Because there is significantly more Mo than Cs in the radionuclide inventory, only a portion of the Mo was added to the new Cs₂MoO₄ radionuclide class.

There are 69 isotopes in the treatment of consequences considered in the MACCS2 analysis, as described in NUREG/CR-7110, Volume 1. These isotopes are grouped into a set of nine chemical classes in the MELCOR analyses that generated the source terms used in the SOARCA analyses. Since release fractions are calculated by MELCOR at the level of chemical classes, it is reasonable and useful to examine how these same chemical classes influence the evaluation of risk. Volumes 1 and 2 of NUREG/CR-7110 discuss the importance of chemical classes.

The radionuclide input was reconfigured to (1) represent the dominant form of Cs as Cs_2MoO_4 , (2) represent the dominant form of iodine (I) as CsI, and (3) represent the gap inventories consistent with the NUREG-1465 recommendations [14]. The MELCOR radionuclide transport, deposition, condensation and evaporation, and scrubbing models were all activated. The model for chemisorption of Cs to stainless steel was activated. In addition, the hygroscopic coupling of the steam or fog condensation or evaporation thermal-hydraulic solutions to the airborne aerosol size and mass was also activated [31].

4.3.4 Radionuclide Inventory

One important input to MELCOR is the initial mass of the radionuclides in the fuel and their associated decay heat [31]. These values are important to the timing of initial core damage and the location and concentration of the radionuclides in the fuel. The radioisotopes in a nuclear reactor come from three primary sources: (1) fission products, which are the result of fissions in either fissile or fissionable material in the reactor core, (2) actinides, which are the product of neutron capture in the initial heavy metal isotopes in the fuel, and (3) radioactive decay of these fission products and actinides. Integrated computer models such as the TRITON sequence in SCALE exist to capture all of these interrelated physical processes, but they are intended primarily as reactor physics tools [35]. As such, their standard output does not provide the type of information needed for SOARCA. Therefore, this report describes a method for deriving the needed information. It is important to note that no changes to the physics codes were needed. The method described here merely extracts additional output from the TRITON sequence and combines it in a way that makes it useful for the SOARCA project.

4.3.4.1 Methods

Reactor physics codes implicitly account for both of the physical parameters of interest for SOARCA (i.e., decay heat power and radionuclide inventories), but they do not provide a mechanism to easily extract and combine these results. This section will describe the tools used to calculate the radioisotopic inventory and a new code developed to properly combine these results for use in the SOARCA calculations. The results were combined in a manner so as to capture actual plant operating data.

The TRITON sequence from SCALE 5.1 was used to develop input data for MELCOR. TRITON allows detailed two-dimensional calculations of reactor fuel, including the ability to deplete fuel to a user-defined level of accuracy. TRITON accurately models curvilinear surfaces such as cylindrical fuel rods and allows the fuel to be burned down to the subpin-cell level. There is no requirement to perform any homogenization of the two-dimensional geometry. TRITON allows for accurate depletion of highly self-shielded fuel such as poison pins. For more information, refer to the SCALE documentation [36].

The BLEND3 code was developed from previous work performed by ORNL, and its capabilities were extended for this study. BLEND3 uses the reactor-specific fuel loading from three different cycles, the nodal exposure, and the assembly-specific power data from the licensee to derive node-averaged radioisotopic inventories. TRITON uses generic fuel assembly data and ties them to specific reactor operating conditions. Then, BLEND3 performs the following tasks. First, for a given node, BLEND3 identifies which specific power ORIGEN output files are

assigned to the specified input power. Second, for three different cycles of fuel, BLEND3 interpolates a radioisotopic inventory from the relevant ORIGEN output files. Finally, using the input volume fractions for the three different cycles of fuel, BLEND3 creates a new, volumetrically averaged ORIGEN output file for the node for the specified input conditions.

The PRISM module from SCALE 5.1 was then used to drive ORIGEN decay calculations using the newly created averaged ORIGEN output files as input. PRISM is a SCALE utility module that allows the user to automate the execution of a series of SCALE calculations.

4.3.4.2 Peach Bottom Model

The Peach Bottom model is based on the Global Nuclear Fuel (GNF) 10×10 (GE-14C) fuel assembly. The GNF 10×10 is representative of a limiting fuel type actually being used in commercial BWRs. Figure 7 illustrates the GNF 10×10 model. The axial nodalization of the core is designed, in part, to account for changes in material composition and mass along the axial length of a typical fuel assembly. For example, some BWR fuel assembly designs (modern 10×10 assemblies, for example) incorporate fuel rods of different lengths within a single assembly. As a result, the amount of UO₂ and other constituents can differ at the top and bottom of an assembly. Discrete locations of fuel rod spacers along the axial height of an assembly also affect local Zircaloy mass. The distribution of material mass within the axial nodalization of the core takes these variations into account.

At nine different specific power histories, 27 different TRITON runs were performed to model three different cycles of fuel. The specific power histories ranged from 2 megawatt-days per metric ton of uranium (MWd/MTU) to 45 MWd/MTU to cover all expected BWR operational conditions. For times before the cycle of interest, an average specific power of 25.5 MWd/MTU was used. For example, for second cycle fuel, the fuel was burned for its first cycle using 25.5 MWd/MTU, allowed to decay for an assumed 30-day refueling outage, and then nine different TRITON calculations were performed with specific powers ranging from 2 to 45 MWd/MTU). The BLEND3 code was then applied to each of the 50 nodes in the MELCOR model using the average specific powers and volume fractions. Once new libraries for each of the 50 nodes in the model were generated, the final step in the procedure was to deplete each node for 48 hours. The decay heats, masses, and specific activities as a function of time were processed and applied as input data to MELCOR to define decay heat and the radionuclide inventory. The SOARCA application, in keeping with the intent of using best estimate approaches, based the Peach Bottom fuel analysis of decay power and radionuclide inventories on the assumption that the accident occurs at a point midway in a recent fuel cycle.




Figure 7 Schematic of modeling detail for BWR GNF 10×10 assembly

4.3.4.3 *Surry Model*

Previously, detailed input was developed for Surry in a separate NRC program investigating the source term from high-burnup uranium fuel. This study used the same methodology as the Peach Bottom model (Section 4.3.4.2) but extended the burn-up of the lead assembly to the licensing limit (i.e., above current best-estimate practices). Based on comparisons to the Peach Bottom decay heat, the best-estimate, midcycle decay power for a recent Surry fuel cycle is expected to be about 17–18 percent lower than that used in the SOARCA MELCOR analyses for Surry.

4.3.4.4 *Evaluation of the Results*

Very few measurements of decay heat exist, and those that do are not directly relevant to this study. Therefore, the discussion of the decay heat predictions will be limited to a comparison to previously published work. RG 3.54, “Spent Fuel Heat Generation in an Independent Spent Fuel Installation” [37] summarizes a source of decay heat predictions, and results from RG 3.54 will be used to assess the predictions in the current study. Decay heat for two decay times will be used as a check on the consistency of the results presented in this study. By interpolation of tables in RG 3.54 for a specific power of 27 MW/MTU, decay powers at 1 and 2 years following shutdown of 9.3 W/kgU and 5.1 W/kgU, respectively, are calculated. Using the results from the Peach Bottom calculations, the corresponding decay powers are 8.92 W/kgU and 4.734 W/kgU. The maximum difference between results is about 8 percent, which is considered acceptable

given the best estimate nature of the SOARCA study compared to the methods used to generate the tables in RG 3.54.

A quantitative discussion of the radioisotopic predictions presented in this study would be of limited use, given the cycle-specific nature of this work. However, it is beneficial to discuss the relevant SCALE assessment. Specifically, the TRITON module has been assessed by M.D. DeHart and S.M. Bowman [38], S.M. Bowman and D.F. Gill [39], and I. Germina and I.C. Gauld [40]. These assessment reports use data from Calvert Cliffs, Obrigheim, San Onofre, and Trino Vercelles PWRs. The third report [40] summarized comparisons to decay heat measurements from four different BWR assemblies.

5.0 OFFSITE CONSEQUENCE ANALYSES

MACCS2 [41] is a consequence analysis code for evaluating the impacts of atmospheric releases of radioactive aerosols and vapors on human health and the environment. It includes all of the relevant dose pathways: cloudshine, inhalation, groundshine, and ingestion. Because it is primarily a PRA tool, it accounts for the uncertainty in weather that is inherent to an accident that could occur at any point in the future. WinMACCS is a user-friendly front end to MACCS2 that facilitates selection of input parameters and sampling of uncertain input parameters, and it performs postprocessing of results. The final SOARCA calculations use WinMACCS Version 3.6. MACCS2 is still the computational engine underlying WinMACCS.

The SOARCA offsite consequence predictions used MACCS2 Version 2.5. This version includes a number of improvements to the original MACCS2 code, which can be categorized as follows:

- atmospheric transport and dispersion modeling improvements (e.g., morning and afternoon mixing heights, alternative Briggs plume rise model, and alternative long-range plume spreading model)
- capability to describe wind directions in 64 compass directions (instead of 16)
- increased limits on several input parameters (e.g., a limit of 200 plume segments instead of the previous limit of 4)
- up to 20 emergency-phase cohorts (instead of the original limit of 3) to describe variations in emergency response by segments of the population
- enhancements in the treatment of evacuation speed and direction to better reflect the spatial and temporal response of individual cohorts
- capability to run on a cluster of computers instead of an individual processor
- addition of several new options for LCF dose response (i.e., user-input yearly truncation value, user-input yearly truncation value with a lifetime restriction, and a piece-wise linear model)

An expert panel reviewed the MACCS2 code and modeling choices in August 2006, before specific work on Surry and Peach Bottom began. This expert panel review and the NRC staff recommendations influenced much of the development undertaken specifically to support the SOARCA work [42].

Subsequent parts of this chapter describe specific aspects of the consequence modeling in SOARCA that depart from previous studies such as NUREG-1150 [2].

5.1 Weather Sampling

The weather sampling strategy adopted for SOARCA uses the nonuniform weather-binning approach in MACCS2. This approach, which allows the user to specify a different number of random samples to be chosen from each bin, has been available since MACCS2 was first released [41] but was not commonly used in the past. Weather binning is an approach used in MACCS2 to categorize similar sets of weather data based on windspeed, stability class, and the occurrence of precipitation. The SOARCA project chose this sampling strategy to improve the statistical representation of the weather, as is further discussed below.

The standard way of defining weather bins originated in the NUREG-1150 [2] analyses. A set of 16 weather bins differentiates stability classes and wind speeds. An additional 20 weather bins include all weather trials in which rain occurs before the initial plume segment travels a distance of 32 kilometers (20 miles). The bins differentiate rain intensity and the distance the plume travels before rain begins. The parameters used to define the rain bins are the same as those used in NUREG-1150 and documented in the MACCS2 User's Manual [41]. Because the strategy provides for weighting the particular trials chosen (based on the number of samples in the bin and the number of samples requested), the particular choice of a binning strategy is not important (provided a sufficient number of samples is chosen). However, a well-chosen binning strategy will reduce the number of samples required for adequate statistical precision. The binning strategy used in NUREG-1150 and for SOARCA ensures that the rain cases, which are only a fraction of the full year's data, are adequately sampled, with the weighting factors used in the code accounting for the prevalence in the weather record.

For the nonuniform weather sampling strategy approach for SOARCA, the number of trials selected from each bin is the maximum of 12 trials and 10 percent of the number of trials in the bin. Some bins contain fewer than 12 trials. In those cases, all of the trials within the bin are used for sampling. This strategy results in roughly 1,000 weather trials for both Peach Bottom and Surry.

Previous calculations, such as NUREG-1150, used about 125 weather trials, including an additional strategy—rotation—to account for the probability that the wind might have been blowing in a different direction when the release began. This strategy uses wind-rose data constructed from the annual weather file to determine the probability that the wind might have been in any of the compass directions. The strategy used at the time of NUREG-1150 leveraged the weather data to get $125 \times 16 = 1,750$ results for the computational price of 125, but at a cost that the individual results are not truly independent. For the strategy chosen here, the trials are independent.

MACCS2 does not allow the use of rotation in concert with the network evacuation option; therefore, rotation was not an option for SOARCA. The strategy adopted for SOARCA was a compromise between obtaining adequate statistical significance and keeping central processing unit time at a reasonable level.

5.2 Weather Data

The SOARCA project used 1 year of hourly meteorological data for each site (8,760 data points

per site for each meteorological parameter). This was primarily accomplished through a cooperative effort, with the licensee using onsite meteorological tower observations. Each licensee provided 2 years of weather data. The licensees measured and reported hourly precipitation directly. Temperature measurements at two elevations on the site meteorological towers provided stability class data. The project based the specific year of data chosen for each reactor on data recovery (greater than 99 percent being desirable) and proximity to the target year for SOARCA, which is 2005. Different trends (e.g., wind-rose pattern and hours of precipitation) between the years were estimated to have a relatively minor (less than 25 percent) effect on the final results. The next subsection discusses the specific details of the weather data.

For the weather record years and the particular data used in SOARCA, the recovery of data was in excess of 90 percent. The missing data were bridged over using the hourly records before and after by employing “Procedures for Substituting Values for Missing NWS [National Weather Service] Meteorological Data for Use in Regulatory Air Quality Models,” dated July 7, 1992 [43]. The meteorological data parameters were formatted for the MACCS2 computer code.

The NRC staff used the methodology described in NUREG-0917, “Nuclear Regulatory Commission Staff Computer Programs for Use with Meteorological Data,” issued July 1982 [44] to perform quality assurance evaluations of all meteorological data presented. Further review used computer spreadsheets. The NRC staff ensured a joint data recovery rate in the 90th percentile, which is in accordance with RG 1.23, “Meteorological Monitoring Programs for Nuclear Power Plants,” Revision 1, issued March 2007 [45] for the wind speed, wind direction, and atmospheric stability parameters. In addition, it evaluated atmospheric stability to determine if the time of occurrence and duration of reported stability conditions were generally consistent with expected meteorological conditions (e.g., neutral and slightly stable conditions predominated during the year with stable and neutral conditions occurring at night and unstable and neutral conditions occurring during the day). The mixing height data came from the U.S. Environmental Protection Agency’s (EPA’s) SCRAM database⁴ (using data from the years 1984–1992). Data needed for MACCS2 includes 10-meter wind speed, 10-meter wind direction in 64 compass directions, stability class (using the Pasquill-Gifford scale and representative values of 1–6 for stability classes A–F/G (see Section 5.2.1)), hourly precipitation, and diurnal (morning and afternoon) seasonal mixing heights.

All of the SOARCA consequence analyses included boundary weather, but it was imposed beyond the outer boundary (50 miles or ~80.5 kilometers) for which results are reported. Thus, the choice of boundary weather had no influence on the consequence results that are reported. Appendices in the companion Peach Bottom and Surry reports contain the specific parameters chosen to describe the boundary weather.

5.2.1 Summary of Weather Data

Table 2 presents a summary of the meteorological statistical data and shows that the annual average ground-level wind speeds were generally low, ranging from 2.02 to 2.27 meters per second (m/s) at Surry and 2.12 to 2.17 m/s at Peach Bottom. The atmospheric stability

⁴ The EPA SCRAM Web site is <http://www.epa.gov/scram001/mixingheightdata.htm>.

frequencies were consistent with expected meteorological conditions. The neutral and slightly stable conditions predominated during the year, with stable and neutral conditions occurring at night and unstable and neutral conditions occurring during the day.

Figure 8 and Figure 9 show the wind direction (direction the wind blows toward) and atmospheric stability (unstable,⁵ neutral,⁶ and stable⁷) data for the years that were actually used in the consequence analyses (i.e., 2006 for Peach Bottom and 2004 for Surry). The MACCS2 calculations used the Pasquill-Gifford stability classes. These classes were only parsed into unstable (A–C), neutral (D), and stable (E–F) conditions for Figure 8 and Figure 9 for comparisons with expected weather patterns.

Table 2 Statistical Summary of Raw Meteorological Data for SOARCA Nuclear Sites

Parameter	Peach Bottom		Surry	
	Year 2005	Year 2006	Year 2001	Year 2004 [†]
Average Wind Speed (m/s)	2.17	2.12	2.02	2.27
Yearly Precipitation (hr)	588 (6.7%)	593 (6.8%)	388 (4.4%)	521 (5.9%)
Atmospheric Stability (%)	Unstable	21.43	7.09	3.94
	Neutral	63.97	69.67	77.59
	Stable	14.60	17.10	18.47
Joint Data Recovery (%)	97.53	99.25	99.58	99.24

[†] Year 2004, used in the Surry meteorological analysis, is a leap year (8,784 total hourly data points versus 8,760 hourly data points for a regular annual period).




Figure 8 Peach Bottom—Year 2006—wind-rose and atmospheric stability chart

⁵ This corresponds to Pasquill-Gifford stability classes A, B, and C.

⁶ This corresponds to Pasquill-Gifford stability class D.

⁷ This corresponds to Pasquill-Gifford stability classes E, F, and G.




Figure 9 Surry—Year 2004—wind-rose and atmospheric stability chart

5.3 Emergency Response Modeling

An objective of the SOARCA project was to model emergency response in a more detailed and realistic manner using site-specific emergency planning information. The analysis included modeling of the timing of onsite and offsite decisions and implementation of protective actions applied to multiple population segments (called cohorts). Advances in consequence modeling—specifically the development of WinMACCS—made it easier to integrate protective action decision timing and response of the public into the consequence analysis, resulting in an evolutionary advancement over previous studies.

Emergency response programs for NPPs are designed to protect public health and safety in the unlikely event of a radiological accident. These emergency response programs are developed, tested, and evaluated and are in place as an element of the NRC’s defense in depth policy. Detailed plans for onsite and offsite response are approved by the NRC and the Federal Emergency Management Agency respectively.

Offsite response organization emergency plans are required to include detailed evacuation plans for the 10-mile emergency planning zone (EPZ) [46]. Site-specific information was obtained from ORO emergency response plans to support development of timelines for protective action implementation. Site specific planning elements were modeled, for example whether evacuation of schools follows declaration of a site area emergency or a general emergency. The SOARCA project integrated response plan elements and a best estimate of protective action decision timing that was based upon actual biennial exercise history. Specific population cohorts were identified and their evacuation timing modeled. This detailed modeling was undertaken for the SOARCA project to improve the overall fidelity of the consequence analyses.

Figure Figure 10 shows the 10- and 20-mile radial distances around the Peach Bottom site.




Figure 10 10- and 20-mile radial distances around the Peach Bottom site

The SOARCA project assessed the ORO protective action decision-making process as detailed in emergency plans and developed a best estimate of implementation of those decisions by ORO populations within the 10-mile EPZs. The project also assessed possible variations of emergency response for the two sites studied, including evacuation and sheltering of population groups beyond the EPZ to a distance of 20 miles from the plants. As discussed in NUREG-0654/FEMA-REP-1, Revision 1, “Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants,” issued November 1980 [46], detailed planning within 10 miles would provide a substantial base for expansion of response efforts, should this prove necessary. Any response beyond the EPZ was expected to be limited to areas where dose projections indicate protective actions are necessary. State or county response agencies would inform the OROs of these projections in areas beyond the EPZ. Protective actions would be implemented in these areas beyond the EPZ in an ad hoc manner, which means that such actions would follow the existing local all-hazards emergency response plans.

For dose calculation purposes, evacuees are treated in the model as traveling to a point 30 miles from the site. This treatment is consistent with previous calculations (e.g., NUREG-1150) where evacuees moved 10 miles beyond the evacuation zone, at which point they were assumed to receive no further dose. Previous analyses chose the evacuation zone to represent the EPZ and did not consider shadow evacuation. The SOARCA analyses consider a shadow evacuation beyond the EPZ out to a distance of 20 miles from the plant. Thus, evacuating to a 30-mile radius results in the outermost evacuees traveling 10 miles beyond their initial location.

A shadow evacuation is the voluntary (self-initiated) evacuation of members of the public from areas that are not under official evacuation orders and typically occurs when a large scale

evacuation is ordered. Shadow evacuations are often reported and observed, but there is little quantitative data available regarding these evacuations. SOARCA models a shadow evacuation of 20 percent of the public residing in the 10- to 20-mile area beyond the EPZ [48] based on data from a national telephone survey of residents of EPZs. In the survey, about 20 percent of people who had been previously asked to evacuate had also evacuated for situations in which they were asked not to evacuate (e.g., shadow evacuation). The size of the shadow evacuation is greatly affected by the emergency messaging used by the local authorities and could be larger or smaller. A shadow evacuation can delay the evacuation of people closer to the plant increasing their risk of exposure. SOARCA modeled shadow evacuations to improve realism.

The initiating event for many of the accident scenarios considered by SOARCA is a large earthquake close to the plant site. For this event, it was assumed that severe damage would be generally localized (e.g., 30–40 kilometers from the site). The SOARCA team considered the effects of such an earthquake on emergency response capabilities onsite and offsite as well as the evacuation speed of the public. However, considerable uncertainty exists in characterizing the impacts of an earthquake, and the SOARCA project therefore addressed the earthquake effects in a separate analysis. A consequence analysis was performed for the accident sequences for each site, and a single seismic analysis was performed for the more challenging accident postulated for each site.

The study performed a limited and conservative seismic analysis of local infrastructure, which may affect evacuation activities for each site. The seismic analysis indicated that long-span bridges, typically bridges crossing the river and interstate roadway crossings (at Surry), close to each site are unlikely to survive the earthquake and are assumed to be impassable throughout the emergency response. The study also assumed that some smaller bridges and road crossings would fail, as well as some roadways where underlying soils could slide off into adjacent waterways. Residential and commercial structures would be damaged but generally would survive the earthquake. The local electrical grid is assumed to be out of service through automatic shutdown or equipment failures; however, it is not expected that power would be out within the entire 10-mile (314-square-mile) EPZ. A limited backup power system is in place for the sirens at Peach Bottom, allowing some sirens to operate. Backup power is available for the sirens at Surry and those sirens are assumed to operate. OROs would perform route alerting to notify the population of the need to take protective actions in areas where sirens are not functional. Route alerting consists of emergency responders driving through neighborhoods using loudspeakers or going door to door to notify residents of the emergency and is a routine and effective method of informing the public [47]. Response parameters that may be affected by an earthquake (e.g., mobilization of the public, evacuation speed, shielding) were adjusted to reflect the potential impact.

5.3.1 Base Case Analyses of Emergency Response

The SOARCA project used WinMACCS to develop and model a case for each accident sequence that resulted in a radioactive release to the environment that would invoke protective actions. Initial protective actions at Surry, for which Supplement 3 to NUREG-0654/FEMA-REP-1, Revision 1 [63] provides guidance, would likely include evacuation of the 2-mile zone around the NPP and of a 5-mile downwind keyhole and would expand to 10 miles, if necessary, based on dose projections. Pennsylvania implements a 360-degree, 10-mile evacuation. For

accommodates speed and direction variations for each evacuating cohort. To develop the input, a review of the evacuation routes determined the likely directions in which evacuees would travel. The evacuation area was mapped onto a grid with 64 compass sectors and 15 radii that formed the basis for the network evacuation model. All accident sequences at each site had the same evacuation network. Response timing and evacuation speed parameters were created specifically for each accident sequence. A newly developed option in WinMACCS and MACCS2 allowed an adjustment within grid elements to increase or decrease speeds based on expected traffic congestion. In addition, for cases where the hourly meteorological data included precipitation, the speeds of all evacuating cohorts were reduced. For dose modeling purposes, all evacuees were assumed to travel to a point 30 miles from the site. This distance accounts for the fact that the assembly sites are at some distance from the plant. Whether doses are actually received by the evacuees during any part of their travel is a complicated function of the direction of travel and the times and the directions of the plumes as they are released from the plant. Each plume disperses in a straight line in its own downwind direction.

5.3.2 Sensitivity Analyses of Emergency Response

After completion of the base case analysis, the following three variations were conducted as sensitivity analyses:

- (1) Evacuation to a distance of 16 miles from the plant. This analysis assessed the complete evacuation of 16 miles around the plant. It assumed the members of the public in the 16- to 20-mile zone would shelter.
- (2) Evacuation to a distance of 20 miles from the plant. This analysis developed an ETE for the 20-mile area to provide realistic modeling parameters for the movement of the public.
- (3) Delay in implementing protective actions. This analysis included an assumption that there could be a 30-minute delay in implementing protective actions by the public. This sensitivity study assumes that a delay could occur in notification to offsite authorities, notification from offsite authorities to the public, receipt of the warning by the public, or for other reasons. The analysis assumed that cohorts take 30 minutes longer to start implementing protective actions than in the base case analysis.

The first two sensitivity studies used the Oak Ridge Evacuation Modeling System to create additional ETEs for each site to establish speeds and mobilization parameters for movement of the public residing between 10 and 20 miles. This system developed ETEs for the general public within the 10- to 20-mile zone.

The development of the parameters for the sensitivity analyses showed that, for the larger evacuation areas, the travel speeds were typically slower than in the baseline analyses. This was because of the additional vehicle load on the roadway network in the more populated areas, such as Lancaster, PA. For the third sensitivity analysis, which assessed a delay in implementation, the speeds remained unchanged. The effects of these variations in emergency response on latent cancer fatality risk calculations are discussed further in Section 6.5.

5.4 Source Term Evaluation

A source term evaluation for each of the accident scenarios used MELMACCS [49], which reads a MELCOR plot file and extracts information useful for source term definition for MACCS2. MELMACCS requires the selection of a number of user options. The following paragraphs describe the specific choices made for SOARCA.

The first set of choices is related to the chemical groups or classes to be included in the analysis. Here, the analyses included the standard set of fission product groups (i.e., the xenon, cesium, barium, iodine, tellurium, ruthenium, molybdenum, cerium, and lanthanum groups). A related quantity defining the burnup to be assumed when calculating the fission product inventory depends on the plant type. In an effort to provide a best estimate fission product inventory for Peach Bottom, SOARCA used an ORIGEN calculation to estimate the inventory at midcycle for which peak rod burnup is estimated to be 49 MWd/kg. MELMACCS used these data to specify the inventory for MACCS2, and the MACCS2 input is, therefore, consistent with the MELCOR calculation. Surry used a previously available fission product inventory based on the regulatory limit of burnup (65 MWd/kg for the peak fuel rod). This inventory is conservative.

A set of parameters define the ground elevation (grade) in the MELCOR reference frame, the height of the building from which release occurs, and the initial plume dimensions. The SOARCA MELCOR analyses use reactor shutdown as the reference time, so the time of accident initiation is always set to zero in the MELMACCS input.

MELMACCS calculates aerosol deposition velocities based on the geometric mean diameter of each aerosol bin as defined in the MELCOR analysis. Expert elicitation data form the basis for the deposition velocities, using the median value of the combined distribution from the experts [50]. This report applies the MELMACCS equation to determine the deposition velocities. The equation accounts for the dependence of deposition velocity on surface roughness, wind speed, and aerodynamic particle diameter. MELMACCS also accounts for independent particle size distributions for each of the chemical groups reported by MELCOR. Thus, the aerosol size distribution and the resulting deposition velocity distribution are generally different for each chemical group. This is accounted for by assigning different mass fraction distributions across the aerosol bins for each chemical group in the MACCS2 input.

Typical values for surface roughness and mean wind speed, 0.1 m and 2.2 m/s, respectively, are used as inputs in MELMACCS. This value of surface roughness is commonly used for consequence analyses in the United States and is consistent with the value in NUREG-1150 [2]. However, a value that is more representative of the terrain at the two sites is also investigated as a sensitivity study and the results documented in the reports for the two sites. The specific weather files determined the mean wind speeds used in the consequence analyses. Table 3 displays the deposition velocities in SOARCA analyses for both Peach Bottom and Surry.

Table 3 Deposition Velocities Used in the SOARCA Analyses

Bin #	Median Diameter (µm)	Deposition Velocity (m/s)
1	0.15	5.35×10^{-4}
2	0.29	4.91×10^{-4}
3	0.53	6.43×10^{-4}
4	0.99	1.08×10^{-3}
5	1.8	2.12×10^{-3}
6	3.4	4.34×10^{-3}
7	6.4	8.37×10^{-3}
8	11.9	1.37×10^{-2}
9	22.1	1.70×10^{-2}
10	41.2	1.70×10^{-2}

MELCOR results include the relative quantities of aerosols contained in each size bin listed in the table. MACCS2 uses this information, plus the deposition velocities in the table, to determine the rate of depletion of aerosols from the plume. Generally, the larger aerosols deposit more quickly and so are depleted more rapidly from the plume. The peak in the aerosol size distribution is usually a few micrometers (µm), which corresponds to a deposition velocity of a few millimeters per second.

Finally, significant releases were broken up into 1-hour plume segments. MACCS2 allows plume segments to travel in only one compass direction based on weather data. More plume segments can better represent plume transport and dispersion caused by possible changes in the weather (such as the wind direction) during the release. Longer plume segments were sometimes used for trivial releases, such as those where the segment content is a very small fraction of the total release. Finer resolution of these releases was not necessary to maintain the fidelity of the calculation. The MELCOR analyses provided the amount of each chemical element group in each aerosol bin for each plume segment.

5.5 Site-Specific Parameters

The SOARCA project took weather data for each site from meteorological archives provided by each plant (see Section 5.2). It then processed the raw data into 64 compass sectors to use the angular resolution capabilities in WinMACCS 3.6 and MACCS2 2.5.

SECPOP2000 [51] initially created site files for 16 compass sectors, which is the only angular resolution supported by that code. WinMACCS then interpolated these site files onto the 64-compass-sector grid used for the consequence analyses. The granularity of the population data for 16 compass directions is maintained for the 64 compass directions data. The SECP2000 population data were also scaled by a factor of 1.0533 to account for the average U.S. population growth between the years 2000 and 2005. 2010 U.S. Census data was not used because most calculations were already completed by the time it was released. Changes in

population over the last decade are not expected to have a significant impact on any of the calculated individual latent cancer fatality risks reported in Chapter 6.

Consequence analyses used the standard approach of evaluating accidents in the following two phases:

- (1) Emergency phase. This phase begins with the initiating event and continues for about 1 week. The release from the plant and plume transport through the MACCS2 grid occurs during this phase. This phase also includes emergency response (i.e., evacuation and relocation of the population to reduce exposures and doses). The project chose the length of this phase to ensure that all plumes can exit the calculational mesh during the period, because certain assumptions about doses (e.g., that all late phase doses are small enough to warrant applying the dose and dose rate effectiveness factor) could be questionable if the early phase was made too short.
- (2) Long-term phase. This phase is the period following the emergency phase and continues for 50 years. Three actions take place during the long-term phase. Land that is contaminated above the level that is allowable for habitation is decontaminated and potentially interdicted for an additional period. During this time, the land is not available for human habitation. Land that cannot be restored to habitability is condemned, in which case the residents do not return during the long-term phase.

Both sites needed a choice for surface roughness, which affects both vertical dispersion and deposition velocities. A generic value of 10 centimeters for surface roughness was selected for the consequence analyses, just as it had been in NUREG-1150 and most other previous studies. However, sensitivity studies also evaluated the effect of site-specific surface roughness. The reports for each of the sites document these sensitivity studies.

The project evaluated shielding factors applied to evacuation, normal activity, and sheltering for each relevant dose pathway (i.e., inhalation, deposition onto skin, cloudshine, and groundshine) for each site based on values used in NUREG-1150 [2] and NUREG-6953, Volume 1, "Review of NUREG-0654, Supplement 3, 'Criteria for Protective Action Recommendations for Severe Accidents,'" issued December 2007 [52]. A review of the discussion of shielding in the NUREG-1150 documentation suggests that the factors the authors considered were adequate for SOARCA purposes. One departure from the NUREG-1150 values is for normal activity. The SOARCA project reevaluated each of the normal activity values, assuming that the average person spends 19 percent of the day outdoors and 81 percent of the day indoors [63]. It evaluated the value for each of the pathways as a linear combination of 19 percent of the value for evacuation and 81 percent of the value for sheltering.

For dose calculations, the project modeled evacuees as traveling to a distance of 30 miles from the plant. In addition, it relocated the nonevacuating cohort and the public beyond the EPZ from areas where the projected dose during the emergency phase exceeded a set of two upper bounds. These bounds were based on dose levels published by EPA, which are 1 to 5 rem. SOARCA used the upper limit of this range (5 rem) to trigger hot-spot relocation for both Surry and Peach Bottom and used the lower limit of this range (1 rem) to trigger normal relocation for Surry,

while it used 0.5 rem for Peach Bottom, to be consistent with the Pennsylvania habitability criterion.

MACCS2 performs hot-spot relocation first and normal relocation second. The choices of times associated with normal and hot-spot relocation depended on the specific accident scenario, because they are based on plume arrival. The scenario-specific time for completion of the relocation includes the time for response personnel to identify the involved area, for them to notify the residents within that area that relocation is necessary, and for the residents to remove themselves from the area. Because the timing of relocation is keyed to plume arrival, there is always a period of exposure before initiation of relocation. Volumes 1 and 2 of NUREG/CR-7110, discuss the specific choices for the parameters controlling the exposure period.

Site-specific values determine long-term habitability. Most States adhere to EPA guidelines that allow a dose of 2 rem in the first year and 500 millirem (mrem) per year thereafter. The EPA recommendation that has traditionally been implemented in MACCS2 is 4 rem over 5 years (2 rem in the first year + 4 years \times 0.5 rem) of exposure, and this study adopts that convention. MACCS2 cannot explicitly use the EPA recommendation because MACCS2 accepts only one dose and one time period. Some States, like Pennsylvania, have a stricter habitability criterion (i.e., 0.5 rem/year beginning in the first year). Thus, the habitability or return criterion is site specific, as Volumes 1 and 2 of NUREG/CR-7110 discuss further.

Some States have distributed potassium iodide (KI) tablets to people who live near commercial NPPs. KI has been distributed within the EPZ at the Peach Bottom and Surry sites. The purpose of the KI is to saturate the thyroid gland with iodine so that further uptake of iodine by the thyroid is diminished. If taken at the right time, KI can nearly eliminate doses to the thyroid gland from inhaled radioiodine. Ingestion of KI is modeled for half of the residents near plants where KI has been distributed by the State or local government. A further assumption is that most residents do not take KI at the optimal time (from shortly before to immediately after plume arrival), so the efficacy is only 70 percent (i.e., the thyroid dose from inhaled radioiodine is reduced by 70 percent).

Other site-specific parameters include farmland and nonfarmland values. These values are also scaled from NUREG-1150 values using the Consumer Price Index as the basis for price escalation. A scaling factor of 1.09 accounts for inflation between the years 2002 and 2005. Land values influence the decision to decontaminate, interdict, or condemn land. If the assessed cost of decontamination is higher than the land value, the assumption is the land would be condemned. Because the public would not be allowed to return to condemned land and, therefore, no dose would be received, the land values did have a second-order effect on the predicted long-term health consequences.

5.6 Non-Site-Specific Parameters

The SOARCA analyses do not treat the ingestion of contaminated food and water. The reasoning is that abundant supplies of food and water are available in the United States and can be distributed to areas affected by a reactor accident.

Much of the non-site-specific data used for consequence analysis in SOARCA are taken from reports that document a joint NRC/Commission of the European Communities expert elicitation study [50]. These data include atmospheric dispersion parameters, dry deposition velocities, wet deposition parameters, and acute health-effect parameters. In all cases, the point-value consequence analyses in SOARCA use median values extracted from the elicitation study [50].

The SOARCA analyses based the dose conversion factors on Federal Guidance Report (FGR) -13, "Cancer Risk Coefficients for Environmental Exposure to Radionuclides: Updates and Supplements," CD Supplement, Revision 1, issued April 2002 [53]. This guidance report also recommended changes to the biological effectiveness factors (BEFs) for alpha radiation for two of the organs used to estimate latent cancer health effects, to be consistent with the evaluation of risk factors for cancers associated with those organs. The two organs are bone marrow and breast; for these organs, the BEFs for alpha radiation were changed from the standard value of 20 to 1 and 10, respectively. Doses to these organs are used to evaluate occurrences of leukemia and breast cancer, respectively. The choice of BEFs for these tissues is dictated by EPA 402-R-93-076, "Estimating Radiogenic Cancer Risks," issued June 1994 [54].

A February 2009 ORNL memo, "Risk Coefficients for SOARCA Project" [55], also recommended using dose to the pancreas as a surrogate for dose to soft tissue to estimate residual cancers. The reason for the choice of the pancreas dose coefficient for the "residual" cancer sites is because it serves as a reasonable surrogate for the residual group for both external radiation fields and the intake of radionuclides. Because MACCS2 does not currently read the data for the pancreas from the dose conversion factor file, a workaround was created. Values of the dose coefficients for the pancreas were copied into the organ called bladder wall. Thus, residual cancers are associated with the organ called bladder wall, which actually contains data for the pancreas.

The SOARCA study applied a dose and dose rate effectiveness factor to all doses in the late phase of the offsite consequence calculation and to those doses in the early phase that were less than 20 rem to the whole body. This factor, which appears in the denominator, accounts for the fact that protracted low doses are perceived to be less effective in causing cancer than acute doses. The dose and dose rate effectiveness factor for all cancers except for the breast was 2.0, and for the breast, it was 1.0.

The January 2012 ORNL memorandum [74] also recommended risk factors for latent health effects that come from the National Research Council's Committee on the Biological Effects of Ionizing Radiations (BEIR) V report, "Health Effects of Exposure to Low Levels of Ionizing Radiation," issued 1990 [56], and are consistent with the modified dose conversion factor file described in the preceding paragraph. These risk factors include seven organ-specific cancers plus residual cancers that are not accounted for directly. In 2009, the National Research Council released the BEIR VII report, an additional study of the biological effects of ionizing radiation. No one-to-one correspondence exists between the cancers reported in BEIR VII and those in the earlier BEIR V report. Therefore, the dose coefficients of tissues of the body in FGR-13 may or may not be consistent with the BEIR VII cancer sites. Thus, the SOARCA staff decided to await EPA's review of BEIR VII and subsequent update of FGR-13 before implementing BEIR VII risk coefficients.

Values from NUREG-1150 [2] provide the basis for decontamination parameters, which consist of two levels of decontamination, just as in NUREG-1150. The cost parameters associated with decontamination are adjusted to account for inflation using the Consumer Price Index. This report does not consider costs associated with a reactor accident; however, these parameters do affect decisions on whether contaminated areas can be restored to habitability and therefore affect predicted doses and risk of health effects.

5.7 Estimating Latent Cancer Fatality Health Effects

Experts generally agree that it is difficult to characterize cancer risk because of the low statistical precision associated with relatively small numbers of excess cases at low doses. This limits the ability to estimate trends in risk. From an epidemiological standpoint, the number of LCFs attributable to radiation exposure from accidental releases from a severe accident would not be statistically detectable above the normal rate of cancer fatalities in the exposed population (i.e., the excess cancer fatalities predicted are too few to allow the detection of a statistically significant difference in the cancer fatalities expected from other causes among the same population). For example, in 2006, the World Health Organization estimated that 16,000 European cancer deaths would be attributable to radiation released from the 1986 Chernobyl NPP accident, but these predicted numbers are small relative to the several hundred million cancer cases that are expected in Europe through 2065 from other causes. Moreover, the World Health Organization concluded that “it is unlikely that the cancer burden from the largest radiological accident to date could be detected by monitoring national cancer statistics.”

New findings have been published from analyses of fractionated or chronic low-dose exposure to low, linear energy transfer radiation. In particular, these recent findings included a study of nuclear workers in 15 countries, studies of persons living in the vicinity of the Techa River in the Russian Federation who were exposed to radioactive waste discharges from the Mayak Production Association, a study of persons exposed to fallout from the Semipalatinsk nuclear test site in Kazakhstan, and studies in regions with high natural background levels of radiation. Cancer risk estimates in these studies are generally derived from the Japanese atomic bomb data. The most recent results from analyzing these data are consistent with a linear or linear-quadratic dose-response relationship of all solid cancers together and with a linear-quadratic dose-response relationship for leukemia. A linear-quadratic form for a dose model has a dependence on the square of the dose, as well as on the dose itself.

In the absence of additional information, the International Commission on Radiological Protection (ICRP), the National Academy of Sciences, and the United Nations Scientific Committee on the Effects of Atomic Radiation have each indicated that the current scientific evidence is consistent with the hypothesis that an LNT dose-response relationship exists between exposure to ionizing radiation and the development of cancer in humans.

Conversely, in “*Dose-effect relationships and estimation of the carcinogenic effects of low doses of ionizing radiation*,” dated March 30, 2005 [57], the French National Academy of Medicine advocates the following on page 1:

A linear no-threshold relationship (LNT) describes well the relation between the dose and the carcinogenic effect in this dose range (0.2 to 3 Sv) [to the whole body] where it could be tested. However, the use of this relationship to assess by extrapolation the risk of low and very low doses deserves great caution. Recent radiobiological data undermine the validity of estimations based on LNT in the range of doses lower than a few dozen mSv which leads to the questioning of the hypotheses on which LNT is implicitly based.

Although the French National Academy of Medicine raises doubts about the validity of using LNT to evaluate the carcinogenic risk of low doses (less than 100 millisieverts (mSv) (10 rem)), and particularly for very low doses (less than 10 mSv (1 rem)), it did not articulate the exact value that should be ascribed to a dose threshold.

Ultimately, MACCS2 converts external and internal exposures to individual members of the public from collective organ dose to LCFs. The LNT model raises the concern that the summation of very small exposures may inappropriately attribute LCFs to individuals receiving these exposures. Organizations such as ICRP and the Health Physics Society (HPS) consider it to be an inappropriate use of these exposures. While the National Council on Radiation Protection and Measurements (NCRP) supports the LNT model, it recommends binning exposures into ranges and considering those ranges separately. Moreover, in situations involving very small exposures to large populations, ICRP and NCRP have noted that the most likely number of excess health effects is zero when the collective dose to such populations is equivalent to the reciprocal of the risk coefficient (about 20 person-sieverts (Sv) (2,000 person-rem)). Nevertheless, issues remain related to assessing public exposure, estimating offsite consequences, and communicating these assessments to the public. Several organizations such as ICRP have addressed this issue. In its most recent recommendations (ICRP Report 103, "The 2007 Recommendations of the International Commission on Radiological Protection," approved March 2007 [58]), ICRP stated the following:

Collective effective dose is an instrument for optimization, for comparing radiological technologies and protection procedures. Collective effective dose is not intended as a tool for epidemiological studies, and it is inappropriate to use it in risk projections. This is because the assumptions implicit in the calculation of collective effective dose (e.g., when applying the LNT model) conceal large biological and statistical uncertainties. Specifically, the computation of cancer deaths based on collective effective doses involving trivial exposures to large populations is not reasonable and should be avoided. Such computations based on collective effective dose were never intended, are biologically and statistically very uncertain, presuppose a number of caveats that tend not to be repeated when estimates are quoted out of context, and are an incorrect use of this protection quantity.

Although ICRP provided qualitative guidance on situations where collective dose should not be used, it did not provide guidance on when these concepts actually are, and are not, appropriate, nor did it clearly articulate the boundaries within which the calculations are valid, as well as the dose ranges for which epidemiological and cellular or molecular data provide information on the

health effects associated with radiation exposure. ICRP did note, however, that when ranges of exposures are large, collective dose may aggregate information inappropriately and could be misleading for selecting protective actions.

The National Academy of Sciences reported the following [56]:

The magnitude of estimated risk for total cancer mortality or leukemia has not changed greatly from estimates in past reports such as Biological Effects of Ionizing Radiation (BEIR) and recent reports of the United Nations Scientific Committee on the Effects of Atomic Radiation (UNSCEAR) and ICRP. New data and analyses have reduced sampling uncertainty, but uncertainties related to estimating risk for exposure to low doses and dose rates and to transporting risks from Japanese A-bomb survivors to the U.S. population remain large.

The National Academy of Sciences goes on to conclude that “current scientific evidence is consistent with the hypothesis that there is a linear, no-threshold dose-response relationship between exposure to ionizing radiation and the development of cancer in humans.”

Many groups acknowledge the uncertainties associated with estimating risk for exposure to low radiation doses. One important question that remains is what health consequences, if any, are attributable to very low radiation exposure. In its most recent recommendations (ICRP Report 103 [58]) described above, ICRP warned that the computation of cancer deaths based on collective effective doses involving trivial exposures is not reasonable and should be avoided. However, the report did not explicitly provide a quantitative range for which exposures should not be considered. However, in its 2007 Report 104, “Scope of Radiological Protection Control Measures” [59], ICRP concludes that the radiation dose that is of no significance to individuals should be in the range of 20–100 microsieverts (μSv) (2–10 mrem) per year whole body dose. The International Atomic Energy Agency has stated that an individual dose is likely to be regarded as trivial if it is on the order of some several millirem per year.

Alternatively, HPS developed a position paper, “Radiation Risk in Perspective,” revised August 2004 [60], to specifically address quantitative estimation of health risks. This position paper concludes that quantitative estimates of risk should be limited to individuals receiving a whole body dose greater than 0.05 Sv (5 rem) in 1 year or a lifetime dose greater than 0.1 Sv (10 rem) in addition to natural background radiation. HPS also concluded that risk estimates should not be conducted below these doses. The position paper further states that low dose expressions of risk should be only qualitative, discuss a range of possible outcomes, and emphasize the inability to detect any increased health detriment.

The LNT model provides a viewpoint that is consistent with the NRC regulatory approach, and past analyses using the MACCS2 code have assumed an LNT dose-response model. The NRC is neither changing nor contemplating changing radiation protection standards and policy as a result of an approach taken in the SOARCA study to characterize offsite health consequences for low probability events. Still, the NRC can use different approaches for different applications. Therefore, the SOARCA analyses consider a range of dose truncation values ranging from LNT to a dose truncation level based on the HPS position that there is a dose below which, because of

uncertainties, a quantified risk should not be assigned, which is 5 rem/year with a lifetime dose limit of 10 rem.

The SOARCA analyses also considered two additional dose truncation levels. One is the 10 mrem/year dose truncation value suggested in ICRP Report 104 [59]; the other is U.S. average background radiation combined with average annual medical exposure as a dose truncation level (abbreviated as US BGR), which is 620 mrem/year. Results for three of these four dose truncation levels are reported for each of the accident scenarios considered in the SOARCA study. The results for the 10-mrem/year dose truncation levels were calculated but are not included in the report because the results are very similar to LNT and are also always slightly less than the LNT results.

5.8 Risk Metrics Reported

The statistic that is chosen to convey the likelihood of LCFs resulting from an accident at an NPP is the mean, population-weighted individual risk. This value is more meaningful than the predicted number of LCFs in the sense that it may be compared with cancer fatality rates that have other causes. Individual risks can be presented as conditional risks (i.e., as if the accident had taken place) or as absolute risks (i.e., accounting for the likelihood of the accident occurring per year of reactor operation). The latter definition of risk is more useful, because it conveys the full meaning of risk, which is probability (or frequency) times consequence.

The term “population-weighted” in the preceding paragraph carries the meaning of the effect of population distribution along with wind-rose probabilities of the predicted risk. This statistic is simply the number of predicted fatalities divided by the population within a specified region. The use of the word “mean” is intended to convey that the results are weighted averages over the annual weather trials used in the analysis. The work presented in this report considers uncertainty in the weather. Subsequent work will explore the effect on the predictions of uncertainties in other input parameters.

The mean, population-weighted individual risks range from 0 to 50 miles. The 0- to 10-mile range represents the population within the EPZ. Analyses of severe accident mitigation and severe accident mitigation design alternatives generally use the range from 0 to 50 miles.

6.0 RESULTS AND CONCLUSIONS

To assess the benefits of the various mitigative measures and to provide a basis for comparison to past analyses of unmitigated severe accident scenarios, the SOARCA project treated the selected scenarios in two separate and distinct manners. In the first, it analyzed scenarios that included an assessment of reasonable mitigation measures for which procedures and equipment (and training) exist. Alternatively, if adequate time exists, this would suffice for implementation in lieu of fully developed procedures and training (especially for simple actions), e.g., refilling water storage capabilities. In the second manner, it assumed that the key or vital measures necessary to prevent core damage or to mitigate radiological release were not taken to compare them with previous analyses of unmitigated scenarios. This comparison could reveal the benefits of improved severe accident phenomenological understanding and modeling.

6.1 Mitigation

While this report does not determine the respective likelihoods of the mitigated and unmitigated cases of each scenario, the SOARCA results demonstrate the potential benefits of employing 10 CFR 50.54(hh) mitigation enhancements for the scenarios analyzed. MELCOR analyses were used both to confirm the time available to implement mitigation measures and to confirm that those measures, when successfully implemented, are effective in preventing core damage or significantly reducing radiological releases. When successful mitigation is assumed, the MELCOR results indicate no core damage for all scenarios except the Surry STSBO and its TISGTR variant. The security-related mitigation measures that provide alternative ac power and portable diesel-driven pumps are especially helpful in counteracting SBO scenarios. For the Surry STSBO and its TISGTR variant, the mitigation is sufficient to flood the containment through the containment spray system to cover core debris resulting from vessel failure. For the ISLOCA scenario, installed equipment unrelated to 10 CFR 50.54(hh) is effective in preventing core damage owing to the time available for corrective action. Mitigation results are included in Tables 4 through 7.

6.2 Accident Progression and Radionuclide Release

An important result of the MELCOR analyses was that the select severe accidents proceed much more slowly than the SST1 case from the 1982 Siting Study. The reasons for this are threefold: (1) research and development of better phenomenological modeling has produced a much more protracted and delayed core degradation transient with substantial delays of reactor vessel failure, (2) all aspects of accident scenarios receive more realistic treatment, which includes more complete modeling of plant systems and often yields delays in core damage and radiological release, and (3) the scope of SOARCA focuses on the more likely and important accident scenarios, while past treatments included less likely accident progressions. In general, the bounding approaches in past simplified treatments used qualitative logical models. In SOARCA, where specific self-consistent scenarios are analyzed in an integral fashion using MELCOR, the result is that accident conditions or attributes that contribute to a more severe response in one area may produce an ameliorating effect in another area.

For the LTSBO scenarios for both Peach Bottom and Surry (the most likely severe accident scenario for each plant considered in SOARCA) analyzed assuming no mitigation, core damage begins in 9 to 16 hours, and reactor vessel failure begins at about 20 hours. Offsite radiological release due to containment failure begins at about 20 hours for Peach Bottom (BWR) and at 45 hours for Surry (PWR). The SOARCA analyses therefore show that time may be available for operators to take corrective action and get additional assistance from plant technical support centers even if initial efforts are assumed unsuccessful. For the most rapid events (i.e., the unmitigated STSBO in which core damage may begin in 1 to 3 hours), reactor vessel failure begins at roughly 8 hours, possibly allowing time to restore core cooling and prevent vessel failure. In these cases, containment failure and radiological release begins at about 8 hours for Peach Bottom and at 25 hours for Surry. For the unmitigated Surry ISLOCA, the offsite radiological release begins at about 13 hours and in the other bypass event analyzed, the TISGTR, the radiological release begins at about 3.5 hours but is shown by analyses to be substantially smaller than the 1982 Siting Study SST1 release.

Table 4 and Table 5 provide key accident progression timing results for SOARCA scenarios. Table 4 shows the same times for lower head failure and start of the release to the environment, because drywell shell melt-through occurs about 15 minutes after lower head failure.

Table 4 Peach Bottom Accident Progression Timing Results

Scenario	Mitigated			Unmitigated		
	Time to start of core damage (hours)	Time to lower head failure (hours)	Time to start of release to environment (hours)	Time to start of core damage (hours)	Time to lower head failure (hours)	Time to start of release to environment (hours)
Long-term SBO	No Core Damage			9	20	20
Short-term SBO with RCIC Blackstart*	No Core Damage**			7	17	17
Short-term SBO without RCIC Blackstart	Not Applicable**			1	8	8

* Blackstart of the reactor core isolation cooling (RCIC) system refers to starting RCIC without any ac or dc control power. Blackrun of RCIC refers to the long-term operation of RCIC without electricity, once it has been started. This typically involves using a portable generator to supply power to indications such as reactor pressure vessel (RPV) level to allow the operator to manually adjust RCIC flow to prevent RPV overfill and flooding of the RCIC turbine. STSBO RCIC blackstart and limited blackrun is credited as an unmitigated case for SOARCA purposes because the licensee has included its use in procedures. Past NRC severe accident analyses of STSBO scenarios did not credit blackstart of RCIC. A sensitivity calculation without blackstart was therefore performed to provide a basis for comparison to past analyses.

** A scenario with 10 CFR 50.54(hh) mitigation, but without RCIC blackstart was not analyzed.

Table 5 Surry Accident Progression Timing Results

Scenario	Mitigated			Unmitigated		
	Time to start of core damage (hours)	Time to lower head failure (hours)	Time to start of release to environment (hours)	Time to start of core damage (hours)	Time to lower head failure (hours)	Time to start of release to environment (hours)
Long-term SBO	No Core Damage			16	21	45
Short-term SBO	3	7	66	3	7	25
Short-term SBO with thermally induced steam generator tube rupture	3	7.5	3.5*	3	7.5	3.5
Interfacing systems LOCA	No Core Damage			13	19	13

* Although the time at which release to the environment starts is the same in the mitigated and unmitigated cases, containment failure is delayed by about 46 hours in the mitigated case compared to the unmitigated case.

The SOARCA study also demonstrated that the magnitude of the environmental radionuclide release is likely to be much smaller than the SST1 source term, again as a result of (1) extensive research and improved modeling, (2) integrated and more complete plant simulation, and (3) the SOARCA project’s focus on the more likely severe accident scenarios, while past treatments included less likely accident progressions. Historically important radionuclides have included the more volatile fission products (i.e., those released in greater quantity from the overheated fuel) such as iodine and cesium. These two radionuclides have also been useful representatives of radionuclides with a short half-life (iodine) and those with a long half-life (cesium). SOARCA analysis typically predicts iodine releases on the order of 1-2 percent for the dominant scenarios with the highest releases on the order of 10-15 percent for the lower frequency, more severe scenarios. By contrast, the SST1 source term in the 1982 Siting Study assumed an iodine release of 45 percent. With respect to cesium, SOARCA predicts releases of 2 percent or less. By contrast, the SST1 source term assumed a cesium release of 67 percent. Figure 12 and Figure 13 provide the radionuclide release results for iodine and cesium.




Figure 12 Iodine releases to the environment for SOARCA unmitigated scenarios and the 1982 Siting Study SST1 case




Figure 13 Cesium releases to the environment for SOARCA unmitigated scenarios and the 1982 Siting Study SST1 case

Past PRAs and consequence studies showed that sequences involving large early releases were important risk contributors. For example, the 1982 Siting Study SST1 results were controlled by an internally initiated event with a large early release that was assigned a representative

frequency of 1×10^{-5} per reactor-year. However, in the SOARCA study, no sequences resulted in a large early release, even considering external events and unsuccessful mitigation. This is a result of research conducted over the last several decades that has shown that phenomena earlier believed to lead to a large early release are of extremely low probability or not physically feasible. This research was focused on phenomena that had been previously assumed to be prime contributors to severe accident risk, including direct containment heating and alpha mode failure.

The PWR SBO with a TISGTR was historically believed to result in a large, relatively early release, potentially leading to higher offsite consequences. However, MELCOR analysis of Surry performed for SOARCA shows that the release is small, because other reactor coolant system piping inside containment (i.e., hot leg nozzle) fails soon after the tube rupture and thereby retains fission products within the containment. Also, the release was somewhat delayed; for the STSBO where loss of injection occurred at the start of the accident, the tube rupture and release began about 3.5 hours into the event. Moreover, core damage, tube rupture, and radiological release could be delayed for many hours if auxiliary feedwater were available even for a relatively short time.

6.3 Offsite Radiological Consequences

The result of the accident progression and source term analysis is that releases are delayed, smaller, and more dispersed relative to the 1982 Siting Study SST1 case. This fact, combined with the realistic simulation of emergency response and the greater distances radioactive material is expected to disperse, led to essentially no risk of early fatalities being calculated as close-in populations were evacuated before or shortly after plume arrival.

Because of the last factor, significantly more of the latent cancer fatality risk in the selected SOARCA scenarios comes from low doses compared to the results of the SST1 source term from the 1982 Siting Study. Therefore, a dose truncation significantly reduces the quantified LCF risk in the SOARCA scenarios, much more so than a dose truncation would have for the SST1 from the 1982 Siting Study.

Latent health effects calculated using any of the dose-response models (in combination with the frequency of release) referenced in this study are small in comparison to the NRC Safety Goal. Much of the LCF risk was in fact derived from the small doses received by populations returning to their homes in accordance with emergency planning guidelines. Because much of the health risk is caused by the return of the population, it is therefore controllable. For example, for the Peach Bottom LTSBO, for individuals living within the EPZ, 99 percent of the LCF risk derives from the long-term dose received by the population returning to their homes and being exposed to small radiation doses. Similarly, about 70 percent of the LCF risk to individuals within 50 miles is from returning home. The percentage is larger for the EPZ, because of its evacuation before the start of the release. Here, the calculation of scenario-specific LCF risk, though very small, is strongly influenced by the relationship between low-dose health effects modeling and criteria for allowing the population to return.

Tables 6 and 7 show estimates of conditional (i.e., assuming the accident has occurred) scenario-specific probabilities of an LCF range from roughly 10^{-4} to 10^{-5} , using the LNT dose-response model (other dose models result in lower or much lower conditional risk). The tables also provide the product of this value and the scenario CDF, which is best described as the scenario-specific risk of LCF for an individual located within 10 miles of the plant. Scenario-specific risk of an LCF for an individual within 10 miles of the plant is on the order of 10^{-9} to 10^{-11} per reactor-year. These risk estimates are millions of times lower than the general risk of a cancer fatality in the United States from all causes, approximately 2×10^{-3} per year and thousands of times lower than the NRC Safety Goal.

Comparisons of SOARCA's calculated LCF risks to the NRC Safety Goal [72] and the average annual U.S. cancer fatality risk from all causes [73] are provided to give context that may help the reader to understand the contribution to cancer risks from these nuclear power plant accident scenarios. However, such comparisons have limitations for which the reader should be aware. Relative to the safety goal comparison, the safety goal is intended to encompass all accident scenarios. SOARCA does not examine all scenarios typically considered in a PRA, even though it includes the important scenarios. SOARCA represents a mix of limited PRA models with a deterministic treatment of various long-term mitigating features. In fact, any analytical technique, including PRAs, will have inherent limitations of scope and method. As a result, comparison of SOARCA's scenario-specific calculated LCF risks to the NRC Safety Goal is necessarily incomplete. However, it is intended to show that adding multiple scenarios' low risk results in the $\sim 10^{-10}$ range to approximate a summary risk from all scenarios, would yield a summary result that is also below the NRC Safety Goal of 2×10^{-6} or two in one million.

Relative to the U.S. average individual risk of a cancer fatality comparison, the sources of an individual's cancer risk include a complex combination of age, genetics, lifestyle choices, and other environmental factors whereas the consequences from a severe accident at a nuclear plant are involuntary and unlikely to be experienced by most individuals.

Table 6 Peach Bottom Results for Scenarios Assuming LNT Dose-Response Model

Scenario	Core damage frequency (CDF) (per reactor-year)*	Mitigated		Unmitigated	
		Conditional scenario-specific probability of latent cancer fatality for an individual located within 10 miles	Scenario-specific risk (CDF x Conditional) of latent cancer fatality for an individual located within 10 miles (per reactor-year)	Conditional scenario-specific probability of latent cancer fatality for an individual located within 10 miles	Scenario-specific risk (CDF x Conditional) of latent cancer fatality for an individual located within 10 miles (per reactor-year)
Long-term SBO	3×10^{-6}	No Core Damage		9×10^{-5}	$\sim 3 \times 10^{-10}$ ****
Short-term SBO with RCIC Blackstart**	3×10^{-7}	No Core Damage ***		7×10^{-5}	$\sim 2 \times 10^{-11}$ ****
Short-term SBO without RCIC Blackstart		Not Applicable ***		2×10^{-4}	$\sim 6 \times 10^{-11}$ ****

* The CDF assumes that 10 CFR 50.54(hh) equipment and procedures were not used.

** Blackstart of the reactor core isolation cooling (RCIC) system refers to starting RCIC without any ac or dc control power. Blackrun of RCIC refers to the long-term operation of RCIC without electricity, once it has been started. This typically involves using a portable generator to supply power to indications such as reactor pressure vessel (RPV) level to allow the operator to manually adjust RCIC flow to prevent RPV overfill and flooding of the RCIC turbine. STSBO RCIC blackstart and limited blackrun is credited as an unmitigated case for SOARCA purposes because the licensee has included its use in procedures. Past NRC severe accident analyses of STSBO scenarios did not credit blackstart of RCIC. A sensitivity calculation without blackstart was therefore performed to provide a basis for comparison to past analyses.

*** A scenario with 10 CFR 50.54(hh) mitigation, but without RCIC blackstart was not analyzed.

**** Estimated risks below 1×10^{-7} per reactor year should be viewed with caution because of the potential impact of events not studied in the analyses and the inherent uncertainty in very small calculated numbers.

Table 7 Surry Results for Scenarios Assuming LNT Dose-Response Model

Scenario	Core damage frequency [CDF] (per reactor-year)*	Mitigated		Unmitigated	
		Conditional scenario-specific probability of latent cancer fatality for an individual located within 10 miles	Scenario-specific risk [CDF x Conditional] of latent cancer fatality for an individual located within 10 miles (per reactor-year)	Conditional scenario-specific probability of latent cancer fatality for an individual located within 10 miles	Scenario-specific risk [CDF x Conditional] of latent cancer fatality for an individual located within 10 miles (per reactor-year)
Long-term SBO	2×10^{-5}	No Core Damage		5×10^{-5}	$\sim 7 \times 10^{-10}$ ****
Short-term SBO	2×10^{-6}	No Containment Failure **		9×10^{-5}	$\sim 1 \times 10^{-10}$ ****
Short-term SBO with TISGTR	4×10^{-7}	3×10^{-4} ***	$\sim 1 \times 10^{-10}$ ****	3×10^{-4}	$\sim 1 \times 10^{-10}$ ****
Interfacing systems LOCA	3×10^{-8}	No Core Damage		3×10^{-4}	$\sim 9 \times 10^{-12}$ ****

* The CDF assumes that 10 CFR 50.54(hh) equipment and procedures were not used.

** Accident progression calculations showed that source terms in the mitigated case are smaller than in the unmitigated case. Offsite consequence calculations were not run, since the containment fails at about 66 hours. A review of available resources and emergency plans shows that adequate mitigation measures could be brought onsite within 24 hours and connected and functioning within 48 hours. Therefore 66 hours would allow ample time for mitigation through measures transported from offsite.

*** Containment failure is delayed by about 46 hours in the mitigated case relative to the unmitigated case. Rounding to one significant figure shows conditional LCF probabilities of 3×10^{-4} for both mitigated and unmitigated cases, however the original values were 2.8×10^{-4} for the mitigated case and 3.2×10^{-4} for the unmitigated case.

**** Estimated risks below 1×10^{-7} per reactor year should be viewed with caution because of the potential impact of events not studied in the analyses and the inherent uncertainty in very small calculated numbers.

To provide perspective on alternative low-dose health effect modeling, the SOARCA project has also developed LCF risk estimates assuming non-LNT models, which are based on the premise that below a certain dose, cancer risks cannot be reliably quantified, or are nonexistent. Dose truncation values used for SOARCA included 620 mrem/year (representative background radiation including average annual medical exposures), and 5 rem/year with a 10-rem lifetime cap (based on the Health Physics Society's position that there is a dose below which, because of

uncertainties, a quantified risk should not be assigned). Table 8 and Table 9 show the results of sensitivity calculations for dose truncation values compared with LNT results. Using these truncation values makes the already small scenario-specific LCF risk calculations even smaller, in some cases, by orders of magnitude.

For Surry scenarios except ISLOCA, the background results in Table 9 differ from the HPS results, because the background truncation value clearly falls below the plant-specific population return criterion of 4 rem over 5 years, which is intended to represent EPA’s (adopted in Virginia) criterion of 2 rem in the first year and 0.5 rem/year in subsequent years; however, the HPS truncation value does not. The ISLOCA results are the same to one significant digit within a radius of 10 miles for both truncation values, because most of the emergency phase doses exceed both of these criteria, while, on the other hand, long-term doses make an insignificant contribution to the overall doses. The results in Table 8 and Table 9 assume that the probability of 10 CFR 50.54(hh) mitigation is zero.

SOARCA analyses included calculations of individual scenario-specific LCF risk for several distance intervals, including 0 to 10 miles and 0 to 50 miles. This chapter presents results for selected distance intervals however Chapter 7 of NUREG/CR-7110, Volume 1 and 2, contains the results for all distance intervals in the Peach Bottom and Surry analyses. The analysis indicated that individual LCF risk estimates generally decrease with increasing distance, in large part because of plume dispersion and fission product deposition closer to the site. This trend is seen for all unmitigated scenarios modeled in SOARCA except for the Peach Bottom STSBO without RCIC blackstart and the Surry ISLOCA. More details regarding these two scenarios are discussed in Section 6.5 of this report and in Chapter 7 of NUREG/CR-7110, Volume 1 and 2.

Table 8 Peach Bottom Results for Scenarios without Successful Mitigation for LNT and Alternative Dose-Response Models

Scenario	Scenario-specific risk of latent cancer fatality for an individual located within 10 miles (per reactor-year)		
	Linear No-Threshold	Background	Health Physics Society
Long-term SBO	3×10^{-10}	2×10^{-12}	1×10^{-12}
Short-term SBO with RCIC Blackstart	2×10^{-11}	2×10^{-13}	9×10^{-14}
Short-term SBO without RCIC Blackstart	6×10^{-11}	4×10^{-12}	4×10^{-12}

Table 9 Surry Results for Scenarios without Successful Mitigation for LNT and Alternative Dose-Response Models

Scenario	Scenario-specific risk of latent cancer fatality for an individual located within 10 miles (per reactor-year)		
	Linear No-Threshold	Background	Health Physics Society
Long-term SBO	7×10^{-10}	6×10^{-12}	2×10^{-14}
Short-term SBO	1×10^{-10}	5×10^{-12}	2×10^{-14}
Short-term SBO with thermally induced steam generator tube rupture	1×10^{-10}	3×10^{-11}	5×10^{-12}
Interfacing systems LOCA	9×10^{-12}	2×10^{-12}	1×10^{-12}

Because the SBO scenarios were seismically induced, the study added analyses to evaluate the potential impact of the seismic event on the evacuation. Although road network infrastructure may be damaged during an earthquake, resulting in reduced evacuation speeds, other effects such as wider deployment of emergency responders and a larger shadow evacuation may improve evacuation timing. The analyses for both Surry and Peach Bottom indicated changes to the evacuation resulting from the earthquake would change the LCF risk by less than 10 percent and may actually cause the consequences from radionuclide release to decrease as in the case of the Peach Bottom plant, because the population is on alert after the earthquake.

6.4 Comparison to NUREG/CR-2239 (the 1982 Siting Study SST1 case)

The SOARCA offsite early fatality risk calculations are dramatically smaller than reported in NUREG/CR-2239 [1]. This Siting Study predicted 92 early fatalities for Peach Bottom and 45 early fatalities for Surry for the SST1 source term. In contrast, SOARCA predicted that the early fatality risk was essentially zero for both sites.

For LCF results, the exact basis for NUREG/CR-2239 estimates could not be recovered, but literature searches and sensitivity analyses with MACCS2 suggested that these estimates are for the population within 500 miles of the site. Moreover, an attempt to reproduce the results of NUREG/CR-2239 led to agreement within about a factor of 2. Given the uncertainty in the basis for these results, the SOARCA study performed an additional set of calculations to enable the current, state-of-the-art results to be compared with the 1982 Siting Study. For this set of calculations, the most severe source terms predicted by the SOARCA analyses (see Figure 12 and Figure 13) were replaced by the largest source term from the Siting Study—the SST1 source term. No other modeling or parameter changes were made, including the timing of public evacuation. Thus, this comparison does not attempt to replicate the Siting Study; it simply evaluates the largest source term, SST1, from that study and compares the results with those from the current work.

Table 10 and Table 11 summarize the comparison to the Siting Study source term results for the Peach Bottom and Surry sites, respectively, assuming an LNT dose-response function. Although the SST1 source term is identical in both comparisons, the scenario-specific LCF probabilities associated with this source term shown in the tables are different because of the difference in evacuation modeling and other offsite consequence parameters for the two sites.

Table 10 Conditional (i.e., assuming accident occurs), Mean, LNT, Scenario-Specific Probabilities of LCF for People within the Specified Radii of the Peach Bottom Site

Radius of Circular Area (mi)	1982 Siting Study SST1	SOARCA Unmitigated STSBO
10	3.3×10^{-3}	2.1×10^{-4}
20	1.8×10^{-3}	5.7×10^{-4}
50	4.6×10^{-4}	1.9×10^{-4}

Table 11 Conditional, Mean, LNT, Scenario-Specific Probabilities of LCF for People within the Specified Radii of the Surry Site

Radius of Circular Area (mi)	1982 Siting Study SST1	SOARCA Unmitigated ISLOCA	SOARCA Unmitigated STSBO with TISGTR
10	1.0×10^{-2}	3.0×10^{-4}	3.2×10^{-4}
20	5.1×10^{-3}	3.4×10^{-4}	1.9×10^{-4}
50	1.5×10^{-3}	1.6×10^{-4}	6.5×10^{-5}

For the 0-10 mile radius, the area associated with the NRC Safety Goal for latent cancers, the scenario-specific probabilities of latent cancer fatality calculated for SOARCA are substantially smaller than predicted in the 1982 Siting Study for SST1. Considering both the Peach Bottom and Surry comparisons, this difference diminishes with increasing radius, falling from a factor of 33 within 10 miles to a factor of about 2.4 within a 50-mile radius and beyond. The quantification of latent cancer fatality risk is more uncertain at low doses, such as at far distances, and the diminishing difference in conditional LCF risk can be explained as an influence of competing factors. For instance, while the SOARCA radionuclide releases are significantly smaller than the 1982 Siting Study SST1 case, they are also calculated to persist to longer distances because the effective deposition velocity is lower than assumed in the 1982 Siting Study. A farther spread of radioactive material is more likely to create lightly contaminated, habitable areas, in which people are assumed to receive very small doses over an extended period of time, as well as very low LCF risk as calculated using the LNT dose-response model. Previous studies, with larger releases and plumes that deposited over shorter distances, were more likely to predict either uninhabitable or unaffected areas, both of which are areas

where individuals do not receive elevated LCF risk. In addition, the cancer risk factors from radiation are estimated to be higher than previously thought [56] and the inventory of fission products has been updated to account for greater burnup and power levels. This combination of modeling differences between SOARCA and the 1982 Siting Study accounts for the fact that the calculated risks are similar for populations farther from the site.

Figure 14 provides additional comparisons of SOARCA results for both mitigated and unmitigated scenarios to 1982 Siting Study SST1 results for people within 10 miles of the plant.




Figure 14 Comparison of average individual LCF risk results for SOARCA mitigated and unmitigated scenarios to the NRC Safety Goal and to extrapolations of the 1982 Siting Study SST1 (plotted on logarithmic scale)

6.5 Sensitivity Analyses on the Size of the Evacuation Zone

As discussed earlier in Section 5.3.2, SOARCA included sensitivities to analyze the effects of increased evacuation sizes on scenario-specific latent cancer fatality risks for people within different distances of each plant. These sensitivities were performed for distances of 16 miles and 20 miles from the plant and compared to the base case of a 10 mile radius evacuation. Selected results are presented below in Table 12 and Figures 15 and 16; however more details are provided in NUREG/CR-7110, Volumes 1 and 2. The Peach Bottom unmitigated STSBO scenario without RCIC blackstart and the Surry unmitigated ISLOCA scenario were chosen for these sensitivities because they result in the largest releases of radioactive materials of all scenarios analyzed for each plant. The Peach Bottom unmitigated STSBO scenario without RCIC blackstart releases about 12% of the core inventory of I-131 and 2% of the Cs-137 to the environment and begins at 8 hours. The Surry unmitigated ISLOCA scenario releases about 16% of the core inventory of I-131 and 2% of the Cs-137 and begins at about 13 hours.

Table 12 Effect of Size of Evacuation Zone on Mean, Individual, LNT, Scenario-Specific LCF Risk for People within the Specified Radii of the Plant for the Peach Bottom Unmitigated STSBO without RCIC Blackstart and the Surry Unmitigated ISLOCA

Radius of Circular Area (mi)	Peach Bottom Unmitigated STSBO without RCIC Blackstart		Surry Unmitigated ISLOCA	
	Base Case 10-mile Evacuation	Sensitivity 20-mile Evacuation	Base Case 10-mile Evacuation	Sensitivity 20-mile Evacuation
10	6×10^{-11}	2×10^{-10}	9×10^{-12}	1×10^{-11}
20	2×10^{-10}	7×10^{-11}	1×10^{-11}	8×10^{-12}
30	1×10^{-10}	8×10^{-11}	8×10^{-12}	7×10^{-12}
40	7×10^{-11}	6×10^{-11}	6×10^{-12}	5×10^{-12}
50	6×10^{-11}	5×10^{-11}	5×10^{-12}	4×10^{-12}




Figure 15 Mean, individual, LNT, scenario-specific LCF risk for the Peach Bottom unmitigated STSBO scenario without RCIC blackstart for people within a circular area of specified radius from the plant.




Figure 16 Mean, individual, LNT, scenario-specific LCF risk for the Surry unmitigated ISLOCA scenario for people within a circular area of specified radius from the plant.

Analysis of the evacuation size sensitivities for both Peach Bottom and Surry shows that for the base case, LCF risk is slightly higher for people within a 20 mile radius of the plant compared to people within a 10 mile radius of the plant. This result is likely due to SOARCA's modeling assumptions rather than physical reality. SOARCA models a shadow evacuation, which is the voluntary (self-initiated) evacuation of members of the public from areas that are not under official evacuation orders, yet it does not model an evacuation that (for which there is no preplanning) would be ordered by officials for certain areas outside the EPZ. Therefore, the slight increase in LCF risk in the base case for people within a 20 mile radius of the plant relative to people within a 10 mile radius is not considered a meaningful insight.

Analysis of Figure 15 and 16 also shows that expanding the evacuation size from a 10 mile radius to a 20 mile radius results in increased LCF risk for people in the 0-10 mile area. SOARCA analyses show that an evacuation beyond the area closest to the plant will delay those most at risk, i.e., closest to the plant. The increased risk to the population within 10 miles of the plant is due to slower evacuation speeds because of additional traffic congestion and delays that result from evacuation of a larger population.

Further, SOARCA's evacuation size sensitivities show that an evacuation out to 20 miles from the plant results in decreased risk for the population relative to the base case 10 mile evacuation. For the Peach Bottom unmitigated STSBO without RCIC blackstart, the scenario-specific LCF risk falls from 2×10^{-10} per reactor-year to about 7×10^{-11} , a factor of about 3, while the risk reduction is much smaller for the Surry unmitigated ISLOCA scenario. The decrease in average LCF risk out to 20 miles is seen as within the bounds of modeling assumptions and not indicative of a measurable benefit. For the 20 mile evacuation, SOARCA did not model a shadow evacuation; however if this was included, it would likely delay the evacuation of the people within 20 miles and increase the scenario-specific LCF risk. This likely leads to an underestimation in scenario-specific LCF risk for the people within 20 miles during the 20 mile evacuation.

Overall, the increases and reductions to scenario-specific LCF risk shown in Table 12 and Figure 15 and 16 are extremely small on an absolute scale. The LCF risks calculated for SOARCA's base case and 20-mile evacuation sensitivity are all millions of times smaller than the average annual risk of cancer death for an individual in the United States.

6.6 Conclusions

The results of the SOARCA project represent a major change in the staff's perception of severe reactor accidents and their consequences. Specific conclusions of the project are as follows:

The SOARCA results demonstrate the potential benefits of employing 10 CFR 50.54(hh) mitigation enhancements for the scenarios analyzed. When successful mitigation is assumed, the MELCOR results indicate no core damage for all scenarios except the Surry STSBO and its TISGTR variant. For the Surry STSBO with mitigation, the core is damaged; however, containment failure is delayed by an additional 41 hours compared to the unmitigated case. The

mitigation measures (i.e., containment sprays) are effective in knocking down the airborne aerosols. For the Surry STSBO with TISGTR with mitigation, the core is damaged and containment failure is delayed by an additional 46 hours compared to the unmitigated case. This is a bypass scenario, and therefore the release to the environment begins at the same time as in the unmitigated case. For both the mitigated and unmitigated cases, the individual scenario-specific LCF risk for the EPZ was small, approximately 1×10^{-10} per reactor-year, assuming an LNT dose-response model.

When the selected SOARCA scenarios were assumed to proceed unmitigated (i.e., neither 10 CFR 50.54(hh) implementation nor other key operator actions that would prevent core damage), MELCOR analyses indicated that the accidents progress more slowly and with smaller releases than the 1982 Siting Study SST1. Whereas the 1982 Siting Study SST1 case results in a large early release at 1.5 hours, the SOARCA analyses show no large early releases for the scenarios analyzed.

The individual early fatality risk from SOARCA scenarios is essentially zero. Individual LCF risk from the selected specific, important scenarios is thousands of times lower than the NRC Safety Goal and millions of times lower than the general cancer fatality risk in the United States from all causes, even assuming the LNT dose-response model. Using a dose-response model that truncates annual doses below normal background levels (including medical exposures) results in a further reduction to the LCF risk (by a factor of 100 for smaller releases and a factor of 3 for larger releases). LCF risk calculations are generally dominated by long-term exposure to small annual doses (about 500 mrem per year) corresponding to evacuees returning to their homes after the accident and being exposed to residual radiation over a long period of time.

SOARCA results indicate that bypass events (e.g., Surry ISLOCA) do not pose a higher scenario-specific latent cancer fatality risk than non-bypass events (e.g., Surry SBO). While consequences are greater when the bypass scenario happens, this is offset by the scenario being less likely to happen. SOARCA reinforces the importance of external events relative to internal events and the need to continue ongoing work related to external events risk assessment.

The SOARCA analyses show that emergency response programs, implemented as planned and practiced, reduce the scenario-specific risk of health consequences among the public during a severe reactor accident. Sensitivity analyses of seismic impacts on site-specific emergency response (e.g., loss of bridges, traffic signals, and delayed notification) at Peach Bottom and Surry do not significantly affect LCF risk.

SOARCA results, while specific to Peach Bottom and Surry, may be generally applicable for plants with similar designs. However, additional work is needed to confirm this, since differences exist in plant-specific designs, procedures, and emergency response.

7.0 REFERENCES

- [1] U.S. Nuclear Regulatory Commission, NUREG/CR-2239, “Technical Guidance for Siting Criteria Development,” Sandia National Laboratories, Albuquerque, NM, 1982.
- [2] U.S. Nuclear Regulatory Commission, NUREG-1150, “Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants,” Washington, DC, 1990.
- [3] U.S. Nuclear Regulatory Commission, WASH-1400, “Reactor Safety Study: An Assessment of Accident Risks in U.S. Commercial Nuclear Power Plants,” Washington, DC, 1975.
- [4] U.S. Nuclear Regulatory Commission, “Safety Goals for the Operation of Nuclear Power Plants,” *Federal Register*, 51 FR 28044, 1986.
- [5] U.S. Nuclear Regulatory Commission, RG 1.174, Rev. 1, “An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis,” Washington, DC, November 2002.
- [6] U.S. Nuclear Regulatory Commission, NUREG/CR-7008, “Best Practices for Simulation of Severe Accident Progression at Nuclear Power Plants,” Washington, DC, 2010 (To be published).
- [7] U.S. Nuclear Regulatory Commission, NUREG-1570, “Risk Assessment of Severe Accident-Induced Steam Generator Tube Rupture,” Washington, DC, March 1998.
- [8] *U.S. Code of Federal Regulations*, 10 CFR 50.65, “Requirements for Monitoring the Effectiveness of Maintenance at Nuclear Power Plants,” 1999.
- [9] *U.S. Code of Federal Regulations*, 10 CFR 50.62, “Requirements for Reduction of Risk from Anticipated Transients without Scram (ATWS) Events for Light-Water-Cooled Nuclear Power Plants,” 1984.
- [10] *U.S. Code of Federal Regulations*, 10 CFR 50.63, “Loss of All Alternating Current Power,” 1988.
- [11] U.S. Nuclear Regulatory Commission, NUREG/CR-4334, “An Approach to the Quantification of Seismic Margins in Nuclear Power Plants,” Lawrence Livermore National Laboratory, Livermore, CA, 1985.
- [12] Klapp, U., et al., “Seismic PSA of the Neckarwestheim 1 Nuclear Power Plant,” *Transactions, SMiRT 19, 19th International Conference on Structural Mechanics in Reactor Technology*, August 2007, Toronto, Canada, International Association for Structural Mechanics in Reactor Technology.
- [13] U.S. Atomic Energy Commission, TID-14844, “Calculation of Distance Factors for Power and Test Reactor Sites,” Washington, DC, 1962.
- [14] U.S. Nuclear Regulatory Commission, NUREG-1465, “Accident Source Terms for Light-Water Nuclear Power Plants,” Washington, DC, 1995.
- [15] Atomic Energy Commission, WASH-740, “Theoretical Possibilities and Consequences of Major Accidents in Large Nuclear Power Plants,” Washington, DC, 1957.

- [16] U.S. Nuclear Regulatory Commission, NUREG-0956, “Reassessment of the Technical Bases for Estimating Source Terms,” Washington, DC, July 1986.
- [17] *U.S. Code of Federal Regulations*, 10 CFR 100.11, “Determination of Exclusion Area, Low Population Zone, and Population Center Distance,” 1962.
- [18] U.S. Nuclear Regulatory Commission, NUREG-0340, “Overview of the Reactor Safety Study Consequence Model,” Washington, DC, 1977.
- [19] U.S. Nuclear Regulatory Commission, NUREG-0772, “Technical Bases for Estimating Fission Product Behavior During LWR Accidents,” Washington, DC, June 1981.
- [20] U.S. Nuclear Regulatory Commission, NUREG-0771, “Regulatory Impact of Nuclear Reactor Accident Source Term Assumption,” Draft for Comment, Washington, DC, 1981.
- [21] U.S. Nuclear Regulatory Commission, NUREG-0773, “The Development of Severe Accident Source Terms: 1957–1981,” Washington, DC, November 1982.
- [22] Gieske, J.A., et al., BMI-2104, “Radionuclide Release Under Specific LWR Accident Conditions,” Battelle Memorial Institute, Columbus, OH, 1985.
- [23] Magallon, D., I. Huhtiniemi, and H. Hohmann, “Lessons learned from FARO/TERMOS corium melt quenching experiments,” *Nuclear Engineering and Design*, 189: 223–238, 1999.
- [24] Chu, T.Y., et al., NUREG/CR-5582, SAND98-2047, “Lower Head Failure Experiments and Analyses,” Sandia National Laboratories, Albuquerque, NM, 1998.
- [25] Farmer, M.T., S. Lomperski, and S. Basu, “Results of Reactor Material Experiments Investigating 2-D Core-Concrete Interaction and Debris Coolability in International Conference on Advanced Power Plants,” ICAPP’04, Pittsburgh, PA, 2004.
- [26] Carbajo, J.J., NUREG/CR-5942, ORNL/TM-12229, “Severe Accident Source Term Characteristics for Selected Peach Bottom Sequences Predicted by the MELCOR Code,” Oak Ridge National Laboratory, Oak Ridge, TN, 1993.
- [27] Bayless, P.B., NUREG/CR-5214, EGG-2547, “Analysis of Natural Circulation During a Surry Station Blackout Using SCDAP/RELAP5,” Idaho National Engineering Laboratory, Idaho Falls, ID, 1988.
- [28] Nuclear Energy Agency, Committee on the Safety of Nuclear Installations, NEA/CSNI/R(99)24, “Technical Opinion Paper on Fuel-Coolant Interaction,” Organisation for Economic Co-operation and Development, Paris, France, 2000.
- [29] Pilch, M.M. and T.G. Theofanous, “The probability of containment failure by direct containment heating in Zion,” *Nuclear Engineering and Design*, 164:1–36, 1996.
- [30] Theofanous, T.G., et al., NUREG/CR-6025, “The Probability of Mark-I Containment Failure by Melt-Attack of the Liner,” U.S. Nuclear Regulatory Commission, Washington, DC, 1993.
- [31] Gauntt, R.O., et al., NUREG/CR-6119, Vol. 1, Revision 3, “MELCOR Computer Code Manuals, Vol. 1: Primer and User’s Guide, Version 1.8.6,” Sandia National Laboratories, Albuquerque, NM, 2005.

- [32] Lorenz, R.A. and M.F. Osborne, NUREG/CR-6261, "A Summary of ORNL Fission Product Release Tests with Recommended Release Rates and Diffusion Coefficients," U.S. Nuclear Regulatory Commission, Washington, DC, 1995.
- [33] Clement, B. and T. Haste, "Comparison report on International Standard Problem ISP-46 (Phebus FPT-1)," Note Technique SEMAR 03/021, Draft Final Report, 2003.
- [34] Ducros, G., et al., "Fission product release under severe accidental conditions: general presentation of the program and synthesis of VERCORS 1–6 results," *Nuclear Engineering and Design*, 208:191–203, 2001.
- [35] Greene, N.M., L.M. Petrie, and R.M. Westfall, ORNL/TM-2005/39, "Version 5, Vols. I-III: NITAWL-III: Scale System Module for Performing Resonance Shielding and Working Library Production, SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluations," Oak Ridge National Laboratory, Oak Ridge, TN, 2005.
- [36] Oak Ridge National Laboratory, ORNL/TM-2005/39, "Version 5.1., Vols. I-III: SCALE: A Modular Code System for Performing Standardized Computer Analyses for Licensing Evaluations," Oak Ridge, TN, 2006.
- [37] U.S. Nuclear Regulatory Commission, RG 3.54, "Spent Fuel Heat Generation in an Independent Spent Fuel Installation," Washington, DC, 1999.
- [38] DeHart, M.D. and S.M. Bowman, "Improved radiochemical assay analyses using TRITON depletion sequences in SCALE," *Proceedings of International Atomic Energy Agency Technical Meeting "Advances in Applications of Burnup Credit to Enhance Spent Fuel Transportation, Storage, Reprocessing and Disposition,"* International Atomic Energy Agency, London, 2005.
- [39] Bowman, S.M. and D.F. Gill, "Validation of Standardized Computer Analyses for Licensing Evaluation/TRITON Two-Dimensional and Three-Dimensional Models for Light Water Reactor Fuel," *PHYSOR-2006, American Nuclear Society Topical Meeting on Reactor Physics: Advances in Nuclear Analysis and Simulation*, Vancouver, British Columbia, Canada, American Nuclear Society, 2006.
- [40] Germina, I. and I.C. Gauld, "Analysis of Decay Heat Measurements for BWR Fuel Assemblies," *Transactions of the American Nuclear Society*, 94:385–387, 2006.
- [41] Chanin, D. and M.L. Young, NUREG/CR-6613, SAND97-0594, "Code Manual for MACCS2 User's Guide," Sandia National Laboratories, Albuquerque, NM, 1997.
- [42] Laur, M.N., "Meeting with Sandia National Laboratories and an Expert Panel on MELCOR/MACCS Codes in Support of the State of the Art Reactor Consequence Analyses Project," Memo to J.T. Yerokun, U.S. Nuclear Regulatory Commission, Washington, DC, September 7, 2006, Agencywide Documents Access and Management System Accession No. ML062500078.
- [43] Atkinson, D. and R.F. Lee, "Procedures for Substituting Values for Missing NWS Meteorological Data for Use in Regulatory Air Quality Models," July 7, 1992, http://www.rflee.com/RFL_Pages/missdata.pdf.

- [44] U.S. Nuclear Regulatory Commission, NUREG-0917, “Nuclear Regulatory Commission Staff Computer Programs for Use With Meteorological Data,” Washington, DC, July 1982.
- [45] U.S. Nuclear Regulatory Commission, RG 1.23, Rev. 1, “Meteorological Monitoring Programs for Nuclear Power Plants,” Washington, DC, March 2007.
- [46] U.S. Nuclear Regulatory Commission, NUREG-0654/FEMA-REP-1, Rev. 1, “Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants,” Washington, DC, November 1980.
- [47] U.S. Nuclear Regulatory Commission, NUREG/CR-6864, “Identification and Analysis of Factors Affecting Emergency Evacuations,” Sandia National Laboratories, Albuquerque, NM, 2005.
- [48] U.S. Nuclear Regulatory Commission, NUREG/CR-6953, Vol. 2, “Review of NUREG-0654, Supplement 3, ‘Criteria for Protective Action Recommendations for Severe Accidents’: Focus Groups and Telephone Survey, Washington, DC, October 2008.
- [49] McFadden, K.L., N.E. Bixler, and R.O. Gauntt, “MELMACCS System Documentation (MELCOR to MACCS2 interface definition),” Sandia National Laboratories, Albuquerque, NM, 2005.
- [50] Bixler, N.E., et al., “Evaluation of Distributions Representing Important Non-Site-Specific Parameters in Off-Site Consequence Analyses,” to be published as a NUREG Report, Sandia National Laboratories, Albuquerque, NM, 2010.
- [51] Bixler, N.E., et al., NUREG/ER-6525, Rev. 1, SAND2003-1648P, “SECPOP2000: Sector Population, Land Fraction, and Economic Estimation Program,” Sandia National Laboratories, Albuquerque, NM, 2003.
- [52] U.S. Nuclear Regulatory Commission, NUREG/CR-6953, Vol. 1, “Review of NUREG-0654, Supplement 3, ‘Criteria for Protective Action Recommendations for Severe Accidents,’” Washington, DC, December 2007.
- [53] U.S. Environmental Protection Agency, Federal Guidance Report 13, “Cancer Risk Coefficients for Environmental Exposure to Radionuclides, Updates and Supplements,” CD Supplement, E.C., Rev. 1, Prepared by Oak Ridge National Laboratory, Oak Ridge, TN, for Office of Air and Radiation, Washington, DC, April 2002.
- [54] U.S. Environmental Protection Agency, EPA 402-R-93-076, “Estimating Radiogenic Cancer Risk,” Washington, DC, June 1994.)
- [55] Eckerman, K.F., Memo, “Risk Coefficients for SOARCA Project,” Oak Ridge National Laboratory, February 2009.
- [56] National Academy of Sciences, “Health Effects of Exposure to Low Levels of Ionizing Radiation: BEIR V,” National Research Council, National Academy Press, Washington, DC, 1990.
- [57] Aurengo, A., et al., “*French National Academy of Medicine report: Dose-effect relationships and estimation of the carcinogenic effects of low doses of ionizing radiation*”. 2005, French Academy of Sciences, French National Academy of Medicine.

- [58] International Commission on Radiological Protection, Report 103, “The 2007 Recommendations of the International Commission on Radiological Protection,” *Annals of the ICRP*, 37(Nos. 2–4), 2007.
- [59] International Commission on Radiological Protection, Report 104, “Scope of Radiological Protection Control Measures,” *Annals of the ICRP*, 37(No. 5), 2007.
- [60] Health Physics Society, PS010-1, “Position Statement of the Health Physics Society—Radiation Risk in Perspective,” McLean, VA, August 2010.
- [61] Boyack, B.E., et al., LA-12240, “MELCOR Peer Review,” Los Alamos National Laboratory, Los Alamos, NM, 1992.
- [62] U.S. Nuclear Regulatory Commission, NUREG-1738, “Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants,” Washington, DC, 2001.
- [63] Wheeler, T., G. Wyss, and F. Harper, SAND2000-2719/1, “Cassini Spacecraft Uncertainty Analysis Data and Methodology Review and Update,” Vol. 1, “Updated Parameter Uncertainty Models for the Consequence Analysis,” Sandia National Laboratories, Albuquerque, NM, November 2000.
- [64] U.S. Nuclear Regulatory Commission, Supplement 3 to NUREG-0654/FEMA-REP-1, Rev. 1, “Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants,” Washington, DC, July 1996.
- [65] American Society of Mechanical Engineers. (ASME) RA-Sb-2005, “Standard for Probabilistic Risk Assessment for Nuclear Power Plant Applications,” Addendum B to ASME RA-S-2002, ASME, New York, New York, December 30, 2005.
- [66] U.S. Nuclear Regulatory Commission, Regulatory Guide 1.200, “An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities,” Rev. 2, Washington, DC, March 2009.
- [67] U.S. Nuclear Regulatory Commission, NUREG-1860, “Feasibility Study for a Risk-Informed and Performance-Based Regulatory Structure for Future Plant Licensing,” Appendix D. Volumes 1 and 2, Washington, DC, December.
- [68] U.S. Nuclear Regulatory Commission, NUREG/CR-4550, “Analysis of Core Damage Frequency: Surry Power Station, Unit 1, External Events,” Washington, DC, December 1990.
- [69] Virginia Electric and Power Company (Dominion), Surry Power Station, Updated Final Safety Analysis Report, 2011.
- [70] Dames and Moore, “Report, Environmental Studies, Proposed Nuclear Power Plant, Surry, Virginia, Virginia Electric and Power Company,” December 1966.
- [71] Weaver, Thomas, “State-of-the-Art Consequence Analyses (SOARCA), Liquefaction Analyses,” Memo to K.H. Gibson, U.S. Nuclear Regulatory Commission, Washington, DC, January 2012, Agencywide Documents Access and Management System No. ML12024A295.

- [72] U.S. Nuclear Regulatory Commission, “Safety Goals for the Operations Nuclear Power Plants; Policy Statement”, 51 FR 28044, 51 FR 30028, 10 CFR Part 50. Available at: <http://www.nrc.gov/reading-rm/doc-collections/commission/policy/51fr30028.pdf>.
- [73] U.S. Cancer Statistics Working Group. *United States Cancer Statistics: 1999-2007 Incidence and Mortality Web-based Report*. Atlanta: U.S. Department of Health and Human Services, Centers for Disease Control and Prevention and National Cancer Institute; 2010. Available at: www.cdc.gov/uscs.
- [74] Eckerman, K.F., Memo, “Radiation Dose and Health Risk Estimation: Technical Basis for the State-of-the-Art Reactor Consequence Analysis Project,” Oak Ridge National Laboratory, January 2012, Agencywide Documents Access and Management System No. ML12159A259.

APPENDIX A

SOARCA AND THE FUKUSHIMA DAIICHI ACCIDENT

Objective

The State-of-the-Art Reactor Consequence Analyses (SOARCA) study was nearly at the end of its peer review when the Fukushima Daiichi accident occurred on March 11, 2011. Following the accident, the U.S. Department of Energy (DOE) and the U.S. Nuclear Regulatory Commission (NRC) began a cooperative effort to use the MELCOR code for a forensic analysis of event progression to develop a more detailed understanding of the accident. This cooperative effort is ongoing.

Based on limited information currently available, the Fukushima accident has many similarities and differences with some of the Peach Bottom sequences analyzed in SOARCA. The objective of this appendix is to compare and contrast the Fukushima accident and the SOARCA study for the following topics: (1) operation of the reactor core isolation cooling (RCIC) system, (2) hydrogen release and combustion, (3) 48-hour truncation of releases in SOARCA, (4) multiunit risk, and (5) spent fuel pool (SFP) risk. It must be emphasized that there are significant gaps in information and uncertainties about what actually occurred in the Fukushima reactors. These uncertainties do not allow firm conclusions on comparisons with SOARCA results. It is expected to take a number of years for the Japanese organizations involved to be able to access the containments and fully evaluate the conditions of the nuclear fuel and other equipment to allow a more complete understanding of the events.

Background

The Great East Japan Earthquake, which rated a magnitude 9.0 on the moment magnitude scale (M_w), occurred northeast of Tokyo off the east coast of Honshu Island. This earthquake resulted in the automatic shutdown of the Fukushima Daiichi reactors. The earthquake precipitated a tsunami that exceeded 14 meters (45 feet) in height at the Fukushima Daiichi site. The earthquake and subsequent tsunami produced widespread devastation across northeastern Japan, resulting in approximately 25,000 people dead or missing, displacing many tens of thousands of people, and significantly affecting the infrastructure and industry in the northeastern coastal areas of Japan.

On March 11, 2011, Fukushima Daiichi Units 1, 2, and 3 were in operation, and Units 4, 5, and 6 were shut down for routine refueling and maintenance activities; the Unit 4 reactor fuel was offloaded to the Unit 4 SFP. The description of events below is based on our current understanding of the accident, which, as previously stated, is subject to significant uncertainty.

As a result of the earthquake, all of the operating units appeared to experience a normal reactor trip within the capability of the safety design of the plants. The three operating units (Units 1, 2, and 3) automatically shut down, inserting all control rods into the respective reactors. Also, as a result of the earthquake, offsite power was lost to the entire facility. The emergency diesel

generators started at all six units providing alternating current (ac) electrical power to critical systems, and the facility response to the seismic event appears to have been normal.

Approximately 40 minutes after the earthquake and shutdown of the operating units, a large tsunami wave inundated the site, followed by multiple additional waves. The estimated height of the tsunami exceeded the height for which site protection features against tsunamis were designed by approximately 8 meters (27 feet). The tsunami resulted in extensive damage to site facilities and a complete loss of ac electrical power at Units 1 through 5 (i.e., a station blackout (SBO)). Unit 6 retained the function of one of the diesel generators.

Without ac power, the plants relied on batteries and turbine-driven and diesel-driven pumps for reactor core cooling (it should be noted that immediately after the tsunami, Units 1 and 2 were without 125 volt dc power too). The operators took actions to maintain core cooling functions well beyond the normal capacity of the station batteries. However, without sufficient offsite assistance, which appears to have been hampered by the devastation in the area, among other factors, Units 1 through 3 eventually lost the ability to further extend cooling of the reactor cores. This ultimately resulted in significant damage to the reactor cores in these units, the extent of which is still the subject of evaluation.

At varying points in time after the tsunami, Units 1, 3, and 4 experienced explosions, further damaging the facilities and containment and reactor buildings. The Unit 1 and 3 explosions were apparently caused by the buildup of hydrogen gas within containment produced during fuel damage in the reactor and subsequent movement of that hydrogen gas from the drywell into the reactor building. The explosion that occurred in Unit 4 may have involved hydrogen that was transported through a ventilation system connected to Unit 3.

As information about the damage to plant safety functions was gathered over the weeks and months following these events, many similarities became apparent between the calculated damage progression in the boiling-water reactor (BWR) SBO accident scenarios in the SOARCA analyses and the progression of events at Fukushima. These similarities include the following:

- the sequence and timing of events that followed the loss of core cooling, including the onset of core damage and fission product release from fuel,
- challenges to containment integrity that accompanied the loss of decay heat removal and the accumulation of hydrogen generated during in-vessel damage to reactor fuel, and
- the destructive effects of hydrogen combustion in the reactor building.

As noted in the discussion of hydrogen combustion below, the SOARCA analyses and the Fukushima events appear to have released hydrogen to the reactor building by different mechanisms. But in both cases, the end result was structural failure of the building and radionuclide release to the environment caused by energetic combustion. Similarities were also observed in characteristics of radionuclide release to the environment in the SOARCA calculations and early measurements of activity in the areas surrounding the Fukushima site.

Some notable differences in the events that unfolded at Fukushima and the BWR long-term SBO (LTSBO) scenario studied in the SOARCA project were also readily apparent. These differences led the NRC staff to take a closer look at the models used and assumptions made in the LTSBO analyses. The NRC's SOARCA team qualitatively compared the results from the SOARCA analyses to the preliminary events and information available at this early stage in the evaluation of the Fukushima Daiichi accident, and the results are discussed below.

The information used to evaluate these topics was gleaned from a variety of sources. Most important among these are the following:

- “Report of the Japanese Government to the IAEA [International Atomic Energy Agency] Ministerial Conference on Nuclear Safety,” June 2011 [[1]]
- “Special Report on the Nuclear Accident at the Fukushima Daiichi Nuclear Power Station,” Institute of Nuclear Power Operations (INPO), November 2011 [7]

Shortly after the accident, the NRC established a task force to conduct a methodical and systematic review of the agency's processes and regulations to determine whether it should make additional improvements to its regulatory system. The task force report, “Recommendations for Enhancing Reactor Safety in the 21st Century” [[2]], found, among other things, that prolonged SBO and multiunit events present challenges to emergency response. The task force report presented a number of recommendations that address physical, administrative, and regulatory enhancements to further reduce the risk of similar challenges occurring among the U.S. fleet of nuclear power plants.

Operation of the Reactor Core Isolation Cooling System

According to the “Report of Japanese Government to IAEA Ministerial Conference on Nuclear Safety” [[1]], and the Institute of Nuclear Power Operations (INPO) “Special Report on the Nuclear Accident at the Fukushima Daiichi Nuclear Power Station” [[7]], the RCIC system was used to maintain coolant injection to the reactor pressure vessel (RPV) for approximately 70 hours in Unit 2 and for 21 hours in Unit 3¹. The SOARCA study performed MELCOR analyses for the Peach Bottom station blackout scenarios shown in the following table.

¹ When the RCIC system tripped in Unit 3, a separate steam-driven high-pressure coolant injection system (HPCI) automatically started and ran for approximately 2 hours. Unit 1 has a different system (isolation condenser) and does not have the RCIC system.

	Start of RCIC operation (hours)	End of RCIC operation (hours)	Duration of RCIC operation (hours)
Fukushima Unit 2	0	70	70
Fukushima Unit 3	0	21	21
Peach Bottom unmitigated LTSBO	0	5	5
Peach Bottom unmitigated STSBO with RCIC blackstart	1	3	2
Peach Bottom unmitigated STSBO without RCIC blackstart	Not modeled	Not modeled	N/A

Note: The MELCOR analysis was truncated at 48 hours, as discussed below.

The operators at Fukushima Units 2 and 3 were able to successfully operate their RCIC systems to maintain water inventory within the core for a period of time that greatly exceeded the operating period assumed in the SOARCA calculations of the unmitigated LTSBO scenario.

In the SOARCA analysis of the unmitigated LTSBO scenario, the RCIC system operates for 4 hours while direct current (dc) power is available and an additional 1.2 hours after station batteries are exhausted² (i.e., RCIC blackrun). Measurement of the reactor water level would be lost at 4 hours, when station batteries that provide dc power to critical plant instrumentation are exhausted. This condition led to the assumption that manual operation of RCIC would maintain a constant (throttled) flow rate with the goal of maintaining the reactor coolant water level. However, as discussed in the detailed description of the MELCOR analysis of the unmitigated LTSBO scenario, sustained (constant flow) operation of RCIC after the loss of dc power would lead to an increase in the RPV water level and steamline flooding in approximately 1.2 hours. Flooding the main steamline would result in flooding the RCIC turbine, disabling the system. Overfilling the RPV is a consequence of the imbalance between the termination of coolant losses through safety relief valves (which reclose on a loss of dc power) and continued coolant addition by the RCIC system.

Flooding of the RCIC turbine by reactor vessel overfill does not appear to have occurred at Fukushima, and the operators successfully ran the system for an extended period of time in Units 2 and 3. One reason for the extended length of RCIC operation at Fukushima, in comparison to the unmitigated LTSBO timeline in the SOARCA analysis, is the station batteries at Fukushima were designed to provide dc power for a longer period of time than the batteries at Peach Bottom (8 hours for Fukushima versus 2 hours). At both plants, the actual duration of dc power would be longer than the design basis because of margins incorporated into the system design, as well as manual actions that can be taken to shed nonessential loads on the dc emergency bus. The maximum length of time that dc power was available at Fukushima appears to have been considerably longer than the maximum battery duration considered in the SOARCA analysis for Peach Bottom, even when load shedding is taken into account.

A second reason for the difference in RCIC operating time is that manual actions taken at Fukushima to manage RCIC operation after the loss of dc power appear to have differed from

² RCIC is a steam-driven coolant injection system that does not require ac power for it to start or operate as a coolant injection system. Steam flow to the RCIC turbine can be remotely controlled with dc power from the station batteries. However, manual operation using valve handwheels (i.e., blackstart, blackrun) is also possible.

those assumed in the unmitigated LTSBO scenario. The precise actions taken by TEPCO operations personnel to control RCIC flow in Units 2 and 3 are not known. However, it is clear that RCIC flow at Fukushima Units 2 and 3 was regulated at values that prevented overflow of the RPV and flooding of the main steamlines. The INPO report [7] indicates portable electric generators were installed and power was restored to critical plant instrumentation in the control room, including RPV water-level measurement. This action facilitated control of RCIC flow to maintain the RPV level at desired values. The SOARCA analysis of the unmitigated LTSBO sequence did not credit staging and alignment of portable electric generators (i.e., equipment required in Title 10 of the *Code of Federal Regulations* (10 CFR) 50.54(hh)). The 10 CFR 50.54(hh) equipment at Peach Bottom also includes portable coolant pumps, which, according to the SOARCA analyses, would satisfactorily maintain core cooling and avert core damage if aligned and operated successfully. Therefore, differences in operator actions to manage RCIC flow after the loss of dc power versus those assumed for SOARCA, as well as differences in the availability of portable mitigation equipment, contributed to differences in the timeline of events at Fukushima versus the timeline calculated for the unmitigated LTSBO scenario.

Finally, the RCIC system in Fukushima Units 2 and 3 appears to have run for many hours under conditions that exceed established operating limits for the turbine-driven pumps. The reason that the RCIC pumps eventually stopped running is not known. However, preliminary DOE/NRC forensic analysis of event progression at Units 2 and 3 indicate the torus water temperature in both units exceeded values that would have challenged pump operation because of loss of adequate net positive suction head, vibration and mechanical damage from pump cavitation, or overheating of pump bearings caused by inadequate cooling. The SOARCA models did not anticipate nor incorporate sustained endurance of the RCIC system (well beyond design limits).

These differences in the factors contributing to the duration of RCIC operation at Fukushima and the SOARCA analyses result in two differences in the observed chronology of events that follow the eventual loss of coolant injection. First is the difference in the times at which core damage and fission product release to the environment begin. These events were predicted to begin at 20 hours in the SOARCA unmitigated LTSBO analysis, but they began at Fukushima Units 2 and 3 on the third and second day of the accident, respectively. Second, sustained operation of the RCIC system at Fukushima resulted in a larger cumulative transport of heat from fission product decay (in the form of steam) from the RPV to the suppression pool in the containment (torus). Suppression pool temperatures at the time the RCIC pumps ceased operating in Fukushima Units 2 and 3 were, therefore, much higher than the calculated pool temperature in the SOARCA analysis of the unmitigated LTSBO scenario. Increases in suppression pool temperature result in additional evaporation of water from the pool to the containment atmosphere; this in turn results in an increase in containment pressure. Therefore, containment pressure in the Fukushima reactors at the time core damage began was higher than the pressure calculated in the Peach Bottom LTSBO scenario. When hydrogen, generated by oxidation of Zircaloy cladding in the core, was released to the containment atmosphere, containment pressure increased further. The combination of a high base pressure from long-term evaporation of steam and accumulation of noncondensable hydrogen gas in the Fukushima containments likely resulted in pressures that were sufficiently high to induce leakage through the drywell head flange while in-vessel core damage was underway. Release of hydrogen to the reactor building

through the drywell head flange likely led to the destruction of the Fukushima reactor buildings by hydrogen combustion. In contrast, the shorter duration of RCIC operation in the unmitigated LTSBO scenario resulted in less heating of the suppression pool, less evaporation of water to the containment atmosphere, and a lower base pressure in containment at the time core damage and hydrogen generation began.

The extended period of core cooling by sustained RCIC operation at Fukushima affected more than the timeline for core damage and containment pressure at the time core damage began. The mechanisms for hydrogen (and fission product) leakage out of containment into the reactor building were affected by differences in containment thermodynamic conditions, which were influenced by the operation of the steam-driven RCIC system.

Hydrogen Release and Combustion

The physical damage to Fukushima reactor buildings will perhaps be the most enduring visible image of plant damage initiated by the earthquake and tsunami in Japan in March 2011. The apparent cause was combustion of hydrogen that was generated by high-temperature oxidation of fuel cladding. Extensive cladding oxidation and core material melting is believed to have occurred in Fukushima Units 1, 2, and 3, although the timelines for core damage differed in each unit because of differences in equipment and operator response.

At Fukushima Units 1 and 3, hydrogen generated from the oxidation of fuel cladding in the core was likely transported from the RPV to the containment (drywell and wetwell) through an open or cycling safety relief valve. Hydrogen is predicted to be released to the containment by the same pathway in the unmitigated SOARCA scenarios. The precise pathway by which hydrogen was released from the containment to the reactor building at Fukushima is uncertain. The Japanese Report to the IAEA [[1]] suggests the pathway was leakage through the drywell head flange, which is normally sealed by a pair of O-ring seals. High internal pressures developed within the drywell as a consequence of the failure of engineered systems for containment heat removal from loss of ac power from various causes and the accumulation of noncondensable hydrogen. The resulting mechanical loads transmitted to the drywell head and closure bolts are believed to have resulted in leakage past the closure seals, through the head flange to the upper portion of the reactor building. The Japanese government report [[1]] suggests this leakage pathway developed in all three units in which core damage occurred (Units 1, 2, and 3).

Leakage across the drywell head flange is modeled in the SOARCA scenarios. Opening criteria for this leak pathway are based on NRC calculations of the internal pressure required to cancel the compressive force on the closure head flange created by the torque applied to the head bolts. Only one of the SOARCA calculations (unmitigated LTSBO) resulted in a drywell pressure sufficiently high to open this release pathway before drywell liner melt-through. In this case, the liner melt-through occurs shortly after head flange leakage begins. As a result, in the SOARCA scenarios, significant hydrogen release to the reactor building occurs only after mechanical failure of the containment pressure boundary, which in the SOARCA calculations results from molten debris failing the drywell liner after RPV lower head failure (i.e., drywell liner melt-through). Containment failure by this mechanism is not believed to have occurred in any of the units at Fukushima. However, the Japanese government report suggests the possibility of

some amount of molten debris being released from the RPV lower head to the drywell floor within the reactor pedestal in Units 2 and 3. Additionally, TEPCO has announced that a recent analysis of Unit 1 (accident simulations performed with the MAAP computer code) suggest the bulk of the fuel was released into the drywell through RPV lower head failure [1]. TEPCO concluded from this analysis that fuel released to the drywell floor eroded approximately 70 centimeters (2.3 feet) of concrete on the drywell floor within the reactor pedestal, but the fuel did not move laterally across the drywell floor.

The BWR MELCOR model used in the SOARCA calculations ignites and burns hydrogen in regions of the reactor building where local concentrations satisfy assumed flammability criteria (see NUREG/CR-7110, Volume 1). The pressure generated by hydrogen combustion within the reactor building results in opening the blowout panels in the walls of the refueling floor. In the station blackout scenarios examined in the SOARCA calculations, the combustion pressure is sufficiently high to also fail (open) many doorways within the building (e.g., into and out of the stairwells) and the large railroad access doorways to the environment at grade level. Structural failure of the steel roof of the reactor building can also occur, if these pathways are insufficient to relieve the internal pressure generated by hydrogen combustion. Roof failure was calculated to have occurred in the SOARCA short-term SBO (STSBO) scenario but not in the LTSBO scenario.

Generation of hydrogen from oxidation of fuel stored in the SFP of Fukushima Unit 4, which was shut down for maintenance at the time of the accident, is not believed to have occurred in significant quantities. However, the Unit 4 reactor building was severely damaged, apparently by the combustion of hydrogen that leaked into the building. It has been proposed that the source of hydrogen in the Unit 4 reactor building was hydrogen that flowed through piping that connects the standby gas treatment system (SGTS) in Unit 3 to a parallel system in Unit 4. Hydrogen may have entered the SGTS system in Unit 3 when containment venting was performed, because the containment vent system at Fukushima allows the operator to direct gases through the SGTS for filtration before being released to the stack³. Although venting through a similar pathway is possible at Peach Bottom (e.g., opening the containment ventilation system, which is connected to the SGTS), a different release pathway for containment venting is simulated in the SOARCA calculations for Peach Bottom⁴. Virtually all BWR Mark I containments in the United States have a hardened vent that bypasses the normal containment ventilation system and associated SGTS and vents the containment atmosphere directly to the environment. This pathway bypasses the SGTS filters and is comprised of rigid piping rather than the thin metallic ductwork common to building ventilation systems. As a result, hydrogen gas would be discharged to the environment, rather than leaking to the reactor building through leaks or ruptures in ventilation duct work, which would not likely survive the internal pressure

³ The precise configuration of the containment vent pathway used at Fukushima is not clear in terms of its discharge location relative to the SGTS filters. The INPO report describes a configuration that bypasses SGTS. However, as noted earlier, SGTS ductwork is believed to be the path by which hydrogen flowed from Unit 3 into Unit 4.

⁴ Selection of a containment venting pathway is a proceduralized action at Peach Bottom and includes an assessment of potential adverse characteristics of each pathway. For example, venting through the drywell (or wetwell) ventilation system to SGTS could adversely affect the environment in the reactor building if relatively weak ventilation ductwork were to fail because of high internal pressure, releasing hydrogen and radioactivity into the reactor building. This could cause accessibility issues for other operator actions.

anticipated if containment venting were to become necessary. Therefore, hydrogen leakage to the reactor building would not occur as a result of containment venting if the hardened vent is used, as assumed in the SOARCA models. While hardened vents that allow the operator to bypass the SGTS filters were installed at Fukushima between 1999 and 2001, it is unclear whether they were used during the March 2011 events.

48-Hour Truncation of Releases in SOARCA

The 48-hour truncation time for SOARCA was based on the many resources available at the State, regional, and national level that would be available to mitigate a severe reactor accident. The staff reviewed available resources and emergency plans and determined that adequate mitigation measures (at minimum, the ability to flood the reactor building) could be brought onsite within 24 hours and connected and functioning within 48 hours. The decision to truncate releases at 48 hours (72 hours for the Surry LTSBO) was made well before the Fukushima accident. Based on the assumptions made for SOARCA, the releases that would occur within 48 hours for the Peach Bottom unmitigated scenarios cease because of reactor building flooding. For Fukushima, as discussed above, the operators delayed releases beyond the SOARCA assumption, so substantial releases occurred beyond 48 hours. In addition, the operators at Fukushima were not able to flood the reactor buildings, as assumed for SOARCA.

For mitigated cases, the SOARCA analysis assumed the effectiveness of mitigation measures well within 48 hours. This assumption is considered reasonable, given the vast network of resources available in the United States. These resources include an offsite emergency operations facility, which would provide access to fleetwide emergency response personnel and equipment, including the 10 CFR 50.54(hh) mitigation measures and equipment from sister plants. These assets, as well as those from neighboring utilities and State preparedness programs, could be brought to bear on the accident if needed. In addition, SOARCA did not assume a tsunami, and such an event is considered highly unlikely at Peach Bottom and Surry. If sites were subject to tsunamis, these events could affect the availability and effectiveness of mitigation measures. In response to the recommendation of the NRC's Near Term Task Force report, SECY-11-0093, dated July 12, 2011, the NRC is currently evaluating whether changes to mitigation strategies are warranted.

Multiunit Risk

As demonstrated by the Fukushima accident, severe accidents that affect multiple reactors located at a common site are possible. Such accidents may happen following an initiating event that simultaneously challenges all reactors (e.g., earthquakes, tsunamis, loss of the electrical power grid) or following an accident in a single reactor that cascades to other reactors through interconnected electric power or cooling water systems, or inaccessibility to areas of the plant because of an ongoing radioactive release at one unit. An example of physical interactions for multiunit risk is the ad hoc installation of a temporary power cable from a mobile electric power supply to the standby liquid control pump in the Fukushima Unit 2 reactor building [[7]]. TEPCO personnel completed their work to install this equipment minutes before the explosion in the Unit 1 reactor building occurred. Debris generated by the explosion in Unit 1 damaged the

temporary cables and the power supply vehicle in Unit 2, defeating earlier actions to recover the standby liquid control pump as a resource for high-pressure coolant injection.

Although beyond the scope of the SOARCA project, the NRC staff previously recognized the potential risks of multiunit accidents and has taken steps to further analyze them. As a result of the SOARCA analyses, the NRC established a generic issue to further consider the implications of multiunit accidents. Subsequently, in SECY-11-0089 [[3]], the staff proposed a site-wide Level 3 probabilistic risk assessment (PRA) that included an analysis of multiunit accidents initiated by internal and external causes during any plant operating mode. The scope of this proposed analysis includes all spent fuel stored onsite either in SFPs or in dry casks in addition to all reactors. The proposed analysis would assess the radiological consequences from multiple releases that may occur at separate times. In its staff requirements memorandum dated September 21, 2011 [[3]], the Commission directed the staff to complete the site-wide Level 3 PRA project within 4 years.

Spent Fuel Pool Risk

The SOARCA analyses did not include impacts on the spent fuel pools (SFPs) for either Peach Bottom or Surry. However, various recent risk studies, most recently NUREG-1738, “Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants,” issued February 2001 [[4]], have shown that storage of fuel in a high-density configuration in SFPs is safe and that the risk of a significant release of radioactive materials as a result of loss of SFP cooling is expected to be less than reported in previous studies. More advanced analyses of SFPs have been conducted as part of the NRC’s post-9/11 security assessments. However, these are not publicly available because of their sensitive nature. The agency has since restated its views that spent fuel is stored safely in high-density configurations in a response to SECY-08-0036, “Denial of Two Petitions for Rulemaking Concerning the Environmental Impacts of High-Density Storage of Spent Nuclear Fuel in Spent Fuel Pools (PRM [Petition for Rulemaking]-51-10 and PRM-51-12),” dated June 19, 2008 [[5]], as well as the revision to NUREG-1437, “Generic Environmental Impact Statement for License Renewal of Nuclear Plants—Draft Report for Comment,” issued July 2009 [[6]]. Partly because of changes in the path forward of the planned Yucca Mountain geologic repository and the Fukushima accident, interest in the safety of spent fuel storage has recently increased. Therefore, the NRC has commissioned an SFP scoping study, which started in 2011, aimed at updating the estimation of radiological consequences of a severe accident on SFPs with both high-density and low-density storage configurations. The scenario considered in the study is a beyond-design-basis seismic event in the range of 0.5 to 1 g peak ground acceleration. The study involves seismic and structural analysis of the earthquake and its effects on the SFP; thermal-hydraulic and severe accident progression modeling with the MELCOR computer code; emergency preparedness and response; and, finally, offsite consequence analyses with the MACCS2 code. The plan is to document the results of the study in a publicly available report within the next year.

In the analyses presented in this report, hydrogen produced by oxidation of Zircaloy, whether produced in-vessel during core degradation, or ex-vessel by core-concrete interactions, is predicted to be burned in compartments of the reactor building as released via the failure of the drywell liner by melt-attack. These burns occur as flammability conditions are attained, mainly

as hydrogen concentrations increase to the point that combustion can occur. The burns produce sufficient building over pressure to open the refueling bay blowout panels and blow open doors in the building. The explosions that were observed in the accidents at Fukushima were significantly larger than predicted in the SOARCA analyses, perhaps involving detonations where ignition might have taken place at higher concentrations than predicted in SOARCA. The damage to the Fukushima Unit 3 refueling bay was especially significant with building debris (steel and concrete) falling into the spent fuel pool, also located in the refueling bay. The debris observed in the Unit 3 spent fuel pool may well have mechanically damaged some of the fuel assemblies stored there; however, isotopic analysis of the pool water performed by TEPCO for radioactive contamination does not suggest any significant releases from the fuel rods. Moreover, the water of the spent fuel pool provides massive scrubbing capability for any released fission products such that this potential source for environmental release becomes vanishingly small. The structural damage could, on the other hand, present engineering challenges for maintaining long term cooling of the fuel stored in the pool in the days and weeks following the accident. For these reasons, SOARCA did not consider source terms from ancillary damage to the spent fuel pool from hydrogen deflagrations.

References

- [1] Nuclear Emergency Repose Headquarters - Government of Japan, "Report of the Japanese Government to the IAEA Ministerial Conference on Nuclear Safety - The Accident at TEPCO's Fukushima Nuclear Power Stations," IAEA Ministerial Conference on Nuclear Safety, Vienna, Austria, June 7, 2011.
- [2] Miller, C., et al., "Recommendations for Enhancing Reactor Safety in the 21st Century - The Near-Term Task Force Review of Insights from the Fukushima Daiichi Accident," SECY-11-0093, Nuclear Regulatory Commission, Washington DC, July 12, 2011.
- [3] U.S. Nuclear Regulatory Commission (NRC), "Options for Proceeding with the Future Level 3 Probabilistic Risk Assessment Activities," SECY-11-0089, Nuclear Regulatory Commission, Washington DC, September 21, 2011.
- [4] U.S. Nuclear Regulatory Commission, "Technical Study of Spent Fuel Pool Accident Risk at Decommissioning Nuclear Power Plants," NUREG-1738, U.S. Nuclear Regulatory Commission, Washington DC, February, 2001.
- [5] U.S. Nuclear Regulatory Commission, "Denial of Two Petitions for Rulemaking Concerning the Environmental Impacts of High-Density Storage of Spent Nuclear Fuel in Spent Fuel Pools (PRM-51-10 and PRM-51-12)," SECY-08-0036, Nuclear Regulatory Commission, Washington DC, June 19, 2008.
- [6] U.S. Nuclear Regulatory Commission, "Generic Environmental Impact Statement for License Renewal of Nuclear Plants - Draft Report for Comment," NUREG-1437 Volume 1, Revision, Nuclear Regulatory Commission, Washington DC, July, 2009.
- [7] Institute of Nuclear Power Operations, "Special Report on the Nuclear Accident at the Fukushima Daiichi Nuclear Power Station," INPO-11-005, Institute of Nuclear Power Operations, Atlanta, GA, November 2011.

APPENDIX B

**SOARCA PEER REVIEW COMMITTEE FINAL LETTERS
AND
SOARCA PEER REVIEW COMMENT RESOLUTION REPORT**

The SOARCA team assembled a panel of independent, external technical experts from industry, consulting, academia, and research laboratories to review the SOARCA analyses and assure their technical accuracy. The 11 members of the committee possess technical expertise in the fields of severe accident phenomenology and modeling; plant design, operation, and maintenance; mitigation measures; offsite emergency planning, preparedness, and response; radiological health consequences; seismic and structural analysis; and probabilistic risk assessment applications. In addition to ensuring technical accuracy, the committee also assessed whether the underlying technical work supported the project’s conclusions.

The SOARCA team provided draft reports of NUREG-1935, “State-of-the-Art Reactor Consequence Analyses (SOARCA) Report,” and NUREG/CR-7110, Volume 1, “SOARCA Peach Bottom Integrated Analysis,” and Volume 2, “SOARCA Surry Integrated Analysis,” to the peer review committee at various points and held meetings with the members of the committee in July 2009, September 2009, March 2010, October 2010, and December 2011. During some of these meetings, the NRC staff explained how peer reviewer comments were considered and addressed.

The final letters from the individual members of the peer review committee are provided in this appendix. Individual letters, rather than a consensus report, were provided so that each member’s points of view could be fully expressed. The entirety of the final peer review committee report is publicly available in the NRC’s Agencywide Documents Access and Management System (ADAMS) at Accession No. [ML120610005](#).

This appendix also includes the NRC letter providing resolutions of open peer review comments from the March 2010 and October 2010 meetings, which is also publicly available at ADAMS Accession No. [ML11118A056](#).

In addition, the full documentation of all interactions with the peer review committee is publicly available at ADAMS Accession No. [ML121250030](#).

Contents

Peer Review Committee Final Letters, January 2012.....	B-2
NRC Comment Resolution Report, July 2011.....	B-89

**PEER REVIEW OF THE STATE-OF-THE-ART
REACTOR CONSEQUENCE ANALYSIS (SOARCA)
PROJECT**

Manuscript Completed: January 2012

Prepared by:

Ken Canavan, Electric Power Research Institute (EPRI);
Bernard Clément, Institut de Radioprotection et de Sécurité Nucléaire;
Jeff R. Gabor, ERIN Engineering;
Robert E. Henry, Fauske and Associates;
Roger B. Kowieski, Natural and Technological Hazards Management Consulting, Inc.
(NTHMC);
David E. W. Leaver, WorleyParsons Polestar;
Bruce B. Mrowca, Information Systems Laboratories;
Kevin R. O’Kula, URS Safety Management Solutions;
John D. Stevenson, JD Stevenson Consulting Engineer Company;
Karen Vierow, Texas A&M University;
Jacquelyn C. Yanch, Massachusetts Institute of Technology

Prepared for:

Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555

TABLE OF CONTENTS

	Page
1. Introduction.....	1
1.1 Importance of SOARCA Peer Review.....	1
1.2 Peer Review Objectives.....	1
1.3 Peer Review Committee Members.....	2
1.4 Report Organization.....	4
2. Peer Review Process.....	5
2.1 Committee Charter.....	5
2.2 Peer Review Scope.....	5
2.3 Coverage of SOARCA Topics by Committee Members' Areas of Expertise.....	5
2.4 Peer Review Approach and Methodology.....	7
3. Individual Assessments from Peer Review Committee Members.....	9
3.1 Ken Canavan.....	10
3.2 Bernard Clement.....	14
3.3 Jeff Gabor.....	19
3.4 Robert Henry.....	24
3.5 Roger Kowieski.....	29
3.6 David Leaver.....	34
3.7 Bruce Mrowca.....	42
3.8 Kevin O'Kula.....	46
3.9 John Stevenson.....	53
3.10 Karen Vierow.....	55
3.11 Jacquelyn Yanch.....	60
Appendix A Peer Review Comments Submitted to the SOARCA Liaison following July 2009 Meeting.....	A-1
Appendix B Peer Review Comments Submitted to the SOARCA Liaison following September 2009 Meeting.....	B-1
Appendix C Comments on SOARCA Document Description Submitted to the SOARCA Liaison following March 2010 Meeting.....	C-1
Appendix D Memo Providing Guidance on SOARCA Issues.....	D-1
Appendix E Memo on Uncertainty Quantification and Sensitivity Analysis.....	E-1
Appendix F Memo Providing Guidance on the Uncertainty Analysis Methodology.....	F-1

1. Introduction

1.1 Importance of SOARCA Peer Review

The Nuclear Regulatory Commission (NRC) is conducting the State-of-the-Art Reactor Consequence Analysis (SOARCA) to update evaluations of hypothetical severe accident progression and offsite consequences in nuclear reactors. SOARCA originated in efforts to assess nuclear power plant response to security-related events. The project aims to provide more realistic assessments of the risks posed by nuclear power plants by reducing excessive conservatism in earlier evaluations and incorporating the most recent plant information and analysis technologies. An anticipated result is a major change in the general public's perceptions of nuclear reactor safety.

In this context, the SOARCA incorporates insights and analysis techniques that are significantly different from those used in previous consequence analyses, along with updated information on plant improvements and security-related enhancements. The advances and changes in these areas represent major improvements in the knowledge of severe accidents and risks to the public health.

The SOARCA Peer Review Committee was appointed to provide an independent review of these updated analyses. Technical experts from industry, consulting, academia, and research laboratories have been assembled to assess all aspects of the project in an impartial manner and provide guidance and suggestions. The Committee possesses extensive knowledge regarding plant design, operation and maintenance, safety and security-related equipment, severe accident phenomenology, emergency preparedness, and radiological health consequences and analysis thereof.

The SOARCA integration of analysis tools and techniques, along with incorporation of recent plant improvements and security-related enhancements, represents a new application of the state-of-the-art analysis techniques. The Peer Review Committee fills the essential role of reviewing the technical work performed under the SOARCA. The scope of review includes correctness of information used, assumptions, analysis methodologies, application of current standards, and practices and interpretation of results.

1.2 Peer Review Objectives

The main objective of the Peer Review Committee is to provide independent reviews by each Committee member of the technical work conducted within the SOARCA project. The primary focus is to assure that the SOARCA study is technically accurate.

Guidance with respect to specific issues, as requested by NRC staff, and comments on the effectiveness of presentation within the SOARCA NUREG documents to the public have also been offered by the Committee members.

1.3 Peer Review Committee Members

The Peer Review Committee is comprised of the following eleven technical and scientific experts.

- Ken Canavan, a Senior Program Manager in the Risk and Safety Management (RSM) program for the Electric Power Research Institute (EPRI), reviewed accident sequence selection and progression. For the last 24 years he has worked in the risk and safety discipline for nuclear utilities, consultants, and most recently EPRI on the development of probabilistic risk assessments (PRA), PRA methods, risk-informed applications, peer certification process, and several unique applications of risk technology. Mr. Canavan earned a Bachelor of Engineering in Chemical Engineering with a nuclear sequence from Manhattan College.
- Bernard Clément, senior expert at France's Institut de Radioprotection et de Sûreté Nucléaire, reviewed accident progression and radiological release. His 30-plus years in nuclear safety research have examined light-water reactor design-basis and beyond design-basis accidents as well as liquid-metal fast-breeder reactor safety. Clément has chaired the scientific analysis working groups of the Phebus FP and International Source Term Programs. He is a graduate of the French Ecole Centrale de Paris.
- Jeff R. Gabor, vice president of the risk management group for ERIN Engineering, reviewed accident progression and radiological release. In more than 25 years of nuclear power plant safety experience, he has worked on numerous Level 2 Probabilistic Safety Analysis (PSA) updates, supported several utilities' severe accident and thermal-hydraulic analyses, and developed severe accident mitigation guidance, and he was a principal author of the Boiling Water Reactor Modular Accident Analysis Program. He earned a Bachelor of Science in nuclear engineering and a Master of Science in mechanical engineering from the University of Cincinnati.
- Robert E. Henry, senior vice president and co-founder of Fauske and Associates, reviewed accident progression and radiological release. Henry's more than 40 years of nuclear safety and engineering experience include work on light-water reactor response to severe accidents and severe accident management guidelines for all commercial U.S. reactors. He earned his bachelor's, master's and doctoral degrees in mechanical engineering from the University of Notre Dame.
- Roger B. Kowieski, president of Natural and Technological Hazards Management Consulting, Inc. (NTHMC), reviewed off-site emergency planning and response. His 30 years of experience cover a very broad spectrum of emergency planning and preparedness including reviews of radiological and chemical hazards assessment reports; development of protective actions decision making trees; development of lesson plans and trainee manuals; conducting of training sessions for facility personnel; design and evaluation of Radiological Emergency Preparedness (REP) exercises for nuclear power plants for FEMA. While with FEMA until 1988, he served as a FEMA expert witness before the NRC Atomic Safety and Licensing Boards (ASLBs) in connection with licensing actions on the Indian Point and Shoreham Nuclear Power Stations. He currently serves as the Regional Coordinator, assisting FEMA Region 3 in the planning

and execution of all REP exercises in this region. Kowieski earned his Master of Science degree in Environmental Engineering from Wroclaw Polytechnic, Wroclaw, Poland.

- David E. W. Leaver, a senior vice president and principal at WorleyParsons Polestar, reviewed radiological release, emergency response, and offsite radiological consequences. He performed some of the earliest PRA studies of nuclear plants during his more than 30 years in reactor safety, risk assessment, radiological source term and accident analysis, emergency planning support to the nuclear industry, and meteorological analysis. Leaver earned his Bachelor of Science in electrical engineering from the University of Washington, and earned his Master of Science in engineering economic systems and a doctorate in mechanical engineering from Stanford University.
- Bruce B. Mrowca, vice president and manager for nuclear system analysis operations of Information Systems Laboratories, reviewed probabilistic risk assessment (PRA) sequence selection and mitigation measures. His more than 25 years of experience in commercial nuclear power include PRA development and application, instrumentation and control design and fire protection analysis. He earned his Bachelor of Science in electrical engineering from the University of Maryland.
- Kevin R. O’Kula, of URS Safety Management Solutions, reviewed offsite radiological consequences. For more than 26 years O’Kula has examined topics including accident and consequence analysis, source term evaluation, commercial and production reactor PRA and severe accident analysis, and safety software quality assurance. He earned his Bachelor of Science in applied and engineering physics from Cornell University, and his Master of Science and doctorate in nuclear engineering from the University of Wisconsin.
- John D. Stevenson, a senior consultant at JD Stevenson Consulting Engineering Company, reviewed structural and seismic issues. His 35 years of experience include developing structural and mechanical construction and design criteria for qualifying nuclear power plants, structures, systems and components applications to resist extreme natural and man-induced hazards. Stevenson earned his Bachelor of Science in civil engineering from Virginia Military Institute, and his Master of Science and doctoral degrees in civil engineering from Case Institute of Technology. He currently is chairman of the Technical Advisory Committee to the International Atomic Energy Agency Seismic Safety Center.
- Karen Vierow, associate professor of nuclear engineering at Texas A&M University, chaired the Committee and reviewed severe accident modeling. Her 20 years of experience in nuclear engineering focus primarily on thermal hydraulics, reactor safety, severe accidents and reactor design. Vierow earned a Bachelor of Science in nuclear engineering from Purdue University and a Master of Science in nuclear engineering from the University of California at Berkeley. She earned her doctorate in quantum engineering and system sciences from the University of Tokyo.
- Jacquelyn C. Yanch is Professor of Nuclear Science and Engineering at the Massachusetts Institute of Technology where she has been a member of the faculty since 1989. Yanch reviewed the off-site radiological consequences. Her research deals with the production, detection, applications, and health effects of ionizing radiation and

involves both physical experimentation and computational dosimetry applied to human irradiations. Current experimental work involves long-term irradiations of cell and animals at low dose-rates. In 2009 Professor Yanch also became a member of the MIT Department of Biological Engineering. Yanch has served on the MIT Reactor Safeguards Committee and the Committee on Radiation Exposure of Human Subjects and has been a member of the MIT Radiation Protection Committee for 20 years.

1.4 Report Organization

Section 2 of this report describes the Peer Review Committee charter and scope of review. The coverage of SOARCA topics is explained and the peer review approach is discussed.

Each Committee member's individual assessment of the SOARCA effort is included in Section 3.

The Appendices include comments and suggestions that the Peer Review Committee members have provided to the SOARCA point of contact throughout the review process.

2. Peer Review Process

2.1 Committee Charter

The Peer Review Committee's charter is to provide independent reviews of the technical work conducted by the NRC and Sandia National Laboratories for the SOARCA project. The primary focus is to assure that the SOARCA study is technically accurate. The Committee is also to assess whether the conclusions and the Executive Summary are supported by the underlying technical work presented in the draft SOARCA NUREG report.

Guidance with respect to presentation within the SOARCA NUREG documents of the results to the general public may also be offered by the Committee.

The final deliverable is this technical report documenting the findings of individual Committee members.

The Committee began its work in July 2009 and submitted the final version of this report in January 2012.

2.2 Peer Review Scope

The scientific and technical experts on the Committee were requested to assess the methodological approach, underlying assumptions, results and conclusions obtained for Peach Bottom and Surry reactors. The Committee members also commented on the presentation of the SOARCA evaluations within the SOARCA NUREG documents.

The documents reviewed included draft SOARCA NUREG documents, presentation materials provided at Peer Review Committee meetings, comment resolution documents and supporting documents that were supplied at the Committee's request. The draft SOARCA NUREG document dated Dec. 23, 2011 (Main Report), Oct. 12, 2011 (Volume 1) and Nov. 17, 2011 (Volume 2) is the latest version available to the Committee at the time of preparation of this report.

The scope of the review does not include the Uncertainty Quantification and Sensitivity Analysis. However a proposed Uncertainty Analysis methodology was presented to the Committee on Oct. 26-27, 2010 and a peer review guidance memo was requested to be included in this report as an attachment. The parameters and their distributions to be used in the Uncertainty Analysis were presented to the Committee on January 5, 2012.

The current effort also does not include editorial review of the SOARCA documents.

2.3 Coverage of SOARCA Topics by Committee Members' Areas of Expertise

Peer Review Committee members reviewed the SOARCA according to their areas of expertise as follows:

Accident sequence selection

Ken Canavan
Bruce Mrowca

Accident progression

Ken Canavan
Bernard Clément
Jeff Gabor
Robert Henry

Mitigation measures

Jeff Gabor
Robert Henry
Bruce Mrowca

Radiological release

Bernard Clément
Jeff Gabor
Robert Henry
David Leaver

Off-site emergency planning and response

Roger Kowieski
David Leaver

Off-site radiological consequences

David Leaver
Kevin O’Kula
Jacquelyn Yanch

Seismic issues

John Stevenson

Structural issues

John Stevenson

Probabilistic Risk Assessment applications

Ken Canavan
Bruce Mrowca

Severe accident modeling

Jeff Gabor
Robert Henry
Karen Vierow

2.4 Peer Review Approach and Methodology

Five meetings were conducted between the Peer Review Committee members and the SOARCA team. Prior to each meeting, SOARCA documentation was transmitted to the Committee for review.

The first meeting between the Committee members and the SOARCA team was held in Rockville, MD on July 28-29, 2009. A draft of the SOARCA NUREG document, dated July 2009, was received for review prior to the meeting. The SOARCA team presented the project to the Committee members and initial comments and questions were discussed verbally. Following the meeting, the Committee provided written comments on the SOARCA document and information presented at the two-day meeting, as documented in Appendix A.

The second meeting was conducted on September 15-16, 2009 in Bethesda, MD. Prior to this meeting, supplemental materials including reports of MELCOR and MACCS external review committees, the 1982 Sandia Siting Study and a memo from Dana Powers on fission product retention in steam generator tubes were transmitted to the Committee members. The SOARCA team presented the latest results to the Committee members and comments and questions were discussed verbally. Following the meeting, the Committee provided written comments on the SOARCA document and information presented at the two-day meeting, as documented in Appendix B.

The third meeting was conducted on March 2-3, 2010 in Rockville, MD. A draft of the SOARCA NUREG document, dated February 14, 2010, was received for review prior to the meeting. Presentations by the SOARCA team on the first day focused on comment resolution and plans for Uncertainty Quantification and Sensitivity Analysis. Through discussion with the SOARCA team, the latter effort was determined to be outside of the Committee's charter. The second day of meetings was primarily for discussions amongst the peer reviewers and small-group meetings with members of the SOARCA team, as requested by the peer reviewers.

Several action items arose from this meeting. First, the Committee members were asked to provide written comments on the description of the SOARCA in the draft NUREG. These comments are included in Appendix C. Second, issues arose for which the SOARCA team requested guidance on a time scale shorter than that for preparation of the Committee's final report. This memo is attached as Appendix D. Third, the Committee members were asked for their insights into the Uncertainty Quantification and Sensitivity Analysis, an issue which several members were interested in but which was determined to be outside of the review scope. This memo is attached as Appendix E.

The fourth was held on October 26-27, 2010 in Rockville, MD. For meeting preparation, the reviewers received a draft plan for the Uncertainty Analysis, dated Oct. 19, 2010, a draft NUREG/CR on uncertain input parameters for use in off-site consequence analysis codes and an ORNL report documenting an uncertainties in cancer risk coefficients. The SOARCA team discussed the June 2010 ACRS meeting, the proposed Uncertainty Analysis technical approach and resolution of peer review comments from earlier meetings. On the second day, the peer reviewers discussed completion of this report.

Action items arising in this meeting were to: prepare a list of unresolved review comments; draft a guidance memo on the Uncertainty Analysis; and finalize this report. The guidance memo is included herein as Attachment F.

The fifth and final meeting was held in Rockville, MD on Dec. 6-8, 2011. Prior to this meeting, the reviewers received the draft SOARCA NUREG document dated Nov. 29, 2011 (Main Report), Oct. 12, 2011 (Volume 1) and Nov. 17, 2011 (Volume 2). The SOARCA team presented changes in SOARCA analyses and results since the previous meeting on the first two days. On the third day, a description of the MELCOR code validation effort was provided and discussed.

The SOARCA team provided a written response to reviewer comments to date on July 29, 2011. A teleconference between the SOARCA team and the peer reviewers was conducted on Sept. 5, 2011 to discuss the responses and clarify whether the reviewers had any remaining issues.

Another teleconference was held on Jan. 5, 2012 to explain to the peer reviewers the selection of parameters being used in the Uncertainty Analysis and their distributions. The reviewers have not seen the results or conclusions of the Uncertainty Analysis at the time of preparation of this final report.

The final deliverable of the Peer Review Committee is a report to the SOARCA team documenting the technical findings of the individual peer reviewers. The report has been assembled and coordinated through the Peer Reviewer Committee chair.

A consensus opinion of the Committee has not been pursued or documented during the review process. All of the written materials described above, which were provided to the SOARCA team by the reviewers, have been assembled by and coordinated through the Peer Review Committee chair. Each reviewer's assessment of SOARCA has been transmitted as received, without editing or other modification.

3. Individual Assessments from Peer Review Committee Members

Individual assessments of the SOARCA by each Peer Review Committee member are included in the next page, in alphabetical order by reviewers' last names. These assessments are included exactly as they were transmitted to the Chair of the Committee and have not been edited in any manner.

Individual Input from Review of State-of-the Art Consequence Analysis (SOARCA)

**Ken Canavan, Senior Program Manager
Risk and Safety Management (RSM)
Electric Power Research Institute**

Overview

As stated in “State-of-the-Art Reactor Consequence Analysis (SOARCA) Project Methods,” the overall objective of SOARCA is to develop a body of knowledge regarding the realistic outcomes of severe reactor accidents. Supporting objectives include:

- incorporate plant improvements and updates not reflected in earlier assessments
- incorporate state-of-the-art integrated modeling of severe accident behavior
- evaluate the potential benefits of recent security-related mitigation improvements in preventing core damage and reducing an offsite release should one occur;
- enable the NRC to communicate severe-accident-related aspects of nuclear safety to stakeholders; and
- update quantification of offsite consequences found in earlier NRC publications such as NUREG/CR-2239, “Technical Guidance for Siting Criteria Development.”

The SOARCA study has largely met its objectives. Plant improvements and significant changes in design, maintenance, and operational practices that have been implemented over the past twenty years have been incorporated and reflected in the SOARCA models. State-of-the-art severe accident modeling has not only been implemented in SOARCA, but the state-of-the-art has been extended by SOARCA through the significant amount of technical work and research developed for, and implemented in, the study. SOARCA has addressed the benefits of the improvements at the plants including the recent security related enhancements. In the area of severe accident communication, the technical community will benefit from the developments in SOARCA; the benefits and efficacy of communication with other stakeholders was beyond the scope of this review. The last objective, the quantification of offsite consequences was addressed, for the more likely accident sequences, through the selection of the most significant accident scenarios and the detailed modeling of the radiological consequences. Additional discussion of this last objective is provided in the following paragraphs.

While the goals and objectives of SOARCA appear to be largely achieved, and in some cases exceeded, there are some observations worthy of note. This reviewer’s comments are limited to the assigned topical area of accident sequence analysis.

Consequence Analyses

The overall goal of SOARCA, as supported by the objectives of the study, is to develop current and realistic estimates of the potential offsite consequences from the more likely severe accidents for an operating nuclear power plant. However, as is the case of all consequence analyses, SOARCA focuses on only the most significant accident sequences for detailed consequence analysis. While effort in SOARCA is expended to attempt to ensure that the most significant sequences, in terms of both frequency of occurrence and related consequences are chosen, there are always questions as to the rigor of this process in any analyses of this type. As such, some may question the impact of non-dominant or individually non-significant accident sequences or whether this approach is sufficient for the application chosen.

For example, there is the possibility that certain accident sequences, while not dominant, may have higher risk than would be indicated by the frequency of the accident sequences due to an increased consequence. While these sequences may not dominant the risk, in terms of either frequency and/or consequence, they could be contributors. Combinations of several lower order sequences could have higher consequence than the specific accident sequences considered by SOARCA and could contribute to higher risk. While SOARCA did indeed capture the most likely sequences and did accurately capture the consequence from these sequences this approach may not be sufficient to demonstrate completeness.

This issue of “completeness” is common in consequence analyses. That is, for consequence analyses, it can be difficult to demonstrate completeness. The benefits of a frequency-weighted approach, such as a level 3 probabilistic risk analysis (PRA), is that the accident sequence frequencies and consequences can be used in the determination of risk. The results of the PRA accident sequence frequencies and the related consequences can be evaluated both individually and collectively. However, the frequency-weighted approach is also susceptible to instances where the results can be misinterpreted, taken out of context, or manipulated without proper basis. This reviewer believes the benefits of demonstrating completeness outweigh the potential for intentional or unintentional misuse.

A level 3 PRA performed for a SOARCA plant would have the benefit of reduced resources (due to work performed for SOARCA) as well as the benefits of validation of the SOARCA approach and demonstration of completeness.

Plant-Specific Nature of SOARCA

The SOARCA analysis was developed by applying the methodology to two plants, Surry and Peach Bottom. Such a plant-specific derivation incurs both positive and negative aspects. With plant-specific information, plant-specific conclusions can be drawn based on the design features, maintenance and operation practices at that particular site. Conversely, because these plants do not encompass all of the design, maintenance and operation practices across the nuclear fleet – both those that reduce consequences and

those that might increase consequences – some conclusions are likely applicable to that site only and the results may not be typical.

For example, because the Peach Bottom drywell does not have a curb, direct containment heating via corium contact with the liner is possible. In other BWR Mark I containments, the liner may prevent or reduce the likelihood of corium contact with the liner.

While an alternative to the current approach or analysis is not recommended, it is important to emphasize that the results can be influenced in a material way by plant-specific features.

Individual Accident Sequences

As part of the SOARCA review, the accident sequences criteria used in the SOARCA study were applied generically to various accident sequences in previously published PRA studies. The conclusion of this comparison was that no new accident sequences were identified that should have been included in SOARCA. However, it should be noted that this review was informal and generic. Plant-specific application could produce different results. While the generic comparison does provide some assurance that the criteria was correctly applied, the completeness issue discussed in the “Consequence Analysis” section apply.

Safety valves and pilot operated relief valves play a significant role in the accident sequences analyzed in SOARCA. The successful operation of these valves, as well as their failure modes under beyond design basis conditions, is clearly significant in the analysis. This reviewer believes the safety valve failure modes considered in the SOARCA analysis are very likely. However, this likelihood illustrates another advantage of a frequency weighed approach where competing and important phenomena can be frequency weighted, the result is a more holistic view of risk and the key contributors.

Summary

The SOARCA analysis has met its stated primary goal of developing current and realistic estimates of the potential site-specific offsite consequences from the more likely severe accidents for operating nuclear power plant.

In addition, the other objectives of the study were also achieved including incorporation of plant improvements and updates, state-of-the-art integrated modeling of severe accidents, and incorporation of the benefits of recent security-related mitigation improvements.

However, SOARCA is a consequence study and, as such, has issues associated with demonstrating completeness. Consequence studies are limited in their ability to obtain the most utility from the final results because it is difficult to implement advancements in the technology or changes in the state of knowledge. In addition, SOARCA is plant-specific, which has the benefit of reflecting the specific plant conditions, but has the

detriment of not reflecting the range of potential designs or how these alternate designs might influence the results. In the accident sequence analysis, changes in assumptions or the state of knowledge of certain phenomena could influence the results of the analysis and further limit the usefulness of the final result.

Evaluation by B. Clément

Summary

The reviewer looked at all the documentation provided by the SOARCA project. His evaluation mainly focussed on the domains related to his personal background: (i) objectives and approach, (ii) accident scenario analysis, and (iii) uncertainty analysis. Finally, recommendations for possible work continuation are given.

The SOARCA project succeeded in achieving the objective of updating quantification of offsite consequences. This was done by using best-estimate simulation tools on a limited number of accident sequences. The selected scenarios result in containment failure, very large leakage or bypass representing a class of accidents with quite large but not early releases. This is considered as being correct, and overall, the SOARCA methodology proved to be useful.

The accident progression is calculated using the MELCOR state-of-the-art code. In the calculations, a creep rupture of the hot leg nozzle occurs before induced failures in other locations of the RCS and before failure of the lower head of the reactor pressure vessel. The reviewer considers that uncertainties exist concerning the first failure location. This was addressed for SGTR but not for RPV failure. A recommendation in that sense was made during the review meetings. The MELCOR code does not yet incorporate all the outcomes of recent R&D on fission products behavior, especially as far as iodine is concerned. To overcome this difficulty, a superimposition of gaseous iodine source term directly coming from Phebus experimental results was superimposed to the one calculated by MELCOR. This gives consistent results for the sequences that were studied, but it might not be the case for other sequences.

Addressing the uncertainties issue within the frame of the SOARCA project will certainly increase the robustness of the results and the confidence we can have in the conclusions. Given the important amount of work needed, the project proposes to conduct the uncertainty study on one sequence for one power plant. This is considered as being acceptable and a good starting point. Besides, the methodology for uncertainty analysis is valid.

For future consideration, it is recommended: (i) to proceed to a revision of part of the SOARCA documentation according to new PRA results if their outcomes make it useful, (ii) to address other pilot plants representative of other designs using the SOARCA methodology, and (iii) to benchmark SOARCA evaluations of some selected sequences with a new MELCOR version incorporating significant new features when it becomes available.

Introduction

Given his background, the reviewer mostly focused on general documents describing the SOARCA objectives and methodology as well as on accident progression and source-term analyses. For the same reason, more input will be found for the Surry PWR than for the Peach Bottom BWR.

SOARCA Objectives and Approach

Among the different objectives assigned to the SOARCA project, the most important in the reviewer's opinion is to "update quantification of offsite consequences found in earlier NRC publications." Indeed, the quantifications in NUREG/CR-2239 were likely overly pessimistic.

The SOARCA study takes into account significant plant improvements and updates not reflected in earlier assessments and evaluates the potential benefits of mitigation improvements. In that sense, it is up to date.

SOARCA uses an integrated approach based on the use of two best-estimate simulation tools, MELCOR and MACCS2. These two codes incorporate to a large extent the current status of knowledge on severe accidents.

For fully answering the question, "Is SOARCA a best-estimate study," one needs to consider the accident-scenario selection procedure discussed in the next section.

Overall, the reviewer considers that the SOARCA approach is useful and valid.

Accident Scenario Selection

Because SOARCA is not a full Level 3 PRA study, only a limited number of scenarios has been selected. The accident scenario selection is based on Core Damage Frequency criteria. Though radionuclide release frequency criteria would have been preferable, the results of Level 2 and Level 3 PRA results made available to the project at its initiation were probably not enough numerous and/or complete to do so. As a result of the chosen screening criteria, sequences with Large Early Release Frequency were not considered due to their very low occurrence probability. All the unmitigated SOARCA scenarios result in containment failure, very large leakage, or bypass representing a class of scenarios with quite large but not early releases. Release is much smaller for mitigated scenarios. It is considered that the screening method used leads to a correct selection of scenarios.

Accident Progression and Source-Term Analysis

The accident progression is calculated with MELCOR, which is undoubtedly a state-of-the-art tool for core degradation but does not yet incorporate all the recent outcomes of research on source term.

Concerning the accident progression for Surry, one of the most important results of the analysis is that a creep rupture of the hot leg nozzle occurs before induced failures in other locations of the RCS and before failure of the lower head of the reactor pressure vessel. It is also considered that the rupture of the hot leg nozzle results in a large break. This has important consequences for what happens next. First, the depressurization of the RCS allows injection of water by the accumulators, which delays the progression of the accident. Secondly, this avoids any high pressure melt ejection. In addition to this base case, scenarios

with thermally induced SGTR were considered. Although the base case scenario is credible and corresponds to the best-estimate philosophy of SOARCA, uncertainties on different failure modes and locations must be taken into account.

The analysis shows that hydrogen combustion by jet ignition becomes possible after the hot leg rupture. Bounding cases are given for AICC and detonation. It would be interesting to see whether we are far from the σ criterion for flame acceleration and the λ criterion for detonation in order to evaluate them.

Again, for the Surry analysis, the releases are due to containment's overpressure. The basement failure and the associated release path were not considered. In most of the analyzed sequences, the duration between debris discharge to cavity (followed shortly by cavity dryout), and increased leakage of containment is probably sufficiently short to consider that release through the failed basement will not be an important contributor to the overall release. This might not be the case for the unmitigated long-term station blackout where this time difference is about 24 hours. This point could be addressed in the future through a sensitivity study.

As for Peach Bottom accident progression, the same general comments about MELCOR can be made. The question of uncertainties on mechanical failures is also relevant: it applies for Peach Bottom to the rupture of the main steam line.

Concerning the release of fission products from the fuel, MELCOR uses CORSOR-Booth models with diffusion coefficients adjusted on a large number of experimental data. One can consider that the results obtained are reliable. One can draw the same conclusion for the transport of aerosol in the RCS despite the fact that some phenomena are not modelled. The chemical aspects, especially for iodine, are more complex. No transport of gaseous iodine in the RCS is considered, although this was experimentally evidenced. There is also no treatment of gas iodine chemistry in the containment. The project made a sensitivity study to cope with this modelling lack: gaseous iodine concentrations observed in the Phebus FPT-1 experiment were added to the containment inventory. As the calculated iodine releases are already high, this addition does not make a big difference. It should, however, not be forgotten that this would probably not be true for other sequences with lower releases. Also, it is expected that gaseous iodine releases due to gas phase chemistry phenomena in the containment could last for a longer time than the 48 hours considered in the studies.

Uncertainty analysis

Addressing the uncertainties issue within the frame of the SOARCA project will certainly increase the robustness of the results and the confidence we can have in the conclusions. Given the large amount of work needed, the project proposes to conduct the uncertainty study on one sequence for one power plant. This is considered as being acceptable and a good starting point.

Uncertainties are generally classified in two categories: epistemic and random. In principle, their treatment should be different. However, the practical way to cope with uncertainties when using physical/numerical models is to assign a probability distribution function to a number of selected parameters and/or model options, not making any distinction between the different types of uncertainties. This is also acceptable. There is nevertheless a type of uncertainty that cannot be treated that way: it is the case when you know that some physical phenomena, potentially important, are not modelled in the tools you are using. Then a solution can be to make a sensitivity analysis by superimposing "by hand" (using side calculations and/or considerations) the hypothesized effect of such phenomena and looking at how much it

impacts the overall results of the study. An example of such an approach is what was already done for gaseous iodine using results from Phebus FP. If not giving an uncertainty, the method can allow a qualitative measurement of the impact of nonmodelled phenomena.

As for the statistical method, Monte Carlo sampling should be preferred to Latin Hypercube, not only for theoretical reasons, but also for practical ones: tools are available in MELCOR and work well.

A most important part of the work is the selection of parameters to be examined and the determination of their probability density functions. This needs to be done based on expert judgment and reviewed, not necessarily outside of the project.

At a first glance, the list of parameters presented during the March 2010 review meeting for Peach Bottom accident progression seems to be adequate. One difficulty is that some of them might not be fully independent, whereas they should be for a Monte Carlo sampling. Attention must be paid to core degradation parameters for which interdependencies are suspected by the reviewer.

Concerning the probability density functions, the choice of finite ones is supported because sampling in the tails of infinite distributions may lead to the selection of a parameter's value that falls largely outside of the validation range of the model. In addition to uniform and triangular distributions, truncated Gaussian and truncated log-normal could also be selected for some cases.

Recommendations

The objectives of the SOARCA project were not to develop a full Level 3 PRA. There is however an undeniable interest in developing Level 2 and Level 3 PRAs. Such developments, if possible, should be made in parallel with the continuation of SOARCA project. Depending on the outcomes of new PRAs, it might be useful to proceed to a revision of part of the SOARCA documentation.

The SOARCA methodology has now been applied to two pilot plants representative of two major classes of U.S. operating nuclear power plants. Before deciding on extending it to the whole U.S. fleet, it would be interesting to address other pilot plants representative of other designs such as BWRs with Mark 2 containment or PWRs with ice-condensers containments.

The outcomes of the uncertainty analysis may have two different consequences: some aspects may appear unimportant and should be treated with fewer details in the future; on the contrary, some other aspects may appear more important than initially foreseen, and they need closer attention in the future.

Progress has been made in recent years in the knowledge of accident progression and source-term evaluation. Not all the outcomes have been incorporated in MELCOR models, and advances in knowledge are still ongoing. It should be valuable, when a MELCOR version incorporating significant new features becomes available, to benchmark the present SOARCA results with this new version for some selected sequences.

Update as of January 20th, 2012

This update follows the release end 2011-beginning 2012 of the latest version of SOARCA reports (main report including executive summary, appendices A and B) as well as the uncertainty analysis report, taking into account the outcomes of the December 2011 phone

conference. It also includes a short paragraph about the resolution of various comments by NRC.

Resolution of comments by NRC

The answers to comments are in general satisfactory. There is only one point still deserving attention: the likelihood of thermally-induced steam generator tube rupture for Surry. A first answer was that “it was considered incredible for the scope of the present study”. A more convincing one was that “separate multi-year work is underway , in a different NRC project, to assess he likelihood of TI-SGTR, considering updated flaw distributions and material changes”. The outcomes of the programme could be used for a possible revision, if needed, of SOARCA study.

The comments on the uncertainty studies have also been well taken into account. It is well appreciated that the possible correlations between input variables of the models will be taken into account for some of them in the Monte Carlo study. For the analysis of consequences, it is appreciated that the possible threshold when not using the Linear No Threshold model is not considered as a random variable. Instead results using different models will be presented and this is a good point.

Comments on the executive summary

This part of the report is well done. Several comments were made during the December 2011 phone conference and it is understood that they will be taken into account.

Individual Input from Peer Review Committee Members

Jeff R. Gabor – ERIN Engineering and Research, Inc.

Summary

The State-of-the-Art Reactor Consequence Analysis (SOARCA) project has applied modern analysis tools and advanced methodologies to assess the potential consequences from selected hypothetical severe reactor accidents. The SOARCA project is a significant step forward in severe accident consequence analysis which in the future will provide valuable input to risk assessments. These risk assessments that support the operation of current reactors and the licensing of new reactors must be based on best-estimate evaluations and not unduly biased by conservative assumptions. The SOARCA project objectives are stated as:

- Develop a body of knowledge regarding the realistic outcomes of severe reactor accidents
- Incorporate significant plant improvements and updates not reflected in earlier assessments
- Evaluate benefits of mitigation improvements
- Enable NRC to communicate severe-accident-related aspects of nuclear safety to stakeholders
- Update quantification of offsite consequences found in NUREG/CR-2239

The independent Peer Review Team that was formed includes experts in all phases of severe accident analysis. The majority of my comments on the SOARCA project have been focused on severe accident progression and radionuclide release. My attention has been applied to the use of the MELCOR code in modeling the plant response to severe accident conditions and any modeling assumptions used in the evaluation. From my past experience with a significant number of severe accident analyses, the SOARCA accident progression analysis work represents an advancement of the state-of-the-art in severe accident analysis. The accident progression analysis is thorough and addresses the key severe accident phenomena identified by experts throughout the world. The evaluation makes excellent use of available experimental evidence from a vast array of international programs. Where it is true that the details of any such study are dependent on the specific plant and scenarios being evaluated, the methods and underlining modeling techniques applied in the SOARCA accident progression analysis could apply to any LWR.

Overall, SOARCA successfully addressed the major objectives of the project related to severe accident progression by using state-of-the-art deterministic methods for modeling severe accident plant response. However, due to the primarily deterministic approach taken, great care must be taken in communicating these results in any context that include a discussion of risk to the public. The project and associated documentation details a more realistic assessment of the potential consequences associated with operating nuclear reactors for the accident progression scenarios evaluated and portrays a more up-to-date understanding of the key accident phenomena.

It should be noted that the focus on individual accident progression scenarios in a deterministic framework has limitations. As identified in my specific comments below, the consequences of specific severe accident scenarios can be strongly influenced by the selection of the accident progression paths. While the SOARCA team focused primarily on the important (or more likely) path, the consequences computed are a strong function of the path selected. This is why the presentation of risks must be made in a fully probabilistic framework, rather than a quasi-probabilistic framework like the one adopted by the SOARCA project. As the SOARCA project did not evaluate a full spectrum of scenarios, great care must be taken in the communication of these results. While potentially representative, these results are plant-specific, limited in scope, and do not fully characterize plant risk.

The original consequence analyses portrayed in NUREG/CR-2239 preceded the NRC's adoption of a Severe Accident Policy Statement and PRA Policy Statement, both of which encourage the staff to adopt a risk perspective in considering severe accidents. While SOARCA has advanced the understanding of severe accident progression and provides representative results for selected severe accident scenarios, it is unfortunate that it was beyond the scope of the project to provide a complete set of results in the context of an integrated risk perspective.

The following sections outline more specific observations and comments associated with my individual review. These comments reflect over 2 years of interactions between the Peer Review group and the SOARCA team. During that period there have been numerous presentations made to clarify issues and to reply to individual Peer Review comments.

Peer Review Assessment

The starting point for accident progression analysis is the selection of the representative sequences that could lead to severe accident conditions. The SOARCA development team utilized a screening technique to identify those sequences with the highest likelihood to lead to core damage conditions and to result in a significant release to the environment for the specific plants being studied and for the limited scope of severe accident scenarios considered. My initial comments related to sequence selection were focused around demonstrating completeness in the study. The current executive summary adequately describes the sequence screening criteria and explains how this method is capable of capturing the most significant contributors to offsite consequences. Where more traditional Level 1 PRA techniques can identify a wider range of sequences and provide additional insights, the SOARCA screening methods are judged to adequately capture the major contributors to off-site consequences for the plants analyzed.

The accident progression analysis represents a state-of-the-art deterministic evaluation and makes significant use of available experimental programs. Several of my initial comments on the accident analysis are provided here along with any resolution provided by the SOARCA development team.

Lower Head Penetration Failure – comments were provided as to the omission of lower head penetration failure as a possible vessel failure mode. The SOARCA analysis did not include these failure mechanisms based on the fact that the majority of BWR accident sequences are assumed to result in the RPV being depressurized prior to core relocation into the lower head. It

is acknowledged that the likelihood of these failure mechanisms is reduced at lower RPV pressures.

SRV failing in the open position - the SOARCA analysis identified SRV sticking open during core heat-up as the dominant mechanism for causing RPV depressurization. Competing phenomena includes the heat-up and potential failure of the Main Steam Line nozzle. As a result of my comments, Section 5.5 of the Peach Bottom Integrated Analysis includes a substantial analysis of the uncertainty associated with the SRV failure mode. Cases were included assuming an early failure of the SRV, a failure but with only ½ of the relief area, and a case without SRV failure but with subsequent creep failure of the main steam line nozzle. These sensitivity cases provide valuable insights and show that the highest release of iodine to the environment is associated with the MSL creep failure case. Where it is understood that the SOARCA development team believes that SRV failure case represents the best-estimate, it would be useful to show the consequence impact due to the MSL failure case. In the analysis of the MSL creep rupture, the larger radionuclide release results from an earlier challenge to containment. The sensitivity of the results to this failure mode are further evidence that focus on the analysis and reporting of individual accident progression scenarios can be misleading. This is why a fully risk-informed approach to the presentation of consequence information is preferable.

Hydrogen ignition in SBO - comments were provided to identify the source for hydrogen ignition in the station blackout sequences. Section 5.2.3 of the Surry Accident Analysis was updated to include a more thorough discussion of ignition sources. Hot gases exiting the reactor vessel upon hot leg creep rupture and at the time of lower head failure were shown to have sufficient energy to ignite the hydrogen. An additional investigation was performed to study hydrogen combustion upon mitigation using containment sprays. Prior to spray recovery the containment atmosphere can be inerted by the steam present, however, as the steam fraction is reduced from spray actuation, small burns are shown to occur. My review comment addressed a possible delay in hydrogen ignition upon spray actuation and Section 5.2.3 was revised to include this sensitivity. In addition, the SOARCA results demonstrate that operation of the containment sprays provides for significant scrubbing of the airborne fission products, and therefore limits any possible release should the containment fail as a result of deflagration or detonation of hydrogen.

Uncertainty Analysis – as a follow on to the original SOARCA project, a detailed uncertainty analysis (UA) was developed with input from the Peer Review group. The UA addressed parameters relating to the sequence of events, in-vessel accident progression, ex-vessel accident progression, containment behavior, chemical forms of iodine and cesium, aerosol deposition, and numerous items impacting the off-site dose calculations. The mean values, upper and lower bounds, and the overall parameter distributions were presented to the Peer Review group allowing for significant technical discussion. Overall, the UA approach was found to represent the state-of-the-art and would capture the major contributors to high consequences. Selected items were found that were not included and recommended for inclusion in the final UA document. These items included consideration of; 1) delays in key operator actions, 2) transverse in-core probe failures, 3) SRV tail-pipe failures and, 4) additional inputs affecting Main Steam Line creep rupture.

There was a considerable amount of discussion relating to accident progression on several other topics, however, the items mentioned above were judged to potentially have the most significant impact on the consequence analysis and reflect the great care that is needed in characterizing the comprehensiveness and applicability of the SOARCA results.

Conclusion

This review specifically addressed severe accident progression and radionuclide release. I reviewed the SOARCA documentation based on over 25 years experience with similar accident analyses and primarily looked to answer the following 5 questions:

1. Did SOARCA address the important accident progression phenomena?
2. Does the analysis represent a best-estimate approach making use of available experimental data?
3. Does the study adequately address the uncertainty in severe accident phenomena?
4. Does the SOARCA modeling represent an integrated approach by accounting for the interactions between the primary system, containment, secondary buildings, mitigation systems, and related phenomenology?
5. Does the documentation accurately reflect the analysis performed?

As a result of my review of the documentation and through extensive interactions with the SOARCA development team, I would judge each of these questions to be adequately addressed in the analysis, with the exception of item 3 which is being addressed as part of a separate program. Specific to each of the questions above, my review concluded the following:

1. Table 4.5.9-3 of the ASME Standard for Probabilistic Risk Assessment (ASME RA-Sb-2005) provides a detailed list of Large Early Release Frequency (LERF) contributors to be considered in the containment performance evaluation of a PRA. This represents one of the most concise lists of Level 2 PRA phenomena that can impact the timing and release of radionuclides in the event of a severe accident. With the exception of items that were screened out due to low frequency (e.g. containment isolation failure, ATWS-induced failure), the other phenomena have been addressed in the SOARCA evaluation. In addition, the IAEA Draft Safety Guide, DS393, on Development and Application of Level 2 Probabilistic Safety Assessment for Nuclear Plants includes a similar list in Table 5 identifying key severe accident phenomena. Again, except in cases where the low frequency threshold was exceeded, the key phenomena have been addressed in the SOARCA evaluation. Based on these references and the screening out of lower likelihood contributors, the SOARCA analysis addresses the important accident progression phenomena.
2. The SOARCA evaluation does represent a best-estimate analysis of the limited set of selected severe accident scenarios with focus on the current mitigation capabilities at the plants. In addition, relevant experimental results relating to severe accident progression appear to have been reviewed and applied to the overall modeling of the plant.
3. Given the substantial uncertainties in severe accident progression analysis, it is not sufficient to characterize the potential consequences of a severe accident scenario using a single accident progression analysis, even if it is felt to be the best estimate case. As

demonstrated by the sensitivity studies requested by the peer review team, accident progression can be strongly influenced by assumptions regarding potentially beneficial failures (e.g., SRV sticking open). A one-at-a-time sensitivity analysis can demonstrate the robustness of the analysis and also identify critical modeling assumptions and inputs. As part of the SOARCA project and as a result of comments provided by this Peer Review group, several sensitivity analyses were performed and provide a better understanding of the controlling phenomena and identified areas for potential future investigations. These sensitivities were performed in a one-at-a-time manner, which is helpful, but they fall short of addressing all potential outcomes. A full appreciation of the results and uncertainties can only be accommodated in a fully probabilistic assessment addressing the applicable aleatory and epistemic uncertainties. Where the Peer Review group had considerable input into the uncertainty analysis approach, final results were not available to the group prior to finalization of this report.

4. Dating back to the original Individual Plant Examinations (IPE), the industry and the NRC have observed the importance of performing a fully integrated analysis. For example, the interaction between fission product transport and the thermal-hydraulic conditions can be shown to provide a dominant feedback when calculating the source term release to the environment. The use of MELCOR to model all important phenomena and system interactions applicable to the selected severe accident progression scenarios evaluated has provided a more realistic analysis.
5. The SOARCA documentation provides a clear picture of the major assumptions and methodology used to perform the analysis. The executive summary adequately provides the overall conclusions of the analysis with the appropriate details contained in separate appendices.

SOARCA represents a major advancement in our understanding of severe accident progression and radionuclide release. Through the adoption of a risk-informed regulatory environment, severe accident response has become a significant consideration for operating reactors. It will be important that this technology be applied beyond just the confines of the research departments and can be used to provide needed input to risk-informed regulatory decision-making. To this end, it is important that the largely deterministic analytical techniques employed in the SOARCA project be extended into true risk frameworks (i.e., a Level 2/3 PRA) in order to more completely characterize the results and communicate risks.

Robert E. Henry Final Review Comments on the SOARCA Report

Since my background is severe accident phenomenology, my contribution to the SOARCA Review Committee, has been to focus on the MELCOR calculations that were performed for the Peach Bottom and Surry reference plants. This involves the timing of events related to core damage, RCS challenges and challenges to the containment integrity, as well as fission release, transport and deposition within the RCS and containment, including the possible releases to the environment.

In my original review of the SOARCA process and the preliminary results, I made the following two comments.

1. The SOARCA Program is a major step forward in developing a credible, integral, technical basis for evaluating the consequences of possible radiological releases, that carries forward all of the lessons that have been learned from industrial experience, as well as large scale international experiments and analyses.
2. The inclusion of a MELCOR "best practices" document is a very important feature of the SOARCA evaluation. It defines the manner in which the accident progression for both BWRs and PWRs was evaluated as part of these central estimate calculations and also provides some of the features that are to be explored through the upcoming uncertainty analyses. In that regard, it is necessary that the best practices document describes the manner in which the evaluations were performed. It is important that the review committee reviews and comments on the controlled features associated with the MELCOR calculations.

As the SOARCA activity approaches its conclusion, I continue to believe that this activity is a major step forward in developing credible, integral analyses for severe accident sequences to be used in regulatory decision-making. Furthermore, I also think that a review of the MELCOR "best practices" document is an important component of the documentation that should be reviewed along with each MELCOR accident analysis that is used in specific regulatory decisions. It is overly-ambitious to expect that integral accident analysis computer codes correctly represent every nuance of an accident sequence; nor is this always necessary. There are numerous times where the shortcomings of an analytical model result in differences between calculations and reality that do not result in any substantive difference in the decisions that need to be made. Conversely, there are other times when the differences could potentially make a difference, if not now, perhaps in future evaluations/decisions. Therefore, it is worth noting where these subtle differences may exist and what physical phenomena may be contributing to a somewhat different response. These are indicated below.

Accident Sequence Selection

The focus on the sequences of Station Blackouts and containment bypass is appropriate since these are the major contributors to risk. How such sequences could be initiated, and the

frequency of the initiation, is site specific. Nonetheless, focusing on these sequences also challenges all involved to conceptualize one, or more, strategies that utilized the full capabilities of the reactor site to keep the reactor core covered with water. As has been fully documented, the experience during the TMI-2 accident was that a small amount of radioactive material was passed outside of the containment due to the use of the "letdown" system. This also generated some confusion at the time, but the SAMGs that were put in place after that accident identified the various ways in which containment isolation could be challenged and guidelines were developed that would make the control room operators cognizant of how to address such conditions. The same insights should be sought-out as more information becomes available for the Fukushima core damage events.

With respect to what is known to date for the Fukushima accidents, the selection of the SBO sequences for the SOARCA is certainly validated. Equally important is the role of RCIC turbine driven injection system, that is conservatively modeled in the SOARCA accident response evaluations, which was found to be extremely effective in the units where it was part of the design (Units 2 and 3). On both units it was able to run long after the batteries were anticipated to be exhausted. These insights will need to be continually reviewed as more information is released by TEPCO to insure that the conditions which existed during the accidents are clearly understood and interpreted.

MELCOR Modeling of the Severe Accident Sequences

The MELCOR computer code provides an integral representation of core damage events for both BWR and PWR sequences and has been applied to the Peach Bottom and Surry reference plants. Those features that are of particular importance to the evaluations for the accident sequences and the references are:

1. The timing of when the top of the reactor core is uncovered,
2. The extent of hydrogen generation as the core is overheated in steam,
3. Release of fission products from the fuel pins into the Reactor Coolant System (RCS),
4. The downward relocation of molten core as the constituent materials melt or are liquefied,
5. The possible challenges to the integrity of the RCS pressure boundary,
6. Relocation of molten core materials into the Reactor Pressure Vessel (RPV) lower plenum,
7. The potential for rapid steam generation in the RCS,
8. Failure of the RPV that would be sufficient to discharge molten fuel to the containment,
9. Release of fission products from the RCS into the containment,
10. The potential for High Pressure Melt Ejection (HPME),
11. The potential for rapid steam generation in the containment,
12. The potential for Molten-Core-Concrete-Integrations (MCCI),
13. The potential for hydrogen burns,
14. Challenges to the containment integrity and

15. The potential for containment by-pass.

Of these, I find the MELCOR results to be reasonable and benchmarked with the appropriate phenomenological experiments, except for some aspects of items #5, #8 and #9. The possible role of each and how they may influence future evaluations are discussed below.

Item #5

Item #5 relates to the possible challenges to the RCS pressure boundary integrity and this includes the in-core instruments that are part of the reference plant designs. The instrument thimbles in both of the designs are fabricated from stainless steel and Inconel tubing and have a central channel that is open to the containment atmosphere. As a result, these materials have the lowest melting temperatures of the materials that form the pressure boundaries in the reactor core. Consequently, these instrument thimbles will heat-up along with the other core materials and as they approach their melting temperatures, they can be anticipated to fail and release fission products and hydrogen to the containment atmosphere. This is consistent with multiple observations from the TMI-2 event (Henry, 2011). These flow paths were not modeled in the MELCOR analyses of the reference plants. Also, complementary scoping analyses were performed by the SOARCA team, assuming no changes in the flow path geometry (no ablation), to quantify the extent of this release for the Peach Bottom accident conditions concluded that these flow paths would result in only a small release to the containment (drywell). Within the context of what was assumed, I agree with the evaluations performed by the SOARCA team. However, the results from the TMI-2 VIP (Neimark and Hins, 1991 and Wolf et al, 1993), showed that the flow paths were dramatically altered. Therefore, the scoping calculations presented to the Review Committee are useful, but do not necessarily provide the total story.

There are two facets of these release paths that should be followed in future integral evaluations. The first relates to open lattice core PWR assessments and specifically to the evaluations of the natural circulation flows from the core to the steam generators. Failures of the instrument thimbles, like those in the Surry design, would occur when the core-to-upper plenum natural circulation flows are becoming influential. Opening flow paths to the containment at this time would cause an outflow of steam and hydrogen from the core and decrease the flows to the steam generators. This could substantially change the evaluations related to the thermally induced SGTR. It is noted that since the flow paths from the core would be to the containment, the long term release of fission products to the environment would not be substantially affected.

The second influence relates to the BWR (Peach Bottom) calculations. Failure of the in-core instruments would result in fission product releases to the drywell and these could subsequently be discharged to the environment if drywell venting were to be implemented or if the containment would be impaired. Possible surrogates for this discharge of steam, hydrogen and fission products to the drywell could be the creep failure of a main steam line upstream of the inboard MSIV or a stuck open safety valve that discharges to the drywell. Of particular note for this flow path is that the fission product vapors and aerosols may not experience extensive scrubbing in the pressure suppression pool. Since the dominant sequences in the SOARCA

analyses experience significant MCCI and significant releases to the drywell, I do not believe that, in the overall sense, this flow path has a major influence on the SOARCA results. Nevertheless, future analyses for these, and other, severe accident sequences should include these flow paths to remove such questions.

Item #8

Thermal attack of the RPV by relocating molten material involves the competitive processes of (1) heat transfer to the vessel wall, (2) heat transfer to the lower plenum structures including those that penetrate the RPV wall and (3) the structural response of the wall and the penetrations. Hence, assessing the nature of the RPV failure is difficult.

The MELCOR analyses neglects the response of the lower head penetrations and evaluates the RPV failure based on the creep response of the lower head only. Because the failure condition is eventually calculated for the sequences considered, the nature of the RPV failure does not have a significant influence on the ultimate fission product releases to the environment and the off-site consequences. However, future analyses may have a somewhat different focus that is more accident management related and these may have a greater interest in how the failure may occur. In particular, assessment of accident management strategies may be impacted if there would be a number of comparatively small holes (failures) in the RPV wall.

Item #9

This item is influenced by Item #5 and was discussed previously.

MELCOR Best Practices Document

As noted above, the MELCOR "best practices" document is an important aspect of the document for the Peach Bottom and Surry analyses, particularly the benchmarks of the MELCOR models with the key experiments that relate to the thermal hydraulic and fission product behavioral characteristics of the reactor core, the RCS and the containment. The benchmarks were presented during the last committee meeting and, it was agreed that these addressed the experiments of particular importance for the SOARCA studies.

Nevertheless, it is worth noting for future analyses that it would be advantageous for future studies if one facet would be added to the MELCOR "best practices". Specifically, each benchmark results in certain insights that are generally carried forward to the application of the integral system code to reactor systems. Perhaps the most involved of these are those insights that are tied to the nodalization of the core, the RCS and/or the containment; particularly when these relate to the possible formation of natural circulation flows and/or stratification. Some of the containment analyses presented to the Review Committee demonstrated results where natural circulation flows would have been initiated and the calculated temperature distribution would have been modified substantially. These were discussed extensively and it was noted by the SOARCA team that the necessary countercurrent flow model in the containment was not part of the archived code used for the reference plant analyses. Furthermore, it was agreed that, while the calculated results were not realistic, the influence of the natural circulation flows that would modify the calculated results would not substantially alter the fission product releases

to the environment. However, it is recommended that the MELCOR “best practices” include the insights developed from an individual benchmark such that these would be implemented in integral plant analyses going forward as noted in my comment #2 at the beginning of my comments. Without such a procedural step, it is not clear what is learned and used from the benchmarks.

References

Henry, R. E., 2011, TMI-2: An Event in Accident Management for Light-Water-Moderated Reactors, published by the American Nuclear Society, LaGrange Park, Ill.

Neimark, L. and Hins, A. G., 1991, “Metallographic and SEM Examinations of Nozzle Segments,” OECD TMI-VIP Program Review Meeting, Argonne National Laboratory, September 23-24.

Wolf, J. R., et al, 1993, “TMI-2 Vessel Investigation Project Integration Report,” NUREG/CR-6197.

Review Comments on the SOARCA Project Documents
Emergency Response Modeling

To: Karen Vierow, Chair
SOARCA Peer Review Committee

From: Roger B. Kowieski, P.E.
NTHMC, Inc.
Member of SOARCA Peer Review Committee

Date: January 19, 2012

Subject: **Review Comments on the SOARCA Project Documents**
Emergency Response Modeling Sections

My evaluation of the SOARCA project documents mainly focused on the off-site emergency response sections, where I feel qualified to express an opinion.

In my March 30, 2010 memorandum to you, I provided my evaluation and review comments relating to the Surry and Peach Bottom nuclear power plants. Based on my review of the SOARCA project documents, I found that the parameters used and assumptions made in the emergency response modeling were reasonable and adequate. Furthermore, the emergency response timelines used in the modeling are consistent with the actual response action timelines by the off-site response organizations (ORO's), which were observed and documented by me, in the previous exercises at the Surry and Peach Bottom nuclear power plant sites.

Finally, all of my initial review comments on the draft SOARCA documents were satisfactorily addressed in the revised version. Please note that my previous comments and subsequent resolutions are attached, and are an integral part of this memorandum.

Thank you again for the opportunity to serve on the SOARCA Peer Review Committee.

Enclosures

Memo

To: Karen Vierow, Chair
SOARCA Peer Review Committee

From: Roger B. Kowieski, P.E.
Member, SOARCA Peer Review Committee

Date: March 30, 2010

Subject: Review Comments of the SOARCA NUREG Documents with
Respect to Emergency Response Modeling

OVERVIEW

In my review of the SOARCA documents, I mainly concentrated on the Emergency Response Sections as they related to the Surry and Peach Bottom nuclear power plants. For each site, the modeling was performed for six (6) cohorts, which were established for each population subgroup, representing a meaningful number of individuals. The population data were obtained from the U.S. Census Bureau from the 2000 census data. The population was projected to 2005 using a multiplier of 1.053, also obtained from the Census Bureau.

The WinMACCS network evaluation application was used in the modeling, which accounts for site-specific travel direction and speed. For both plants, the travel direction and speed parameters were derived from the Evacuation Time Estimates (ETEs) prepared by each utility, as required by 10CFR50.47, Appendix E. The SOARCA project used a normal weather weekday scenario that includes schools in session. The SOARCA documents correctly state that the Off-site Response Organizations (OROs) generally do not develop detailed protective action plans for areas beyond the 10-mile Emergency Planning Zone (EPZ). For the 50-mile Ingestion Exposure Pathway, the states with support from the Federal Government are responsible for taking protective actions in the event that an incident causes the contamination of human food or animals' feed. The Protective Action Guides (PAGs) are published in the EPA Manual of Protective Actions for Nuclear Incidents, EPA 400-R-92-001, dated October 1991.

The emergency response timelines presented for both plants identified the following:

- Notification of emergency classification levels to the ORO
- Actions taken by the state and local organization such as the siren sounding and broadcast of an Emergency Alert System message
- Evacuation times for six (6) cohorts of population

Based on my participation and evaluation of several exercises at the Surry and Peach Bottom sites, I concur with the response timelines used in the SOARCA emergency response

modeling. The emergency response timelines used in modeling are consistent with the actual response action times observed and documented in the previous exercises.

In my initial review of the draft SOARCA documents, I have made several comments which were satisfactorily addressed in the revised SOARCA documents, Rev. 1-2/15/2010. Details of my comments and subsequent resolutions are provided in the attached two (2) tables.

I appreciate the opportunity to serve on the SOARCA Peer Review Committee.

**Comments on Emergency Response Sections by Roger B. Kowieski
And Subsequent Resolution of Those Comments**

Peach Bottom SOARCA Document

No.	Peer Reviewer Comments	Response/Resolution	Peer Reviewer Evaluation of Response Resolution
1.	Why is siren used at particular points? It gives the impression that people move at this time. Suggest changing to "siren + ES message."	The figures and associated text describing evacuation timing have been updated to clarify population motion.	The revised figures and text now correctly reflect the Alert and Notification sequence.
2.	Reconsider the 1 hour allowed to evacuate after second siren. (SOARCA team requested feedback from the committee on this 1-hour time.) Peach Bottom long term station blackout.	The data available to the SOARCA analysis team are consistent with the time lines provided in the documentation to within 15 minutes. 1 hour is also standard in evacuation time estimates. Sensitivity study #3 was performed, which includes a delay of an additional 30 minutes in the response of the public. This delay did not result in any changes in the off-site consequences relative to the baseline case.	Sensitivity study (analyses) satisfied the reviewer's comment.
3.	The evacuation time of the Special Facilities is late and will not go over well with the public.	The relevant text has been updated to clarify that these groups shelter earlier in the event and then evacuate at the time specified.	The revised text clearly states that the sheltering is valuable protective action for the Special Facilities in the early stages of the nuclear power plant incident, prior to an evacuation.
4.	It appears that the existing documents do not address the notification of public in case of a siren failure.	Data have been added to section 6.2.5 justifying the assumption that sirens operate correctly.	The sirens operability records show that that the Peach Bottom sirens are 99.8% reliable.
5.	The seismic analysis time line suggests that after declaration of GE by the plant, sirens and EAS message could be activated within 45 minutes. Based on the actual field experience, it takes approximately 15 minutes for the nuclear power plant to notify the state authorities and may take an additional 38-40 minutes before the sirens' activation and EAS message are completed. Therefore, total time required to complete the A/N sequence may vary between 53-55 minutes.	The timelines used in the analyses are very near the times experienced in exercises. To address any difference in timing, Sensitivity #3 was performed, increasing the initial delay in the notification of the public by 30 minutes.	The sensitivity analysis properly incorporated the timelines experienced during the actual exercise events. The results of the sensitivity analysis are reasonable and acceptable.

Surry SOARCA Document

No.	Peer Reviewer Comments	Response/Resolution	Peer Reviewer Evaluation of Response Resolution
1.	One of the accident progression time lines suggests that after declaration of GE by the plant, sirens and EAS message could be activated within 45 minutes. Based on the actual field experience, it could take up to 60 minutes to complete the A/N sequence (Sirens/EAS message).	The timelines used in the analyses are very nearly the times experienced in exercises. To address any difference in timing, Sensitivity #3 was performed, increasing the initial delay in the notification of the public by 30 minutes.	The sensitivity analysis properly incorporated the timelines experienced during the actual exercise events. The results of the sensitivity analysis are reasonable and acceptable.
2.	It appears that the existing documents do not address the notification of public in case of siren(s) failure. Should a siren fail, it may take additional 45 minutes to notify the affected public by Route Alerting procedures.	The siren operating rates were reviewed under the reactor operations program (ROP) and found to be 99.9% at Surry, which would correspond to the loss of about 1 siren. Route alerting for this one area would not affect the total evacuation time of the public. Text has been added to section 6.2.5 to reflect the performance of the sirens.	The sirens operability records show that the Peach Bottom sirens are 99.9% reliable.
3.	There is a strong precedent for presenting only out to 50 miles of data. Consider not showing the 100-mile data. (Bixler 1 st pres. Slide 18)	Results in older studies went out to much longer distances: 500 mi in the citing study and 1000 mi in NUREG-1150. SOARCA takes a dramatic departure from these earlier works by limiting consequence analysis results to much shorter distances. The final determination by the NRC staff is to limit the consequence predictions to a 50 mile radius, which is reflected in revision 1 and subsequent revisions of the documentation.	The final determination by the NRC staff to limit the consequence prediction to a 50-mile radius is reasonable and considered to be adequate. The current planning for the ingestion exposure EPZ is limited to about 50 miles from the power plant, because the contamination will not exceed the Protective Action Guides (PAGs) published by EPA and FDA. It is estimated that much of the particulate material in the radioactive plume would have been deposited on the ground within about 50 miles from the nuclear power plant.
4.	The evacuation time of the Special Facilities is late and will not go over well with the public. (Bixler 1 st pres. Slide 20)	The relevant text has been updated to clarify that these groups shelter earlier in the event and then evacuate at the time specified.	The revised text clearly states that the sheltering is valuable protective action for the Special Facilities in the early stages of the nuclear power plant incident, prior to an evacuation.
5.	Too much time is spent on the non-evacuating public.	Consequence results for the nonevacuating cohort will continue to be included in the overall consequence calculations, but a short paragraph has been inserted to describe the fraction of the emergency phase risk within 10 miles of the plant that is attributed to the nonevacuating cohort. In some of the slowly developing sequences, 100% of the emergency phase risk is from nonevacuees.	If the nonevacuating public is properly informed and elects not to follow the recommendations to evacuate by public officials, they should be solely responsible for any negative consequences.

H:\research\NRC SOARCA\peer reviewer report\5 (edited)5 Kowieski 2010_SOARCA_PB Surry.docx

Individual Input on SOARCA Report,, Revision 1

David Leaver

January 19, 2012

This note is to record my overall impressions of the SOARCA project and associated documentation. As a peer reviewer, I have had the benefit of reviewing drafts of the four volume report (a July, 2009 draft, a revised draft issued in February, 2010, and a further revision issued near the end of calendar 2011). There were also a number of meetings, all of which I attended, where SOARCA team members (NRC staff and Sandia contractors) presented information developed in the SOARCA project. As part of the peer review process, I and other peer reviewers prepared a number of written comments on the draft documents which are provided, along with the NRC resolution, in the appendices to this peer review report.

There is also to be an uncertainty analysis report in the suite of SOARCA documents. The methodology used in the uncertainty analysis was discussed in a peer review meeting and comments on this methodology were generated by the peer review team. Peer reviewers also had the benefit of reviewing a draft report on uncertainty results.

The SOARCA project and peer review were near completion at the time of the Fukushima accident (March 11, 2011). As a result of the accident and the need for the nuclear community to focus on understanding the accident and developing insights, SOARCA efforts were put on hold for a period of time. This resulted in some delays and additional work to prepare an appendix which compared and contrasted the Fukushima accident with the SOARCA study.

In preparing this note on my overall impressions of SOARCA, I have not repeated my written comments which were submitted as described above. Rather, this note provides my general assessment of the quality and completeness of the SOARCA effort, and presents some broad observations on reactor safety and public health risks associated with operation of U.S. commercial reactors in light of what has been learned from SOARCA.

My overall impression of the SOARCA project and associated documentation is that it is a substantive, high quality effort which makes a significant contribution to the understanding of U.S. commercial reactor risk. In particular:

1. The technical quality of the SOARCA work is high and in my view it provides a major advancement in the state-of-the-art of characterization of integrated severe accident risk in Level 2 and Level 3. In addition to the fact that NRC had access to the resources necessary for such a multi-year, substantive effort (funding, skilled and experienced personnel, peer review resources), the high quality is the result of a number of things that were done leading up to and during the SOARCA project, including:

1

34

- a. Improved computational analysis tools (an updated version of MELCOR including, for example, validation against recent experimental data on fission product release; a new, Windows-based version of MACCS2, WinMACCS); methodical consideration of choices among alternative modeling options for addressing important, but uncertain aspects of severe accident behavior per the SOARCA volume entitled, "MELCOR Best Modeling Practices")
- b. Assessing the impact of severe accident mitigative features and operator actions to mitigate accidents (explicit consideration of such features and operator mitigation actions, developed over the last few years, had not been done in risk assessments prior to SOARCA)
- c. Modeling emergency response in a realistic and practical manner using site-specific information and taking advantage of advancements in the consequence model (WinMACCS) which allowed detailed integration of protective actions into consequence analysis, providing significant advancement over previous studies

An additional, non-technical point indirectly supporting the quality of the SOARCA project is the transparency which has been and continues to be a key objective. This is evident from information presented by NRC at Regulatory Information Conferences in the last several years, previous NRC meetings with the ACRS as well as upcoming meetings where the SOARCA documentation will have been made available to ACRS members, an extensive outside peer review (resulting in this peer review report), upcoming public meetings which are being scheduled, and a very complete set of reports to be issued once Commission approval is obtained. It is apparent that full, open communication on SOARCA is an extremely high priority to NRC, to the benefit of all stakeholders.

The internal event Level 1 work, while not advancing the state-of-the-art, utilized the latest Level 1 information available (NRC's plant-specific SPAR models and Surry and Peach Bottom licensee PRAs). In addition, the NRC interfaced closely with the Surry and Peach Bottom plant staffs during development of the Level 1 information, and the plant staffs were asked to review the documents for fact checking.

Regarding external event Level 1 work, while utilizing the best available external events information, the selection process in SOARCA for external event sequences was less clear. SOARCA does acknowledge that detailed sequence characteristics are more difficult to specify for external event scenarios. Because of their potential for risk (as borne out by the Fukushima accident), large seismic events should be assessed as part of a separate, future study integrated into the NRC seismic research program.

2. On the matter of completeness of scope, the SOARCA project has taken an approach that in my judgment is technically sound. In risk assessments completeness is never perfect, and SOARCA does not address every aspect of reactor risk, nor does it purport to. It has, however, identified those classes of accident events which were not considered as part of SOARCA. My judgment is that none of these classes of accident events is likely to substantially alter the SOARCA findings

on reactor risk. However, there would be benefits to applying more detailed best estimate, SOARCA-like methods to at least some of these classes of accident events (multi-unit risk as an example, again as borne out by the Fukushima accident). In addition, it would be beneficial if SOARCA were to be extended to other LWR plant types (e.g., BWR Mark II and PWR ice condenser containments) which would further strengthen the completeness of the effort.

3. On the matter of completeness of sequence selection, the Level 1 (cdf) screening process used in the SOARCA project as part of sequence selection is reasonable from a technical standpoint. Again, while not perfect, in my mind there are several points supporting the SOARCA process and the fact that risk-significant scenarios were not overlooked:
 - a. The process was not so much a black and white, above the line-below the line process as it was use of the cdf frequency screens as guidance with intelligence applied in looking below the frequency screens for higher consequence events that could impact risk (in fact, examples were cited where scenarios below the screen would not have consequences high enough to offset the lower frequency).
 - b. High consequences in previous risk assessments, such as WASH-1400 and NUREG-1150, were the result of bypass sequences and severe accident phenomena (e.g., steam explosion, direct containment heating, hydrogen detonation) assumed to cause early containment failure. Bypass sequences are explicitly addressed in SOARCA. With respect to severe accident phenomena leading to containment failure, as a result of the investment of significant time and resources in a number of experimental and analytical studies over the last several decades, these phenomena have been shown to be essentially impossible in an LWR severe accident environment.
 - c. Mitigative actions not previously considered in risk assessments have a significant effect in mitigating consequences and providing confidence in the risk results.

An additional point is that a full-scope Level 3-oriented process to determine those sequences important to risk would have required a substantially greater commitment of resources than what was done for SOARCA. Having said this, the NRC has announced that over the next four years it will be performing a full scope, site-wide Level 3 PRA including an analysis of multi-unit accidents initiated by internal and external causes during any plant operating mode.

A final point is with regard to the Fukushima accident. As pointed out in SOARCA's Fukushima appendix, while there were differences in timing and other details of accident progression between the Fukushima accident and the SOARCA study, with respect to accident types and offsite health consequences there is nothing forthcoming from the Fukushima accident that suggests that the SOARCA selection process overlooked important accident scenarios.

Some broad observations on reactor safety and public health risks associated with operation of U.S. commercial reactors in light of what has been learned from SOARCA are as follows:

- While it has long been recognized, or at least strongly suspected, within the nuclear safety community that the characterization of commercial LWR risk in previous studies was unrealistic

and excessively conservative, the SOARCA project has now provided very strong, convincing evidence of this. More work remains to be done, but in my view there is little doubt that fission product releases are dramatically smaller and delayed (even without the mitigative measures discussed below) and thus that the associated public health risks are greatly reduced, much lower than perceived in many quarters.

- The 50.54 (hh) mitigative measures, indeed the integrated set of operator actions including EOPs and SAMGs, considered in SOARCA are very important not only because of the risk impact but also because of the fact that these measures provide margin for uncertainties in sequence selection and analysis, and make the SOARCA risk predictions even more robust . These measures were put in place relatively recently and had not been considered in previous risk studies. SOARCA has not attempted to quantify the probability of success of these mitigative measures. A human reliability study addressing the full set of integrated mitigative measures (e.g., incorporates the measures into the SPAR models) would be valuable to provide this quantification and to serve as a metric to assess the effectiveness of the effort to improve the reliability of 50.54 (hh) measures.
- Perhaps the most significant finding from the SOARCA project regarding safety of operating LWRs is the importance of the role of emergency response and accident management in reducing risk. The TMI-2 accident, the Fukushima accident, and the events of September 11, 2001 (did not involve reactors, but could have) show the importance of this, and collectively suggest that even with the benefit of decades of operating experience plus the insights from PRA, it is difficult for the nuclear community to anticipate all possible events which could cause a challenge to safety at a nuclear plant or possibly lead to an accident. Because of this, a diverse, flexible emergency response system is needed which focuses on maintaining key safety functions of core cooling, containment integrity, and spent fuel pool cooling, and for which there is high assurance that the system will exist and be functional under unexpected conditions which could cause the accident in the first place. For operating LWRs, a crucial aspect of this emergency response system is accident management including integrated EOPs, SAMGs, 50.54 (hh) measures, and the equipment and management systems to assure reliable implementation. While SOARCA was (properly so) performed with no agenda with regard to application of the results, it is now an appropriate time for the nuclear community begin consideration of how SOARCA methods and results could be used to further improve LWR safety and provide even better optimization of safety resources, with particular focus on a diverse, flexible, reliable emergency response system.

**Comments on Late-2011 Issued SOARCA Documents Including
Executive Summary and Fukushima Appendix**

David Leaver

January 19, 2012

1. SOARCA has added an appendix to the Main Report on the Fukushima Dai-ichi accident. This appendix in my view has the correct objective (compare and contrast the Fukushima accident and the SOARCA accident for a reasonable list of topics) and is presented at an appropriate level of detail. My main comment is that there is currently no mention of Fukushima in the main body of the Main Report or the Table of Contents. It is suggested that SOARCA add a short paragraph on Fukushima to the introductory portion of the Main Report which acknowledges the Fukushima accident by paraphrasing information from the Objective section of Appendix A and refers the reader to the appendix. It is also suggested that NRC indicate that there are a number of other topics associated with the Fukushima accident which while not discussed in Appendix A are being or will be treated as part of other work to provide more detailed understanding of and insights from the accident.
2. The individual PB and Surry volumes make the following referrals to Fukushima:
 - a. Volume 1 (PB) – Mentions Fukushima briefly on page 12 while discussing LTSBO mitigation measures
 - b. Volume 1 (PB) - Includes several paragraphs of Fukushima discussion in Section 6.6 in the context of supporting ability of plant and offsite to truncate the release at 48 hours for PB
 - c. Volume 2 (Surry) – Includes similar paragraphs of Fukushima discussion in Section 6.6 in the context of supporting ability of plant and offsite to truncate the release at 48 hours for Surry

This is somewhat uneven and tends to provoke questions as to why there is not more discussion of the Fukushima accident in the plant-specific volumes. A better way to do this would be to place these three referrals in the Fukushima main report appendix, and then mention in the main report introduction (see comment above) that due to time limitations no attempt has been made to include Fukushima information in the plant-specific volumes.

3. There is a need for a consistent presentation and qualitative characterization of the likelihood of success of mitigated vs. unmitigated scenarios in SOARCA. At the December 6-8, 2011 peer review meeting, NRC indicated that, in the absence of a quantitative HRA study, it did not want to take a definitive position in the SOARCA documents that mitigation would succeed. This is understandable.

On the other hand, at the meeting there certainly appeared to be a sense among the SOARCA project team members that, based on the plant walkdowns and other information gathered by SOARCA on operator response to accidents, mitigation success is more likely than not. In

addition, there are numerous statements in the current draft documents that qualitatively support the reasonableness if not the success of mitigation:

- a. Main Report, page 30: In reference to the ISLOCA scenario frequency in the licensee PRA, the report states that “This frequency does not include any consideration of averting core damage by refilling or cross-connecting RWSTs. This is a significant conservatism.”
- b. Main Report, page 78: “...scenarios were analyzed including an assessment of reasonable mitigation measures for which procedures and equipment (and training) exist.”
- c. Main Report, page 78: “The SOARCA assessment and analyses demonstrate the feasibility and benefits of B.5.b mitigation for the analyzed scenarios.”
- d. Volume 1, page 19: “The specific actions necessary to accomplish local, manual startup and operation of RCIC are delineated in plant procedures, and the actions are reviewed as part of routine operator training. Therefore, successful RCIC blackstart is assumed to occur in the baseline calculation for the STSBO.”
- e. Volume 1, page 207: “It is expected that mitigative actions would be attempted and that unmitigated variants are less likely.”
- f. Volume 1, page 219: “The staff expects that plant actions would be successful in mitigating the important severe accident scenarios considered in this study.”
- g. Volume 2, page 93: The following statement introduces the Section 5 integrated analyses, and states that the unmitigated scenarios are sensitivity studies with the implication that the unmitigated versions are not the expected outcomes but are done for completeness and to provide a basis for comparison with previous studies.

“The analysis includes calculations to confirm the table-top exercise results to ensure that the timing and capacity of mitigation measures are sufficient to prevent core damage or delay or reduce fission product releases. This analysis also includes sensitivity calculations without B.5.b mitigation measures.”

- h. Volume 2, page 232: In the context of the MELCOR analysis of unmitigated ISLOCA, it is stated that, “...assuming failure to refill or cross-connect RWSTs for 13 hours is a significant conservatism.”

A suggested way to provide this consistent presentation and qualitative characterization of the likelihood of mitigation success is to characterize all of the unmitigated scenarios as sensitivity studies in Section 5 of the two plant volumes (i.e., implement what is stated in the introduction to Volume 2, Section 5). That is, for PB LTSBO, Surry LTSBO, Surry STSBO, Surry STSBO with thermally-induced tube rupture, and Surry ISLOCA, present the mitigated version first followed by the sensitivity study (unmitigated version) as is done for PB STSBO and Surry Spontaneous SGTR.

4. Sections 6 and 7 of Volumes 1 and 2 should be changed to be consistent with the presentation and qualitative characterization of mitigation success described in comment 3. As written, Sections 6 and 7 launch into emergency response parameter development and associated consequence analysis for almost entirely unmitigated scenarios with little or no explanation. See, for example, Table 14 in Volume 1 and Table 6-1 in Volume 2 which together list 16 scenarios, 14 of which are unmitigated. I understand the need to have a scenario that challenges EP and produces consequences, but Sections 6 and 7 should walk the reader through the selection of scenarios in a way that is consistent with the consistent presentation and qualitative characterization noted above.
5. The Executive Summary also has a similar problem of optics on mitigation success. The top of page 3 of the Executive Summary mentions that accident scenarios are analyzed both mitigated and unmitigated, but then pretty much the entire discussion on pages 3 and the very visible figures on page 4 address unmitigated results without any mention of the very significant results regarding unmitigated scenarios. Discussion of unmitigated scenario results is somewhat obscured in the middle of page 5. A more even-handed discussion would better represent SOARCA results.
6. The first sentence of the second paragraph of page 5 of the Executive Summary should be expanded to state that SOARCA results demonstrate the benefits of employing not only 50.54 (hh) security enhancements, but also EOPs and SAMGs. For example, RCIC blackstart is part of SAMGs.
7. On page 7 of the Executive Summary, it is suggested that the parenthesis statement be changed to say factor of 100 for unmitigated LTSBO and factor of 3 for unmitigated STSBO and ISLOCA. The current terminology of "smaller releases" and "larger releases" is undefined and confusing.
8. SOARCA should consider stating at the end of Main Report Section 1.7 (or perhaps in the SECY that forwards the SOARCA reports to the Commission) that, based upon the importance of the mitigation measures, the HRA study mentioned on page 19 of the Main Report should be performed, for example as part of the NTF work on reliability of 50.54(hh) measures or as part of the Level 3 PRA project. Such an HRA study could provide a metric to measure the effectiveness of the effort to improve reliability of 50.54(hh) measures.
9. Despite its best attempts, SOARCA will be criticized by some members of the public for not considering worst case accidents. Much has been done in the original work and report updates to defend the approach which is good. One additional thing which would be useful in this regard is to provide a general statement regarding the effect of using higher percentile weather on the overall conclusions. I would be surprised if 90% or 95% meteorology changed the overall conclusions at all, i.e., still essentially no early fatalities, and still small LCF effects in comparison to NRC Safety Goal and most still controllable.
10. The LCF risk consequence bar charts in Section 7 of the two plant volumes plot cumulative LCF risk vs. distance. As was discussed at length in the December 6-8 peer review meeting, in several

of these charts (Surry unmitigated ISLOCA, PB STSBO w RCIC blackstart, PB STSBO w/o RCIC blackstart) the 20 mile risk exceeds, or is nearly as large as, the 10 mile risk. This presentation is problematic due to the optics of the bar charts. Many readers who open Volumes 1 and/or 2 will quickly turn to Section 7 and look at these bar charts, and will pay little if any attention to the extremely low absolute risks associated with the ordinate values nor to the conservatisms or qualifiers embodied in these charts (e.g., the fact that the charts represent unmitigated accidents, the fact that much of the risk is controllable). The data behind the charts should certainly be presented in the tables, but the charts themselves should be revised to provide some perspective on the LCF risks and put them in context. The fact that the 20 mile risk may exceed the 10 mile risk, once evacuation of the EPZ is taken into account, is not what is important. Rather, what is important is that it is predicted that those closest to the site are able to avoid nearly all exposure by evacuating prior to plume arrival, and the fact that the doses and associated LCF risks out to any distance are so small in comparison to any societal measure of cancer risk (NRC Safety Goal and cancer fatality risks from all causes).

11. There should be some mention of how or to what extent SOARCA QA was accomplished. Page 27 notes that the SPAR models have been developed and maintained under a formal QA program. Can the same be said about the SOARCA models and documentation? If not, then a description of how quality was controlled would be good.

State-of-the-Art Reactor Consequence Analysis (SOARCA) Project
Independent Technical Review
Bruce Mrowca

Introduction

This document summarizes my independent technical review of the approach and underlying assumptions and results obtained for the Peach Bottom and Surry SOARCA analyses. My review focused on determining if the assumptions and results are defensible and represent the state-of-the-art. As this reviewer's expertise is related to probabilistic risk assessment (PRA) techniques, my review is limited to the selection and characterization of analyzed scenarios or sequences, and the treatment of mitigation measures and operator actions. Review comments were originally based on the SOARCA Project Report, Revision 1, dated February 15, 2010 and updated based on comment responses dated July 2011 and the updated Revision 4 draft report dated December 23, 2011.

SOARCA Objective

In the Revision 1 draft, the Executive Summary stated, "[t]he overall objective is to develop a body of knowledge regarding the realistic outcomes of severe reactor accidents." The stated supporting objectives are as follows:

1. Incorporate significant plant improvements and updates not reflected in earlier assessments including system improvements, training and emergency procedures, offsite emergency response, and recent security-related enhancements as well as plant updates in the form of power uprates and higher core burnup.
2. Incorporate state-of-the art integrated modeling of severe accident behavior.
3. Evaluate potential benefits of recent security-related mitigation improvements.
4. Enable the NRC to communicate severe-accident-related aspects of nuclear safety to stakeholders including federal, state, and local authorities; licensees; and the general public.
5. Update quantification of offsite consequences of NUREG/CR-2239, "Technical guidance for Siting Criteria Development."

Although these objectives are no longer presented in the Executive Summary, they are stated in a slightly revised form in Section 1.2 of the Main Report. It remains the opinion of this reviewer that these objectives were only partially achieved. This is not to say that the integrated approach to the phenomenological modeling of accident progression was not valuable and that the insight that accident progression proceeds much more slowly than earlier treatments is very informative. However, the innovative and state-of-the-art techniques used in the SOARCA analysis are focused on this phenomenological modeling and are not used for the identification of sequences to be modeled or for the application of security-related mitigation improvements. Although significant improvements were made from the earlier revision of the report, there still remain significant limitations which regards to the selection and frequency quantification of the analyzed sequences. These limitations reduce the ability to effectively communicate severe-accident-related aspects of nuclear safety and limit the ability to provide an update of NUREG/CR-2239.

With respect to Supporting Objective 1, this reviewer would have preferred to see this objective re-written to reflect a more balanced perspective. The change could have been simply to use the term "plant design and operational changes" in lieu of "plant improvements" and to have included consideration of "state-of-knowledge" changes that have occurred in the modeling of accident sequences. These changes would have re-enforced the inclusion of both positive and adverse impacts. In the response to my initial comment on this issue, the SOARCA Project stated that the team attempted to accurately reflect plant conditions and use the latest Level 1 information concerning the initiators derived from the plant-specific SPAR models. They also stated that realistic information such as fuel burnups, power uprates and

State-of-the-Art Reactor Consequence Analysis (SOARCA) Project
Independent Technical Review
Bruce Mrowca

contemporary higher population densities, all of which have the effect of increasing negative consequences were accounted for. Therefore, although the language is unfortunate, the practice employed during the execution of the program appears reasonable.

Sequence Selection

In Section 1.6 of Draft Revision 4, it is stated that the selection of important sequences would best be achieved through the use of a full-scope Level 3 PRA. The report notes that this was not feasible because no current full-scope Level 3 PRAs were generally available. Therefore, the SOARCA Project Team chose to draw from available information. In order to demonstrate completeness, a key challenge for the SOARCA project was the identification and selection of the accident sequences to be analyzed.

The approach used for SOARCA was to analyze sequences with a core damage frequency (CDF) of greater than 10^{-6} per reactor-year. In addition, sequences were included that have an inherent potential for higher consequences (and risk), with a lower CDF – those with a frequency greater than 10^{-7} per reactor-year. The report further states that “[b]y adoption of these criteria, we are reasonably assured that the more probable and important core melt sequences will be captured.” Draft Revision 1 stated that the sequence identification is consistent with the American Society of Mechanical Engineers’ (ASME’s) “Standard for Probabilistic Risk Assessment for Nuclear Power Plants,” ASME RA-Sb-2005, which defines a significant sequence, in part, as one that individually contributes more than 1 percent to the CDF. The Revision 1 report used an assumed CDF of 10^{-4} per reactor-year to conclude that the SOARCA sequence selection criterion is 1 percent of an acceptable CDF goal and the SOARCA sequences are consistent with Regulatory Guide 1.200 and the ASME standard. Although the ASME Standard remains in the reference list, the discussion of the consistency with the Standard’s screening criteria has been removed.

In order to meet the communication and siting objectives, the approach for selecting and screening the accident sequences needs to be defensible and transparent. This reviewer found weaknesses in both. As sequence selection was primarily based on the above screening criteria with some qualitative additions, the approach to screening is directly relevant to the degree at which “the likely (i.e., best estimate) outcomes of a severe accident at a nuclear power plant” were captured and included in the analysis.

The case for using the selected screening process is not well made. The analysis states that the priority of the work is to bring a “more detailed, best-estimate, and consistent analytical modeling to bear in determining realistic outcomes of severe accident scenarios” and concludes that the benefits could most efficiently be demonstrated by applying these methods to a set of the more important severe accident sequences. However, the stated project objectives are much farther reaching than demonstrating the benefits of realistic analytical methods. The benefits of realistic analysis can be achieved by selecting any relevant set of sequences. For the narrow objective of demonstrating the benefits of realistic methods, this reviewer agrees that approach taken is sufficient. However, the other identified objectives suggest that it is necessary to capture all or a significant portion of the risk. Specifically, a more comprehensive approach would appear to be called for in order to communicate risk and to provide an update of the quantification of offsite consequences contained in NUREG/CR-2239.

It is this reviewer’s experience that there are several means that could have been used to limit the scope of sequences addressed by this analysis. These include the following:

1. Evaluate all sequences using simplified consequence techniques and then use the SOARCA techniques for those where the identified consequences are significant. In essence, one refines the analysis based on the significance. This approach has the benefit of ensuring that all sequences are addressed and that those that are significant receive the more detailed and integrated analysis.

State-of-the-Art Reactor Consequence Analysis (SOARCA) Project
Independent Technical Review
Bruce Mrowca

2. Map all core damage sequences into consequence groups and analyze the bounding sequence within the group. This approach would again assure complete accountability. The challenge is to be able to identify the bounding sequences. This challenge is avoided by the first approach.
3. Evaluate all significant accident sequences consistent with the expectation of the ASME PRA standard such that their summed percentage is 95% and the individual percentage is 1%. If this approach is performed using CDF, then there is a need to ensure that bypass events are addressed similarly to those proposed by the SOARCA Project. This reviewer believes that the targeted sequences identified in the SOARCA report represent significantly less than the 95% ASME PRA criterion.

A review of the Surry SPAR Model (Version EE.3P) and the Peach Bottom SPAR Model (Version EE-L2-3P) by this reviewer finds an internal events CDF of 6×10^{-6} and 3×10^{-6} per reactor year, respectively. It would not be unusual to double these frequencies to account for external events, yielding 1.2×10^{-5} and 6×10^{-6} , respectively. Therefore, to obtain the identified screening criteria would require a significantly lower screening value, at least one order of magnitude lower, than that used by the SOARCA Project. The use of the acceptable surrogate goal for the quantitative health objectives contained in the Commission's Safety Goal Policy statement as opposed to the estimated CDF associated with each plant, likely results in significant risk being screened. In response to these concerns, the SOARCA Project Team stated that the selected sequences are representative in terms of reflecting the range of potential consequences and were intentionally not organized to be a comprehensive risk study.

Given the limitation of utilizing available Level 1 risk models, the approach appears to be adequate for demonstrating the benefit of realistic consequence analysis. However, a more satisfying approach would have been to apply state-of-the-art techniques to the developing the accident sequences. Such an approach would have significantly lessened the concern as to the completeness and calculated frequencies of the identified sequences.

Treatment of Mitigation Measures and Operator Actions

A stated SOARCA objective is to evaluate the potential benefits of recent security-related mitigation improvements. However, a stated limitation of SOARCA in Section 1.6 is "a comprehensive human reliability assessment has not been performed to quantify the probabilities of plant personnel succeeding in implementing these measures and the likelihood of success or failure is unknown." The lack of a human reliability assessment severely limits the credibility of the determining the benefit of these additional actions. It also results in incomplete frequency information as the frequencies of the sequences with the added actions cannot be determined. It is this reviewer's opinion that the SOARCA Project did not demonstrate through state-of-the-art techniques that the mitigation improvements objective was achieved.

Update Quantification of Offsite Consequences of NUREG/CR-2239

The off-site quantification contained in NUREG/CR-2239 (the siting study) uses a set of five siting source terms to represent five accident groups, each assigned a suggested representative probability, and states that these values can be adjusted to approximately represent any current LWR design. For example, SST1 was assigned the probability of 1×10^{-5} , the highest consequence and lowest probability of the source terms considered. The siting study used Indian Point as a base case and examined the role of population distribution in determining reactor accident consequences. It also included a sensitivity study using the actual population distribution and 1-year average wind rose from each of the 91 U.S. reactor sites having either an operating license or a construction permit (as existed in 1982). Sensitivity analysis was also performed for reactor size. Although it is valuable to compare the results of SOARCA

State-of-the-Art Reactor Consequence Analysis (SOARCA) Project
Independent Technical Review
Bruce Mrowca

such a comparison appears to fall short of the scope needed to meet the objective of updating the quantification of the consequence analysis included in the siting study.

Conclusions

It is clear that the insights gained from the integrated phenomenological analysis using self-consistent scenarios are significant and the report demonstrates the benefits of this more realistic treatment. However, the process for selecting the scenarios and for applying the security-related recovery actions appears to have considerable limitations. The lack of a Level 3, internal and external events PRA for the selected plants resulted in the use of a sequence selection and screening process that does not guarantee completeness. The failure probabilities for the additional security-related mitigation actions were not determined preventing the determination of the mitigated sequence frequencies and the full assessment of their impact.

And finally, the objective of updating the consequence analysis contained in NUREG/CR-2239 does not appear to be fully achieved. The siting study has much broader scope addressing all the sites. To fully achieve this objective additional analysis is required.

The integrated approach to the phenomenological modeling of accident progression provides valuable insights and demonstrates the importance of using the current body of knowledge regarding the realistic outcomes of severe accidents. It also makes clear that applying similar techniques to the sequence identification and quantification process would likely yield valuable insights and significantly improve our understanding of both the accident progression and offsite consequences.



January 26, 2012

**TO: Professor Karen Vierow
Associate Professor and Graduate Coordinator
Department of Nuclear Engineering
Texas A&M University
337 Zachry Engineering Center, 3133 TAMU
College Station, TX 77843-3133**

FROM: Kevin O’Kula

**SUBJECT: Individual Assessment on State-of-the-Art Reactor Consequence Analyses
(SOARCA) Project**

Introduction and Summary

A final assessment has been conducted of the State of the Art Reactor Consequence Assessment (SOARCA) Project and is part of the Peer Review Team’s review of the methods, inputs, analyses, results and findings for Peach Bottom and Surry Nuclear Power Plants for selected severe accident sequences. The review of the SOARCA project by this peer reviewer was based on presentations and handout made at four of the five Peer Review meetings in Rockville and Bethesda, Maryland,¹ multiple NRC staff-SOARCA team-Peer Review telecons, and a full series of supporting SOARCA documentation.

The SOARCA project analysis is reviewed in the course of the next seven sections as follows.

- Section 1 - Adequacy of the SOARCA Concept
- Section 2 – SOARCA Approach
- Section 3 – Reasonableness of the SOARCA Technical Results
- Section 4 – Uncertainty Analysis
- Section 5 – Attainment of the SOARCA Objectives
- Section 6 – Final Items for Consideration, and
- Section 7 – Suggestions on Improving Current Reports.

¹ This reviewer was not able to attend the fifth and final meeting in December 2012.

1. Adequacy of the SOARCA Concept

It is the judgment of this reviewer that the SOARCA study more than met its goal of applying state-of-art, and valid approaches for evaluating severe accident phenomena and ensuing subsequent offsite consequences. With respect to offsite consequence analysis, many parts of the analyses were technically “cutting edge”. Included were:

- Use of a high resolution, 64-sector, polar coordinate grid in the atmospheric transport and dispersion (ATD) in MACCS2
- Modeling of emergency phase actions, specifically use of the network evacuation model and accounting for EPZ roads and their capacities
- Improved assessment of shielding factors and assignment of population cohorts
- Capability to input current FGR-13 as well as older sets of dose conversion factors
- Improved, updated ICRP-60 dosimetric models and the capability to run a full range of latent health effect models.

However, other aspects of the offsite consequence analyses maintain older models or input data. These are acceptable for achieving the overall goals on the SOARCA project in most cases but merit some thinking in the direction of upgrades or replacement with other options for later work in commercial plant offsite consequence analysis studies. A list of candidates under this improvement area includes:

- Straight-line Gaussian plume segment model
- Economic consequence model with older (e.g. NUREG-1150, Ref. 2) data, and
- Assumptions and input data associated with decontamination and cleanup of economic assets. As with economic consequences, calibrating this important part of the analysis with the approach taken for decontamination in the mid- to late eighties isn’t consistent with a state-of-the-art analysis.

The limitations, were outweighed by the strengths of the SOARCA methods and skills of the Project team. The net outcome was a project that met its goals.

2. SOARCA Approach

SOARCA project, practices and methodologies were described for the most part, with appropriate level of detail for the accident scenario selection process. Criteria for event selection and screening are defined sufficiently and appropriate for the intent of the SOARCA analysis.

For the Peach Bottom plant, this process resulted in the following accident scenarios:

- Long-term station blackout (unmitigated and mitigated)
- Short-term station blackout with RCIC blackstart (unmitigated and mitigated), and
- Short-term station blackout without RCIC blackstart (unmitigated and mitigated).

For the Surry plant, the SOARCA process resulted in the following accident scenarios:

- Long-term station blackout (unmitigated and mitigated)
- Short-term station blackout (unmitigated and mitigated)
- Short-term station blackout with thermally induced steam generator tube rupture (unmitigated and mitigated), and
- Interfacing systems loss of coolant accident (unmitigated and mitigated).

I remarked in 2010 that the discussion presented during peer review meetings and in the documentation was sufficient to justify using a set of robust scenarios for each plant. No additional information has been observed that contradicts this conclusion. More complete modeling and the addition of other scenarios will be best saved for a near-term, full-scope Level 3 analysis, should that objective be chosen by the NRC.

The approach taken for the offsite consequence analysis was comprehensive and met expectations for contemporary standards and assumptions. Innovative methods were applied rigorously for, but not limited to

- Evacuation (network) modeling and cohort representation
- Publishing of latent cancer fatality risk results through three different health effect models
- Highly accurate dispersion polar coordinate grid
- Site-specific dose mitigative setpoint modeling and other aspects of emergency planning analysis.

The interface between the MELCOR source term development and input to the offsite MACCS2 consequence analysis is now better documented than earlier. In other words, while satisfactory MELCOR-MACCS2 integration was apparently achieved, much of this work was not documented to the appropriate level of detail that would be desirable in a study of this magnitude. However, a complete discussion should be documented fully in the near future to allow safety professionals and regulators an opportunity to draw their own conclusions.

Nonetheless, the chronological treatment applied in the SOARCA analysis was notably consistent from scenario selection through offsite consequence evaluation for each of the baseline, accident sequences discussed in the NUREG/CR reports. More will be said about the integration in Section 6.

The SOARCA processes were sufficiently best-estimate with respect to the offsite consequence analysis performed. It will be important to finalize the uncertainty analysis to understand parameter impacts and sensitivities, and where the best-estimate values lie relative to other statistical figures-of-merit.

3. Reasonableness of the SOARCA Technical Results

In general, the overall technical results are well substantiated and explained in sufficient detail so as to support key findings and study insights. Good use was made of the NUREG/CR-2239 (Ref. 3) SST1 source term with respect to the composition, timing, and magnitude of the release relative to SOARCA source terms, and comparison to the latent cancer fatality quantitative health objective (NRC safety goal). An opportunity was missed to connect with one or two metrics reported for Peach Bottom and Surry from NUREG-1150. A SOARCA study examination of an accident sequence from the 1990 NUREG-1150 study and compared with a SOARCA unmitigated sequence for population dose or mean land contamination would have presented useful insights one step more directly associated with the reduced source term, than obtained by reporting LCF risk metrics. In other words, use of the LCF to provide comparison

was done well but needed to add one last layer of calculation through use of one of three health effect models. This would not have been required if analysis were terminated earlier.

4. Uncertainty Analysis

For credibility with the PRA community, the SOARCA project, as a best-estimate, realistic approach to severe accident sequence analysis, requires an understanding of the implied margins in intermediate quantities and in the reported LCF risk quantities. The peer review panel was informed on the status of the uncertainty analysis and responses to earlier memoranda issued in 2010 during the December 2011 meeting presentation by Dr. Ghosh, the draft Uncertainty analysis document provided in late December, and the last telecon conducted in early January 2011.

While the panel had an opportunity to see this work in progress and ask questions, it was informed that no additional opportunities would be available to comment on this important aspect of the SOARCA Project. Having thought about this over the last few weeks and recognizing the quality of the current draft document (“State-of-the-Art Reactor Consequence Analyses (SOARCA) Project: Uncertainty Analysis”), this is a satisfactory if the final loose ends are completed. I’ll note one last time that the single parameter that would have provided additional insights in its incorporation in this type of evaluation is the habitability – long-term dose criterion (DSCRLT). Because this aspect of the analysis, i.e., when residents would be able to return to their homes, results in this long-term dose and this eventually becomes the basis for a small but finite LCF risks in some of the health effect models, it would be of interest to quantify at some point (perhaps at minimum in a sensitivity analysis study).²

5. Attainment of SOARCA Objectives

The judgment of this reviewer is that the SOARCA project largely met its over-arching objective as stated in the SOARCA Main Report, (page 10 of NUREG-1935), i.e., “to develop a body of knowledge regarding the realistic outcomes of severe reactor accidents,” and “to develop best estimates of the offsite radiological health consequences for potential severe reactors accidents for two pilot plants. Included with the primary objective are corresponding and supporting objectives. While many areas are still being addressed and need additional work, these include: (i) incorporating the significant plant improvements and updates not reflected in earlier assessments including system improvements, training and emergency procedures, offsite emergency response, and recent security-related enhancements described in Title 10, Section 50.54(hh) of (10 CFR 50.54(hh)) as well as plant updates in the form of power uprates and higher core burnup; (ii) crediting state-of-the-art integrated modeling of severe accident behavior which includes the insights of some 25 years of research into severe accident phenomenology

² Also, after the Fukushima event, the need to plan, deploy, mobilize equipment, and coordinate large-scale decontamination operations would seem to require some intermediate time period to be included. Currently, the model in the SOARCA Project jumps immediately to the long-term activity without an in-between period. A rarely used time phase, the intermediate phase, can be modeled in MACCS2 between SOARCA’s seven-day emergency phase and the fifty-year long-term phase. A sensitivity analysis could help examine what level of exposure decrement could be achieved with a preliminary waiting period. This may be left to the next full-scope Level 3 PSA.

and radiation health effects; (iii) evaluating the potential benefits of recent security-related mitigation improvements in preventing core damage and reducing an offsite release should one occur; (iv) enabling the NRC to communicate severe-accident-related aspects of nuclear safety to stakeholders; (v) updating quantification of offsite consequences found in earlier NRC-sponsored work such as NUREG/CR-2239 and NUREG-1150.

6. Final Items for Consideration

Past review reports have itemized as many as eight areas as unaddressed or opportunities for improvement. Through the responsiveness of the SOARCA Project Team, the original list has been addressed to disposition: (1) surface roughness length, (2) deposition velocity, (3) non-site specific and site-specific parameters (partially), (4) boundary weather, and (5) polar grid dimensions. The final documents are readable, sufficiently scrutable and there is a much improved appropriateness of presentation. There are still several items that could be considered before the full set of NUREG documents is published.

1. **MELCOR-to-MACCS2 transition:** The documentation in the NUREG-1935 Main Report, and in the plant-specific NUREG/CR-7110 reports, is incomplete with the MELCOR accident scenario source term to MACCS2 input transition. The pedigree of the MELMACCS technical report (Ref. 49 in the executive summary Main Report) remains an internal laboratory report. It is recommended that the report be formally added to the SOARCA document collection .
2. **Listing of the MACCS2 input parameters used:** Although this is not a full discussion, the input parameter values in the Surry and Peach Bottom appendices is adequate at this point, and much appreciated. In time, a discussion and justification would be key information in defending how the model was run.
3. **Centralized and plant-specific discussion of MACCS2 improvements:** Section 5 of the Main Report summarizes improvements in the Offsite Consequence Analyses, and specifically, those features in Version 2.5 of the MACCS2. This section mentions a number of the major improvements to the original MACCS2 code used to quantify SOARCA offsite consequence predictions. To improve the level of detail in the reports regarding how these improvements were utilized, it is suggested that an additional level of detail be provided in the plant-specific reports, in Section 7, immediately after Surry/Peach Bottom Source Terms.
4. **Reporting of additional risk metrics consequence measures –** In addition to the conditional and absolute health effect risks reported in the SOARCA study, the metrics of population dose in the fifty-mile region and land contamination (I, Te, Ba and Cs would be obvious choices based on the plant-specific results reported. The population dose metric would allow comparison to some selected accident scenarios used in NUREG/CR-2239 and in NUREG-1150.

7. Suggestions on Improving Current Reports

The addition of an appendix to the Main Report on SOARCA and the Fukushima Daiichi Accident is strategically important to the acceptability of the project results as a whole. However, a few lines should be mentioned in the Executive Summary about the statement on Fukushima and its relationship to the SOARCA Project, and acknowledged in the Table of Contents.³

The order of discussion in the plant-specific reports appears to be somewhat out of sequence with the order followed in the main report. For example, each plant report transitions from integrated thermal hydraulics, accident progression, and radiological release analysis into emergency preparedness, with a subsequent results section. This is a somewhat sharp transition without the expected phenomenological logic that is carried in the main report.

There is mention in the Main Report on “alternative long-range plume spreading model” as part of one of the atmospheric transport and dispersion modeling improvements. However, there appears to be no additional discussion on this feature in the main report or in the plant-specific documents.

Acknowledgement

As a reviewer of the multi-year SOARCA Project, I wish to thank all the SOARCA Project Team for their presentations, technical interchange, responsiveness and willingness to work with the peer reviewers. In particular, Dr. Nate Bixler is appreciated for his time carefully explaining his position and thinking applied in the SOARCA consequence analysis modeling area.

References/Bibliography

1. *State-of-the-Art Reactor Consequence Analyses (SOARCA) Project, Main Report*, NUREG-1935, Predecisional, Revision 4, U.S. Nuclear Regulatory Commission, (December 2011).
2. *State-of-the-Art Reactor Consequence Analyses (SOARCA) Project, Volume 1: Peach Bottom Integrated Analysis*, Predecisional, Sandia National Laboratories, NUREG/CR-7110 (December 2011).
3. *State-of-the-Art Reactor Consequence Analyses (SOARCA) Project, Volume 2: Surry Integrated Analysis*, Predecisional, Sandia National Laboratories, NUREG/CR-7110 (December 2011).
4. *State-of-the-Art Reactor Consequence Analyses (SOARCA) Project: Uncertainty Analysis*, Draft Report, NUREG/CR-XXXX, Sandia National Laboratories.

³ This may have been mentioned or agreed to in the December 2011 meetings or during the phone call in January 2011.

5. NUREG-1150, V., Severe Accident Risks: An Assessment for Five U.S. Nuclear Power Plants. Nuclear Regulatory Commission, Washington, DC, 1990.
6. NUREG/CR-2239, Technical Guidance for Siting Criteria Development. 1982, Sandia National Laboratories: Albuquerque, NM.
7. H-N Jow, J.L. Sprung, J.A. Rollstin, L.T. Ritchie, and D.I. Chanin. *MELCOR Accident Consequence Code System (MACCS), Volume 2. Model Description*; Sandia National Laboratories, Albuquerque, NM. NUREG/CR-4691 (SAND86-1562), 1990.
8. D.I. Chanin, M. I. Young, and J. Randall. *Code Manual for MACCS2: Volume 1, User's Guide*; NUREG/CR-6613 (SAND97-0594), Sandia National Laboratories, published by the U.S. Nuclear Regulatory Commission, Washington, DC, 1998.

Peer Review Comment on the SOARCA Project and the Resultant NUREG-1935 Report

John D. Stevenson

January 23, 2012

This note is to record my peer review of the SOARCA project and associated documentation. As a peer reviewer, I have reviewed drafts of three NUREG's as follows:

- NUREG/CR-7110, "State-of-the-Art Reactor Consequences Analysis Project," Vol. 1, Peach Bottom Integrated Analysis.
- NUREG/CR-7110, "State-of-the-Art Reactor Consequences Analysis Project," Vol. 2, Surry Integrated Analysis.
- NUREG-1935, "State-of-the-Art Reactor Consequences Analysis (SOARCA) Project," Main Report.

There were also a number of peer review meetings which I attended, where SOARCA team members (NRC staff and Sandia contractors) presented information developed as part of the SOARCA project. As part of the peer review process, I prepared a number of written comments on the draft documents listed above and presentations that were made at the peer review meetings which are documented in the appendices to this peer review report.

My peer review was limited to my areas of expertise which is associated with the natural hazard external events and the generation of hydrogen in a Loss of Coolant Accident, LOCA with a potential for early release of significant levels of radiation from the containment structures and systems.

I agree from a natural phenomena hazard standpoint, the greatest threat to the loss of electrical power both from sources outside and inside the two NPP's studied resulting in station blackout is a very low probability of occurrence earthquake (i.e. less than a 10^{-6} /yr probability of exceedence earthquake).

The concern raised is that such a level of earthquake for the Surry NPP could lead to the soil liquification or consolidation leading to displacement that might cause containment penetrations to rupture and thereby lead to early containment failure which was identified in the SOARCA study.

A second potential early release from the containment of the results of a core melt accident caused by a potential station black out evaluated by the SOARCA project, was the potential for hydrogen generated by the postulated core melt to be accumulated in a sufficient quantity to cause a detonation within the

1

containment structure that could result in pressure loads on the containment structure at or near the ultimate capacity of the containment. Deflagration of hydrogen inside the containment has been postulated and considered in the SOARCA evaluation of the potential for early release of core melt radiation from the containment. The potential for the hydrogen concentrations to build-up to a concentration sufficient for a detonation is controlled by the steam in the containment generated by the core melt acting to prevent hydrogen deflagration or detonation. The activating of the containment spray system which is designed to condense the steam in the containment and thereby reduce containment pressure also eliminates the steam as hydrogen deflagration or detonation suppressing agents.

Generally, it is assumed in the design of PWR containments, because of their large volume, that one or more deflagrations of hydrogen generated in the containment due to core melt will prevent the build-up of the hydrogen concentration to detonation levels. In BWR containment dry wells in U.S. NPP's there are installed filtered vents which can be activated to release containment hydrogen to the atmosphere before a detonation level of hydrogen is allowed to occur.

There is a need to assure that the severe accident management team is aware of the potential for hydrogen build-up in containment to detonation concentration levels and for them to develop administrative procedures or install hardware to preclude this detonation level build-up from occurring.

My overall impression of the SOARCA project and associated documentation is that it is a realistic effort to validate the consequences of a complete loss of cooling to a large commercial BWR and PWR power reactor and as such makes a significant contribution to the understanding of U.S. commercial reactor risk.

Review Comments of the SOARCA Project
Karen Vierow
January 20, 2012

In formulating this review, I prepared a list of key questions that should be answered to evaluate the SOARCA project. Topics and aspects of the SOARCA project for which I feel qualified to comment on are evaluated below. Several of the comments are limited to severe accident modeling and have been qualified as such.

1 Adequacy of the SOARCA Concept

- 1.1 Is SOARCA a valid approach to evaluating severe accident phenomena and the offsite consequences of reactor severe accidents?

The SOARCA approach for modeling severe accident phenomena is a valid approach because it is a comprehensive and integrated analysis approach applied to selected scenarios that could hypothetically lead to severe accident event sequences. Physics-based deterministic methods and probabilistic risk assessments are combined to take advantage of the best of both approaches in the severe accident analyses.

- 1.2 Is the SOARCA truly “state-of-the-art”?

SOARCA is state-of-the-art for analysis of severe accident sequences in that the latest version of MELCOR severe accident modeling has been adopted.

MELCOR had previously been compared against other leading severe accident codes in the U.S. by this reviewer and other researchers. Multiple journal articles document comparisons against the MAAP code and/or the SCDAP/RELAP5 code for scenarios similar to those studied by SOARCA. In particular, the high-pressure natural circulation scenario, studied within SOARCA for the Surry PWR reactor, has been extensively studied in these efforts. The thermal-hydraulic phenomena and major in-vessel severe accident phenomena have been demonstrated to be in good agreement for the three codes. The integral effect of diversified core models in terms of total hydrogen production and total core debris mass slumping into reactor vessel lower head were also shown to be consistent for the three codes.

Version 1.8.6 of the MELCOR code has been used in the SOARCA. The changes from MELCOR 1.8.6 to 2.1 are those needed for “modernization” to a newer FORTRAN version. The MELCOR 2.1 code models have been shown to reproduce the results of MELCOR 1.8.6 version out to machine accuracy. Therefore, version 1.8.6 of MELCOR may be considered state-of-the-art for the current purposes.

- 1.3 Even if SOARCA is state-of-the-art, is the approach adequate to achieve the goals?

As discussed above, the MELCOR code has been shown to be state-of-the-art, with comparable capabilities as other leading U.S. codes for severe accident analysis. Comparison of severe accident code predictions against experimental and plant data is an essential test of code accuracy that provides additional information on the relative merits of the various severe accident models. MELCOR severe accident models have been validated against a number of separate effects tests and the TMI-2 plant data. The presentation by R. Gauntt at the Dec. 8, 2011 meeting revealed that the code validation has been conducted in a systematic manner to test code simulation capabilities for key phenomena and their interactions. Since many of the key models for the SOARCA have been validated, MELCOR may be considered adequate for severe accident calculations in order to achieve SOARCA goals.

A considerable amount of excessive conservatism in past calculations has been removed by incorporating plant improvements and updates into the assessments. The code now produces results that are more realistic than were previous analyses. The severe accident calculations also include modeling improvements and insights that have been achieved since the earlier calculations were performed.

Some analysis aspects remain that require additional sensitivity studies and uncertainty quantification. First, conservative safety factors have been applied in certain areas where uncertainty remains. Second, where scientific knowledge is insufficient to develop mechanistic models, assumption of values for various parameters must be done.

As recommended in an April 9, 2010 memo from members of the peer review committee to the SOARCA team, uncertainty quantification and sensitivity analysis are essential to the credibility of the SOARCA. The Uncertainty Analysis currently being conducted is an important effort to address this recommendation. The peer review committee was presented on Jan. 5, 2012 with the uncertainty parameters and their respective value distributions adopted for the Uncertainty Analysis. The list is subjective, but it appeared to capture the most significant uncertainty parameters.

2 Reasonableness of the SOARCA Technical Results

The severe accident progression results are reasonable, as reported in the SOARCA documentation. The temporal trends and absolute numbers (such as maximum temperature, pressure, etc.) have been explained within the text. Where significant uncertainties exist, these have been investigated in a conservative manner so that results do not include excessive optimism about nuclear plant safety.

3 Attainment of SOARCA Objectives

The SOARCA objectives are, quoting from Section 1.2 in the Main Report:

The overall objective of the SOARCA project is to develop a body of knowledge regarding the realistic outcomes of severe reactor accidents. Corresponding and supporting objectives are as follows:

- *Incorporate the significant plant improvements and updates not reflected in earlier assessments including system improvements, training and emergency procedures, offsite emergency response, and recent security-related enhancements described in Title 10 of the Code of Federal Regulations (10 CFR) 50.54 (hh), as well as plant updates in the form of power uprates and higher core burnup.*
- *Incorporate state-of-the-art integrated modeling of severe accident behavior, which includes the insights of some 25 years of research into severe accident phenomenology and radiation health effects.*
- *Evaluate the potential benefits of recent security-related mitigation improvements in preventing core damage and reducing or delaying an offsite release should one occur.*
- *Enable the NRC to communicate severe-accident-related aspects of nuclear safety to stakeholders including Federal, State, and local authorities; licensees; and the general public.*
- *Update quantification of offsite consequences found in earlier NRC publications such as NUREG/CR-2239, "Technical Guidance for Siting Criteria Development"*

The overall objective has been attained for the reactors evaluated by SOARCA, as evidenced by the reduction of conservatism in the evaluations and the use of plant-specific data, procedures, scenarios, and other information. Each scenario has been investigated in careful detail to assure consistent and reasonable evaluations.

The analysis presented here is for two specific plants, a PWR unit at Surry and a BWR unit at Peach Bottom. Many *insights* have been gained; however, care should be taken in extrapolating results to other plants. Since each unit may have unique operating procedures, mitigation equipment, and the like, differences should be identified before applying the results of the current analyses to other plants.

Regarding the first bulleted goal, the attainment of this goal is clearly demonstrated in the SOARCA document as far as plant improvements and updates. The method for inclusion of power uprates and higher core burnup in the MELCOR analysis was clarified in the SOARCA team's July 2011 response to my comment.

Attainment of the second bulleted goal has been achieved for severe accident analysis, as discussed in item 1.

The third bulleted goal has been documented in Volumes 1 and 2, which present the comparisons of mitigated and unmitigated scenarios. Mitigation steps have significant, positive effects on the event progression and consequence reduction.

Addressing the fourth bulleted goal, the documents are thorough and well-prepared. Members of the public who are willing to invest time and have a familiarity with nuclear and related technologies will be able to understand the SOARCA approach and results as presented in the SOARCA documents. For the general public less familiar with the technologies, a document written in layman's terms is needed. Such documents were mentioned at earlier Peer Review Committee meetings, and it is anticipated that they will be produced and disseminated. This last action is essential to attaining the fourth bulleted goal.

I leave evaluation of the fifth goal to others.

4 Presentation of the SOARCA effort as a "best-estimate" study

The primary objective of the SOARCA project is stated in several locations of the SOARCA document and in presentations to the Peer Reviewer Committee to be a "best estimate evaluation of the likely consequences of important severe accident events..." The first such claim appears in the Abstract of the Summary Report. Other locations such as the Abstract of Volume 2 state that "This study has focused on providing a realistic evaluation of accident progression, source term and offsite consequences..."

It is suggested that the current evaluations are not entirely best-estimate and that care be taken in the SOARCA documents to qualify this claim. A claim to "more best-estimate", or "more realistic", results than produced by earlier analyses is appropriate.

While the SOARCA team has done a commendable job of enabling more realistic evaluations of severe accident consequences, several conservatisms have, in fact, been retained. Many of these conservatisms are, in the judgment of this peer reviewer, reasonable and should be discussed collectively in a visible location within the SOARCA document.

Because a "best-estimate evaluation" is a stated primary goal of the SOARCA project, this reviewer suggests that a compendium of conservatisms be included within the SOARCA

documentation, perhaps as an appendix or within a discussion section on the extent to which SOARCA objectives have been met. Within this appendix or discussion, the argument should be made that inclusion of some conservatism is warranted. Two reasons for justification come readily to mind. First, conservatism is one method for treating uncertainties. Second, if a nonconservative approach were to be taken, the SOARCA project could be interpreted by the public as being overly optimistic about nuclear safety and thereby lose credibility.

An alternative suggestion is to perform a calculation in which the conservatisms are removed. This approach is analogous to performing the consequence analysis using actual weather condition from a typical day, instead of specifying conservative or time-averaged conditions.

The SOARCA team explained in their July 2011 response that they understand this concern and have identified conservatisms throughout the documents. A concise discussion of conservatisms would be convenient, but the lack thereof does not detract from the quality of the SOARCA project.

5 Appropriateness of Presentation in the SOARCA Documents

5.1 Does the SOARCA appear objective and uninfluenced by licensees or other constituents?

The SOARCA project appears to have been conducted independently from licensees and other constituents. While discussions with utility staff were necessary to obtain the required plant descriptions and other information, the evaluations were performed with codes that may or may not be used by plant personnel and without utility involvement.

Representation of industry, consulting, academia and international research institutes on the Peer Review Committee promotes a fair review of the process and makes possible an adequate and impartial evaluation of the SOARCA.

5.2 Will the public interpret the SOARCA as intended?

Those educated in nuclear and related technologies should find the SOARCA document a detailed and well-prepared presentation of the effort. Emphasis on the objectivity and impartial nature of the effort should be emphasized. Stating the NRC's mission to protect the public's health and examples of where the NRC has denied requests for licenses or other permissions may remind the public that the NRC does not gain by painting a bright picture about the safety of nuclear power plants.

As mentioned earlier, a description of the effort in layman's terms is important when communicating with a large percentage of the population. Particular care is needed with respect to presentation of health effects and to assure the general public that all cohorts have been given adequate consideration. The cohort that voluntarily does not follow evacuation guidance must be clearly noted as being voluntary nonevacuees.

The MELCOR Best Modeling Practices volume provided in earlier NUREG drafts is exceptionally helpful in understanding the philosophy and implementation of models for key phenomena. For many of these calculation aspects, code developers and users may arrive at different approaches. Several important aspects of the severe accident evaluations that would not have been apparent otherwise are explained and therefore could be reviewed for acceptability.

Summary Statement

4

58

This review has been performed primarily with respect to the severe accident modeling techniques and results.

The severe accident modeling of SOARCA has been performed with a state-of-the-art code version, MELCOR 1.8.6. The code has been demonstrated to have capabilities with at least the same level of fidelity as other leading severe accident codes in the U.S. Most of the models used in SOARCA have been validated against plant data and separate effects test data.

Some analysis aspects remain that require additional sensitivity studies and uncertainty quantification. This reviewer believes that "closing the loop" on remaining issues via uncertainty quantification and sensitivity analysis will enable achievement of the SOARCA goals for severe accident analysis of the Surry and Peach Bottom plants.

The SOARCA objectives, as stated in the Executive Summary, have been achieved in large part. In particular, a large amount of information regarding severe accident analysis has been developed. The plant-specific analyses of a unit at Surry and at Peach Bottom have provided insights into the behavior of other reactors. Care should be taken in extrapolating the results to other plants. Documentation has been well prepared, although a SOARCA document in layman's terms would also find good use.

A considerable reduction of conservatism has been achieved in the SOARCA analyses. Care should be taken in public documents and presentations to qualify the degree to which the analysis methods and results can be regarded "best-estimate" or "realistic." The qualified claim of *more realistic* evaluations seems appropriate. The conservatisms remaining in the calculations should be compiled in a single section in the SOARCA document.

Finally, the SOARCA appears to be objective and uninfluenced by interested parties. The presentation seems appropriate. Particular care should be given to presentation of health effects so that the general public understands that all cohorts have been given adequate consideration.

Examination of Off-Site Consequences of a Severe Reactor Accident

Reviewer: Jacquelyn C. Yanch, PhD

Full Report: December 2010

Preface: January 2012

Preface:

The severe reactor accident at Fukushima in March 2011 allowed a number of SOARCA assumptions and findings to be realistically evaluated. Importantly, we saw that there was sufficient time following the start of the reactor accident for the public to be alerted and for evacuation to proceed. Little to no radiation dose (beyond natural background) was received at the time of the accident. The number of acute health effects was zero and most members of the public will receive essentially no additional dose from the accident until (and unless) they are permitted to return to their homes. This confirms the conclusions of the SOARCA study which found, for all scenarios examined, that substantial radiation dose can be effectively avoided through evasive action on the part of each member of the public.

Evacuation is necessary to avoid the potential health effects of living in an environment contaminated with fission products. However, the accident at Fukushima Daiichi has also illustrated the costs, the trauma, and the disruption associated with dose avoidance through evacuation.

The Fukushima accident contaminated over 1000 km² of land. Approximately 100,000 people lost their homes and have been forced to live for many months, and perhaps for many years, in crowded shelters and temporary housing. For some, the loss of home and community will be permanent. Evacuees have lost jobs, families have been separated, farmland has been rendered unusable, shops and factories have had to be abandoned, and societal infrastructure in many villages, towns and communities has been destroyed.

Thus the main consequence of a severe reactor accident is likely not radiation-induced health effects in the population but instead, massive disruption of the lives of tens of thousands of people as they struggle to deal with an environment contaminated with fission products, and an economic burden that extends far beyond the evacuees to the nation's taxpayers at large.

No effects on the population other than radiation-induced health impact are evaluated in the SOARCA study and no attempt has been made to evaluate the consequences of environmental contamination and its impact on human suffering, human health, or the local and national economic consequences of a severe reactor accident. This is a significant and important omission. The study results contain the good news that radiation-induced health effects from a severe reactor accident can be avoided and the accident at Fukushima has shown us that this is indeed the case. However the bad news is that undertaking extensive dose avoidance through long-term evacuation and relocation is associated with enormous drawbacks and these drawbacks are very likely more harmful than the radiation dose being avoided. [This is discussed in detail in my review.] Existing data simply do not support extensive societal disruption to avoid dose-rates as low as 20 mSv/yr. No data demonstrate harm at dose-rates this low (~8 times average natural background levels). On the other hand, the drawbacks of long-term loss of home, community, farms, and industry are all too clear. This trade-off needs to be critically examined.

Examination of Off-Site Consequences of a Severe Reactor Accident

Reviewer: Jacquelyn C. Yanch, PhD

December 2010

Abstract:

The SOARCA study's evaluation of the rate of progression of different accident scenarios, coupled with the anticipated rate of evacuation of the public, reduces, to very low levels, the estimated likelihood of any acute effects of radiation. The health-related impact of an accident then results, almost exclusively, from long-term, low dose-rate irradiation. How much radiation exposure the public receives depends on what dose-rates "trigger" their relocation and their return home. While these trigger levels are set by individual states, not by the NRC, the SOARCA study brings to light significant problems associated with where these levels are set and the impact they will have on the public as they try to meet these levels. For instance, relocation and return home levels are set below the doses received as part of natural background in several parts of the world, and are also lower than the doses received by many people from diagnostic medical examinations. The strategies in place to avoid these radiation doses following an accident place a considerable burden on members of the public and it is not clear that these efforts are justified in terms of better long-term health. We know very little about the health impact of low dose and, more particularly, of low dose-rate radiation; we should make every effort to redress this lack of understanding so that the public can be appropriately guided as they deal with the aftermath of a severe reactor accident.

Summary of Review (One-Page)

Part A: Review Comments

Part B: Our fundamental lack of knowledge about the health impact of the post-accident radiation scenario.

What is our current understanding of the health effects of the radiation conditions represented by the return-home dose-limits? The data used and the process involved in establishing radiation risk estimates and for setting return-home dose limits are discussed.

Part C: Recommendations

Strategies for improving our understanding of radiation effects in the dose regime most relevant to a severe reactor accident are discussed.

Appendix List of Acronyms and Dose Conversion Table

Literature Cited

Examination of Off-Site Consequences of a Severe Reactor Accident

Reviewer: Jacquelyn C. Yanch, PhD

Review Summary:

1. Dose to the public is avoided during an accident but is received upon returning home.

For most of the scenarios addressed in the SOARCA study, the accident proceeds slowly enough that, should it be necessary to give the evacuation order, the public can leave in a timely way so that little to no radiation dose is incurred until the public is permitted to return home. When to return home is determined by return-home dose-limits set by individual states.

2. What is the health impact of the return-home dose-rates? We don't know yet.

None of the data we use in estimating radiation-induced health effects were obtained at the doses and dose-rates similar to those encountered upon returning home. Therefore we have essentially *no* understanding of the potential health consequences of these radiation conditions. More importantly, we have no understanding of the health impact of the radiation dose-rates that were avoided by staying away from home for so long.

3. SOARCA approach to estimating health impact reflects the state-of-the-art.

The strategy for determining the impact of exposure to anthropogenic radiation (assuming a threshold for acute effects, integrating the dose over a 50 year period, assuming cancer is the only impact on long-term health, the use of a DDREF of 2.0, and the application of a common risk factor throughout the entire dose range) is broadly consistent with the approach taken by the scientific field in general and by several national and international agencies and committees.

4. Extensive new data concerning reactors are incorporated in the SOARCA documentation but little new knowledge is available concerning the health impact.

While our ability to quantitatively address the likelihood of a severe reactor accident has improved dramatically over the last few decades, there has been little change in the depth of understanding of the consequences of radiation exposure to people, and we know little more today, about the consequences of living with an elevated dose-rate, than we did 30 years ago.

5. Who bears the burden of responding to the accident?

The burden of minimizing radiation dose is normally borne by the nuclear utility, but once radionuclides are dispersed in the environment this burden shifts to members of the public. The public undertakes the significant upheaval, effort, and financial cost devoted to minimizing their radiation dose. At the present time, however, we do not know what dose-rates we need to avoid and therefore we do not know what dose-avoidance efforts are really justified in terms of actual hazards to our health.

6. The return-home dose limits (set by individual states) are set very low, exacerbating the burden on the public. Even the least conservative return home dose limit is *lower* than the natural background doses in many areas of the world. The criterion used in PA is less than a factor of 2 higher than the average background in the United States and is significantly less than the dose received from a single CT exam of the abdomen. In this context, major dose-avoidance strategies such as long-term residential relocation until the return-home dose limit can be met, are unlikely to be in the best interests of the public.

Part A: Review Comments

A.1 Dose to the public results from returning home.

The SOARCA study results predict that dose to the public, for nearly all scenarios considered, will be very low. Evacuation training, experimental testing of evacuation, and experience with natural disasters, coupled with improved understanding of accident progression and knowledge of when, after initiation of the accident, release of radionuclides can be expected, has provided significant assurance that radiation exposure to the public in the direct aftermath of all accidents considered can be kept very low. That is, for most of the scenarios addressed, the accident proceeds slowly enough that, should it be necessary to give the evacuation order, the public can leave in a timely way so that little to no radiation dose is incurred until the public is permitted to return home.

When to return home is a decision made by individual states (not by plant management and not by the NRC). Pennsylvania sets the dose-rate limit at which residents can return home at 5 mSv (500 mrem) per year; Virginia follows the EPA recommendation of 20 mSv (2 rem) in year one and 5 mSv (500 mrem) per year thereafter.

Getting to the low dose-rate stipulated by the return-home dose-limits (RHDLs) requires that the public undergo significant upheaval or undertake significant cost and effort. Time will allow for physical decay of the radionuclides and for the effects of weathering [1] however during this time residents must live away from their homes. Alternatively, decontamination procedures such as scrubbing and/or flushing surfaces; soaking, plowing or removing soil; and removal and replacement of surfaces, etc., [1] can reduce dose-rates, but the cost to decontaminate can be considerable. If decontamination costs are greater than the cost of the land or dwelling then the land is considered condemned. [If land is condemned, no dose is accrued by the residents because they never return.]

Given the ready availability of foodstuffs from outside the area affected by the reactor accident, radiation dose from contaminated food and water can be avoided by prohibiting consumption of local produce, livestock, and water. Therefore, radiation dose from ingested radionuclides is not considered in the SOARCA study. Upon return home, then, the dose is assumed to come primarily through external radiation by gamma-emitters deposited on the ground, specifically the long-lived gamma emitters: ^{134}Cs and ^{137}Cs (2.1 yr and 30 yr half-lives, respectively).

A.2 What is the impact of the return-home dose-rates on human health? We don't really know.

Our understanding of what impact the return home dose-rates will have on people is very primitive. In fact, we have essentially *no* understanding of the potential health consequences of the dose-rates encountered upon returning home. The limited data we do have regarding radiation-induced health effects are highly uncertain and, in addition, are relevant to situations that bear very little resemblance to the conditions reflected by the return-home dose limits (RHDLs). [This is discussed in detail in Part B.]

More important perhaps is the fact that we have no understanding of the effects of those somewhat *higher* dose-rates we plan to spend considerable resources on to avoid (e.g. by relocation, decontamination, etc.). In other words, we do not know how necessary these dose avoidance strategies are for optimal human health or at what dose-rate it becomes necessary to perform them.

A.3 SOARCA evaluation of health impact follows state-of-the-art approach.

As a society we have developed strategies for dealing with our lack of knowledge of the health effects from low dose-rate radiation. We need these strategies to guide radiation protection policies. For routine radiation protection our limited understanding of the potential hazards presents little difficulty, mostly due to the specifics of this scenario, namely who controls the radiation source, who bears the risk, and who bears the costs of keeping the doses very low. [This is discussed further in Point 5.] Can these radiation protection strategies also be used to project long-term health effects from accidental exposures? Caution is often expressed *against* extending these

strategies to predicting the long term effects of small doses to a large population [2-4], however, as discussed in the SOARCA documentation, few recommendations for precisely *how* to project the effects of small doses have been provided by agencies or committees involved in generating risk estimates. Therefore, in the absence of a better approach, this caution is routinely ignored by the scientific community in situations where the potential magnitude of the impact of low doses is of interest and the result is that the general approach taken in radiation protection is nearly universally employed.

Two health consequences of elevated radionuclide levels in the environment are considered in the SOARCA study: (i) early deaths due to the acute radiation syndrome, and (ii) latent cancer fatalities (occurring many years later). Given the expected rate of progression of the various accident scenarios and the anticipated success of evacuation plans, the risk of acute fatalities (which will only occur following very large radiation doses) is either zero or very, very low. Radiation-related risks then become latent cancer fatalities resulting primarily from exposure to the long-term, chronic radiation dose-rates encountered upon being allowed to return home.

To estimate the risk of latent cancer fatalities from elevated dose-rates in the environment, the dose-rates are first integrated over a 50-year period to derive a total dose. This dose is then multiplied by a risk factor (risk of death per Sv) to determine risk of cancer fatality. Risk factors are from NUREG 6555 [5], and are based on mean responses of 13 experts who provided their estimates of the risk of a latent cancer fatality following a large (1 Gy) whole body radiation dose delivered very quickly (over 60 seconds)¹. As long as the dose in the first week of the accident scenario is below 0.2 Sv, the doses are assumed to be “low dose rate” and a dose-rate effectiveness factor (DREF) of 2.0 is applied to the risk estimate. In other words, the risk of long-term chronic radiation delivery is assumed to be half of the risk of an acute delivery of the same dose. [More on the use of a DREF in Part B.]

This strategy for determining the risks of exposure to anthropogenic radiation (assuming a threshold for acute effects, integrating the dose over a 50 year period, assuming cancer is the only impact on long-term health, the use of a DREF of 2.0, and the application of a common risk factor throughout the entire dose range) is broadly consistent with the approach taken by several national and international agencies and committees including BEIR, ICRP, NCRP, UNSCEAR, and the EPA [4,6-10]. Thus the approach taken in the SOARCA study for estimating the impact on health of elevated radionuclide levels in the environment has been performed using a state-of-the-art approach.

A.4 Level and depth of new knowledge: reactor systems versus health impact.

It is striking, however, to compare the state-of-the-art related to the impact of low dose-rate radiation on health with the vastly greater depth and detailed understanding we have of many aspects related to nuclear reactors and their subsystems. Significant new information and new analyses have been brought to bear on updated estimates of accident severity since the publication of NUREG/CR 2239 in 1982 [11]. This new knowledge reflects a deeper understanding of the causes and progression of reactor-based accidents through years of development and testing of models of individual systems, and by comparison of theoretical and model-based predictions with measurement data. The huge increase in computational power that has taken place over the same time period has facilitated extensive iterative refinement of the models and, importantly, has made it possible to integrate the models into a comprehensive analysis package in which accident-related changes in one part of the system can be tracked to other parts of the system in a spatially- and temporally-dependent manner.

Thus, while our ability to quantitatively address accident progression has improved dramatically over the last few decades, there has been little change in the depth of understanding of the consequences of radiation exposure to people and we know little more today, about the consequences of living with an elevated dose-rate, than we did 30 years ago.

¹These risk factors are consistent (within the uncertainty represented by 90% confidence limits and assuming use of a DREF) with those in BEIR V and BEIR VII reports (National Research Council Committee on the Biological Effects of Ionizing Radiation, 1990 and 2005, respectively [6,7]).

This is because we rely on essentially only one dataset (the A-bomb survivor population) to inform our understanding of the long term effects of ionizing radiation on human health. Within that dataset, so few people were exposed to doses relevant to the return-home scenarios addressed by the SOARCA study, that no effect of these radiation doses can be detected with statistical significance, even given the decades-long, high-quality analyses performed on this dataset. Unlike the development of reactor models and accident tracking, which have benefited considerably by orders-of-magnitude improvement in computational power over the past few decades, improved understanding of the consequences of elevated radiation levels on human health has come about only on the time scale of human lifetimes, that is, as more of the A-bomb survivors die and their causes of death are incorporated into our understanding of radiation risk. [See Part B.]

Our limited understanding of the potential consequences of low dose, low dose-rate radiation affects both routine radiation protection scenarios and the accident situation that has led to elevated radionuclides in the environment. In each scenario, however, the implications of our lack of knowledge and the optimal strategies for dealing with it differ considerably.

A.5 Strategies for routine radiation protection are *not appropriate* for use in accident scenarios.

The state of Pennsylvania sets the RHDL at the same dose-rate used to limit dose to the general public from anthropogenic radiation sources in routine radiation protection, 5 mSv (500 mrem) per year. [Information on the setting of dose limits is provided in Part B.] Virginia, which follows EPA guidelines, sets its RHDL a factor of 4 higher for the first year but thereafter matches the 5 mSv/year dose-rate limit used in radiation protection.

When it comes to protecting the public, however, situations involving the unplanned release of radionuclides are *fundamentally different* from those involving routine radiation protection from man-made sources [12,13]. Each situation involves very different trade-offs and these differences should lead to different dose limits. The two situations differ in the level of control over the source of radiation, in the costs associated with keeping doses to the public low, and in who pays these costs.

In the context of routine radiation protection, the source is very tightly controlled [12]. Exposure of the public is allowed to occur but only if the potential risks are smaller than the positive net benefit (e.g. the availability to society of electricity from nuclear power), and even then the risk is kept so low as to be considered trivial (i.e. allowed doses are within the natural fluctuations of background radiation doses [12,13]). Efforts to restrict doses to the public and the financial cost of doing so rest with the owner and producer of the anthropogenic radiation. Any dose-reduction strategies set in place by the owner to protect the public (eg. scrubbers in the stacks), protects all members of the public simultaneously. The owner is actually legally obliged to undertake any 'reasonably achievable' effort to further minimize dose to the public in keeping with the ALARA principle (as low as reasonably achievable). The fact that we do not know how necessary it is, from a health perspective, to keep doses ALARA in the low dose range has become a minor issue, primarily because we are able to keep the doses very low.

This situation is very different from an accident scenario in which radionuclides have been dispersed in the environment. In this case the source of the radiation is no longer controlled. Dose can be avoided, or at least minimized, but only by taking significant and often costly steps. While principles of ALARA can still be applied, the costs (both financial and effort) of applying these principles to avoid or minimize dose have shifted from the source owner to *individual* members of the public as well as to society at large. For instance, while financial reimbursement for some expenses may be available, it is individual members of the public who undergo the upheaval of evacuation, who may need to leave their homes to live in another area (sometimes for long periods of time, perhaps permanently), who face lost opportunity costs, who will be involved in decontamination procedures, who will face prohibitions against consuming local food and water, who may need to abandon farmland or livestock, and who may be urged to spend less time out of doors (since their home will provide some protection against external gamma rays) [1]. Local communities will need to determine what to do with radioactive waste products such as the water from decontamination procedures and surfaces deemed too contaminated to clean, and to make decisions regarding access to such things as community buildings and transportation routes.

With the public now engaging in the efforts for dose avoidance, it is very important that these efforts be clearly justified in terms of the real benefits to their health resulting from undertaking these efforts. At the present time we cannot say that there is a significant impact on health that will be avoided, for instance, by staying away from home, possibly for years [1], until the state-imposed return home dose-rate has been reached. However, we also cannot say that there is *no* impact on health by returning too early. We simply have too little information to address this question.

A.6 The return-home dose-limits in the context of our other radiation doses.

Although we cannot say with certainty what impact the return-home doses will have on health, we can examine these doses in the context of other radiation doses we experience. Figure 1 shows a logarithmic scale of radiation dose on which the average natural background dose to members of the public in the US is indicated (3.1 mSv/year) [14]. This dose comes primarily from isotopes belonging to the ^{238}U and ^{232}Th primordial radionuclide series. Around the world, however, the levels of uranium and thorium vary considerably (by factors of 200 – 400) leading to a large range of natural background radiation doses [15].

Also indicated on Figure 1 are the doses received from a single chest x-ray exam (radiograph) and from a single x-ray Computed Tomography (CT) scan of the abdomen [16]. The use of radiation-based diagnostic medicine has skyrocketed in the last 30 years. In the US we have seen the per capita rate of radiological exams increase by a factor of 10 since the 1980's and nuclear medicine procedures have increased by a factor of 2.5 [17]. Our average per capita dose from diagnostic medicine has increased by about 600% over this time [17].

There were 67 million CT exams performed in the US in 2006 alone; this represents an average of 1 CT exam for every 4 or 5 people in 2006. Some people however, undergo more diagnostic exams than others. Sodickson et al investigated the radiology history of all patients (>31,000) who had undergone diagnostic CT exams at any time during the year 2007 in a tertiary care academic medical center [18]. They found that 33% of all patients who had undergone any CT exam in 2007 had already undergone 5 or more CT exams during their lifetime. Five percent had between 22 and 132 exams and fifteen percent of the 31,000 patients had cumulative radiation doses exceeding 100 mSv. The mean number of exams was 6.1 leading to mean cumulative doses of 54 mSv [18]. While these data reflect the experience in only one hospital, they provide an indication of the doses received by a significant fraction of the population.

For the evacuated public returning home following a severe reactor accident, the doses received during their first year home are also indicated on Figure 1. [The dose to trigger relocation following an accident at the Surry plant used in the SOARCA study (10 mSv) is also shown.] The bases on which the RHDLs are set are not entirely clear. The FDA has suggested use of 2 standard deviations in natural radiation dose as an acceptable radiation risk [19]. In examining "acceptable" risk the EPA compares risks associated with actions already undertaken and accepted by society [1]. However if the acceptability of risk criterion is to be used we must keep in mind that even the least conservative RHDL (20 mSv in the first year) is lower than the natural background doses in many areas in the world. The RHDL for Pennsylvania (5 mSv) is less than a factor of 2 higher than the average background in the US. The dose accumulated from living the first year under RHDL conditions is less than the dose measured from a *single CT exam of the abdomen* (8 mSv) [16].

One rationale the EPA gives for setting the RHDL at 20 mSv is that limiting dose to this level is *reasonably achievable* [1]. It is clear that undertaking the dose avoidance strategies described above will be effective in minimizing dose to the public and thus meeting the dose limit of 20 mSv is achievable. Whether or not it is *reasonable* for the public to undertake these dose avoidance strategies depends on whether they are avoiding a real and significant hazard in doing so. Since the data we use to predict the impact of radiation were all generated at doses and dose-rates much larger than those represented by the RHDL (see Part B), we are ill-equipped to address this question at the present time. Determining the answer to this question should be a high priority; suggestions for proceeding are given in Part C.

Logarithmic Scale of Dose




Figure 1. A logarithmic scale of dose showing a range of activities exposing people to ionizing radiation. Shown are annual background dose to residents of the US [14] and to those living in high background regions of the world [15]. Also shown are doses from airline travel and those from radiographic (e.g. chest exam) and CT procedures. [Note that all radiological doses are determined assuming the patient is Reference Man, a thin 70 kg man, 170 cm tall [20]. Since 60% of the population is overweight [21] and since the automatic shut off of the x-ray beam during radiological procedures occurs only when a sufficient number of x-rays has exited the patient, thicker patients require longer irradiation times. For those with only a few cm of extra fat the dose increase is only a factor of 2-5, however since x-ray attenuation increases exponentially with thickness, the dose increase reaches factors of 10 or even more for the very overweight [22]. The average lifetime dose to patients from multiple CT exams [18], shown in orange, is thus an *underestimate*, by an amount that depends on the body fat characteristics (i.e. thickness) of the patients studied.] Vertical lines represent doses used to trigger relocation following an accident at the Surry plant (solid) and those used as return-home criteria (dotted lines).